

**BEFORE THE ENERGY FACILITY SITING COUNCIL
OF THE
STATE OF OREGON**

**IN THE MATTER OF THE APPLICATION)
FOR A SITE CERTIFICATE FOR THE)
PORT WESTWARD GENERATING PROJECT)**

FINAL ORDER

ISSUED BY

**OREGON ENERGY FACILITY SITING COUNCIL
625 MARION STREET NE
SALEM, OREGON 97301-3742**

503.378.4040 voice
503.373.7806 fax
www.energy.state.or.us

NOVEMBER 8, 2002

BLANK

TABLE OF CONTENTS

A.	INTRODUCTION	1
B.	PROCEDURAL HISTORY	2
B.1	COMMENTS ON APPLICATION	4
B.2	PUBLIC HEARING ON DRAFT PROPOSED ORDER	14
B.2.a	Comments	14
B.2.b	Response To Comments On the Draft Proposed Order	20
B.3	COUNCIL REVIEW OF THE DRAFT PROPOSED ORDER	30
B.4	CONTESTED CASE PROCEEDING.....	30
B.5	COUNCIL ACTION ON ASC.....	34
C.	GENERAL FINDINGS	34
C.1.	DESCRIPTION OF THE FACILITY	34
C.1.a.	The Energy Facility.....	34
C.1.b.	Related or Supporting Facilities.....	36
C.2.	LOCATION OF THE FACILITY	38
C.2.a.	The Energy Facility Site	38
C.2.b.	Related or Supporting Facility Sites	38
D.	COUNCIL FACILITY SITING STANDARDS	40
D.1.	INTRODUCTION: GENERAL STANDARD OF REVIEW, OAR 345-022-0000.....	40
D.2.	ORGANIZATIONAL EXPERTISE, OAR 345-022-0010	41
D.2.a.	Applicant Qualification and Capability, OAR 345-022-0010(1)	41
D.2.b.	Applicant Qualification and Capability: ISO Programs, OAR 345-022-0010(2).....	44
D.2.c.	Third-Party Services and Permits: Contracts, OAR 345-022-0010(3)	44
D.2.d.	Third-Party Services and Permits: Conditions, OAR 345-022-0010(4).....	44
D.3.	RETIREMENT AND FINANCIAL ASSURANCE, OAR 345-022-0050	46
D.4.	LAND USE, OAR 345-022-0030.....	53
D.5.	STRUCTURAL STANDARD, OAR 345-022-0020.....	56
D.6.	SOIL PROTECTION, OAR 345-022-0022	64
D.7.	PROTECTED AREAS, OAR 345-022-0040.....	70
D.8.	FISH AND WILDLIFE HABITAT, OAR 345-022-0060.....	74
D.9.	THREATENED AND ENDANGERED SPECIES, OAR 345-022-0070	84
D.10.	SCENIC AND AESTHETIC VALUES, OAR 345-022-0080	92
D.11.	HISTORIC, CULTURAL AND ARCHAEOLOGICAL RESOURCES, OAR 345-022-0090.....	96
D.12.	RECREATION, OAR 345-022-0100.....	100
D.13.	PUBLIC SERVICES, OAR 345-022-0110	103
D.14.	WASTE MINIMIZATION, OAR 345-022-0120	114
D.15.	CARBON DIOXIDE STANDARD FOR BASE LOAD GAS PLANTS, OAR 345-024-0550	117
E.	OTHER APPLICABLE REGULATORY REQUIREMENTS:	133
E.1.	REQUIREMENTS UNDER COUNCIL JURISDICTION.....	133
E.1.a.	Noise	133
E.1.b.	Wetlands and Removal/Fill Permit.....	141
E.1.c.	Public Health and Safety.....	150
E.1.d.	Water Pollution Control Facilities Permit.....	158

E.2. REQUIREMENTS THAT ARE NOT UNDER COUNCIL JURISDICTION	160
E.2.a. Federally-Delegated Programs.....	160
E.2.b. Requirements That Do Not Relate to Siting	160
F. CONDITIONS REQUIRED OR RECOMMENDED BY COUNCIL RULES	161
F.1. MANDATORY CONDITIONS IN SITE CERTIFICATES	162
F.2 OTHER CONDITIONS BY RULE.....	164
G. GENERAL CONDITIONS	167
H. GENERAL CONCLUSION	168
I. ORDER	168

ATTACHMENT A

MEMORANDUM OF UNDERSTANDING: MONETARY PATH PAYMENT REQUIREMENT

ATTACHMENT B

WATER POLLUTION CONTROL FACILITIES PERMIT (B.1) AND ANALYSIS (B.2)

ATTACHMENT C

REMOVAL/FILL PERMIT

ATTACHMENT D

LAND USE STANDARD ANALYSIS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44

FINAL ORDER
PORT WESTWARD GENERATING PROJECT

A. INTRODUCTION

The Oregon Energy Facility Siting Council (the "Council") issues this Final Order ("Order") pursuant to Oregon Revised Statutes ("ORS") 469.370. This Order addresses the Application for a Site Certificate ("ASC" or "application") for the construction and operation of a proposed natural gas-fired combustion turbine/combined-cycle energy facility. The net electric power output of the energy facility would be about 560 megawatts ("MW"). It would use power augmentation, i.e., duct burning, that would allow it to achieve a net electric power output of about 650 MW for a limited number of hours annually. The facility is located in Columbia County about seven miles by road northeast of the City of Clatskanie, Oregon. The proposed facility is known as the Port Westward Generating Project ("PWGP" or "Project").

Portland General Electric Company ("PGE") submitted the application. PGE, an Oregon corporation, is a wholly-owned subsidiary of Enron Corp.

The Council based this Order on its review of the ASC and the comments and recommendations on the ASC by state agencies, local governments, Indian tribes, and the public.

With certain exceptions, no fossil-fueled energy facility with an electric generation capacity of 25 megawatts ("MW") or more may be constructed or operated in Oregon without first obtaining a site certificate from the Council. ORS 469.300(9)(a) and 469.320.

It is the public policy of the State of Oregon that "the siting, construction and operation of energy facilities shall be accomplished in a manner consistent with protection of the public health and safety and in compliance with the energy policy and air, water, solid waste, land use and other environmental protection policies of this state." ORS 469.310.

The Council must ensure that the site certificate contains "conditions for the protection of the public health and safety, for the time for completion of construction, and to ensure compliance with the standards, statutes and rules described in ORS 469.501 and ORS 469.503." ORS 469.401(2).

A site certificate issued by the Council binds the state and all counties and cities and political subdivisions of Oregon. Once the Council issues the site certificate, the responsible state agency or local government must issue any necessary permits that are addressed in the site certificate without further proceedings upon payment of appropriate fees by the certificate holder. ORS 469.401(3).

The Council reviewed the application and the comments of reviewing agencies and affected local governments and tribes identified in accordance with Oregon Administrative Rules ("OAR") 345-021-0050. It also reviewed public comments.

1 The definitions in ORS 469.300, OAR 345-001-0010, and the First Amended Project Order
2 apply to terms used in this order. The following terms, paraphrased from the rule, are used
3 frequently throughout this Order:
4

- 5 · “Energy facility” means the proposed electric power generating plant. The term “energy
6 facility” does not include any related or supporting facility. If a reference is intended to
7 apply to both the energy facility and its related or supporting facilities, the term “facility” is
8 used.
9
- 10 · “Energy facility site” means all land upon which an energy facility is located or proposed to
11 be located.
12
- 13 · “Facility” means an energy facility, together with any related or supporting facilities.
14
- 15 · “Related or supporting facilities” means any structure proposed to be built in connection with
16 the energy facility, including but not limited to pipeline valves, regulators, compressors,
17 vaults, enclosures, switching stations, substations, associated equipment, associated
18 transmission lines, reservoirs, intake structures, road and rail access, pipelines, barge basins,
19 office or public buildings, construction laydown, staging and parking areas, and commercial
20 and industrial structures or other structures proposed by the applicant to be constructed or
21 substantially modified in connection with the construction or operation of the energy facility.
22 “Related or supporting facilities” does not include any structure existing prior to construction
23 of the energy facility, unless such structure must be significantly modified solely to serve the
24 energy facility.
25
- 26 · “Related or supporting facilities site” means all land upon which related or supporting
27 facilities for an energy facility are located or proposed to be located, including any linear
28 rights-of-way.
29
- 30 · “Site” means all land upon which a facility is located or proposed to be located.
31

32 **B. PROCEDURAL HISTORY**

33 **2001**

- 34 · February 28, the Office Of Energy (“Office”) received a Notice of Intent (“NOI”) from
35 PGE
- 36 · March 16, the Office mailed notice to public of the NOI
- 37 · April 2, the Office held an information meeting on the NOI in Clatskanie, Oregon
- 38 · April 30, close of comment on the NOI
- 39 · June 28, the Office issued a Project Order
- 40 · August 2, the Council appointed Columbia County to a Special Advisory Group (“SAG”)
- 41 · August 16, the Office received an ASC
- 42 · August 29-31, PGE distributed the ASC, with cover letter from the Office
- 43 · September 14, the Council appointed the City of Rainier to the SAG
- 44 · September 24, close of public and agency comment on completeness

- 1 · October 5, the Office notified PGE that the ASC was not complete
2 · November 5, the Office issued the First Amended Project Order
3 **2002**
4 · March 26, PGE submitted a revised ASC in response to information requests from the
5 Office, followed by additional materials
6 · April 11, the Office filed the complete ASC
7 · April 12, PGE distributed the filed ASC to agencies, with a cover letter from the Office,
8 which stated that close of comment would be May 24
9 · April 12, the Office mailed public notice of the filed ASC and its request for comments
10 by May 24
11 · April 12, the Office mailed the filed ASC to the Council
12 · April 15, the Office mailed notice of the filed ASC to an updated list of property owners
13 · April 15, PGE distributed the filed ASC to Columbia County, City of Rainier, and local
14 libraries
15 · April 15, the Office distributed the filed ASC to the Council
16 · April 15, the Office published notice of the filed ASC in “The [Longview] Daily News”
17 · April 17, the Office published notice of the filed ASC in the “St. Helens Chronicle”
18 · April 18, the Office published notice of the filed ASC in the “Clatskanie Chief”
19 · April 25, PGE provided Appendix J-5, the wetland delineation for the "southern option"
20 for the BPA Allston Substation to the Trojan Nuclear Plant (“Trojan”) corridor
21 · May 8, PGE updated the list of names of property owners for Exhibit F
22 · May 8, the Office mailed notice of the filed ASC to additional property owners with an
23 extended close of comment date of June 3
24 · May 29, the Office sent Appendix J-5 to the Council
25 · June 6, the Office received a Revised Appendix J-3
26 · June 6, the Office sent revisions of Appendix J-3 to the Council
27 · June 12, the Office sent revisions of Appendix J-3 and PGE’s responses to information
28 request no. 7 to the public libraries for inclusion with the ASC available to the public
29 · June 26, the Office published the Draft Proposed Order
30 · June 28, the Office submitted notice of the Draft Proposed Order and public hearing to
31 the “The Daily News,” the “St. Helens Chronicle,” and the “Clatskanie Chief”
32 · July 1, the Office posted the Draft Proposed Order and notice of the public hearing on its
33 web site
34 · July 1 and 2, the Office mailed notice of the public hearing on the Draft Proposed Order
35 to the appropriate mailing lists
36 · July 8, “The Daily News” published notice of the Draft Proposed Order and public
37 hearing
38 · July 10, the “St. Helens Chronicle” published notice of the Draft Proposed Order and
39 public hearing
40 · July 11, “The Clatskanie Chief” published notice of the Draft Proposed Order and public
41 hearing.
42 · July 12, the Council appointed Jeffrey Chicoine as hearing officer
43 · August 1, the hearing officer held a public hearing on Draft Proposed Order in Clatskanie
44 · August 16, the Council reviewed the Draft Proposed Order at its meeting in Portland

- 1 · August 23, the Office published the Proposed Order
- 2 · August 26, the Office sent the Proposed Order and notice of the contested case to all
- 3 persons who appeared in person or in writing at the public hearing
- 4 · September 8 and 9, three individuals submitted petitions for party status
- 5 · September 17, the hearing officer held a pre-hearing conference for the contested case
- 6 proceeding
- 7 · September 18, the hearing officer issued a pre-hearing order for the contested case
- 8 proceeding
- 9 · October 14, the hearing officer held a contested case hearing
- 10 · October 18, the hearing officer issued his Proposed Order and transferred his original
- 11 record of the contested case proceeding to the Executive Secretary of the Council
- 12 · October 23, Mr. Otto Moosburner mailed exceptions to the Hearing Officer’s Proposed
- 13 Order
- 14 · October 24, the hearing officer issued a Corrected Hearing Officer’s Proposed Order to
- 15 correct an editing error
- 16 · October 29, the hearing officer issued a notice of argument
- 17 · November 1, PGE responded to Mr. Moosburner’s exceptions and the Office joined in
- 18 PGE’s response
- 19 · November 5, the hearing officer issued the Hearing Officer's Comments on Exceptions
- 20 · November 8, the Council heard oral argument and adopted the Corrected Hearing
- 21 Officer’s Proposed Order and Comments on Exceptions and approved the ASC
- 22

23 **B.1 COMMENTS ON APPLICATION**

24 The following discussion groups comments by those submitted by the general public and those
25 submitted by state or local government agencies.

26
27 **Public Comments**

28 **Mr. Donald Edmondson.** In a letter dated May 21, 2002, Mr. Edmondson identified himself as
29 a landowner along one of the proposed rights-of-way from the BPA Allston Substation to Trojan.
30 He commented on several issues, particularly as they related to the corridor identified as
31 Alternate 4 (also “Alignment 4”) between the BPA Allston Substation and its intersection with
32 the Alignment 1 corridor to Trojan. He opposed construction of the transmission line on his
33 property and recommended other routes as having less environmental impact. He stated that one
34 alternative corridor would cross the South Fork of Beaver Creek on his property. He was
35 concerned about damage to wetlands and wildlife habitat and about the removal of trees. He
36 mentioned the possibility of damage to endangered species in the area, but did not identify the
37 species or where they were located relate to the proposed line.

38
39 He asked that the Council consider routes other than Alternate 4. However, the Council must
40 determine whether proposed alternatives meet its standards. For those alternatives that meet its
41 standards, it does not choose among them. The certificate holder chooses the final corridor from
42 among those authorized.

43
44 The Order addresses wetland, fish and wildlife habitat, and threatened and endangered species
45 for all proposed corridors. The Council finds that PGE would meet the Council’s standards on

1 all issues that Mr. Edmondson raised. PGE has considered and proposed other alternate routes,
2 as Mr. Edmondson requested. As indicated in a letter dated June 7, 2002, from PGE's attorney,
3 Mr. Richard Allan, PGE proposed Alternate 4 after discussion with the Bonneville Power
4 Administration ("BPA") about interconnection of the Summit/Westward Project (the "Summit
5 Project") with the BPA Allston Substation and the continuation of PWGP's line from the BPA
6 Allston Substation to Trojan.

7
8 Mr. Edmondson mentioned practices of other companies in maintaining rights-of-way. PGE is
9 the sole applicant. The Council does not consider practices of other companies in maintaining
10 similar properties. Furthermore, the Council imposes conditions on the construction and
11 operation of the transmission line. The Council finds that Alternate 4 (Alignment 4) is an
12 appropriate corridor, as discussed elsewhere in this Order in relation to specific standards.

13
14 **Twenty-five Washington Petitioners from Washington ("Washington Petitioners").** In a
15 letter dated May 17, 2002, the Washington Petitioners stated that they live on the Washington
16 side of the Columbia River within 1.75 miles of the proposed facility and that most are within
17 sight of the proposed facility. They are concerned about noise. They noted that in addition to
18 the proposed PWGP, there are already two other generating plants nearby and another energy
19 facility proposed; and, they were concerned about the cumulative effects of noise from the four
20 facilities.

21
22 Washington Petitioners noted that PGE owns two of the facilities and is proposing to construct
23 and operate PWGP. They ask the Council to regulate all three PGE facilities for noise and to
24 impose a year of continuous noise monitoring. They also stated that the PWGP analysis only
25 addresses PWGP without consideration of the other two PGE facilities.

26
27 Washington Petitioners raise two issues: (1) the scope of Council regulation of other facilities
28 and (2) PWGP's compliance with noise regulations. The Council does not have authority to
29 regulate either the Beaver Generating Plant ("Beaver") or the 24.9 MW generating plant
30 ("Beaver 8") adjacent to it. ORS 469.320(2)(a) exempts Beaver from Council jurisdiction unless
31 it increases its fuel use. Likewise, Beaver 8 is smaller than the threshold for Council jurisdiction.
32 Therefore, the Council cannot impose conditions on the operation of those facilities in this Order.

33
34 In the case of Beaver, that plant was in operation on its site prior to January 1, 1975, so the noise
35 radiating from the plant is regulated by the Department of Environmental Quality ("DEQ") noise
36 control regulation for an existing noise source ("the maximum allowable noise rule"). In the
37 case of Beaver 8, PGE constructed that plant on the same site occupied by Beaver, so Beaver 8,
38 under the DEQ noise control regulation, would be considered a new noise source located on a
39 "previously used" industrial site. It also would be regulated by the "maximum allowable noise
40 rule."

41
42 Under OAR 340-035-0035(1)(B), a new noise source is not allowed to generate noise levels that
43 increase the ambient noise levels more than 10 dBA nor to exceed the maximum allowable noise
44 levels. In effect, the more restrictive limit of the two is the limit that controls the noise source.
45 OAR 340-035-0035(1)(B) is often referred to as the "ambient noise degradation rule."

1
2 In the case of PWGP, the energy facility will be located on a site that has not been used by an
3 industrial or commercial noise source within the last 20 years. It will be regulated by the
4 “ambient noise degradation rule” or the “maximum allowable noise rule,” whichever is more
5 restrictive.
6

7 The noise study PGE conducted for PWGP included an ambient noise degradation study. The
8 ambient noise levels measured during the ambient noise degradation study included noise from
9 Beaver and, in effect, noise from Beaver 8, because the noise study showed that the noise from
10 Beaver 8 is too low to influence the ambient noise levels at receivers in Washington. The noise
11 study showed that summation of the noise from Beaver, Beaver 8, and PWGP would result in, at
12 most, a 2 dBA change in the noise levels found at residences in Oregon and on the Washington
13 side of the Columbia River.
14

15 At the request of the Office, PGE included in the noise study report a discussion of the issue of
16 the cumulative effect of the noise from the proposed Summit Project, PWGP, Beaver, and
17 Beaver 8. The results in the noise study report showed that, if the noise from the Summit Project
18 were held to the same criteria as found for PWGP, the net effect would be that the noise levels at
19 residences in Washington would be at most about 3 dBA higher than they would be without the
20 Summit Project. Thus, with all four power plants considered, the resulting noise levels at
21 residences in Washington could be 0 dBA to 3 dBA louder than that currently found, but they
22 would typically be no more than 2 dBA higher. A 1 dBA to 3 dBA change in noise levels would
23 be undetectable by most people, and if it were detectable by anyone, it would be perceived as
24 only a very slight change in noise level.
25

26 PGE’s noise study report indicated that during the ambient noise measurements only part of the
27 generators were operating at Beaver. Because of this fact, the ambient noise levels used to apply
28 the DEQ criteria to PWGP were most likely a little lower than they could have been if all the
29 generators had been operating. Thus, the DEQ criteria resulting from those levels are a little
30 more protective than could have been required under the DEQ rule because there was lower
31 ambient noise during the test than there might have been.
32

33 In all scenarios, the anticipated noise from PWGP meets both the Oregon and Washington noise
34 standards. As a result, the Council finds, based on the results presented in PGE’s noise study
35 report and further discussion in Section 1.E.a of this Order, residents in Washington will be
36 sufficiently protected from excessive noise levels from the operation of PWGP.
37

38 The Washington Petitioners proposed a condition to require “one year continuous compliance”
39 with Oregon’s noise standard for all three PGE facilities. As explained above, the Council does
40 not have jurisdiction over the other two PGE facilities. It appears that the Washington
41 Petitioners were proposing continuous monitoring of noise levels for a one-year period. If that is
42 the case, that degree of monitoring is neither practical nor necessary.
43

44 First, the facility will have to remain in compliance with Oregon noise standards throughout its
45 operational life, not just for the first year. Second, when continuous noise measurements are

1 made over a long period, such as that proposed by the Washington Petitioners, the measurements
2 are usually made without the presence of an observer. Noise data without the corroboration of
3 the source of the sound are insufficient to determine if a source in question is in or out of
4 compliance with a criterion.

5
6 In Section E.1.a of this Order, the Council adopts conditions to limit noise during construction
7 and to test the noise level of the facility within the first six months of its operation. The
8 certificate holder will conduct that test when environmental conditions are expected to result in
9 maximum sound propagation between the source and the receivers and when the power plant is
10 operating in a mode that produces maximum noise levels. In addition, the measurements will be
11 conducted with observers present who can determine the source of the noise being measured and
12 can report the contribution of the source in question to the measured levels. These tests would be
13 made at two sites in Washington as well as sites in Oregon. The conditions in the site certificate
14 will be practical and provide for an accurate evaluation of the noise generated by PWGP.

15
16 **Mr. Otto Moosburner.** In a letter dated May 20, 2002, Mr. Moosburner also stated his concern
17 about noise. His home is in Washington, about 5,700 feet from the proposed energy facility site.
18 He requested that noise data be collected under various conditions to establish a better base case.
19 He was concerned that the ASC did not discuss specific design, orientation and operational
20 measures PGE would take to minimize noise. He also stated that the ASC did not discuss
21 mitigation measures if the operating facility failed to meet the projected noise levels. He
22 requested that Office encourage PGE to build the facility with a “noise-friendly design” and that
23 there be a “realistic monitoring plan.”

24
25 According to the ASC, the specific design measure that will attenuate noise is the enclosure of
26 the gas turbine. The immediately preceding discussion addresses monitoring protocols. Section
27 E.1.a discusses the findings of compliance with DEQ noise standards and adopts conditions to
28 limit and monitor noise. The Council finds that the discussion and conditions in Section E.1.a of
29 this Order sufficiently address the issues raised by Mr. Moosburner.

30
31 **W. G. Dragich.** W. G. Dragich and the Office corresponded via e-mail between April 17, and
32 April 24, 2002, about the proposed changes to the Kelso-Beaver Pipeline compressor station in
33 Washington to supply natural gas to PWGP and about pipeline safety. The Office explained that
34 interstate gas pipelines are not within the Council’s jurisdiction and provided information about
35 how to contact the regional Federal Energy Regulatory Commission office, which has
36 jurisdiction over the Kelso-Beaver Pipeline.

37
38 **Mr. Rick Nelson.** In a letter dated May 4, 2002, Mr. Nelson commented on three issues:
39 (1) electromagnetic fields, (2) the need for the facility and transmission line, and (3) the effect of
40 the transmission line on property values.

41
42 Electromagnetic Fields. Regarding the health effects of electromagnetic fields, Mr. Nelson
43 discussed reports that magnetic fields may cause diseases in humans. The literature on the health
44 effects of magnetic fields often refers to electric and magnetic fields (“EMF”), even though it is
45 primarily, or only, magnetic fields that are of concern. Electric fields can induce a voltage in

1 objects that, when touched, may cause an injurious or annoying electric shock. The Council has
 2 a standard relating to electrical fields, OAR 345-024-0090. In contrast, some reviewers suspect
 3 human exposure to magnetic fields may cause various forms of cancer and other diseases.

4
 5 Background on Magnetic Fields. There is a more detailed discussion of the health impacts of
 6 EMF from the proposed Project in Section E.1.c. of this Order, but some background discussion
 7 is necessary at this point to frame the issues Mr. Nelson raised. EMF emitted by power lines is
 8 classified as extremely low-frequency (“ELF”) fields. ELF refers to frequencies below
 9 3,000 cycles per second (Hertz) and includes the predominantly 60-Hz fields caused by
 10 transmission of alternating current electricity. In contrast, the earth’s magnetic field is a static
 11 field. The health risks of static EMF are likely to differ from those of ELF EMF. The remainder
 12 of this discussion applies only to ELF EMF.

13
 14 The unit of measurement of magnetic field strength is the Gauss. Field strengths are commonly
 15 expressed as milli-Gauss (mG, or thousandths of a Gauss). The maximum magnetic field
 16 strength at the edge of any of the proposed ROW in the ASC is less than 150 mG. By
 17 comparison, the following magnetic field strengths have been found to be typical of various
 18 transportation systems (Dietrich, F. M., and W.L. Jacobs, *Survey and Assessment of Electric and*
 19 *Magnetic Field (EMF) Public Exposure in the Transportation Environment*, prepared for DOT
 20 (U.S. Department of Transportation) - RSPA, Contract No. DTRS-57-96-C-00073, March 1999).

21		
22	Commuter Train (AC Electric)	49 mG
23	Conventional Transit Bus	17 mG
24	Jetliner	13 mG
25	Conventional Cars and Light Trucks	6 mG
26		

27 The California Public Utilities Commission (“CPUC”) Decision No 93-11-013 includes the
 28 following magnetic field strengths (in mG) for a variety of common sources.

Appliance	Distance from Source to Point of Measurement		
	1.2 inches	12 inches	39 inches
Electric Blanket	2 – 80	--	--
Clothes Washer	8 – 400	2 – 30	0.1 – 2
Television	25 – 500	0.4 – 2	0.1 – 2
Electric Range	60 – 2000	4 – 40	0.1 – 1
Microwave Oven	750 – 2000	40 – 80	3 – 8
Electric Shaver	150 – 15,000	1 – 90	0.1 – 3
Fluorescent Lamp	400 – 4,000	4 – 20	0.1 – 3
Hair Dryer	60 – 20,000	1 – 70	0.1 – 3

31
 32 National Institutes of Environmental Health Sciences (“NIEHS”) Report. In evaluating health
 33 impacts of EMF in Section E.1.c of this Order, the Council relied primarily on an assessment
 34 issued by the U.S. National Institute of Environmental Health Sciences (NIEHS) in 1998. As
 35 explained more fully in Section E.1.c, the NIEHS concluded that EMF cannot be recognized as

1 entirely safe, but that the evidence for health risks due to exposure to EMF is weak. The NIEHS
 2 concluded that a policy of “passive regulatory action” is warranted. This is consistent with the
 3 Council’s current policy of “prudent avoidance.” CPUC currently applies a policy of “no-cost
 4 and low-cost steps to reduce EMF levels.” All three terms refer to a similar set of policies in
 5 which regulatory actions limit the risk of EMF, but do not significantly interfere with, or increase
 6 the cost of providing, electric service.

7
 8 International Agency for Research on Cancer (“IARC”) Findings. The IARC is part of the
 9 World Health Organization. It has prepared a series of monographs in which numerous
 10 substances and exposure practices are evaluated and categorized. The IARC uses the following
 11 categories to characterize the cancer risk of various substances. Examples of substances and
 12 exposure practices are included for context.

Group	Definition	Common Examples
1	Carcinogenic to humans	- Alcoholic beverages - Tobacco Smoke - Chinese-style salted fish - Wood dust - Aluminum production
2A	Probably carcinogenic to humans	- Hairdresser or barber (occupational exposure) - Use of sunlamps - Diesel engine exhaust - Formaldehyde
2B	Possibly carcinogenic to humans	- Coffee (bladder cancer. Some protection against bowel cancer may be provided) - Infection with HIV - Pickled vegetables (traditional in Asia) - Gasoline engine exhaust
3	Not classifiable as to carcinogenicity in humans	- Printing inks - Tea - Various petroleum fuels - Logging and sawmill industries
4	Probably not carcinogenic to humans	

14
 15 The IARC categorizes ELF magnetic fields in Group 2B – possibly carcinogenic to humans.
 16 This evaluation was issued on March 7, 2002. Specifically, the IARC found the following.

- 17 1. There is limited evidence in humans for the carcinogenicity of ELF magnetic fields in
 18 relation to childhood leukemia.
- 19 2. There is inadequate evidence in humans for the carcinogenicity of ELF magnetic fields in
 20 relation to all other cancers.
 21
 22

3. There is inadequate evidence in humans for the carcinogenicity of static electric or magnetic fields and ELF electric fields.
4. There is inadequate evidence in experimental animals for the carcinogenicity of ELF magnetic fields.

The IARC findings of March 2002, are generally consistent with the conclusions of the NIEHS in 1998 and with the findings in Section E.1.c of this Order.

Summary of Mr. Nelson's Concerns. In his letter, Mr. Nelson's claims the following.

1. "Scientific evidence now demonstrates beyond reasonable doubt EMF adversely effects (sic) human health."
2. "In particular, there is now information that ties moderate levels of EMF to childhood leukemia, ALS, and, now, spontaneous abortions."
3. [A study by the CPUC] "showed EMF "likely caused" childhood and adult leukemia, adult brain cancer, ALS, and spontaneous abortions."
4. [The study also] "showed that EMF "possibly caused" childhood brain cancer, female and male breast cancer, Alzheimer's (sic) disease, suicide, and heart problems."
5. "The California EMF project noted that even momentary exposure to magnetic fields greater than 16 mG can lead to a 6-fold increase in the risk of spontaneous abortions."
6. [Other studies show] "there is a clear and consistent pattern of significant risks for average exposure above 4 mG."

Mr. Nelson did not identify the specific reports and studies to which he referred in his letter; but it is clear that he relied heavily upon the California Electric and Magnetic Fields Program.

The California EMF Program. The CPUC initiated the California EMF Program by CPUC Decision 93-11-013. The CPUC decision directed the California Department of Health Services (CDHS) to begin a research and education program in 1994. That program resulted in numerous studies and educational materials that are accessible on the program's web site, www.dhs.ca.gov/ps/deodc/ehib/emf/index.html.

The most thorough assessment of potential risks from magnetic fields resulting from the California EMF Program appears to be a report entitled "An Evaluation of the Possible Risks from Electric and Magnetic Fields (EMFs) from Power Lines, Internal Wiring, Electrical Occupations and Appliances"(hereinafter referred to as the "Risk Evaluation"). Draft 3 of this report was dated March, 2001. It was issued for public comment with the caveat, "DO NOT CITE OR QUOTE." The date the final report will be issued is uncertain.

1
2 Another major product of the California EMF Program is a report titled “Policy Options in the
3 Face of Possible Risk from Power Frequency Electric and Magnetic Fields (EMF)” (hereinafter
4 referred to as the “Policy Options”). This report was issued in April 2001, with the caveat, “DO
5 NOT CITE OR QUOTE.” The date the final report will be issued is uncertain.
6

7 The California EMF Program web page cites the NIEHS report, discussed above, and notes that
8 the NIEHS report is emphasized in its draft Risk Evaluation.
9

10 The California EMF Program web site contains two “fact sheets” that provide summaries of the
11 issue of health risks from magnetic fields. The summaries are generally consistent with the
12 NIEHS report described above. The more detailed fact sheet specifically notes that it is a
13 summary of the state-of-knowledge in 2000. Because Mr. Nelson has apparently relied on the
14 California EMF Program documents to support his comments, a complete response to Mr.
15 Nelson’s concerns must include consideration of those reports. However, in preparing the
16 following analysis, the Council is mindful of the California EMF Program’s admonition against
17 quoting or citing the documents.
18

19 The California EMF Program Risk Evaluation Report. The Risk Evaluation considers numerous
20 studies, some of which have conflicting or inconsistent results. The authors of the Risk
21 Evaluation were required to weigh the evidence to reach a balanced assessment. Results of a
22 single study, taken alone, may be misleading. To represent accurately the authors’ conclusions,
23 the complete “Statement for the General Public” from the Risk Evaluation (Draft 3) is copied
24 verbatim below.
25

26 “On behalf of the California Public Utilities Commission (PUC), three scientists who work
27 for the California Department of Health Services (DHS) were asked to review the studies
28 about possible health problems from electric and magnetic fields (EMFs) from power lines,
29 wiring in buildings, certain jobs, and appliances. The PUC request for review did not include
30 radio frequency EMFs from cell phones and radio towers. The three reviewers agree that
31 statistical studies in the human population suggest there might be a problem, while, for the
32 most part, studies in animals do not. While there are important differences in the numbers
33 the reviewers selected to represent their degrees of confidence that a problem might exist, the
34 following statements properly capture the range of their judgments:
35

36 “It is ‘more than 50% possible’ that EMFs at home or at work could cause a very small
37 increased lifetime risk of childhood leukemia, adult brain cancer, and amyotrophic lateral
38 sclerosis (ALS, Lou Gehrig’s Disease). As this phrase implies, there is a chance that
39 EMFs have no effect at all.
40

41 “It is ‘more than 50% possible’ that EMFs at home or at work could cause a 5-10% added
42 risk of miscarriage, and again, as this phrase implies, there is a chance that EMFs have no
43 effect at all.
44

1 “It is ‘10-50% possible’ that residential or occupational EMFs could be responsible for a
2 small increased lifetime risk of male breast cancer, childhood brain cancer, suicide,
3 Alzheimer’s disease, or sudden cardiac death. As this phrase implies, there is a chance
4 that EMFs have no effect at all.
5

6 “It is ‘very unlikely (2-10% possible) but not impossible’ that residential or occupational
7 EMFs could be responsible for even a small fraction of birth defects, low birth weight,
8 neonatal deaths, or cancer generally.
9

10 “All of the three reviewers give a degree of confidence of at least ‘10-50% possible’ that
11 residential or occupational EMFs could be responsible for a small increased lifetime risk
12 of adult leukemia or female breast cancer, and one gave a degree of confidence that was
13 higher.
14

15 “The reviewers compared the size of possible risks from EMFs to the size of possible risks
16 from chemical and physical agents now being regulated. They agreed that:
17

18 “With the exception of miscarriage, the added risk (if any) of even a highly EMF-
19 exposed individual getting any of these rare diseases would be such that the vast majority
20 of highly exposed individuals (95%-99.9%) would not get them. Calculations suggest
21 that the fraction of all cases of these conditions for which EMF might be responsible
22 would be very low. However, if EMFs really contribute to the cause of these conditions,
23 even these low individual risks and the low fractions of cases could be of concern to
24 regulators. Indeed, when deemed real, theoretical risks smaller than these have triggered
25 regulatory evaluation and sometimes, regulatory control of chemical agents. The
26 uncommon, accumulated high EMF exposures implicated by the evidence on these
27 conditions come from home wiring, nearby power lines, and electrical occupations.
28 There are ways to avoid these uncommon accumulated exposures.”
29

30 The Risk Evaluation uses a “degree of confidence” classification system. The IARC uses a
31 “quality of evidence” classification system. This difference in classification methods can lead to
32 confusion. How, for example, should one compare the draft Risk Evaluation conclusion that it is
33 “more than 50% possible” that EMF could cause childhood leukemia to the IARC conclusion
34 that EMF is a “possible” cause of childhood leukemia? To alleviate this confusion, the draft
35 Risk Evaluation applied the IARC classification guidelines and summarized the results in the
36 Scientific Abstract of Executive Summary of the Risk Evaluation, as follows.
37

38 Classification by California Reviewers Using the IARC Guidelines:
39

40 “Possible Human Carcinogen to Human Carcinogen: childhood and adult Leukemia
41

42 “Possible Cause: adult brain cancer, miscarriage, Lou Gehrig’s disease
43

1 *“Inadequate evidence: male breast cancer, female breast cancer, childhood brain cancer,*
2 *suicide, Alzheimer’s disease, acute myocardial infarction, general cancer risk, birth defects,*
3 *low birth weight or neonatal deaths, depression and electrical sensitivity.”*
4

5 The draft California Risk Evaluation and the IARC are in agreement that EMF is at least a
6 possible cause of childhood leukemia (i.e., IARC Group 2B), but the draft Risk Assessment
7 includes the possibility that the appropriate IARC ranking may be Group 2A (probably
8 carcinogenic to humans) or Group 1 (carcinogenic to humans). There were three reviewers for
9 the Risk Evaluation and their assessments differed in some respects. It is not clear whether the
10 range of classifications described here is a result of differing opinions between reviewers or a
11 result of uncertainty on the part of individual reviewers. The California Risk Evaluation does not
12 present clear and unequivocal support for Mr. Nelson’s claims regarding the dangers of EMF.
13

14 The California PUC Process. In preparing a response to Mr. Nelson’s comments, the Office
15 contacted the CPUC’s project manager for the EMF Program, Ms. Wendy Maria Phelps.
16 Ms. Phelps explained that, after the Risk Evaluation and Policy Options reports are submitted to
17 the CPUC at the end of June, 2002, the CPUC will consider how to proceed. It may or may not
18 accept the conclusions of the Risk Evaluation. It may initiate its own investigation. It may or
19 may not modify its guidelines and rules regarding the siting of transmission lines. The sense that
20 the Office received from Ms. Phelps is that the CPUC will not immediately use the conclusions
21 of the Risk Evaluation to modify significantly the standards for siting or designing transmission
22 lines.
23

24 Council’s Summary. Overall, the California EMF Program’s draft Risk Evaluation expresses a
25 greater level of concern for the possible adverse health effects of EMF than do the 1998 NEIHS
26 report and the 2002 IARC assessment. However, as of the date of publication of this Order, the
27 California EMF Program’s Risk Evaluation is not final. The Council believes it is not
28 appropriate to cite it or to use its conclusions in Section E.1.c where the Council makes findings
29 regarding EMF. Furthermore, based on Draft 3 of the Risk Evaluation, the Council finds that the
30 Risk Evaluation does not justify changes in the findings in Section E.1.c. The conclusions of
31 three reviewers who prepared the California Risk Evaluation do not present compelling evidence
32 regarding the effects of EMF and should not over-ride the conclusions of the NIEHS and the
33 IARC.
34

35 Need for the Facility. Regarding the need for the facility and the transmission line, ORS
36 469.501(1)(L) prohibits the Council from adopting a standard that requires generating facilities
37 to demonstrate need. Likewise, because the proposed transmission lines are related or
38 supporting facility to generating facilities, there is no separate need standard for them.
39 Therefore, the Council does not have authority to consider the need for the facility as Mr. Nelson
40 requested.
41

42 Property Values. Mr. Nelson also requested that the Council consider the potential impact of
43 proposed transmission line on surrounding property values. This issue is not related to a Council
44 standard or to public health and safety; therefore, the Council cannot consider it in its evaluation
45 of the ASC.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44

Agency Comments

Department of Aviation. In a letter dated April 22, 2002, the Oregon Department of Aviation noted that PGE will need to submit a Federal Aviation Administration Form 7460-1. This is a federal form that is not under the Council’s jurisdiction, so there is no action the Council needs to take.

Department of Environmental Quality. In a letter dated April 16, 2002, the Department of Environmental Quality commented on procedural matters relating to the Air Contaminant Discharge Permit (“ACDP”) to clarify the permit process described in the ASC. However, the ACDP is a federally-delegated permit that is not under the Council’s jurisdiction, so there is no action the Council needs to take.

Office of Historic Preservation. In a letter that the Office received on April 17, 2002, the Office of Historic Preservation, Oregon State Parks and Recreation Department, noted that tests had found no cultural resources on the energy facility site.

Department of Forestry. In a letter dated April 26, 2002, the Department of Forestry noted that the ASC correctly identifies the potential need for permits pursuant to the Oregon Forest Practices Act. These are operational permits, rather than siting-related permits, so there is no action the Council needs to take.

Water Resources Department. In a letter dated May 15, 2002, the Water Resources Department (“WRD”) noted that it had reviewed the Port of St. Helens’ permit for municipal water use and found that the use and amounts that PGE requested are within the limits of the permit and use categories.

Columbia County. In a letter dated May 21, 2002, the Planning Division of the Columbia County Department of Land Development Services offered comments and recommended conditions. In a letter dated June 18, 2002, Columbia County provided additional information about the implementation of its agreement with PGE concerning transportation improvements. The Order discusses these in Section D.4 (Land Use), Attachment D, and Section D.13 (Public Services), below.

B.2 PUBLIC HEARING ON DRAFT PROPOSED ORDER

B.2.a Comments

Mr. Jeffrey Chicoine, the hearing officer, held a public hearing on the Draft Proposed Order (“DPO”) in Clatskanie, Oregon, at 7:00 PM on August 1, 2002. Thirty-three people or organizations made written or oral comments at the public hearing or provided written comments to the Office before 5:00 PM on August 2. Fifty-two people signed the registry at the public hearing, and the Office estimated a greater number in attendance. This section summarizes the public comments in a bullet format in alphabetical order by last name or organization.

1 Jan Bays

- 2 · Supported the project because of economic development.
- 3 · Hoped PGE can address issues prospectively.
- 4 · Current power plants are quiet.
- 5 · Concerned about noise, endorsed earlier speakers who raised the issue.
- 6 · Recommended the Council require no increase in ambient noise; but, temporary increases
- 7 are understandable.
- 8 · Concerned about light pollution; hoped current view of stars is preserved.

9

10 Clatskanie Chamber of Commerce

- 11 · Expressed general support.
- 12 · Expressed specific support for the DPO recommendations concerning noise, traffic, and
- 13 transmission lines.

14

15 Columbia County Board of Commissioners

- 16 · Expressed general support.

17

18 George Dennis

- 19 · ASC doesn't discuss cumulative noise impacts from Beaver, Beaver 8, and Summit.
- 20 · He lives in Washington less than a mile from the site.
- 21 · Consider 70 homes that will be impacted by noise.
- 22 · Site certificate should require all three PGE plants jointly to comply with DEQ noise
- 23 standards.
- 24 · There should be testing for one year for compliance with DEQ noise standard.

25

26 Arya Behbehani-Divers, PGE

- 27 · PGE is willing to work with residents on fair market value for property within the
- 28 easements PGE will need.
- 29 · The project would help economic development in the County
- 30 · It would take \$360 million to built the project
- 31 · PGE is a financially sound operating unit.

32

33 Kirk Deal, Pacific Northwest Regional Council of Carpenters

- 34 · Spoke for pile drivers in his union.
- 35 · Supported for project because it would provide jobs. PGE hires locally, which benefits
- 36 the community.
- 37 · PGE's track record of local hires goes beyond the requirements of the Public Services
- 38 standard.

39

40 Paul Ebert

- 41 · This is a valuable opportunity for young people who want to learn the trades.

42

43 Joe Esmonde, International Brotherhood of Electrical Workers ("IBEW") Local 48

- 44 · Supported the project because it will provide local jobs; PGE provides family wage jobs.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43

- Endorsed comments by Mr. Williamson from the Port.

Willard Evenson for Evenson Timber Land Agency

- The BPA corridor from the BPA Allston Substation to Trojan is ample for another transmission line.
- Objected to taking out any additional timberlands for a right-of-way for a transmission line.
- Any additional right-of-way would take most of his tree farm and remaining Douglas fir trees.

Jean and Paul Giepel

- Questioned why PGE did not use the BPA line or right of way from Allston Substation to Trojan.
- Supported positions of Mr. Evenson and Mr. Scott.

Pat Hodges

- The project will bring benefit to local economy.
- Real noise problem is jet boats and jet skis on the river.
- He has lived near power plants built in the 1980s and they weren't a noise problem.

The Honorable Betsy Johnson, State Representative, Oregon House District 31

- Expressed general support of project and PGE.

Elmer Kallio

- Supported the project because it will provide local jobs.

Ken Kern

- Supported economic benefits from project
- As a resident who lives near the site, he is concerned about noise, road improvements, safety, rail use, and property values.
- Supported the noise concerns raised by others at the public hearing.
- The \$3+ million that the County has identified in needed repairs is not adequate.
- Concerned about the impact on adjacent property owners of widening roads.
- The DPO did not address the ability of the dike under Kallunki Road to withstand the weight of construction vehicles.
- Concerned about pedestrian safety during construction and about the speed of vehicles on Kallunki Road.
- Concerned about the noise impact of construction vehicles using the road and how that may affect property values.
- Concerned about how an increase in rail traffic will affect neighbors.
- Wondered whether the development would have a positive or negative effect on property values.

- 1 Jamie Maygra
2 · Neutral for now, but will oppose it if PGE builds it with non-union, out-of-state workers.
3
- 4 Tammy Maygra
5 · Supported hiring local union workers.
6
- 7 Rich McCauley
8 · Concerned about noise, damage to roads and other local impacts.
9 · Encouraged PGE to hire local union workers.
10
- 11 Bill Miller, IBEW Local 125
12 · Expressed general support
13
- 14 Otto Moosburner
15 · Agreed with proposed noise conditions 1, 2, 3, and 5.
16 · Noise condition 4 is inadequate because it leaves too much discretion to PGE. There is
17 no verification that plant was operating at maximum output or that testing would be done
18 under appropriate conditions.
19 · Council should require continuous monitoring at one site in Oregon and one site in
20 Washington.
21 · Council should require independent monitoring.
22 · Ambient monitoring was inadequate.
23 · PGE should notify the Office and public stakeholders of “upcoming plans.”
24 · The monitoring plan and the results of monitoring should be available to the public.
25 · Submitted his letter of May 20, 2002, which this Order addresses in Section B.1 under his
26 name.
27
- 28 Jerry Moss
29 · Represents plumbers and steam fitters
30 · PGE has a good reputation.
31 · Wanted to make sure PGE hires local workers.
32 · PGE needs to work with other developers, SWP and Cascade Grain, to ensure they hire
33 local workers so that PGE doesn’t “suffer.”
34 · Building trades would like to sit down with all three developers.
35
- 36 Greg Nordin
37 · Supported project because it will provide local jobs, a reliable energy source and a
38 benefit to the community.
39 · Noted that speakers at the hearing raised reasonable concerns.
40 · PGE would work with community.
41
- 42 Gerald Rasmussen
43 · Concerned with cumulative impact of four power plants.

- 1 · Concerned that there be an adequate monitoring program during construction and initial
- 2 · operation to ensure compliance with the DEQ noise standard.
- 3 · Submitted letter of May 17, 2002, which this Order addresses in Section B.1 in regard to
- 4 · “Washington Petitioners.”
- 5 · Ask why location has moved from previously identified location. Could PGE move back
- 6 · to earlier spots it considered?
- 7 · The noise from three power plants and peaker will be cumulative and will travel over
- 8 · water and bounce off cliffs.
- 9 · Could the Council require SWP and PWGP to operate at the same rpms to cancel out
- 10 · each other’s noise? Is that in the models?
- 11 · Can the Council assure him that noise and steam from the plants won’t overload the
- 12 · environment?
- 13 · Requested notification of modifications to the plant after it is built.
- 14 · There should be conditions relating to color and landscaping to ensure it blends into the
- 15 · environment.
- 16 · Noise standards require continuous monitoring to assure modeling was done correctly.
- 17 · Requested a copy of all noise monitoring reports.

18
19 Paul Riggs

- 20 · Supported project for local economic benefit.
- 21 · PGE has a good record of hiring locally, but ENRON does not.
- 22 · Requested that the Council require PGE hire local workers.

23
24 Douglas Ruby

- 25 · Supported project because it would provide jobs and help local economy despite short-
- 26 · term construction impacts
- 27 · Wanted to ensure that PGE would hire local workers; local workers will do higher quality
- 28 · work than out of state contractors.
- 29 · Hoped the Office and PGE can address concerns others have raised.

30
31 Edward C. Scott, in person and represented with Mary Scott in a letter by Robert VanNatta,
32 attorney

- 33 · Council lacks jurisdiction to approve the BPA Allston Substation to Trojan Transmission
- 34 · Line option because that segment is not a “related or supporting facility” because it is not
- 35 · an “associated transmission line.”
- 36 · The DPO did not properly consider the application of ORS 215.283(1)(d).
- 37 · The water quality findings in the DPO for the Rainier Watershed zone are inadequate.
- 38 · The BPA Allston Substation Transmission Line doesn’t meet the requirement for a Goal
- 39 · 4 exception.
- 40 · Agreed with the objections raised by Mr. Evenson.

41
42 Mike Seely

- 43 · DPO did not address interference with global positioning systems and communication
- 44 · equipment that he uses to farm directly under power lines.

- 1 · BPA Allston Substation to Trojan Transmission Line isn't needed; existing BPA line can
- 2 handle PWGP output. PGE is just trying to save money. It should work with BPA.
- 3 · County doesn't have the money to improve roads.
- 4 · DPO did not adequately address road impacts on Hermo Road, which he believes will be
- 5 used to serve the plant in the future.
- 6 · Agreement with County does not provide enough money for roads; one mile of Quincy
- 7 Mayger Road was rebuilt in 1986 for \$780,000.
- 8 · Hermo Road needs \$8-10 million in improvements.
- 9 · DPO did not address hydrostatic impacts of improving any roads and how it will affect
- 10 homes alongside. Improved roads will push up the soils.
- 11 · DPO did not adequately evaluate speed.
- 12 · Road improvements should include guardrails; roads need to be wider to accommodate
- 13 24- foot-wide combines. Hermo Road is only 18 feet wide.
- 14 · NPDES should require Port to maintain 68-degree water temp at discharge.
- 15 · Road analysis in DPO is not adequate to address safety issues for Kallunki and Quincy-
- 16 Mayger roads.
- 17 · DPO needs additional analysis of cathodic protection that might be needed for gas lines,
- 18 water lines, and lines from propane tanks.
- 19 · Road studies have not evaluated culverts on Hermo Road to see if they could withstand
- 20 loads caused by power plant. They are inadequately signed.

21

22 Dale Shores

- 23 · Supported the project for its employment impacts.

24

25 Ron Sisco

- 26 · PGE has a great reputation in the community.
- 27 · Proposed project is clean and environmentally sound.
- 28 · Good location.

29

30 Robert Stevens

- 31 · His residence is closer than other sites monitored in Washington.
- 32 · There should be continuous and perpetual noise monitoring.
- 33 · Proposed power plant does not leave much land for marine-related industrial use, which
- 34 may be in violation of Port's purchase agreement with from the Federal government, as
- 35 described in Peter Williamson's testimony.
- 36 · Proposed use was not consistent with his expectations when he bought his property.
- 37 · Concurred with Mr. Rasmussen and Mr. Moosburner.
- 38 · PGE should contact residents regularly about noise.
- 39 · Site certificate conditions should require that there be a noise contact person at the plant
- 40 that residents can contact for objectionable noise.
- 41 · PGE has been responsive to dealing with noise problems at Beaver.
- 42 · Offered his place as a monitoring spot.
- 43 · Objected to moving project from the first proposed site.

44

1 Doug Terrill

- 2 · Supported the project because it would bring jobs to the county.

3

4 Joshua Thomas

- 5 · Concerned about future damage to his property from operations in existing easement
6 from Port Westward to BPA Allston Substation.
- 7 · Claimed that PGE had told him there would not be another transmission line in the
8 easement.
- 9 · There has been recent damage to his property from recent work in the easement; would
10 like the property respected.

11

12 Peter Williamson, Port of St. Helens

- 13 · Supported the project.
- 14 · Provided history of the Port's control of Port Westward industrial area, a summary of its
15 agreement with PGE, and specific reasons why it believes PWGP would be appropriate
16 for the site.
- 17 · Submitted marketing agreement and consulting and leasing agent agreement for the
18 property that PGE leases from Port.

19

20 **B.2.b Response To Comments On the Draft Proposed Order**

21 A. BPA Allston to Trojan Transmission Line

22 1. *Edward Scott, represented with Mary Scott by Robert VanNatta, attorney, raised*
23 *the following concerns:*

24

25 (a) *Is the proposed segment of the transmission line from the BPA Allston Substation*
26 *to Trojan a related or supporting facility to PWGP?*

27

28 Mr. Scott argued that the proposed transmission line segment between the BPA Allston
29 Substation to Trojan is not a related or supporting facility because it is not an "associated
30 transmission line" and is therefore not within the Council's jurisdiction in this
31 proceeding. The term "associated transmission line" is defined in ORS 469.300(4) to
32 mean:

33

34 "...new transmission lines constructed to connect an energy facility to the *first*
35 *point of junction* of such transmission line or lines with either a power
36 distribution system or an interconnected primary transmission system or both
37 or to the Northwest Power Grid." [Emphasis added.]

38

39 Mr. Scott stated that "first point of junction" imposes an obligation on PGE to connect at
40 the nearest possible opportunity for a point of junction, which he argued would be the
41 BPA Allston Substation. This is a misreading of the definition of "associated
42 transmission lines" and an incomplete reading of the definition of "related or supporting
43 facilities."

44

1 There are two aspects of the definitions that shed light on the issue raised by Mr. Scott.
2 First, there is the purpose of the provision, which is to identify the terminus of the related
3 or supporting facility. It limits the Council's siting authority beyond that point. The
4 Council has jurisdiction to the point at which the transmission line actually joins or
5 connects to the distribution system or grid. It would make no sense for the Council's
6 jurisdiction to be measured to a hypothetical connection or the closest conceivable
7 connection if a connection was not actually made there. The Legislature's use of the term
8 "junction" is instructive in this regard. A "junction" refers to "the condition of being
9 joined" or "a place where two things join or meet." The first point of junction is where
10 the line first joins the system or grid. The Legislature did not constrain the Council's
11 jurisdiction to the "nearest conceivable" or "first possible" point of junction, but rather
12 the "first" point of junction. Mr. Scott's reading requires that the Council rewrite the
13 statute to add words the Legislature left out. It is inconsistent with both the text and
14 purpose of the provision.
15

16 Second, it is incumbent upon the applicant to propose where it wishes to connect. This is
17 evident from the definition of a "related or supporting facility." ORS 469.300(24). That
18 "first" does not mean "nearest" is reinforced by the fact that the statute gives the
19 applicant the discretion to propose any legitimate point of connection. After the applicant
20 has done so, the Council is then responsible for evaluating the proposed corridor(s) to
21 that point by application of the Council's standards. While application of those standards
22 may favor or dictate connection at one point or another, that constraint is not found in the
23 definitions of "related and supporting facility" or "associated transmission lines." The
24 Council does not change its findings.
25

26 Mr. Scott also asserted that if the BPA Allston Substation to Trojan transmission line is
27 not a related and supporting facility, PGE would be required to demonstrate the need for
28 it as an independent transmission line. That point is moot, given that the transmission
29 line is a related or supporting facility for a generating plant.
30

31 *(b) Has the DPO properly considered ORS 215.275 and ORS 215.283(1)(d)?*
32

33 Mr. Scott asserted that PGE has not satisfied ORS 215.275. As Mr. Scott correctly
34 asserted, "utility facilities necessary for public service" allowed under ORS 215.283(1)(d)
35 must satisfy the requirements of ORS 215.275. The requirements of ORS 215.275 are,
36 however, applicable only on EFU-zoned land.
37

38 The proposed transmission line crosses only one section of EFU-zoned land. That land is
39 zoned Primary Agriculture-38 (PA-38) and is located immediately adjacent to the RIPD
40 zone at Port Westward. The existing Beaver to BPA Allston Substation transmission line
41 corridor passes through the PA-38 zone.
42

43 The transmission line corridor options from the BPA Allston Substation to Trojan do not
44 pass through EFU-zoned land. Thus, ORS 215.283 and ORS 215.275 are inapplicable to
45 those proposed corridors. PGE has satisfied ORS 215.275.

1
2 Mr. Scott referred to a "punch list" that is found in ORS 215.275(2). That section
3 requires the applicant to demonstrate that it is necessary to locate the proposed utility
4 facility on farmland based on "one or more" factors listed in that section. PGE has
5 established that the utility facility is necessary based on the factors in both (2)(b)
6 (locational dependence) and (2)(d) (use of existing rights-of-way). The Port Westward
7 industrial area is surrounded by land zoned PA-38. To leave Port Westward, a
8 transmission line would need to cross this zone regardless of the route. The proposed
9 route takes advantage of the space within an existing transmission corridor. The Council
10 does not change its findings.

11
12 (c) *Are the water quality findings in the DPO for the Rainier Watershed zone*
13 *adequate?*

14
15 Mr. Scott noted that Appendix D, Land Use Analysis, states that placement of the
16 transmission line in the City of Rainier's Watershed zone would have "no impact on
17 water quality." He characterized the proposed corridor as leading to "deforestation of a
18 significant segment" of the watershed. He noted recent restoration efforts for Fox Creek
19 in the watershed.

20
21 Within the Watershed zone, the proposed corridor would be 125 feet wide and about
22 1.5 miles long. It would comprise about 23 acres. It would not represent a significant
23 portion of the watershed. (Figure C-2 shows about 1,000 acres of the Watershed zone;
24 and, that is not the full extent of the zone.)

25
26 There are several factors that would protect the watershed: (1) the certificate holder
27 would be required to comply with a federal NPDES 1200-C permit for construction
28 impacts regarding storm water and erosion control; (2) conditions would require the
29 certificate holder to protect the soils in the area during construction; and, (3) conditions
30 would require the certificate holder to revegetate the area. The Removal/Fill permit
31 would also protect wetlands and waterways. Furthermore, Fox Creek is located several
32 hundred feet east of the transmission line. The finding of no impact to water quality is
33 justified. The Council does not change its finding.

34
35 (d) *Does the proposed BPA Allston to Trojan transmission line corridor meet the*
36 *requirement for a Goal 4 exception in order to clear an easement 25 feet wider*
37 *than Goal 4 rules allow?*

38
39 Goal 4 relates to forest resources. Goal 4 states "Maximum utilization of utility rights of
40 way should be required before permitting new ones." For safety reasons, PGE proposed
41 to build a transmission line corridor through forest zones that is 25 feet wider than
42 allowed under Goal 4.

43
44 The key question that Mr. Scott raised is whether PGE has demonstrated that the
45 transmission line is needed or whether it could use the one of the two existing BPA

1 230 kV transmission lines that run between the BPA Allston Substation and Trojan.
2 During the public hearing, others stated that they believed that the PGE could use the
3 existing BPA corridor or the existing BPA transmission lines. Therefore, there are two
4 questions regarding maximum use of utility rights of way: (1) Is there room for another
5 transmission line in the BPA corridor, or (2) is there capacity on the BPA line for the
6 output of PWGP?
7

8 The right-of-way for the BPA transmission line between the BPA Allston Substation and
9 Trojan is 125 feet wide. The towers contain two 230 kV circuits. There is no room for
10 another transmission line in that corridor.
11

12 The question of whether a new line is needed for PWGP between the Allston Substation
13 and Trojan is more complicated. In addition to this response, this Order contains a more
14 complete description of the need for the proposed transmission line in Appendix D than
15 provided in the DPO.
16

17 BPA has not notified PGE if BPA will permit PGE to terminate its transmission line from
18 PWGP at the BPA Allston Substation. It may be many months before PGE knows
19 whether it could terminate its line at the BPA Allston Substation. However, PGE has
20 requested that the Council approve PGE's proposed alternative to build the BPA Allston
21 to Trojan segment regardless of BPA's determination of whether PGE could use the BPA
22 Allston Substation.
23

24 In support of its ASC, PGE submitted a report entitled "Programmatic System Impact
25 Study for Generators and Canadian Import in the I-5 Corridor," dated March 2002, and
26 prepared for BPA by Power World Corporation. The study analyzes the capacity of the
27 BPA transmission system to serve new load as new power plants come on line, including
28 Summit and PWGP. A fundamental focus of the study is the reliability of the system and
29 how it would respond to the failure of a major transmission line, i.e. a "contingency."
30 The study necessarily makes assumptions about the sequence of new generating plants
31 and transmission system upgrades. The Council relied on that study.
32

33 The Office had TriAxis, an independent engineering firm that specializes in transmission
34 line engineering, evaluate the BPA study. The engineering firm stated that the BPA
35 study demonstrated that a new line from the BPA Allston Substation to Trojan would be
36 needed, even without PWGP. The BPA study finds no practical alternative construction
37 or Remedial Action Scheme, e.g. taking generation off-line, to solve the grid overload
38 problems predicted by the analysis.
39

40 Even if PWGP connected to the regional transmission system at the BPA Allston
41 Substation, either BPA or PGE would need to build another transmission line between the
42 BPA Allston Substation and Trojan. So, while the Council must make a decision about
43 the transmission line from the BPA Allston Substation to Trojan without knowing if
44 PWGP could have terminated at the BPA Allston Substation, the segment from the BPA
45 Allston Substation to Trojan would likely be built in any case.

1
2 The Council must make its decision in the face of some uncertainty. Because of the
3 complexity of factors affecting the needs of the regional transmission grid, it is not
4 feasible for the Council to write a condition based on simple decision criteria that delays
5 the decision about allowing the construction of the BPA Allston Substation to Trojan
6 transmission line segment until PWGP begins construction. The Council cannot defer
7 parts of its decision for later consideration, but must make its decision based on the best
8 available information it has before it in the record. That evidence indicates that PGE will
9 probably need to build the line to connect to the energy facility to the grid. The Council
10 has a basis for finding that the line is needed and that an exception to Goal 4 is justified.

11
12 (2) *Does the Council consider the economic impact on property owners of removing*
13 *trees for the transmission corridor?*

14
15 The Council does not generally consider the economic impacts of a project. Nor does the
16 Council become involved in negotiations over compensation for an easement for a right-
17 of-way. Nor does Council action regarding a Goal 4 exception affect PGE's authority as
18 a regulated utility to condemn property.

19
20 The Council's review of the requested Goal 4 exception does, however, require a finding
21 that "the significant environmental, economic, social and energy consequences
22 anticipated as a result of the proposed facility have been identified and adverse impacts
23 will be mitigated in accordance with rules of the Council applicable to the siting of the
24 proposed facility." The DPO recognized that the primary adverse economic impact
25 would be a loss of potential timber harvest in the right-of-way allowed by the exception
26 request. It further finds that Oregon law adequately accounts for such impacts in the
27 condemnation of utility right-of-way. The Council does not change its findings.

28
29 B. Transportation Concerns

30 1. *Should PGE provide funds for improvements to Hermo Road?*

31
32 There were extensive comments about needed improvements on Hermo Road. However,
33 construction and operation of PWGP will not affect Hermo Road, which dead ends some
34 distance from the proposed energy facility site. While the County may have long-range
35 plans to improve Hermo Road, PGE does not propose to use Hermo Road in its
36 construction of the facility, nor does it rely on it for operation of the energy facility. The
37 fact that Hermo Road may later become an access route that the operating energy facility
38 might use is not critical to this proceeding.

39
40 2. *Are the proposed transportation improvements detailed in Table D.13-1 adequate*
41 *to address the highway impacts of constructing PWGP?*

42
43 Columbia County, PGE, and Summit Westward negotiated an agreement based on the
44 road improvements listed in Table D.13-1. The listed improvements were developed
45 based on transportation studies prepared for the applicant and other Port Westward

1 developers. The improvements and PGE's financial responsibilities for those
2 improvements are discussed in Section D.13 of the DPO. Proposed conditions make the
3 agreement binding on the site certificate holder for PWGP, whether it be PGE or
4 someone else. Columbia County has determined that the transportation infrastructure
5 improvements are adequate, and that determination is supported by evidence in the
6 record. The Council does not change its findings.

7
8 3. *Will widening roads affect neighboring structures and property values?*

9
10 Columbia County will be making the road improvements as part of a larger road
11 improvement scheme. The County will design those improvements. It is appropriate for
12 the County to address how those designs might affect adjoining structures. The potential
13 impact on property values from road improvements could be positive or negative, but in
14 any case it is not related to a Council standard. It is, in effect, a third-party decision. The
15 Council does not change its findings.

16
17 4. *Can the dike under Kallunki Road withstand construction traffic?*

18
19 Public Services Condition 7 requires PGE to use barges and rail to the extent practicable
20 to delivery bulk materials. Furthermore, the list of improvements includes funds to
21 improve Kallunki Road, as the County deems necessary. This Order adequately
22 addresses the concern. The Council does not change its findings.

23
24 5. *Did the DPO adequately address pedestrian safety and speed along Kallunki
25 Road during construction?*

26
27 Fish and Wildlife Habitat Condition 1(a) requires PGE to post speed signs. That will
28 protect both humans and animals. There is no evidence in the record about pedestrian use
29 of Kallunki Road. The Council does not change its findings.

30
31 6. *Did the DPO adequately address safety on Kallunki and Quincy-Mayger Roads?*

32
33 The DPO did address safety, specifically in the list of proposed improvements in Table
34 D.13-1. It is not possible to respond to a general charge that the DPO was inadequate.
35 The Council does not change its findings.

36
37 7. *Should the Council address the noise of construction vehicles and rail traffic?*

38
39 There are no standards that relate to noise from construction vehicles or rail traffic.
40 However, Public Services Condition 7 in the DPO does require the certificate holder to
41 use barge and railroad deliveries to the extent practicable to minimize the number of
42 freight truck deliveries on local roads. The Council does not change its findings.

1 C. Noise

2 1. *Did modeling consider noise of all four generating projects?*

3
4 Yes. See Section B1 of the DPO.

5
6 2. *Is it appropriate to require a multiple instances of noise monitoring, up to a year*
7 *of continuous monitoring, or perpetual monitoring?*

8
9 Section B.1 gives an explanation of why continuous or multiple monitoring is not
10 appropriate. Furthermore, there is an important distinction between (1) the Council's
11 determination that a facility can likely meet the Department of Environmental Quality's
12 ("DEQ") noise requirements and (2) DEQ's role in enforcing its rules. Those who
13 propose continuous monitoring are proposing that the Council inappropriately assume
14 DEQ's responsibilities for enforcement. The Council does not change its findings.

15
16 3. *Should the project meet a criterion of no increase in ambient noise?*

17
18 No. DEQ rules allow up to a 10 dBA increase in ambient noise for new sources.

19
20 4. *Should the site certificate require PGE to have a point of contact for noise?*

21
22 Noise Condition 3 in Section E.1.a requires the certificate holder to establish a noise
23 complaint system at the construction manager's office during construction. The DPO
24 does not recommend that there be a separate condition that requires the certificate holder
25 identify a specific contact during operation because the energy facility will have a small
26 staff. Contacting the plant manager would suffice. The Council does not change its
27 findings.

28
29 5. *Should there be noise monitoring during construction?*

30
31 There are conditions that will help minimize noise during construction, but there is no
32 DEQ standard for construction activities. With no standard, there is no basis for
33 requiring monitoring. The Council does not change its findings.

34
35 6. *Should PGE be required to notify area residents of "up-coming plans" or*
36 *modifications?*

37
38 No. The Council's site certificate amendment process and notification will suffice. The
39 Council does not change its findings.

40
41 7. *Will monitoring plan and results be available to the public?*

42
43 Yes. PGE will submit them to the Office, where they will be available on request.

44
45 8. *Should PGE be required to mail noise study results to certain parties?*

1
2 No. They will be available from the Office. The Council does not change its findings.

3
4 9. *Can the Council require PGE to move the energy facility site to an earlier*
5 *identified location farther away from houses in Washington?*

6
7 No. The Council evaluates the project as proposed by the applicant. PGE considered a
8 site to the south of Beaver, but geotechnical investigations revealed that the soils at that
9 site were unsuitable for a power plant. PGE did not propose in its ASC to use that site.

10
11 10. *Can the Council require PWGP and Summit to operate at identical revolutions*
12 *per minute to cancel noise?*

13
14 The Council requires that each project meet the DEQ noise standard. The model for
15 noise impacts for PWGP and Summit assumed the facilities would operate independently.
16 However, all generating plants connected to the grid must operate at 60 Hertz, so to that
17 degree they are synchronized. In any case, the four plants at Port Westward would
18 jointly have at most a 3 dBA increase, which is lower than the impact allowed for a single
19 facility. Also, it is not appropriate for the Council to specify detailed operational
20 parameters. Furthermore, the person stating the concern did not show how the speed of
21 generators relates to overall noise levels and that it is the determining factor. The
22 Council does not change its findings.

23
24 11. *Should Condition (4) require PGE to verify that it tested noise when the plant was*
25 *operating at maximum output and under appropriate conditions?*

26
27 The testing procedure is specified by DEQ rules. Noise Condition (4) requires that the
28 certificate holder use a qualified noise specialist. The Office will review the results to
29 ensure that the certificate holder tested the facility under the appropriate conditions. The
30 Council does not change its findings.

31
32 12. *Should site certificate for PWGP bind Beaver and Beaver 8 as well regarding*
33 *noise?*

34
35 No. The Council cannot bind facilities that are not under its jurisdiction. See Section B.1
36 of the DPO.

37
38 13. *Should PGE monitor sites in Washington other than # 5 and # 6?*

39
40 PGE chose Sites # 5 and # 6 in consultation with local citizens in Washington as
41 representative of what the impact from PWGP would be in Washington, even though it
42 only has to show compliance with the DEQ standard at the closest sensitive receptor in
43 Oregon. The modeled results show that there should be no significant increase in noise at
44 the Washington sites, even with two new facilities.

1 The Office's noise consultant re-analyzed the noise data the ASC in order to estimate the
2 ambient noise level and the likely noise impacts at the closest Washington residences
3 from PWGP alone and from PWGP and Summit together with Beaver and Beaver 8. The
4 consultant was able to use data from the sites that had been tested. While Site # 6 is not
5 the closest Washington residence to PWGP, residences that are closer are about the same
6 distance from State Route 4 ("SR 4") as Site # 6. SR 4 is a major source of ambient noise
7 for the Washington sites during the day. Therefore, noise from SR 4 at Site # 6 would be
8 about the same level as that at the nearest residences in Washington during the day. The
9 nearest residences are also about the same distance from Beaver as the Site # 6. Beaver is
10 the major source of ambient noise at night. Therefore, it is likely that the results for
11 Site # 6 are also applicable to the closer sites in Washington. The Office's noise
12 consultant estimated that the closer sites would likely see a 2 dBA increase in ambient
13 noise at night from PWGP alone and, at most, an increase of 3 dBA from the operation of
14 both PWGP and Summit simultaneously. These numbers are well within the DEQ
15 ambient noise degradation regulation parameters.

16
17 The Council's consideration of noise impacts in Washington comes from PGE's
18 voluntary response to the concerns of Washington residents. PGE has made a reasonable
19 response to those concerns as well in the conditions it recommended to the Council.
20 Also, one Washington resident at the public hearing reported that PGE had voluntarily
21 reduced noise levels at Beaver when he had a concern about 10 years ago.¹

22
23 Data suggest there should not be a problem with noise in Washington; the Council will
24 impose conditions to test noise at two Washington sites; and, PGE has a record of
25 working with local residents to address noise problems. The site certificate imposes
26 reasonable conditions to address the concerns of Washington residents about noise. The
27 Council does not change its findings.

28
29 **D. Other Concerns**

30 *1. Should there be additional analysis for cathodic protection of gas, propane and*
31 *water lines near the transmission line?*

32
33 Magnetic fields can induce current in buried pipes and other metal structures, thereby
34 promoting corrosion. Section E.1.c, Public Health and Safety, in the DPO was confused
35 in its discussion of the requirement that the certificate holder design the transmission
36 lines so that induced currents as low as reasonably achievable. The discussion has been
37 clarified in that section.

38
39 Standard utility practices include designing transmission lines to keep both induced
40 voltages and induced currents below specified levels. Furthermore, CFR 49, Part 192
41 requires that the certificate holder ensure that cathodic protection systems installed on
42 transmission lines must not interfere with other existing facilities. Public Health and

¹ The Council has imposed noise conditions based on the analysis that PGE voluntarily provided in the ASC regarding noise levels at Sites # 5 and # 6. This Order does not take a position regarding the Council's authority to impose conditions based on compliance with Oregon's noise regulations in Washington.

1 Safety Condition (9) addresses CFR 49, Part 192. Condition (8) requires coordination
2 with the Oregon Public Utility Commission, which will ensure that the certificate holder
3 will address cathodic protection.
4

5 In addition, OAR 345-024-0090(2) requires that the Council find that the applicant “can
6 design, construct and operate the proposed transmission line so that induced currents
7 form the transmission line and related or supporting facilities will be as low as reasonably
8 achievable.” However, there was no condition in the DPO that explicitly incorporated
9 that rule. Public Health and Safety Condition (3) is modified to add a reference to
10 induced currents, pursuant to the rule.
11

12 2. *Should the Council address interference from the transmission lines for global*
13 *positioning systems and communication equipment when operating equipment*
14 *directly under the lines?*
15

16 Any such interference is a matter of negotiation in the easement agreement between the
17 property owner and PGE. It does not substantially limit farming practices. The Council
18 does not change its findings.
19

20 3. *Should the Council address conditions for the NPDES permit for which the Port*
21 *of St. Helens is applying?*
22

23 That is a Federal permit not within the Council’s jurisdiction, so the comments are not
24 relevant to this proceeding.
25

26 4. *Should the Council impose conditions relating to color of the plant?*
27

28 Scenic and Aesthetic Values Condition (6) requires the certificate holder to paint the
29 plant in matte colors appropriate for the site.
30

31 5. *Should the Council impose conditions relating to landscaping?*
32

33 Land Use Condition (1) in Section D.4 requires the certificate holder to submit a
34 landscaping plan to the County for its approval.
35

36 6. *Should the Council impose conditions limiting the glare from lights?*
37

38 Land Use Conditions (3), (4), and (5) address minimizing glare during the construction
39 and operation of the facility.
40

41 7. *Should the Council address hiring practices?*
42

43 Several persons wanted the Council to ensure that PGE hires local labor. Some specified
44 that PGE should hire union labor. Neither Council standards nor other state permit
45 requirements address hiring practices.

1
2 8. *Is the use of land in the Port Westward industrial area for power production*
3 *consistent with the Port of St. Helen's purchase agreement through which it*
4 *acquired the land from the Federal government?*
5

6 In his testimony on August 1, 2002, Peter Williamson, executive director of the Port of
7 St. Helens, summarized the history of the Port Westward industrial area. He noted that
8 the purpose for which the Port bought the property was to provide "marine dependent"
9 industrial sites. The Land Use Analysis, Attachment D, demonstrates that the proposed
10 energy facility is a conditional use within the Resource Industrial Planned Development
11 zone of the property the Port purchased from the Federal government. It discusses how
12 the project would use barges for delivery of heavy equipment during construction and
13 how it would use water from the river during its operation. Given that the project is a
14 conditional use and that it will take advantage of certain marine-related aspects of the
15 site, the proposed use is consistent with the intended uses of the site. The Council does
16 not change its findings.
17

18 9. *Statements of support.*
19

20 While people raised concerns, as noted above, 20 of the 34 persons who spoke or
21 provided written comments supported the project. Those 20 persons included some who
22 also had concerns about specific elements of the project.
23

24 **B.3 COUNCIL REVIEW OF THE DRAFT PROPOSED ORDER**

25 At its August 16, 2002, meeting in Portland, the Council reviewed the DPO, pursuant to OAR
26 345-015-0230. The Council did not identify any new issues that the Proposed Order should
27 address.
28

29 **B.4 CONTESTED CASE PROCEEDING**

30 On August 26, 2002, the Office of Energy issued a Notice of Contested Case Proceeding
31 ("Notice") with a Proposed Order dated August 23, 2002. The Notice contained deadlines for
32 petitioning for party status and dates for the prehearing conference and hearing for the contested
33 proceeding.
34

35 On September 8 and 9, 2002, three individuals submitted petitions for party status: Otto
36 Moosburner, Robert Stevens, and Gerald M. Rasmussen, through his attorney Eric J. TenBrook.
37

38 On September 10, 2002, Samuel Sadler, project manager with the Office of Energy submitted an
39 Affidavit with the List of Documents Upon Which Office of Energy Relied in Drafting the
40 Proposed Order.
41

42 On September 11, 2002, the hearing officer issued a document labeled Service of Petition for
43 Party Status and Prehearing Conference Agenda. Pursuant to OAR 137-003-005(4), the hearing
44 officer served a copy of each petition for party status to the other petitioners, the applicant and
45 the Office of Energy.

1
2 The hearing officer received no objections to the request for party status from any party. The
3 hearing officer did, however, receive Portland General Electric Company's Proposed Statement
4 of Issues to be Decided at Contested Case Hearing dated September 13, 2002. In response, the
5 hearing officer also received Petitioner Gerald M Rasmussen's Proposed Statement of Issues to
6 be Decided at Contested Case Hearing, which was dated September 16, 2002, and a letter from
7 Janet Prewitt, Oregon Department of Justice, addressing the Office of Energy's Statement of
8 Issues, which was dated September 16, 2002.

9
10 On September 17, 2002, the hearing officer held a pre-hearing conference as scheduled in the
11 Notice. Attending were the applicant, the Department of Justice, the Office of Energy, Gerald
12 Rasmussen, through his attorney, and Otto Moosburner, *pro se*. Petitioner Stevens did not
13 attend. The pre-hearing conference was stenographically recorded, and a transcript was prepared
14 and made part of the record. The hearing officer prepared and issued a Pre-hearing Order on
15 September 19, 2002, reporting on all rulings made, including:

- 16
17 (1) A ruling that permitted Mr. Stevens to continue to participate despite his absence;
- 18
19 (2) Rulings that two issues raised by the petitioners related to monitoring of noise
20 from operations were preserved for hearing;
- 21
22 (3) A ruling that one proposed issue related to construction noise was reserved for
23 later decision, subject to additional briefing by the parties;
- 24
25 (4) A scheduling order for written direct testimony and setting new hearing dates for
26 live testimony;
- 27
28 (5) Directives on the order of presentation of evidence; and,
- 29
30 (6) Directives regarding service of papers.

31
32 On September 20, 2002, supplemental written briefing was received on whether noise from
33 construction was properly preserved for a hearing from the applicant, Office of Energy and
34 Gerald Rasmussen. On September 23, 2002, the hearing officer issued an Order on Issues for
35 Hearing, ruling that the issue of noise from construction was preserved for hearing. Thus, the
36 three issues preserved for a contested case proceeding were:

- 37
38 1. Whether the condition requiring one-time monitoring during the first six months
39 of operation to ensure compliance with applicable DEQ and noise operating
40 standards is adequate.
 - 41
42 2. Whether the lack of a requirement of a continuous monitoring plan by the
43 applicant, PGE is adequate.
- 44

1 3. Whether monitoring during construction is needed to demonstrate actual
2 compliance with noise regulations.
3

4 On September 27, 2002, a stipulation was submitted by the applicant, the Office of Energy and
5 Gerald Rasmussen. In the stipulation, the parties agreed to settle the issues raised by Mr.
6 Rasmussen on the following terms, by agreeing to include a condition in the site certificate in the
7 form found within this Order in condition E.1.a(4)(d) and by Mr. Rasmussen withdrawing his
8 Petition for Party Status, waiving his right to a contested case proceeding, and waiving any right
9 to appeal a Final Order that is consistent with this Stipulation.
10

11 On October 8, 2002, Robert Stevens submitted a letter notifying the hearing officer that he was
12 withdrawing from further participation in the contested case proceeding. The hearing officer
13 sent a copy of the letter to each remaining participant in the contested case proceeding.
14

15 On October 8, 2002, the applicant filed Written Direct Testimony of Albert G. Duple, P.E. and
16 the Office of Energy filed Written Direct Testimony of Kerrie G. Standlee, P.E.
17

18 On October 14, 2002, the hearing officer convened a contested case hearing. The hearing was
19 stenographically reported, and a transcript prepared and is part of the record of this case.
20 Attending were the Department of Justice, the Office of Energy, the applicant and Otto
21 Moosburner. The hearing was opened with a review of the participants' hearing rights pursuant
22 to ORS 183.413. Official notice was taken of the Application for Site Certificate, the Notice of
23 Contested Case Proceeding, and the Draft Proposed Order of the Office of Energy. Marked and
24 received into evidence as the part of the record was Mr. Duple's statement of qualifications
25 (PGE-1), a report prepared by Mr. Duple dated July 2001 (PGE-2), written direct testimony of
26 Mr. Duple (PGE-3), written direct testimony of Mr. Standlee (OOE-1), Resume of Kerrie
27 Standlee (OOE-2), and Memorandum from Kerrie Standlee to Samuel Sadler dated June 13,
28 2002 and October 8, 2002 (carrying two dates) (OOE-3).
29

30 Mr. Standlee and Mr. Duple testified live and were qualified as experts without any objection
31 from any of the parties. Each of the parties had the opportunity to undertake live cross-
32 examination or redirect examination of Mr. Standlee and Mr. Duple. Mr. Moosburner also
33 presented testimony and argument. At Moosburner's request, the hearing officer ruled that he
34 was incorporating into his testimony Mr. Moosburner's letters to the Office of Energy dated May
35 20, 2002 and July 31, 2002, and his live testimony at the public hearing in this case on August 1,
36 2002.
37

38 The hearing officer asked the parties if they had additional evidence to present or if an
39 adjournment was required to obtain additional evidence. The parties responded that they had no
40 additional evidence or a need to for an adjournment. Closing arguments were received from the
41 applicant, the Office of Energy and Mr. Moosburner.
42

43 At the hearing, the hearing officer with agreement from the parties set the following post-hearing
44 schedule:
45

- 1 · October 18, 2002, hearing officer issues Proposed Order
- 2
- 3 · October 25, 2002, exceptions due to hearing officer's Proposed Order.
- 4
- 5 · November 1, 2002, responses to exceptions due to hearing officer's Proposed Order
- 6

7 The parties were directed to serve any such documents pursuant to the service directive
8 contained in the pre-hearing order, consisting of service by e-mail no later than 5 p.m. of the due
9 date with mailing of a hard copy, original that same day.

10

11 The hearing officer then closed the evidentiary record concluded the hearing.

12

13 On October 23, 2002, Mr. Otto Moosburner mailed to the Council a statement of exceptions to
14 the hearing officer's Proposed Order. He challenged certain findings of fact and the conclusion
15 that compliance with the 10dBA limit for increase in ambient noise levels could be demonstrated
16 by a single testing event, as provided in the conditions in the Office's Proposed Order.

17

18 On October 24, 2002, the hearing officer issued a Corrected Proposed Order to correct a
19 paragraph from which text had been inadvertently deleted. The corrected version did not alter the
20 substance of the Proposed Order.

21

22 On October 29, 2002, the hearing officer issued a notice of argument for the Council's meeting
23 on November 8, 2002.

24

25 On November 1, 2002, PGE responded to the exceptions. It requested that the Council reject
26 Mr. Moosburner's exceptions based on the evidence in the record from the expert witnesses in
27 the contested case. On that date, the Office separately joined in PGE's response.

28

29 On November 5, 2002, the hearing officer issued the Hearing Officer's Comments on
30 Exceptions. The hearing officer did not recommend any substantive changes to his Corrected
31 Proposed Order or conditions for the site certificate. However, he noted that the Corrected
32 Proposed Order contained duplicate findings of fact and recommended that the duplications be
33 deleted.

34

35 On November 8, 2002, the Council considered the Hearing Officer's Corrected Proposed Order
36 and the Hearing Officer's Comments on Exceptions, the exceptions, the responses, and oral
37 arguments. The Council adopted the Hearing Officer's Corrected Proposed Order and
38 Comments on Exceptions.

39

40 Findings of facts and conclusions of law from the contested case proceeding are reported in the
41 section of this Order addressing noise standards (Section E.1.a.) because the contested case
42 proceeding was limited to issues over noise standards.

43

1 **B.5 COUNCIL ACTION ON ASC**

2 The Council approved issuing a site certificate for the Port Westward Generating Project to PGE
3 at its meeting in Tigard, Oregon, on November 8, 2002.

4
5 **C. GENERAL FINDINGS**

6
7 **C.1. DESCRIPTION OF THE FACILITY**

8
9 **C.1.a. The Energy Facility**

10 **Major Structures and Equipment.** The net electric power output of the energy facility would
11 be about 560 MW. It would use power augmentation, i.e., duct burning, that would allow it to
12 achieve a net electric power output of about 650 MW for a limited number of hours annually on
13 average.

14
15 The energy facility would consist of two essentially identical combustion turbine generators
16 (General Electric Frame 7FB's or comparable combustion turbines), two heat recovery steam
17 generators ("HRSG"), and two steam generators. It would burn natural gas in the combustion
18 turbines and duct burners. Expanding gases from combustion would turn rotors within the
19 turbines that are connected to electric generators. The hot gases exhausted from the combustion
20 turbines and duct burners would be used to raise steam in the HRSGs. Steam from the HRSGs
21 would be expanded through the steam turbines. Each steam turbine would drive its own electric
22 generator.

23
24 The combustion turbines would be housed in a turbine building that provides thermal insulation,
25 acoustical attenuation and fire extinguishing media containment. The turbine building,
26 occupying a footprint measuring about 230 feet by 560 feet and standing about 90 feet high,
27 would also house the steam turbine generators, condensers, balance of plant equipment, control
28 room, and administrative offices. The enclosure would allow access for routine inspection and
29 maintenance.

30
31 Each of the two HRSGs would occupy a footprint measuring about 50 feet by 150 feet and
32 would stand about 110 feet high. A stack would be provided for each combustion turbine's
33 HRSG. The two stacks would be about 15 to 25 feet in diameter and 200 feet high.

34
35 Four transformers would step-up the combustion turbine and steam turbine generator voltages to
36 the substation voltage of 230 kilovolts ("kV"). Two auxiliary transformers would supply power
37 for plant auxiliary loads.

38
39 Most of the structures comprising the energy facility, including the combustion and steam
40 turbines and generators, the main step-up transformers, the HRSG, and the control rooms, would
41 be contained within an area measuring about 400 feet by 560 feet.

42
43 Two mechanical-draft cooling towers would be used to remove the waste heat from each main
44 condenser and the plant auxiliary heat exchangers. The cooling towers and circulating water
45 pumps would cover an area of about 75 feet by 650 feet and would stand about 50 feet high.

1
2 A switchyard would interconnect the plant's output to the 230-kV transmission network. The
3 switchyard footprint would measure about 300 feet by 500 feet.

4
5 Additional facilities would include: a plant services/warehouse building; two boiler feed pump
6 buildings; a fire water pump building; a water treatment building; a clarifier; a settling basin; a
7 condensate tank, a fire water/service water storage tank and a demineralized water storage tank
8 (each with 440,000-gallon capacity); a natural gas metering station; and, an aqueous ammonia
9 storage tank (with 100,000-gallon capacity and equipped with containment).

10
11 Natural gas would not be stored at the energy facility site. Diesel fuel for the fire pumps would
12 be stored in an aboveground tank. Water treatment chemicals would be stored in permanent
13 aboveground storage tanks or portable plastic tanks (totes). To prevent storm water runoff from
14 chemical storage, all fuel and chemical storage would be inside buildings or under cover in
15 paved areas with a curb. All individual spill containment areas would be designed to hold at
16 least 110 percent of the volume of liquids stored within them.

17
18 A complete fire protection system would be installed within the buildings and yard areas at the
19 energy facility site. The system would be designed to meet the requirements of the Uniform Fire
20 Code, as amended by Oregon and the National Fire Protection Association, and all other
21 applicable fire protection standards. The fire protection system would include a fire water
22 system, a dry chemical extinguishing system, a carbon dioxide ("CO₂") extinguishing system,
23 and portable fire extinguishers. The road system within the energy facility site would be
24 designed for access by large trucks needed for equipment and material deliveries. (These trucks
25 are larger than typical fire trucks.) The minimum turning inside radius for roads would be
26 40 feet.

27
28 The fire water system would include a fire water supply loop, fire hydrants, sprinkler systems,
29 and hoses placed at appropriate locations. Reserved capacity in the 180,000-gallon fire
30 water/service water storage tank would serve as the firewater source.

31
32 The combustion turbine enclosures would be protected by foam or CO₂ systems. If the systems
33 were to activate, an alarm would sound and/or a visual indicator would light up on the gas
34 turbine control panel.

35
36 Portable fire extinguishers would be placed at key locations within the energy facility site. The
37 type and number of portable fire extinguishers would conform to applicable code requirements.

38
39 **Output.** The energy facility would have a net electric power output of about 560 MW at an
40 average annual site condition of 51 degrees Fahrenheit, 14.691 pounds per square inch
41 barometric pressure, and 78 percent relative humidity. The new and clean heat rate would be
42 about 6,790 Btu (higher heating value).

43
44 With power augmentation technologies (duct burning), the energy facility would have a net
45 electric power output of about 650 MW and a new and clean heat rate of about 7,100 Btu (higher

1 heating value). PGE proposes to operate the energy facility with power augmentation
2 technologies for 3,000 hours annually on average.

3
4 **Fuel Use.** The energy facility would use natural gas as the only fuel to power the turbines and
5 the power augmentation technologies. It would use 4,600 MM Btu per hour of natural gas at full
6 load with the duct burners in operation at the average annual site condition.

7
8 **Water Use.** The energy facility would obtain water to generate steam and to cool the steam
9 process from an existing PGE intake structure on the Bradbury Slough of the Columbia River.
10 PGE would enter into a contract with the Port of St. Helens, which has an existing water permit,
11 to obtain water sufficient for operation of the energy facility.

12
13 Average water demand at the energy facility would be about 2,800 gallons per minute (“gpm”),
14 or 4.0 million gallons per day (“gpd”). Peak water demand would be about 3,700 gpm,
15 5.4 million gpd, or 8.3 cubic feet per second (“cfs”).

16
17 The energy facility would require no new state-administered water right, water rights transfer, or
18 surface water right permit for water supply. The Port of St. Helens has an existing municipal
19 water use permit for 30 cfs.

20
21 The water right has a permitted point of diversion, where existing withdrawals occur and the
22 energy facility withdrawals would occur. PGE owns and operates the existing point of diversion.
23 To serve the energy facility, PGE would place additional pumps within the existing intake
24 facility. PGE would employ fish screens compliant with National Marine Fisheries Service
25 (“NMFS”) screening criteria and Oregon Department of Fish and Wildlife (“ODFW”) criteria.

26
27 **Wastewater.** Process blowdown is washdown water, filter backwash or other non-sanitary
28 liquid waste produced within the energy facility. The average volume of process blowdown
29 would be about 190 gpm. Cooling system blowdown is water withdrawn from the cooling
30 system to control the buildup of dissolved salts. The average volume of cooling system
31 blowdown would be about 460 gpm, but it could vary depending on the quality of the river water
32 supply. The energy facility would discharge its process and cooling system blowdown to the
33 Columbia River under a National Pollution Discharge Elimination System (“NPDES”) permit
34 that the Port of St. Helens has requested from DEQ.

35
36 PGE would discharge sanitary sewage to an engineered septic tank and drain field at a rate of
37 about 500 gallons per day, as permitted by a Water Pollution Control Facilities permit. PGE
38 would route storm water from roofs and paved areas to pervious areas to percolate into the
39 shallow groundwater.

40 41 **C.1.b. Related or Supporting Facilities**

42 The energy facility would include the following related or supporting facilities:

43
44 **Natural Gas Pipeline.** Natural gas would fuel the combustion turbine generators and duct
45 burners. The energy facility would be served by the Kelso-Beaver Pipeline, an existing FERC-

1 regulated interstate pipeline with a current capacity of 193,000 decatherms per day. PGE owns
2 the pipeline jointly with two other parties. To create the additional capacity that would be
3 required to serve the energy facility, PGE would add 4,000 to 15,000 compressor horsepower to
4 the Kelso-Beaver Pipeline. All work on the existing pipeline would be subject to FERC
5 approval. The addition of compressor horsepower is intended to ensure 415 to 520 psig gas
6 pressure at the Port Westward Industrial Area with total capacity of 310 million standard cubic
7 feet/day.

8
9 The interconnecting pipeline, about 18 inches in diameter, between the existing Kelso-Beaver
10 Pipeline and the energy facility would be about 1,000 feet long and would be installed below
11 grade with appropriate cathodic protection.

12
13 **Water Supply Pipeline.** Water supply for the energy facility would be drawn from Bradbury
14 Slough at about River Mile 53.8 of the Columbia River from an existing PGE intake facility.
15 The pump capacity of the existing intake facility would be expanded. No major structural
16 improvements or modifications to the intake facility would be required. However, PGE will
17 upgrade the fish screens to comply with NMFS and ODFW criteria regardless of whether it
18 builds the Port Westward Generating Project. PGE would install a water supply pipeline about
19 20 inches in diameter and 6,000 feet long to convey water from the intake facility to the energy
20 facility. The water supply pipeline would traverse upland areas and would avoid wetlands.

21
22 **Reclaimed Wastewater Pipeline.** Process and cooling wastewater discharged from the energy
23 facility would be collected in a settling basin and returned to the Columbia River about one-half
24 mile northwest of the energy facility, pursuant to the Port of St. Helens' NPDES permit.

25
26 **Electric Transmission Line.** The energy facility would deliver electric power to the regional
27 grid by means of a new transmission line consisting of one 230 kV circuit on monopole towers
28 (up to 120 feet high) routed along existing power line easements. There are two transmission
29 line alternatives routes under consideration, with two other short alternative segments in the
30 vicinity of the BPA Allston Substation:

31
32 Alternative One. The first alternative would entail routing the transmission line from the
33 energy facility to the Bonneville Power Administration ("BPA") Allston Substation near
34 Alston, Oregon (a distance of about 10 miles).

35
36 Alternative Two. The second alternative would entail routing the transmission line from
37 the energy facility to the PGE Trojan Substation near Goble, Oregon (a distance of about
38 20 miles).

39
40 PWGP and the Summit Project present a unique situation regarding the transmission lines for
41 their facilities. The two proposed energy projects would be located close to each other and
42 would use the same existing transmission corridor and the same towers from Port Westward to
43 the vicinity of the BPA Allston Substation, Alternative One. The towers would be double-
44 circuited, with PWGP on one side and the Summit Project on the other.

1 The Portland General Electric Transmission Group would build the transmission lines for either
2 or both projects, depending on which energy facilities are eventually constructed. The
3 transmission line for each project is a related or supporting facility for that project, and therefore,
4 must be built to Council standards. However, because the Council is reviewing the applications
5 for both projects simultaneously, because they would use the same towers, and because the same
6 company would build and operate the transmission lines, the Council has consolidated the
7 reviews within the PWGP proceeding and is placing conditions for the transmission lines in the
8 site certificate for the Port Westward Generating Project.

9
10 Some conditions account for the possibility that the certificate holder may construct the Port
11 Westward to BPA Allston Substation Transmission Line may separately from constructing the
12 energy facility. Additionally, if the certificate holder for PWGP does not construct the energy
13 facility within the time specified in its site certificate or if it terminates its site certificate, the
14 Council intends that the certificate holder of the Summit Project must amend its site certificate to
15 include the 230 kV transmission line from the Summit Project to the BPA Allston Substation.

16 17 **C.2. LOCATION OF THE FACILITY**

18 19 **C.2.a. The Energy Facility Site**

20 The energy facility would be located about seven miles by road northeast of the city of
21 Clatskanie in Columbia County, Oregon. The energy facility site would be located on an
22 approximately 852-acre parcel leased to PGE by the Port of St. Helens in Section 15, Township 8
23 North, Range 4 West, Willamette Meridian. The energy facility site would be fenced and would
24 comprise about 19 acres of the larger parcel.

25
26 Bradbury Slough of the Columbia River lies to the northeast of the energy facility site. Access to
27 the energy facility site would be by traveling about 1.5 miles north on Kallunki Road from its
28 intersection with Alston-Mayger Road. The existing PGE Beaver Generating Plant is located
29 about one-half mile southwest of the energy facility site.

30 31 **C.2.b. Related or Supporting Facility Sites**

32
33 **Natural Gas Pipeline Corridor.** The proposed natural gas pipeline would be about 18 inches in
34 diameter and would interconnect with the existing Kelso-Beaver Pipeline about 1,000 feet west
35 of the energy facility site. The natural gas pipeline corridor would lie within the 852-acre parcel
36 leased to PGE by the Port of St. Helens and situated within Section 15, Township 8 North, Range
37 4 West, Willamette Meridian.

38
39 **Water Supply Pipeline Corridor.** The proposed water supply pipeline would supply raw water
40 to the energy facility from the existing PGE Beaver Generating Plant water intake structure in
41 Bradbury Slough of the Columbia River. The pipeline right-of-way would be about 50 feet wide
42 and 6,000 feet long, would cover an area of about 7 acres, and would lie within the 852-acre
43 parcel leased to PGE by the Port of St. Helens and situated within Section 15, Township 8 North,
44 Range 4 West, Willamette Meridian.

1 **Reclaimed Wastewater Pipeline Corridor.** Water discharged from the energy facility would
2 be returned to the Columbia River about one-half mile northwest of the energy facility. The
3 reclaimed water pipeline corridor would be about 100 feet wide and 2,400 feet long, would cover
4 an area of about 6 acres, and would lie primarily within the 852-acre parcel leased to PGE by the
5 Port of St. Helens and situated within Section 15 and 16, Township 8 North, Range 4 West,
6 Willamette Meridian.

7
8 **Transmission Line Corridor.** The transmission line would follow one of two alternative
9 routes:

10
11 Alternative One. Under this alternative, the energy facility would deliver electric power
12 to the BPA Allston Substation near Alston, Oregon, by means of a new 230-kV circuit on
13 monopole steel structures, except where it would have to cross the existing BPA lines. A
14 separate 230 kV circuit would carry the output of the Summit Project on the same
15 structures, as noted above. The new transmission line would be routed on an existing
16 PGE right-of-way that is 250 feet wide, except at the BPA Allston Substation where a
17 new right-of-way may be required. The structures would be placed on or near the
18 centerline of the unused north half of the right-of-way. The transmission line corridor
19 would be about 125 feet wide and 10 miles long, would occupy an area of about 300
20 acres, and would pass through Sections 15, 22, 23, 26, 35 and 36, Township 8 North,
21 Range 4 West, and Sections 31, 5, 6, 4, 3 and 10, Township 7 North, Range 3 West,
22 Willamette Meridian.

23
24 Alternative Two. Under this alternative, the energy facility would deliver electric power
25 to Trojan near Goble, Oregon, by means of a new 230-kV circuit on monopole steel
26 structures. Between PWGP and the BPA Allston Substation, the new transmission line
27 would be routed on an existing PGE right-of-way 250 feet wide as described in
28 Alternative One. The structures would be placed on or near the centerline of the unused
29 north half of the right-of-way. Between the BPA Allston Substation and Trojan, the new
30 transmission line would run parallel to an existing BPA transmission line. This section of
31 the transmission line corridor would be about 125 feet wide and ten miles long, would
32 occupy an area of about 300 acres, and would pass through Sections 10, 11, 15, 14, 23
33 and 24, Township 7 North, Range 3 West, and Sections 19, 30, 29, 28, 33 and 34,
34 Township 7 North, Range 2 West, and Sections 3 and 2, Township 6 North,
35 Range 2 West, Willamette Meridian.

36
37 Alternates 3 and 4. These short alternate segments are in the vicinity of the BPA Allston
38 Substation. They provide flexibility for interconnecting with the substation.

39
40 Unanalyzed Options. As shown on Figure C-2 of the ASC, and in particular the enlarged
41 detail of the BPA Allston Substation, there is a segment of Alignment 1 identified as
42 “2nd (future) circuit.” This Order does not address that proposed segment of Alignment 1.
43

1 **D. COUNCIL FACILITY SITING STANDARDS**

2
3 **D.1. INTRODUCTION: GENERAL STANDARD OF REVIEW, OAR 345-022-0000**

- 4 (1) To issue a site certificate for a proposed facility or to amend a site certificate,
5 the Council shall determine that the preponderance of evidence on the record
6 supports the following conclusions:
- 7 (a) The facility complies with the requirements of the Oregon Energy
8 Facility Siting statutes, ORS 469.300 to ORS 469.570 and 469.590 to
9 469.619, and the standards adopted by the Council pursuant to ORS
10 469.501 or the overall public benefits of the facility outweigh the
11 damage to the resources protected by the standards the facility does not
12 meet as described in section (2);
 - 13 (b) Except as provided in OAR 345-022-0030 for land use compliance and
14 except for those statutes and rules for which the decision on compliance
15 has been delegated by the federal government to a state agency other
16 than the Council, the facility complies with all other Oregon statutes and
17 administrative rules identified in the project order, as amended, as
18 applicable to the issuance of a site certificate for the proposed facility. If
19 the Council finds that applicable Oregon statutes and rules, other than
20 those involving federally delegated programs, would impose conflicting
21 requirements, the Council shall resolve the conflict consistent with the
22 public interest. In resolving the conflict, the council cannot waive any
23 applicable state statute.
- 24
- 25 (2) The Council may issue or amend a site certificate for a facility that does not
26 meet the standards adopted under ORS 469.501 if the Council determines that
27 the overall public benefits of the facility at the proposed site outweigh the
28 damage to the resource that is protected by the standard the facility does not
29 meet***.
- 30
- 31 (3) Notwithstanding section (2) of this rule, the Council shall not issue or amend a
32 site certificate for a proposed facility that does not meet the standards of OAR
33 345-022-0040 if the statutes or administrative rules governing the management
34 of the protected area prohibit location of the proposed facility in that area.
- 35
- 36 (4) In making determinations regarding compliance with statutes, rules and
37 ordinances normally administered by other agencies or compliance with
38 requirements of the Council statutes if other agencies have special expertise, the
39 Office of Energy shall consult with such other agencies during the notice of
40 intent, site certificate application and site certificate amendment processes.
41 Nothing in these rules is intended to interfere with the state's implementation of
42 programs delegated to it by the federal government.
- 43

1 **D.2. ORGANIZATIONAL EXPERTISE, OAR 345-022-0010**

2 This standard has four paragraphs. Two, OAR 345-022-0010(1) and OAR 345-022-0010(2),
3 relate to PGE’s qualification and capability and two, OAR 345-22-0010(3) and OAR 345-022-
4 0010(4), relate to third party permits.

5
6 **D.2.a. Applicant Qualification and Capability, OAR 345-022-0010(1)**

7 To issue a site certificate, the Council must find that the applicant has the
8 organizational expertise to construct, operate and retire the proposed facility in
9 compliance with Council standards and conditions of the site certificate. To conclude
10 that the applicant has this expertise, the Council must find that the applicant has
11 demonstrated the ability to design, construct and operate the proposed facility in
12 compliance with site certificate conditions and in a manner that protects public health
13 and safety and has demonstrated the ability to restore the site to a useful, non-hazardous
14 condition. The Council may consider the applicant’s experience, the applicant’s access
15 to technical expertise and the applicant’s past performance in constructing, operating
16 and retiring other facilities, including, but not limited to, the number and severity of
17 regulatory citations issued to the applicant.

18
19 **Discussion**

20 PGE was incorporated in Oregon on July 25, 1930. PGE is a wholly-owned subsidiary of Enron
21 Corp. (Before PGE submitted its ASC, NW Natural Gas Company offered to purchase PGE
22 from Enron. NW Natural Gas subsequently withdrew its offer to purchase PGE.) The Council
23 finds that it can rely on the experience and expertise of PGE for the purposes of this Order as
24 long as PGE remains an independent operating entity.

25
26 PGE has significant experience in managing the construction of electric generating projects.
27 Recent examples include: Beaver 8, a 24.9-megawatt simple-cycle gas turbine project located at
28 Beaver and completed in July 2001; and, Coyote Springs Unit 1, a 240-megawatt combined-
29 cycle combustion turbine located in Boardman, Oregon, and placed in service in 1995. PGE
30 prepared and negotiated all the contracts for the design and construction of Coyote Springs Unit
31 1, supervised its construction, and performed many of the engineering functions in support of the
32 design and construction work. In addition, in 1999 and 2000, PGE prepared draft engineering,
33 procurement and construction documents in conjunction with the development of Coyote Springs
34 Unit 2 before selling the right to develop that project to an unaffiliated third-party. PGE
35 employees have extensive engineering and project management experience associated with
36 electric generating projects.

37
38 PGE currently operates thermal generating facilities producing over 1,400 megawatts and has a
39 contract to operate the 280-megawatt Coyote Springs Unit 2 when it comes on line. PGE
40 constructed and operates Coyote Springs Unit 1 and the Boardman Coal Plant in compliance
41 with site certificate conditions. In addition to thermal generating facilities, PGE operates major
42 hydroelectric facilities producing an additional 575 megawatts. Table D.2 shows the major
43 projects that PGE operates.

1 PGE conducted interviews with its plant managers and reported that PGE has not experienced
 2 any monetary penalty or fine associated with regulation of any thermal generating facility
 3 operated by PGE within the past five years. PGE has not received a monetary penalty or fine for
 4 regulatory violations at Beaver since it began operation in 1974 or at Coyote Springs Unit 1 since
 5 it began operation in 1995. PGE reported that it has received notices of violation and has self-
 6 reported instances of non-compliance with regulatory requirements, but none of these instances
 7 involved monetary penalties. PGE reported that all problems were minor or not serious and all
 8 were settled to the satisfaction of the affected regulatory authority.

9
 10
 11 **Table D.2**
 12 **MAJOR ELECTRIC GENERATING PROJECTS CONSTRUCTED**
 13 **AND CURRENTLY OPERATED BY PGE**

Project Commercial Operation Date	Technology	Approximate Size (MW)
Beaver Generating Plant (1974)	Gas Combined-Cycle Combustion Turbine	534
Beaver 8 (2001)	Gas Simple-Cycle Combustion Turbine	25
Coyote Springs Unit 1 (1995)	Gas Combined-Cycle Combustion Turbine	241
Boardman Coal Plant (1980)	Coal	600
Round Butte (1964)	Hydro	300
Pelton (1957)	Hydro	108
Oak Grove (1924)	Hydro	44
North Fork (1958)	Hydro	54
Faraday (1907 / 1958)	Hydro	44
River Mill (1911 / 1952)	Hydro	25

14
 15 PGE owns the Trojan Nuclear Plant. The plant ceased operation in 1993 and is now in the
 16 decommissioning process. Within the past five years, PGE was assessed monetary penalties for
 17 two citations issued to Trojan: one from the U.S. Coast Guard for \$250 for one pint of hydraulic
 18 fluid spilled into the Columbia River, and the other from DEQ for \$3,000 for chemical container
 19 violations. PGE received no other citations involving monetary penalties at Trojan during the
 20 past five years. It operated and is now decommissioning the plant in compliance with site
 21 certificate conditions. PGE has considerable experience with facility retirement as a direct
 22 consequence of decommissioning Trojan.

23
 24 Other matters concerning retirement are addressed in Section D.3 of this Order. Other matters
 25 concerning protection of public health and safety are addressed throughout this Order.

26
 27 PGE has not selected a prime contractor for the proposed facility. PGE would enter into turnkey
 28 engineering, procurement and construction contracts (each one an “EPC” contract) with one or
 29 more qualified and credit-worthy contractors; different elements of the facility may be contracted
 30 to different EPC contractors. PGE would draft an EPC contract that would serve as the basis for
 31 negotiations with vendors. PGE could execute separate contracts, for example, for the energy
 32 facility and the transmission lines. PGE plans to provide a Design Basis & Technical
 33 Specifications document in conjunction with a draft EPC contract. PGE has extensive
 34 experience in the process of preparing and negotiating such documents and in selecting EPC
 35 contractors.

1
2 PGE has not selected a combustion turbine vendor for the facility, but expects that General
3 Electric, Siemens Westinghouse, MHI, ABB or equivalent would supply the equipment.

4
5 The Council adopts the following conditions in the site certificate:

- 6
7 **(1) The Certificate Holder shall report to the Office of Energy (“Office”) in a**
8 **timely manner any change in the ownership of Portland General Electric**
9 **Company (“PGE”).**
- 10
11 **(2) Before beginning construction of the energy facility, the Port Westward to**
12 **Bonneville Power Administration (“BPA”) Allston Substation Transmission**
13 **Line, or other related or supporting facilities, the Certificate Holder shall**
14 **identify to the Energy Facility Siting Council (“Council”) whom it has chosen**
15 **to act in the role of the engineering, procurement and construction (“EPC”)**
16 **contractor(s) for specific portions of the work.**
- 17
18 **(3) If the Certificate Holder chooses a third-party contractor to operate the**
19 **facility, the Certificate Holder shall submit to the Council the identity of the**
20 **contractor so the Council may review the qualifications and capability of the**
21 **contractor to meet the standards of OAR 345-0022-0010. If the Council finds**
22 **that a new contractor meets these standards, the Council shall not require an**
23 **amendment to the Site Certificate for the Certificate Holder to hire the**
24 **contractor.**
- 25
26 **(4) Any matter of non-compliance under this Site Certificate shall be the**
27 **responsibility of the Certificate Holder. Any notice of violation issued under**
28 **the Site Certificate will be issued to the Certificate Holder. Any civil**
29 **penalties levied shall be levied on the Certificate Holder.**
- 30
31 **(5) The Certificate Holder shall contractually require the EPC contractor(s) and**
32 **all independent contractors and subcontractors involved in the construction**
33 **and operation of the facility to comply with all applicable laws and**
34 **regulations and with the terms and conditions of the Site Certificate. Such**
35 **contractual provision shall not operate to relieve the Certificate Holder of**
36 **responsibility under the Site Certificate.**
- 37
38 **(6) The Certificate Holder shall obtain necessary state and local permits or**
39 **approvals required for the construction, operation and retirement of the**
40 **facility or ensure that its contractors obtain the necessary state and local**
41 **permits or approvals.**

42
43 The Council finds PGE has demonstrated the ability to design, construct and operate the
44 proposed facility in compliance with site certificate conditions and in a manner that protects
45 public health and safety and the ability to restore the site to a useful, non-hazardous condition.

1
2 **Conclusion**

3 The Council finds that PGE meets the requirements of OAR 345-022-0010(1).
4

5 **D.2.b. Applicant Qualification and Capability: ISO Programs, OAR 345-022-0010(2)**

6 The Council may base its findings under section (1) on a rebuttable presumption that an
7 applicant has organizational, managerial and technical expertise, if the applicant has an
8 ISO 9000 or ISO 14000 certified program and proposes to design, construct and operate
9 the facility according to that program.
10

11 **Discussion**

12 PGE did not submit evidence of ISO certification.
13

14 **Conclusion**

15 The Council finds that PGE has not requested a rebuttable presumption of expertise pursuant to
16 OAR 345-022-0010(2).
17

18 **D.2.c. Third-Party Services and Permits: Contracts, OAR 345-022-0010(3)**

19 If the applicant does not itself obtain a state or local government permit or approval for
20 which the Council would ordinarily determine compliance but instead relies on a permit
21 or approval issued to a third party, the Council, to issue a site certificate, must find that
22 the third party has, or has a reasonable likelihood of obtaining, the necessary permit or
23 approval, and that the applicant has, or has a reasonable likelihood of entering into, a
24 contractual or other arrangement with the third party for access to the resource or
25 service secured by that permit or approval.
26

27 **Discussion**

28 **Raw Water Supply.** PGE would obtain water for operation of the energy facility from the Port
29 of St. Helens. The Port of St. Helens has a Permit to Appropriate the Public Waters (Permit
30 #53677), issued April 24, 2000, allowing for the appropriation of water from the Columbia River
31 at the rate of up to 30.0 cubic feet per second (“cfs”). PGE states the energy facility would use
32 water at the rate of about 8.3 cfs. By letter to PGE dated July 26, 2001, the Port of St. Helens
33 has stated that it “believes it is reasonably likely that the Port and PGE will be able to enter into
34 a contract to provide water to the Port Westward Generating project” at the rate of up to 10.0 cfs.
35

36 **Conclusion**

37 The Council finds that PGE meets the requirements of OAR 345-022-0010(3).
38

39 **D.2.d. Third-Party Services and Permits: Conditions, OAR 345-022-0010(4)**

40 If the applicant relies on a permit or approval issued to a third party and the third party
41 does not have the necessary permit or approval at the time the Council issues the site
42 certificate, the Council may issue the site certificate subject to the condition that the
43 certificate holder shall not commence construction or operation as appropriate until the
44 third party has obtained the necessary permit or approval and the applicant has a

1 contract or other arrangement for access to the resource or service secured by that
2 permit or approval.
3

4 **Discussion**

5 **Reclaimed Wastewater Disposal.** PGE would discharge non-sanitary wastewater from the
6 energy facility site by means of a wastewater treatment facility to be constructed by the Port of
7 St. Helens under an NPDES permit that the Port has yet to obtain from DEQ. The purpose of the
8 NPDES permit would be to allow for the discharge of all wastewater, except sanitary
9 wastewater, from facilities within the boundary of the Port Westward Industrial Area that
10 contract with the Port to discharge wastewater under the Port’s NPDES permit. By letter to PGE
11 dated July 26, 2001, the Port of St. Helens has stated the “Port believes that it is reasonably
12 likely that we will be able to enter into a contract with Portland General Electric to allow PGE to
13 use the wastewater discharge facilities developed under the NPDES permit.”
14

15 By letter to the Port of St. Helens dated February 27, 2002, DEQ acknowledged it had received
16 the Port’s application for an NPDES permit (Application No. 986433) and that review of the
17 application would proceed on a normal schedule.
18

19 The Council finds that it needs to impose additional site certificate conditions relating to
20 obtaining third-party permits because:
21

- 22 (a) There is no contractual agreement between PGE and the Port of St. Helens
23 whereby PGE may use up to 10 cfs of the Port of St. Helens’ water right.
- 24 (b) DEQ has not issued the NPDES permit to allow for the discharge of all
25 wastewater except sanitary wastewater from facilities within the boundary of the
26 Port Westward Industrial Area.
- 27 (c) There is no contractual agreement between PGE and the Port of St. Helens
28 whereby PGE may discharge wastewater from the energy facility by means of the
29 NPDES permit issued to the Port of St. Helens.
30

31 The Council adopts the following conditions in the site certificate:
32

- 33 (7) **Before beginning construction of the energy facility, the Certificate Holder**
34 **shall deliver to the Office a copy of the agreement between the Certificate**
35 **Holder and the Port of St. Helens that provides that the Certificate Holder**
36 **may use at least 8.3 cubic feet per second of the water right held by the Port**
37 **of St. Helens under Permit to Appropriate the Public Waters, issued by the**
38 **State of Oregon, Water Resources Department, Permit No. 53677.**
- 39
40 (8) **Before beginning construction of the energy facility, the Certificate Holder**
41 **shall deliver to the Office evidence that the Oregon Department of**
42 **Environmental Quality has issued to the Port of St. Helens a National**
43 **Pollutant Discharge Elimination System (“NPDES”) permit that provides for**
44 **the discharge of non-sanitary wastewater from the Port Westward Industrial**
45 **Site, including all non-sanitary wastewater produced by the energy facility.**

- 1
2 **(9) Before beginning construction of the energy facility, the Certificate Holder**
3 **shall deliver to the Office a copy of the agreement between the Certificate**
4 **Holder and the Port of St. Helens that provides for discharge of non-sanitary**
5 **wastewater from the energy facility by means of the NPDES permit issued to**
6 **the Port of St. Helens.**

7
8 **Conclusion**

9 The Council finds that PGE meets the requirements of OAR 345-022-0010(4).

10
11 **D.3. RETIREMENT AND FINANCIAL ASSURANCE, OAR 345-022-0050**

12 To issue a site certificate, the Council must find that:

- 13 (1) The site, taking into account mitigation, can be restored adequately to a useful,
14 non-hazardous condition following permanent cessation of construction or
15 operation of the facility.
16 (2) The applicant has a reasonable likelihood of obtaining a bond or letter of credit
17 in a form and amount satisfactory to the Council to restore the site to a useful,
18 non-hazardous condition.

19
20 **Discussion**

21 This section addresses the requirement for restoration of the site to a useful, non-hazardous
22 condition following permanent cessation of construction or operation of the facility, the amount
23 of financial assurance the Council should require, and PGE's ability to offer such financial
24 assurance.

25
26 **Retirement.** For the purposes of the retirement and financial assurance standard, a "useful,
27 non-hazardous condition" is a condition consistent with the applicable local comprehensive land
28 use plan and land use regulations. The energy facility site is currently zoned for Resource
29 Industrial-Planned Development uses. The transmission line corridors are zoned for Primary
30 Agriculture-38, Forest Agriculture-19, Primary Forest-76, Rural Residential-5, and Watershed
31 uses.

32
33 The estimated useful life of the energy facility is 30 years. However, PGE proposes to operate
34 the energy facility for as long as a market exists for the electrical energy that it produces. At the
35 end of its useful life, PGE would retire the energy facility in accordance with the approved
36 retirement plan and in compliance with all laws and regulations in effect at the time of
37 retirement.

38
39 Among the related or supporting facilities is the transmission line between Port Westward and
40 the BPA Allston Substation. This transmission line would serve both the Port Westward
41 Generating Project and the Summit Project. In the event that Westward Energy, LLC,
42 ("Summit/Westward") proceeds with construction of the Summit Project in advance of PGE's
43 beginning construction of the energy facility of the Port Westward Generating Project, PGE
44 would have to proceed with construction of the Port Westward to BPA Allston Substation
45 Transmission Line separate and apart from construction of its energy facility. Therefore, in

1 several instances this Order and the site certificate distinguish between conditions that relate to
2 construction, operation, and retirement of the energy facility, those that relate to the Port
3 Westward to BPA Allston Substation Transmission Line, and those that relate to other related or
4 supporting facilities. For example, the distinction between the Port Westward to BPA Allston
5 Substation Transmission Line and the energy facility is relevant to the retirement and financial
6 assurance standard, as explained below.

7
8 Site restoration would consist primarily of the dismantling and the removal of unneeded
9 equipment and structures. Electric, gas and water transmission lines would be retained, as
10 appropriate, to serve any new industrial uses at the site. Two years before the date on which
11 PGE expects to permanently shut down the proposed energy facility, or the Port Westward to
12 BPA Allston Substation Transmission Line, as appropriate, it would develop and submit a site
13 restoration plan to the Council for its approval.

14
15 The Council adopts the following conditions in the site certificate:

- 16
17 **(1) The Certificate Holder shall retire the facility if the Certificate Holder**
18 **permanently ceases construction or operation of the facility. The Certificate**
19 **Holder shall retire the facility according to a final retirement plan approved**
20 **by the Council, as described in OAR 345-027-0110, and prepared pursuant to**
21 **Condition (2).**
22
23 **(2) Two years before closure of the energy facility, the Certificate Holder shall**
24 **submit to the Office a proposed final retirement plan for the facility and site,**
25 **pursuant to OAR 345-027-0110, including:**
26
27 **(a) A plan for retirement that provides for completion of retirement**
28 **within two years of permanent cessation of operation of the energy**
29 **facility and that protects the public health and safety and the**
30 **environment;**
31
32 **(b) A description of actions the Certificate Holder proposes to take to**
33 **restore the site to a useful, non-hazardous condition; and,**
34
35 **(c) A detailed cost estimate, a comparison of that estimate with the dollar**
36 **amount secured by a bond or letter of credit and any amount**
37 **contained in a retirement fund, and a plan for assuring the**
38 **availability of adequate funds for completion of retirement.**
39
40 **(3) The Certificate Holder shall prevent the development of any conditions on**
41 **the site that would preclude restoration of the site to a useful, non-hazardous**
42 **condition to the extent that prevention of such site conditions is within the**
43 **control of the Certificate Holder.**
44

1 (4) **Notwithstanding Conditions (1), (2), and (3), if the Certificate Holder begins**
2 **construction of the Port Westward to BPA Allston Substation Transmission**
3 **Line before beginning construction of the energy facility and other related or**
4 **supporting facilities, Conditions (1), (2), and (3) shall apply to that**
5 **transmission line separately for as long as it is under construction or**
6 **operation independent of the energy facility; and, a retirement plan that the**
7 **Certificate Holder submits may provide that the Port Westward to BPA**
8 **Allston Substation Transmission Line remains in operation to serve other**
9 **energy facilities.**

10
11 The Council finds that PGE has demonstrated it can adequately restore the site to a useful, non-
12 hazardous condition following facility retirement.

13
14 **Financial Assurance.** PGE estimated the cost of removal of all equipment and structures from
15 the site would not exceed \$8.64 million. PGE developed the \$8.64 million estimate by
16 estimating the book cost of the different elements of the project, including but not limited to
17 structures, buildings and equipment, and multiplying the cost by a restoration rate (salvage rate).
18 The restoration rates used for each element are consistent with the restoration rates used for
19 Coyote Springs Unit 1 in PGE's UE-115 rate case approved by the Oregon Public Utility
20 Commission in the fall of 2001.

21
22 In the event that PGE were to proceed with construction of the Port Westward to BPA Allston
23 Substation transmission line in advance of beginning construction of the energy facility, PGE
24 estimated the cost of removal of all equipment and structures from the Port Westward to BPA
25 Allston Substation Transmission Line would be \$394,000.

26
27 The Council finds that these estimates are within the range of accuracy for estimates of this type.
28 Accordingly, the Council finds that the amount of the retirement fund applicable to the facility is
29 \$8.64 million (in 2002 dollars as of the second quarter) and the amount of the retirement fund
30 applicable to the Port Westward to BPA Allston Substation Transmission Line is \$0.394 million
31 (in 2002 dollars as of the second quarter).

32
33 If a plant is not well-operated, leaks, spills, and improper materials handling over a period of
34 several years could contaminate large amounts of soil, particularly if the spills had access to
35 cracks in concrete or asphalt cover or did not occur over an impermeable surface. In the absence
36 of an effective materials management and monitoring plan, careless practices could result in
37 much higher site remediation costs.

38
39 Accordingly, the Council adopts a condition that requires the certificate holder to prepare and
40 implement a materials management and monitoring plan that addresses the handling of
41 hazardous substances. The Council also requires the certificate holder to conduct Phase I
42 Environmental Site Assessments, in accordance with an industry accepted standard, such as
43 ASTM Standard E-1527, *Standard Practice for Environmental Site Assessments: Phase I*
44 *Environmental Site Assessment Process*, each 10 years. If either monitoring pursuant to the plan
45 or the Environmental Site Assessment concludes that there will be higher remediation costs than

1 can be covered by bond or letter of credit then in place, the Council requires the certificate holder
2 to increase its bond or letter of credit to cover the higher costs.

3
4 PGE provided a letter from ABN AMRO Bank N.V. (“ABN AMRO”) with which it has a long-
5 standing business relationship, whereby ABN AMRO stated it would be willing to furnish or
6 arrange a letter of credit in an amount up to \$10 million for a period not to exceed four years for
7 the purpose of ensuring that the site of the proposed energy facility can be restored to a useful,
8 non-hazardous condition. Because the estimated useful life of the energy facility is 30 years, the
9 term of the required bond or letter of credit would be greater than the term for which ABN
10 AMRO has extended its commitment. However, a bond or letter of credit is usually issued for
11 one or two years at a time and the certificate holder would be required to maintain a bond or
12 letter of credit in effect at all times.

13
14 A bond or letter of credit is financial assurance to the State of Oregon that funds will be available
15 to the State should it have to restore the site because of default by the site certificate holder. It is
16 a last resort; it is not the primary mechanism for restoring the site. It is the responsibility of the
17 site certificate holder to have funds or other financial resources available to it sufficient to restore
18 the site.

19
20 The Council does not have a standard that specifies that a certificate holder must maintain its
21 own retirement fund, but the existence and adequacy of such a fund is of concern to the Council.
22 The Council assumes that a certificate holder would create some fund or other mechanism.
23 Therefore, the Council requires that the certificate holder report annually on the status of its
24 retirement fund or whatever mechanism it uses to ensure it will have adequate funds for site
25 restoration.

26
27 The Council adopts the following conditions in the site certificate:

28
29 **(5) Before beginning construction of the energy facility, the Certificate Holder**
30 **shall submit to the State of Oregon, through the Council, a bond or letter of**
31 **credit in the amount of \$8,640,000 (in 2002 dollars as of the second quarter)**
32 **naming the State of Oregon, acting by and through the Council, as**
33 **beneficiary or payee.**

34
35 **(a) In the event the Certificate Holder begins construction of the Port**
36 **Westward to BPA Allston Substation Transmission Line before**
37 **beginning construction of the energy facility, the Certificate Holder**
38 **shall submit to the State of Oregon, through the Council, a bond or**
39 **letter of credit in the amount of \$394,000 (in 2002 dollars as of the**
40 **second quarter).**

41
42 **(b) If the Certificate Holder has previously begun construction of the Port**
43 **Westward to BPA Allston Substation Transmission Line, the**
44 **Certificate Holder shall increase the amount of such bond or letter of**

1 credit to \$8,640,000 (in 2002 dollars as of the second quarter) before
2 beginning construction of the energy facility.

3
4 (c) The form of the bond or letter of credit and identity of the issuer shall
5 be subject to approval by the Council.

6
7 (d) The Certificate Holder shall maintain a bond or letter of credit in
8 effect at all times until the energy facility or the Port Westward to
9 BPA Allston Substation Transmission Line has been retired, as
10 appropriate.

11
12 (e) The calculation of 2002 dollars shall be made using the U.S. Gross
13 Domestic Product Implicit Price Deflator, Chain-Weight, as published
14 in the Oregon Department of Administrative Services' "Oregon
15 Economic and Revenue Forecast," or by any successor agency (the
16 "Index"). If at any time the Index is no longer published, the Council
17 shall select a comparable calculation of 2002 dollars.

18
19 (f) The amount of the bond or letter of credit account shall increase
20 annually by the percentage increase in the Index.

21
22 (g) The Certificate Holder shall not revoke or reduce the bond or letter of
23 credit before retirement of the facility without approval by the
24 Council.

25
26 (6) The Certificate Holder shall describe in the annual report submitted to the
27 Council, pursuant to OAR 345-026-0080, the status of the retirement fund or
28 other instrument to ensure it has adequate funds to restore the site.

29
30 (7) Before beginning construction of the energy facility, the Certificate Holder
31 shall prepare and submit to the Office a materials management and
32 monitoring plan that addresses the handling of hazardous substances, the
33 measures it will implement to prevent site contamination, and how it will
34 document implementation of the plan during construction. The materials
35 management and monitoring plan shall be subject to approval by the Office.
36 For the purpose of this condition and Conditions (8), (10), (11), and
37 (12) below, the terms "release" and "hazardous substances" shall have the
38 meanings set forth at ORS 465.200.

39
40 (8) Before beginning operation of the energy facility, the Certificate Holder shall
41 prepare and submit to the Office a materials management and monitoring
42 plan that addresses the handling of hazardous substances, the measures it
43 will implement to prevent site contamination, and how it will document
44 implementation of the plan during operation. The materials management
45 and monitoring plan shall be subject to approval by the Office.

- 1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
- (9) Not later than 10 years after the date of commercial operation of the energy facility, and each 10 years thereafter during the life of the energy facility, the Certificate Holder shall complete an independent Phase I Environmental Site Assessment of the energy facility site. Within 30 days after its completion, the Certificate Holder shall deliver the Phase I Environmental Site Assessment report to the Office.
- (10) In the event that any Phase I Environmental Site Assessment identifies improper handling or storage of hazardous substances or improper record keeping procedures, the Certificate Holder shall correct such deficiencies within six months after completion of the corresponding Phase I Environmental Site Assessment. It shall promptly report its corrective actions to the Office. The Council shall determine whether the corrective actions are sufficient.
- (11) The Certificate Holder shall report any release of hazardous substances, pursuant to DEQ regulations, to the Office within one working day after the discovery of such release. This obligation shall be in addition to any other reporting requirements applicable to such a release.
- (12) If the Certificate Holder has not remedied a release consistent with applicable Oregon Department of Environmental Quality standards or if the Certificate Holder fails to correct deficiencies identified in the course of a Phase I Environmental Site Assessment within six months after the date of the release or the date of completion of the Phase I Environmental Site Assessment, the Certificate Holder shall submit within such six-month period to the Council for its approval an independently prepared estimate of the additional cost of remediation or correction.
- (a) Upon approval of an estimate by the Council, the Certificate Holder shall increase the amount of its bond or letter of credit by the amount of the estimate.
- (b) In no event, however, shall the Certificate Holder be relieved of its obligation to exercise all due diligence in remedying a release of hazardous substances or correcting deficiencies identified in the course of a Phase I Environmental Site Assessment.
- (13) All funds received by the Certificate Holder from the salvage of equipment and buildings shall be committed to the restoration of the energy facility site to the extent necessary to fund the approved site restoration and remediation.

1 **(14) The Certificate Holder shall pay the actual cost to restore the site to a useful,**
2 **non-hazardous condition at the time of retirement, notwithstanding the**
3 **Council's approval in the Site Certificate of an estimated amount required to**
4 **restore the site.**

5
6 **(15) If the Council finds that the Certificate Holder has permanently ceased**
7 **construction or operation of the facility without retiring the facility**
8 **according to a final retirement plan approved by the Council, as described in**
9 **OAR 345-027-0110 and prepared pursuant to Condition (2), the Council**
10 **shall notify the Certificate Holder and request that the Certificate Holder**
11 **submit a proposed final retirement plan to the Office within a reasonable**
12 **time not to exceed 90 days.**

13
14 **(a) If the Certificate Holder does not submit a proposed final retirement**
15 **plan by the specified date or if the Council rejects the retirement plan**
16 **that the Certificate Holder submits, the Council may direct the Office**
17 **to prepare a proposed a final retirement plan for the Council's**
18 **approval.**

19
20 **(b) Upon the Council's approval of the final retirement plan prepared**
21 **pursuant to subsection (a), the Council may draw on the bond or**
22 **letter of credit described in Condition (5) and shall use the funds to**
23 **restore the site to a useful, non-hazardous condition according to the**
24 **final retirement plan, in addition to any penalties the Council may**
25 **impose under OAR Chapter 345, Division 29.**

26
27 **(c) If the amount of the bond or letter of credit is insufficient to pay the**
28 **actual cost of retirement, the Certificate Holder shall pay any**
29 **additional cost necessary to restore the site to a useful, non-hazardous**
30 **condition.**

31
32 **(d) After completion of site restoration, the Council shall issue an order to**
33 **terminate the Site Certificate if the Council finds that the facility has**
34 **been retired according to the approved final retirement plan.**

35
36 The Council finds that PGE has a reasonable likelihood of obtaining a bond or letter of credit in a
37 form and amount satisfactory to the Council to restore the site to a useful, non-hazardous
38 condition.

39
40 **Conclusion**

41 The Council finds that PGE meets the retirement and financial assurance standard, OAR 345-
42 022-0050.

1 **D.4. LAND USE, OAR 345-022-0030**

- 2 (1) To issue a site certificate, the Council must find that the proposed facility
3 complies with the statewide planning goals adopted by the Land Conservation
4 and Development Commission. ***

5
6 **Discussion**

7 Pursuant to ORS 469.504(1)(b), PGE elected to ask the Council to determine that the proposed
8 facility complies with OAR 345-0022-0030(1). OAR 345-022-0030(2)(b) *et seq.* provides:

- 9
10 (2) The Council shall find that a proposed facility complies with section (1) if: ***
11 (b) The applicant elects to obtain a Council determination under ORS
12 469.504(1)(b) and the Council determines that:
13 (A) The proposed facility complies with applicable substantive
14 criteria as described in section (3) and the facility complies with
15 any Land Conservation and Development Commission
16 administrative rules and goals and any land use statutes directly
17 applicable to the facility under ORS 197.646(3);
18 (B) For a proposed facility that does not comply with one or more of
19 the applicable substantive criteria as described in section (3), the
20 facility otherwise complies with the statewide planning goals or an
21 exception to any applicable statewide planning goal is justified
22 under section (4); or
23 (C) For a proposed facility that the Council decides, under sections (3)
24 or (6), to evaluate against the statewide planning goals, the
25 proposed facility complies with the applicable statewide planning
26 goals or that an exception to any applicable statewide planning
27 goal is justified under section (4).
28
29 (3) As used in this rule, the "applicable substantive criteria" are criteria from the
30 affected local government's acknowledged comprehensive plan and land use
31 ordinances that are required by the statewide planning goals and that are in
32 effect on the date the applicant submits the application. If the special advisory
33 group recommends applicable substantive criteria, as described under OAR
34 345-021-0050, the Council shall apply them. If the special advisory group does
35 not recommend applicable substantive criteria, the Council shall decide either to
36 make its own determination of the applicable substantive criteria and apply
37 them or to evaluate the proposed facility against the statewide planning goals.
38
39 (4) The Council may find goal compliance for a proposed facility that does not
40 otherwise comply with one or more statewide planning goals by taking an
41 exception to the applicable goal. Notwithstanding the requirements of ORS
42 197.732, the statewide planning goal pertaining to the exception process or any
43 rules of the Land Conservation and Development Commission pertaining to the
44 exception process, the Council may take an exception to a goal if the Council
45 finds:

- 1 (a) The land subject to the exception is physically developed to the extent
- 2 that the land is no longer available for uses allowed by the applicable
- 3 goal;
- 4 (b) The land subject to the exception is irrevocably committed as described
- 5 by the rules of the Land Conservation and Development Commission to
- 6 uses not allowed by the applicable goal because existing adjacent uses
- 7 and other relevant factors make uses allowed by the applicable goal
- 8 impracticable; or
- 9 (c) The following standards are met:
 - 10 (A) Reasons justify why the state policy embodied in the applicable
 - 11 goal should not apply;
 - 12 (B) The significant environmental, economic, social and energy
 - 13 consequences anticipated as a result of the proposed facility have
 - 14 been identified and adverse impacts will be mitigated in
 - 15 accordance with rules of the Council applicable to the siting of
 - 16 the proposed facility; and
 - 17 (C) The proposed facility is compatible with other adjacent uses or
 - 18 will be made compatible through measures designed to reduce
 - 19 adverse impacts.
- 20
- 21 (5) If the Council finds that applicable substantive local criteria and applicable
- 22 statutes and state administrative rules would impose conflicting requirements,
- 23 the Council shall resolve the conflict consistent with the public interest. In
- 24 resolving the conflict, the Council cannot waive any applicable state statute.
- 25
- 26 (6) If the special advisory group recommends applicable substantive criteria for an
- 27 energy facility described in ORS 469.300(9)(a)(C) to (E) or for a related or
- 28 supporting facility that does not pass through more than one local government
- 29 jurisdiction or more than three zones in any one jurisdiction, the Council shall
- 30 apply the criteria recommended by the special advisory group. If the special
- 31 advisory group recommends applicable substantive criteria for an energy facility
- 32 described in ORS 469.300(9)(a)(C) to (E) or a related or supporting facility that
- 33 passes through more than one jurisdiction or more than three zones in any one
- 34 jurisdiction, the Council shall review the recommended criteria and decide
- 35 whether to evaluate the proposed facility against the applicable substantive
- 36 criteria recommended by the special advisory group, against the statewide
- 37 planning goals or against a combination of the applicable substantive criteria
- 38 and statewide planning goals. In making the decision, the Council shall consult
- 39 with the special advisory group, and shall consider:
 - 40 (a) The number of jurisdictions and zones in question;
 - 41 (b) The degree to which the applicable substantive criteria reflect local
 - 42 government consideration of energy facilities in the planning process;
 - 43 and
 - 44 (c) The level of consistence of the applicable substantive criteria from the
 - 45 various zones and jurisdictions.

1
2 **Discussion**

3 Attachment D to this Order, Land Use Standard Analysis, provides the findings and conclusions
4 to demonstrate compliance with the land use standard.

5
6 In a letter dated May 21, 2002, the Planning Division of the Columbia County Department of
7 Land Development Services recommended conditions. The City of Rainier did not comment on
8 the ASC.

9
10 The County proposed that it retain final approval of conditions relating to transportation.
11 However, as discussed in Section D.13 (Public Services) below, the Council must include all
12 conditions in the site certificate that it issues. It cannot defer to later County actions. The
13 Council has incorporated specific recommended conditions from County's agreement with PGE
14 and other transportation-related issues into several conditions that it adopts in Section D.13. The
15 Council believes that it has been responsive to the substance of the County's request.

16
17 The County recommended a condition relating to an outdoor lighting plan. The Council adopts
18 the substance of that condition in Condition (5) in Section D.10 (Scenic and Aesthetic Values).

19
20 The County recommended that the Council adopt conditions relating to the site plan, landscape
21 plan and parking lot plan. The Council has edited the County's recommended conditions to be
22 consistent in style with this Order; and, it adopts the following conditions in the site certificate:

- 23
24 **(1) Before beginning construction of the energy facility, the Certificate Holder**
25 **shall submit a landscaping plan for the energy facility to Columbia County**
26 **as part of its building permit application for the energy facility. The**
27 **landscaping plan shall be subject to County approval, provided that the plan**
28 **is consistent with this Site Certificate and the Final Order. The Certificate**
29 **Holder shall implement the landscaping plan.**
30
31 **(2) Before beginning construction of the energy facility, the Certificate Holder**
32 **shall submit a site plan to Columbia County as part of its building permit**
33 **application.**
34
35 **(3) Before beginning construction of the energy facility, the Certificate Holder**
36 **shall submit to Columbia County as part of its building permit application**
37 **for the energy facility a final parking lot plan that complies with Section**
38 **1400 of the Columbia County Zoning Ordinance. The parking plan shall be**
39 **consistent with this Site Certificate and Attachment D of the Final Order.**
40 **The Certificate Holder shall implement the parking lot plan.**

41
42 The Council also adopts the following land use conditions that are not otherwise addressed in the
43 County's recommendations:
44

1 (4) Before beginning construction of the energy facility or the Port Westward to
2 BPA Allston Substation Transmission Line, as appropriate, the Certificate
3 Holder shall apply for and obtain all appropriate land use permits from
4 Columbia County and the City of Rainier.

5
6 (5) Before beginning construction of the energy facility, the Certificate Holder
7 shall enter into a written contract with Columbia County that recognizes the
8 rights of land owners who are adjacent to and nearby the corridor for the
9 transmission line from the BPA Allston Substation to the Trojan Nuclear
10 Plant where it crosses PF-76 and FA-19 zones to conduct forest operations
11 consistent with the Forest Practices Act and Rules for uses authorized in
12 OAR 660-006-0025, subsections (4)(e), (m), (s), (t), and (w).

13
14 Based on the analysis in Attachment D and subject to conditions, the Council finds that an
15 exception to statewide planning Goal 4 is justified and that PGE has demonstrated compliance
16 with the applicable criteria in Columbia County's and the City of Rainier's acknowledged
17 comprehensive plans and land use regulations that are required by the statewide planning goals
18 and were in effect on the date PGE submitted the application, as well as the statewide planning
19 goals, LCDC administrative rules and any land use statutes directly applicable to the proposed
20 facilities under ORS 197.646(3).

21
22 **Conclusion**

23 The Council finds that PGE complies with the land use standard, OAR 345-0022-0030.

24
25 **D.5. STRUCTURAL STANDARD, OAR 345-022-0020**

26 (1) Except for facilities described in sections (2) and (3)², to issue a site certificate,
27 the Council must find that:

28 (a) The applicant, through appropriate site-specific study, has adequately
29 characterized the site as to seismic zone and expected ground motion
30 and ground failure, taking into account amplification, during the
31 maximum credible and maximum probable seismic events; and

32 (b) The applicant can design, engineer, and construct the facility to avoid
33 dangers to human safety presented by seismic hazards affecting the site
34 that are expected to result from all maximum probable seismic events.
35 As used in this rule "seismic hazard" includes ground shaking, landslide,
36 liquefaction, lateral spreading, tsunami inundation, fault displacement,
37 and subsidence;

38 (c) The applicant, through appropriate site-specific study, has adequately
39 characterized the potential geological and soils hazards of the site and its
40 vicinity that could, in the absence of a seismic event, adversely affect, or
41 be aggravated by, the construction and operation of the proposed facility;
42 and

² In this and other conditions that begin with a reference to "sections (2) and (3)," those sections refer to renewable energy facilities and special criteria facilities.

- 1 (d) The applicant can design, engineer and construct the facility to avoid
2 dangers to human safety presented by the hazards identified in subsection
3 (c). ***
4

5 Discussion

6 Site Characterization³/₄ Seismic Hazards

7 The energy facility site would be located in Seismic Zone 3, as defined by the 1997 Uniform
8 Building Code (“UBC”). Based on preliminary subsurface explorations, the soil profile at the
9 energy facility site corresponds to UBC soil type SF because of the presence of potentially
10 liquefiable soils.

11
12 The proposed related or supporting transmission line would follow the Port Westward to BPA
13 Allston Substation to Trojan transmission line corridors. The existing transmission line corridors
14 are located in Seismic Zone 3, as defined by the 1997 Uniform Building Code. The geology
15 through the corridor consists of basalts and inter-bedded marine sediments, with decomposed
16 overburden soil of variable thickness. The corridors cross several streams and traverse moderate
17 to steeply sloping terrain.

18
19 Two principal types of earthquake sources that are capable of generating ground motions at the
20 facility site are the Cascadia Subduction Zone (“CSZ”) and local crustal faults. The CSZ results
21 from the Juan de Fuca tectonic plate subducting (sliding) beneath the North American
22 continental tectonic plate.

23
24 Both the CSZ and the local crustal faults can be subdivided into two subsets.

- 25
26 · The CSZ can be subdivided into (1) earthquakes that occur between the Juan de Fuca and
27 North American plates, called “interface” earthquakes, and (2) earthquakes occurring
28 solely within the subducting Juan de Fuca plate, called “intraslab” earthquakes.
29
30 · Within the North American plate, the crustal fault sources can be subdivided into
31 (1) earthquakes occurring on known, mapped faults, and (2) earthquakes occurring on
32 unknown, buried, or random faults.
33

34 With respect to potential crustal sources, PGE has stated that the random crustal Maximum
35 Credible Event (“MCE”) would have a magnitude in the range of M6.0 to M6.6³. If the event
36 occurred within 25 kilometers of the site, it could cause ground motions of up to 0.26g mean
37 peak acceleration. Other crustal sources in western Oregon and Washington are located too far

³ In assessing seismic hazards, the applicant must identify and characterize all earthquake sources capable of generating median peak ground accelerations greater than 0.05g (a force 1/20th that of gravity) on rock at the energy facility site. The magnitude (“M”) of an earthquake is determined by the strength of the earthquake at its epicenter. The acceleration of the ground at any point, as measured in g’s, depends on the magnitude of the earthquake, the distance from the epicenter to that point, the type of material through which the ground motion is transferred from the epicenter to the point, and other factors. For a given earthquake, there is only one magnitude (M), but the ground acceleration (g) is site specific.

1 from the site to produce median peak ground accelerations greater than 0.05g at the energy
2 facility site.

3
4 With respect to interface sources, PGE has stated that the MCE would have a magnitude in the
5 range of M8.3 to M8.8 and, if the event occurred within 65 kilometers of the energy facility site,
6 could cause ground motions of up to 0.18g mean peak acceleration at the energy facility site.

7
8 With respect to inter-slab sources, PGE has stated that the MCE would have a magnitude of
9 M7.3. If the event occurred within 40 to 50 kilometers of the site, it could cause ground motions
10 of up to 0.22g mean peak acceleration at the energy facility site.

11
12 The estimated peak bedrock acceleration at the site for a Maximum Probable Earthquake
13 (“MPE”) with a recurrence interval of 500 years and a mean magnitude of M7.25 is 0.21g.
14 Typical probabilistic analyses combine ground shaking hazards from all sources rather than
15 identifying MPE magnitudes for individual sources. About 80 percent of the total hazard
16 contribution for this frequency of exceedance is generated by the subduction sources (primarily
17 the interface source) and 20 percent of the hazard contribution is from the crustal sources.

18
19 Based on PGE’s preliminary geotechnical studies, the most significant potential seismic hazards
20 at the energy facility site are ground shaking, liquefaction⁴, lateral spreading, and subsidence.
21 PGE would prepare estimates of ground shaking during final design of the energy facility.

22
23 Preliminary studies suggest that potentially liquefiable soils underlie the energy facility site.
24 PGE would prepare a complete liquefaction evaluation after completing additional subsurface
25 explorations at the site. Due to the proximity of Bradbury Slough and the Columbia River to the
26 energy facility site, liquefaction-induced lateral spreading would be likely without some form of
27 ground densification or ground improvement. Likewise, post-liquefaction subsidence could also
28 occur without ground treatment.

29
30 If the engineering evaluation indicates that these hazards are likely to occur during the design for
31 ground motions, PGE proposes remedial treatment of the potentially liquefiable layers.
32 Remedial treatment may include such actions as draining the water from the pores of the soil or
33 densifying the soil so that the soil particles are in a configuration that minimizes the volume of
34 inter-particle pores.

35
36 Due to the flat topography of the energy facility site and the adjacent water and gas pipelines, the
37 likelihood of seismically-induced landslides is low. Additionally, the energy facility site is
38 located about 60 miles upriver from the Pacific Ocean. Therefore, the risk of tsunami inundation
39 at the energy facility site is low.

40

⁴ Liquefaction is the process by which ground shaking causes individual soil particles to shift in a way that decreases the volume of the pores between particles. As the volume decreases, water trapped in the pores increases in pressure. As this phenomenon proceeds, soil particles originally supported by contact with adjacent soil particles become supported by a film of high-pressure water. The high-pressure water effectively acts like a lubricant, decreasing the strength of the soil and its capacity to support buildings.

1 Earthquake-generated waves (seiches) within the Columbia River or Bradbury Slough are not
2 expected to exceed the height of the levee at the energy facility site. Therefore, seiche risk is
3 low.

4
5 There are no mapped active crustal faults located within 6 miles of the energy facility site.
6 Furthermore, the deep alluvial deposits underlying the energy facility site would likely mask any
7 surface manifestation of fault rupture or displacement. The risk of fault rupture is very low.
8

9 With respect to the proposed natural gas pipeline, PGE states: (1) the proposed energy facility
10 would be located within 1,000 feet of the existing natural gas supply pipeline for the Beaver
11 Generating Plant; (2) the ground between the existing pipeline and the proposed energy facility is
12 essentially flat (elevation varying from 16 to 18 feet); and (3) based on previous explorations, the
13 subsurface materials consist of medium dense, sandy fill.
14

15 With respect to the proposed transmission lines that will follow the existing Port Westward to
16 BPA Allston Substation to Trojan transmission line corridors, PGE states: (1) the existing
17 transmission lines have operated without problems since installation in the early 1970's; (2) the
18 geology through the corridors consists of basalts and inter-bedded marine sediments, with
19 variable thickness of decomposed overburden soil; (3) the corridors cross several streams and
20 traverse moderate to steeply sloping terrain; and (4) the new transmission line would be subject
21 to the same geologic hazards as the existing transmission line.
22

23 PGE conducted a literature search for landslide hazards along the transmission line corridors. A
24 review of landslide activity resulting from exceptionally heavy rainfall during the winter of
25 1996-1997 found that the Federal Emergency Management Agency identified one large landslide
26 that occurred on a county road about 250 to 500 feet downhill from the existing transmission
27 lines. Other slides occurred along U.S. Highway 30 near Trojan. No transmission lines were
28 impacted by slides.
29

30 **Facility Design for Seismic Hazards**

31 Potentially liquefiable soil layers could result in lateral spreading or subsidence at the energy
32 facility site. Based on preliminary studies, PGE anticipates these risks could be mitigated by
33 installation of stone columns at the energy facility site. Stone columns consist of compacted,
34 crushed rock that is placed underground using a crane-mounted, vibratory probe. The 3-foot to
35 4-foot diameter columns are installed through the potentially liquefiable layers in a grid pattern.
36

37 The benefits of the stone columns are twofold. First, installation of the columns would cause
38 densification of the native loose sands and silts. Second, the columns would act to stiffen the
39 compressible, soft silt layers, which helps reduce settlement under static loads. Therefore, a mat
40 foundation could support the lighter structures for the proposed energy facility. Stone columns
41 would support the mat foundation. Heavily loaded structures that cannot be founded on mat
42 foundations over stone columns could be supported on deep foundations bearing in dense sands
43 below the level of potentially liquefiable soil.
44

1 The ground shaking hazard would be addressed by use of the ground response spectra. The
2 structural engineer would design the facilities to resist lateral base shear based on the spectral
3 values. If the spectral values were found to be lower than the Oregon Structural Building Code
4 values, PGE would build the facility to the code values.

5
6 Based on preliminary geotechnical explorations, the most significant soil stability issue at the
7 proposed energy facility site involves potential seismic liquefaction and lateral spread at the site.
8 In general, potentially liquefiable soils are located from 10 to 50 feet beneath the site. The
9 shallow surface soils consist of medium dense sand fill.

10
11 For the new transmission line, PGE would use the existing subsurface information from design
12 and construction of the existing transmission line as much as practicable.

13
14 **Geotechnical Investigation.** PGE would conduct a geotechnical investigation before final
15 design of the proposed facility. The geotechnical investigation would include the following
16 tasks:

17
18 Task One. Drill three to four exploratory borings to a depth of 125 feet at the energy
19 facility site. The borings would be drilled under locations for the heavily loaded turbine
20 and heat-recovery structures. Standard penetration tests would be performed at 2.5- and
21 5-foot intervals, depending on the depth of sampling. Thin-wall tube samples would be
22 obtained in fine-grained layers, if encountered.

23
24 Task Two. Perform 8 cone penetrometer tests (“CPT”) to a depth of 100 feet each at the
25 energy facility site. The CPT tests would serve three purposes. First, the probes would
26 provide additional subsurface information for the roughly 19-acre energy facility site.
27 Second, PGE anticipates that some form of ground improvement (densification) at the
28 energy facility site would mitigate the liquefaction and lateral spread hazards. PGE can
29 compare the CPT probes before ground improvement with CPT probes after ground
30 improvement to assess the effectiveness of the densification program. Third, a geophone
31 attached to the CPT probe is capable of measuring the shear wave velocity profile of the
32 soil layers. PGE would use these data to evaluate potential soil amplification of bedrock
33 ground motion.

34
35 Task Three. Perform laboratory testing to evaluate the liquefaction susceptibility of the
36 soils at the energy facility site. Specific tests would include eight mechanical gradations,
37 eight Atterberg limits, and natural water contents on all retained samples.

38
39 Task Four. Assess ground response and seismic hazards for the facility. This work
40 would include the following:

- 41
42 · Evaluate the ground response to bedrock motions for the MCE and MPE
43 events. This would include an estimate of potential soil amplification or
44 attenuation and an evaluation of liquefaction and lateral spread. PGE would
45 perform the analyses using the computer program “SHAKE.” PGE would

1 compare the results from the analyses with existing studies regarding the
2 dynamic behavior of similar soil types subjected to earthquake ground
3 motions.
4

5 · If the analyses indicate earthquake-induced liquefaction and lateral spread
6 were likely to occur, PGE would evaluate ground improvement techniques to
7 mitigate this hazard. Ground modification could include vibro-replacement
8 stone columns or vibro-compaction to densify the loose, granular zones; and
9 possibly soil-cement columns under heavily loaded structures if fine-grained
10 layers were present at the energy facility site. PGE would incorporate design
11 and/or performance criteria for ground improvement.
12

13 · PGE would develop ground response spectra for structural design. If the
14 energy facility requires ground improvement, PGE would develop the
15 response spectra assuming post-improvement densities and dynamic soil
16 properties (shear wave velocities and shear moduli). PGE would assume these
17 values based on experts' experience with similar soil types and the expected
18 improvement to soil density. PGE would compare site-specific response
19 spectra to Oregon Building Code target spectra.
20

21 · PGE would develop foundation criteria for various structures of the facility.
22 Criteria could include allowable bearing capacities and estimated settlements,
23 piling support (if needed), static and dynamic lateral earth pressures, and
24 uplift pressures.
25

26 · If subsurface information were not available for the location of transmission
27 line towers, PGE would drill exploratory borings at critical locations during
28 final design.
29

30 · PGE would use the geotechnical investigations proposed for the energy
31 facility site to assess ground conditions for the natural gas pipeline.
32

33 The Council adopts the following conditions in the site certificate:
34

- 35 (1) **The Certificate Holder shall design, engineer and construct the facility to**
36 **avoid dangers to human safety presented by seismic hazards affecting the site**
37 **that are expected to result from all maximum probable seismic events. In no**
38 **event shall the recommended seismic design parameters be any less than**
39 **those prescribed by the Oregon Uniform Building Code. As used in this**
40 **condition, "seismic hazard" includes ground shaking, landslide, liquefaction,**
41 **lateral spreading, tsunami inundation, fault displacement, and subsidence.**
42
- 43 (2) **If the Certificate Holder does not have subsurface information for design of**
44 **the transmission lines that is acceptable to the Office and the Oregon**
45 **Department of Geology and Mineral Industries ("DOGAMI"), then the**

1 Certificate Holder shall drill exploratory borings at critical locations during
2 final design of the proposed transmission lines.

- 3
- 4 (3) Before beginning construction of the facility, the Certificate Holder shall
5 provide the Office and DOGAMI with a report containing results of
6 geotechnical investigations and recommendations for the design of the energy
7 facility, transmission lines and other related or supporting facilities.
8
- 9 (a) The Certificate Holder shall prepare the report consistent with the
10 study designs detailed in the Section D.5 of the Final Order and
11 Section H.3 of the Application for a Site Certificate (“ASC”).
12
- 13 (b) If DOGAMI is not able to review the reports, the Office shall arrange,
14 in consultation with DOGAMI, for an independent review of the
15 report by a qualified registered geologist.
16
- 17 (c) If the Certificate Holder begins construction of the Port Westward to
18 BPA Allston Substation Transmission Line before beginning
19 construction of other parts of the facility, Condition (3) shall apply
20 only to the Port Westward to BPA Allston Substation Transmission
21 Line as long as it is the only part of the facility under construction.
22
- 23 (4) In addition to, or concurrent with Condition (3), before beginning
24 construction within the City of Rainier's Watershed zone, the Certificate
25 Holder shall submit to the City of Rainier, the Office and DOGAMI a
26 geotechnical report prepared by a registered engineer establishing that it can
27 safely accomplish any construction in a known slide hazard area, flood
28 hazard area, or drainage way, or on slopes exceeding 20 percent in that zone.
29
- 30 (5) If the geotechnical investigation reveals evidence that is not described in the
31 ASC, the Certificate Holder shall revise the facility design parameters to
32 comply with appropriate Uniform Building Code requirements.
33
- 34 (6) The Certificate Holder shall notify the Office, the State Building Codes
35 Division and DOGAMI promptly if site investigations or trenching reveals
36 that subsurface conditions differ significantly from those described in the
37 ASC. After the Office receives the notice, the Council may require the
38 Certificate Holder to consult with DOGAMI and the Building Codes Division
39 and to propose mitigation actions.
40
- 41 (7) The Certificate Holder shall notify the Office, the Building Codes Division
42 and DOGAMI promptly if shear zones, artesian aquifers, deformations, or
43 clastic dikes are found at or in the vicinity of the facility site.
44

1 **Site Characterization—Geological and Soils Hazards**

2 PGE evaluated non-seismic or aseismic geologic hazards that could adversely affect, or be
3 aggravated by construction or operation of the proposed energy facility and its related or
4 supporting facilities. The evaluation focused on geologic hazards, such as settlement, landslides,
5 groundwater, flooding, and erosion.
6

7 Settlement. The proposed energy facility site is underlain by loose granular soil and soft,
8 fine-grained soil of variable thickness. These soils would be expected to settle under the
9 weight of the proposed facilities. For this reason and for seismic hazard reasons, heavily
10 loaded structures at the site may require deep foundation support.
11

12 Landslides. Due to the flat topography at the energy facility site, the risk of landslides is
13 low. Along the transmission line corridor, the risk of landslides may be greater,
14 particularly during periods of heavy rainfall.
15

16 Groundwater. High groundwater can impose buoyant forces on buried utilities and
17 structures founded below the static groundwater level. Buoyant forces can be balanced
18 by proper design of buried structures. The groundwater level at the energy facility site is
19 about 13 feet below the surface of the dredged sand fill and is likely to be significantly
20 influenced by the water levels in the adjacent Bradbury Slough and Columbia River.
21

22 Flooding. The energy facility site is protected from flooding by a series of levees. The
23 levees reach an elevation of about 17.5 feet, which is 4.7 feet higher than the predicted
24 flood level for a 100-year flood (U.S. Army, Corps of Engineers, 1978). Risk of flood
25 damage is low.
26

27 Erosion. Soil erosion typically results from the uncontrolled flow of surface water across
28 a site or from high winds acting on silty soils. Due to the relatively flat topography at the
29 energy facility site, surface erosion from water flow could be controlled easily. The soils
30 at the ground surface are predominantly sand fills that have a low susceptibility to wind
31 erosion. Additionally, the undeveloped areas around the energy facility site would be
32 covered with vegetation once construction is complete. Although the footprint of
33 individual towers would be small, sloping terrain along the corridor for the transmission
34 lines would pose more of a challenge for erosion control.
35

36 **Facility Design for Geological and Soils Hazards**

37 Geologic and soils hazards are those that occur in the absence of an earthquake-triggering event.
38 Such hazards may include settlement, landslides, groundwater, flooding, and erosion. PGE has
39 proposed mitigating for these potential hazards with respect to the proposed energy facility and
40 its related or supporting facilities as follows:
41

42 Settlement. PGE would mitigate the risk of settlement (differential) through the use of a
43 mat foundation for the energy facility. For heavily loaded structures, PGE would
44 minimize settlement through the use of deep foundations. For related or supporting
45 facilities and structures supported on shallow foundations, PGE’s design team would use

1 a conservative estimate of total and differential settlement, considering the influence of
2 ground improvement. If needed, PGE would design flexible connections to
3 accommodate the anticipated settlement.
4

5 Landslides. Due to the flat topography at the energy facility site, the risk of landslides is
6 low. PGE proposes no mitigation for landslides at the energy facility site. With respect
7 to the transmission line corridor, PGE would use subsurface information from design and
8 construction of the existing transmission lines as much as practicable. If subsurface
9 information were not available, PGE would drill exploratory borings at critical locations
10 during final design.
11

12 Groundwater. PGE would estimate the magnitude of buoyant loads based on high
13 groundwater levels from piezometers. PGE would either found buried utilities above the
14 groundwater level in the sandy fill or it would design them to have adequate backfill load
15 to resist uplift forces.
16

17 Flooding. The energy facility site is protected from flooding by a series of levees. The
18 tops of the levees are at an elevation of about 17.5 feet, which is 4.7 feet higher than the
19 predicted flood level for a 100-year flood (USACOE, 1978). Risk of flood damage is
20 low. PGE proposed no mitigation. Along the transmission corridor, PGE would locate
21 transmission towers on high ground wherever possible.
22

23 Erosion. Due to the relatively flat topography at the energy facility site, surface erosion
24 from water flow could be controlled easily. The soils at the ground surface are
25 predominantly sand fills that have a low susceptibility to wind erosion. Erosion is more
26 of a concern along the corridor for the transmission lines, but PGE would have to
27 conform to the requirements of the Erosion and Sediment Control Plan of its NPDES
28 1200-C permit for control of storm water runoff during construction of any part of the
29 facility.
30

31 The Council adopts the following condition in the site certificate:
32

33 **(8) The Certificate Holder shall design, engineer and construct the facility to**
34 **avoid dangers to human safety presented by non-seismic or aseismic hazards**
35 **affecting the site. As used in this condition, “non-seismic or aseismic**
36 **hazards” includes settlement, landslides, groundwater, flooding, and erosion.**
37

38 **Conclusion**

39 The Council finds that PGE meets the structural standard, OAR 345-022-0020.
40

41 **D.6. SOIL PROTECTION, OAR 345-022-0022**

42 To issue a site certificate, the Council must find that the design, construction and
43 operation of the facility, taking into account mitigation, are not likely to result in a
44 significant adverse impact to soils including, but not limited to, erosion and

1 chemical factors such as salt deposition from cooling towers, land application of
2 liquid effluent, and chemical spills.
3

4 **Discussion**

5 The Council considers adverse impacts to soils because of potential related impacts to
6 agricultural and forest land uses, native vegetation, fish and wildlife habitat, and water quality.
7 Relevant under this standard are the facility's potential impacts such as erosion, compaction,
8 mass wasting, slumping, chemical spills, and salt deposition resulting from cooling tower
9 evaporation.
10

11 The analysis area for the soil protection standard is the area within the site and on adjacent farm
12 properties. The Council could consider cooling tower drift impacts over a larger area based on
13 wind and weather patterns in the area.
14

15 **Energy Facility Site.** PGE would locate the energy facility on a large alluvial floodplain along
16 the south shore of the Columbia River, about five miles north of Clatskanie, Oregon. The
17 floodplain terrace is about 10 miles long from east to west and varies from one to three miles
18 wide. The elevation of the native alluvium varies from two to six feet. The area is protected
19 from flooding by an engineered levee at elevation 17.6 feet. The proposed energy facility would
20 be located adjacent to the levee on existing dredged fill at an elevation of 18 feet.
21

22 Recent subsurface borings at the energy facility site encountered dredged sand fill to a depth of
23 seven to 11.5 feet. The U.S. Department of Agriculture ("USDA") has mapped this soil
24 (dredged fill) as Udipsamment, or somewhat excessively drained soils that have formed in recent
25 dredge spoils. Underlying this soil to a depth of at least 150 feet were inter-layered deposits of
26 slightly clayey, silty fine to medium sand. Water well drill holes in the vicinity indicate that the
27 alluvial deposits are at least 300 feet deep.
28

29 The USDA has classified the soil in the vicinity of the energy facility site according to soil order,
30 land capability, potential prime farmland, and hydric (wetland) interpretation. The soil order is
31 Entisol, a soil found mainly in recently deposited materials that are too young to have developed
32 soil horizons. The land capability is Class VI, a class with severe limitations, making it
33 unsuitable for cultivation, but capable of serving as pasture and similar low-intensity uses. The
34 energy facility site and vicinity contains no soil that the USDA lists as potential prime farmland.
35 The USDA estimates that one-fourth to one-half of the soils in the vicinity of the energy facility
36 are hydric.
37

38 The proposed energy facility site is currently undeveloped and is zoned as Resource Industrial
39 Planned Development ("RIPD"). It is located about one-half mile northeast of the existing PGE
40 Beaver Generating Plant and about one mile northeast of the Summit Project site. Agricultural
41 uses nearest the proposed energy facility site are about three-fourths of a mile to the south and
42 consist of a poplar grove, crop planting, and pastureland grazing. There are no other significant
43 agricultural demands being placed on the soils.
44

1 PGE intends to install crushed rock columns in a grid pattern below the ground surface to
2 improve the seismic resistance of the subsurface soil deposits and to improve foundation support
3 for the energy facility, as discussed more fully in the discussion of the structural standard,
4 Section D.5. Installation of these crushed rock columns should not adversely affect the dredged
5 fill or native soil deposits.

6
7 **Related or Supporting Pipelines.** The water and gas pipelines are adjacent to the energy
8 facility site and on the same soils as the energy facility.

9
10 **Related or Supporting Electric Transmission Line.** The proposed electric transmission line
11 would parallel the existing Port Westward to BPA Allston Substation-Trojan transmission line,
12 covering a distance of about 20 miles. The majority of the line traverses the foothills of the
13 Coast Range. The land is moderately to steeply sloping.

14
15 The soils along the bulk of the existing and proposed transmission lines are derived from
16 weathering of igneous basalt and marine sandstone and siltstone. The soil along a small portion
17 of the line near the proposed energy facility is sand and silt alluvium, as described above.

18
19 The USDA soil orders along the transmission line route are Entisols, Inceptisols, and Ultisols.
20 Entisols are located on the alluvial floodplain near the proposed energy facility site. Inceptisols
21 are soils that are beginning to form and have weakly developed soil profiles. They are common
22 in the Coast Range, where they have dark surface horizons enriched with organic matter.
23 Ultisols are red soils with strongly developed subsoil horizons of clay. They are mostly
24 paleosols (old soils) that formed long ago when the climate was warmer and wetter.

25
26 The proposed transmission line extends from the proposed energy facility site to Trojan through
27 land predominantly zoned as Primary Forest. Short segments of the transmission line route
28 traverse land zoned as Rural Residential, Forest Agriculture, Primary Agriculture, and Resource
29 Industrial Planned Development. The land zoned Primary Agriculture is located near the
30 proposed energy facility, and the proposed transmission line would cross about one-half mile of
31 this land.

32
33 The Council adopts the following condition in the site certificate.

- 34
35 (1) **Upon completion of construction in an area, the Certificate Holder shall use**
36 **native seed mixes to restore vegetation to the extent practicable and shall**
37 **landscape portions of the site disturbed by construction in a manner**
38 **compatible with the surroundings and proposed use. Conditions (1) through**
39 **(6) shall apply to all soil disturbing activities, including maintenance, repair**
40 **or reconstruction of facilities.**

41
42 **Construction:**

43 **Wind and Water Erosion.** During construction of the facility, potential adverse impacts to on-
44 site soils could result from wind or water erosion. PGE would adhere to the requirements of its
45 NPDES 1200-C permit to minimize such impacts. The NPDES 1200-C permit includes a

1 detailed Erosion and Sediment Control Plan that includes measures designed to contain soil and
2 construction equipment within the energy facility footprint and along the corridors of the related
3 or supporting facilities.

4
5 Energy facility site construction would involve clearing and grubbing, excavation and
6 embankment, utility and outfall excavation and installation, building construction, and creation
7 of a gravel parking area. To control the transportation of soil outside the site, PGE would install
8 gravel construction entrances before clearing and grubbing and other earthwork operations.

9
10 The proposed transmission line corridors run across hilly terrain with slopes generally in the
11 range of 3 percent to 30 percent, with isolated stretches of up to 60 percent. Accordingly,
12 erosion prevention and sediment control in the transmission line corridor is crucial.

13
14 To control the loss of soil to water erosion, PGE would use perimeter sediment control measures,
15 such as sediment fences, straw wattles, bio-filter bags, rock check dams, sediment basins or
16 traps, and gravel filter berms to contain soil within the site boundaries. To control the loss of soil
17 to wind erosion, PGE would apply water or mulch to exposed soil.

18
19 During wet weather conditions, PGE would use temporary gravel or hay mulches, as required.
20 In the event of prolonged wet weather conditions, PGE would limit the size and extent of
21 disturbed areas or require confining vehicles or operations to specified areas. It would also
22 protect soil stockpiles with mulch and plastic sheeting, as required.

23
24 After completing construction in an area, PGE would revegetate the disturbed area with
25 temporary and permanent native seed mixes and apply mulch to the area. In areas with heavily
26 compacted soils, before revegetation PGE would scarify the soil by such methods as tilling,
27 discing, or rotovating.

28
29 PGE proposes to minimize disturbance within the transmission line corridors and make use of
30 existing access roads to the extent possible. PGE would ensure that areas cleared and grubbed
31 for tower construction and materials stockpiles were kept to the smallest possible size.

32
33 The Council adopts the following conditions in the site certificate:

34
35 **(2) The Certificate Holder shall employ the following measures to control soil**
36 **erosion and sediment runoff by water and wind erosion:**

37
38 **(a) Avoid excavation and other soil disturbances beyond that necessary**
39 **for construction of the facility or confine equipment use to specific**
40 **areas.**

41
42 **(b) Remove vegetation only as necessary.**

43
44 **(c) Apply water or mulch, as necessary, for wind erosion control during**
45 **construction.**

1
2 (d) **Revegetate those construction areas that will no longer be used.**

3
4 (e) **Use temporary erosion and sediment control measures, such as**
5 **sediment fences, straw wattles, bio-filter bags, mulch, permanent and**
6 **temporary seeding, sediment traps and/or basins, rock check dams or**
7 **gravel filter berms, and gravel construction entrances, and maintain**
8 **these features throughout construction and restoration to reduce the**
9 **potential for soil erosion and sediment runoff.**

10
11 (f) **Protect soil stockpiles with mulch and plastic sheeting.**

12
13 **Soil Compaction.** Soil compaction was not identified as a limitation for any of the soils in the
14 analysis area. However, most soils can experience some degree of soil compaction under wet
15 conditions.

16
17 The Council adopts the following condition in the site certificate:

18
19 (3) **If excessively wet conditions occur during construction, the Certificate**
20 **Holder shall limit construction activities during such periods to the degree**
21 **practicable in areas susceptible to soil compaction.**

22
23 **Soil Protection Monitoring Program.** PGE would inspect all erosion and sediment control
24 measures weekly during active construction and every two weeks in inactive areas. PGE would
25 also inspect both active and inactive sites daily during periods when one-half inch or more of
26 rain has fallen in a 24-hour period. The purpose of these inspections would be to evaluate
27 whether construction-related impacts to soils are adequately addressed by the applicable
28 mitigation measures.

29
30 PGE would remove trapped sediment when storage capacity had been reduced by 50 percent and
31 would place the sediment in an upland area certified by a qualified wetland specialist. PGE
32 would also observe and record the color and turbidity of water within 35 feet upstream and
33 downstream from locations where surface water from the construction site enters the receiving
34 stream. It would note whether any sheen or floating matter were present and describe any
35 apparent color, the turbidity of the discharge, and any observable difference between the water
36 being discharged and the receiving stream.

37
38 If, in the course of these inspections and observations, PGE were to discover that any of the
39 erosion and sediment control measures it had implemented were ineffective, PGE would
40 implement, maintain, and monitor effective strategies and measures.

41
42 After completing construction in an area, PGE would monitor the area until soils were stabilized.
43 The purpose of this monitoring program would be to evaluate whether construction-related
44 impacts to soils have been adequately addressed by the mitigation measures described in the

1 Erosion and Sediment Control Plan. As necessary, PGE would implement follow-up measures,
2 such as scarification and reseeded, to address any remaining impacts.

3
4 The Council adopts the following conditions in the site certificate:

- 5
6 **(4) After completing construction in an area, the Certificate Holder shall**
7 **monitor the construction area for a period of 12 months to evaluate whether**
8 **construction-related impacts to soils are being adequately addressed by the**
9 **mitigation procedures described in the Sediment Erosion and Control Plan.**
10 **It shall submit its quality assurance measures to the Office for approval**
11 **before beginning monitoring.**
- 12
13 **(5) After completing construction in an area, the Certificate Holder shall use the**
14 **results of the monitoring program in Condition (4) to identify remaining soil**
15 **impacts associated with construction that require mitigation. As necessary,**
16 **the Certificate Holder shall implement follow-up restoration measures to**
17 **address those remaining impacts and shall report in a timely manner to the**
18 **Office what measures it has taken.**
- 19
20 **(6) The Certificate Holder shall remove trapped sediment when the capacity of**
21 **the sediment trap has been reduced by 50 percent and shall place such**
22 **sediment in an upland area certified by a qualified wetland specialist.**

23
24 **Chemical Spills.** During construction of the facility, potential adverse impacts to on-site soils
25 could result from chemical spills. PGE would adhere to the requirements of its NPDES 1200-C
26 Permit to minimize such impacts. Conditions in Section D.3 also address this issue.

27 28 **Operation**

29 During the life of the facility, structures, parking lots, tower footings and other features would
30 permanently cover soils. PGE would revegetate areas disturbed by construction and left
31 uncovered after construction of the facility.

32
33 **Water Erosion.** During operation of the facility, it is unlikely that there would be adverse
34 impacts to on-site soils from water erosion because PGE would revegetate any disturbed areas
35 that are not permanently covered and would divert storm water to pervious surfaces to percolate
36 into the ground.

37
38 **Chemical Spill Containment.** PGE proposes to handle, store and monitor chemicals, including
39 sulfuric acid, neutralizing amine, sodium hydroxide, oxygen scavenger, corrosion/scale inhibitor,
40 and lubricants, at the energy facility site.

41
42 The Council adopts the following conditions in the site certificate:

- 43
44 **(7) The Certificate Holder shall contain all fuel and chemical storage in paved**
45 **spill containment areas with a curb.**

1
2 **(8) The Certificate Holder shall design all inside spill containment areas to hold**
3 **at least 110 percent of the volume of liquids stored within them.**

4
5 **(9) The Certificate Holder shall design all spill containment areas located**
6 **outdoors to hold at least 110 percent of the volume of liquids stored within**
7 **them, together with the volume of precipitation that might accumulate**
8 **during the 100-year return frequency storm.**

9
10 With the conditions, it is unlikely there would be potential adverse impacts to on-site soils from
11 chemical spills.

12
13 **Cooling Tower Drift.** PGE's analysis of cooling tower plume shows there would be no
14 potential adverse impacts warranting mitigation from cooling tower operation. PGE's modeling
15 indicates that the estimated salt deposition rate in the vicinity of the proposed energy facility
16 would be less than 3 kg/km²/month. This rate is well below the estimated ambient salt
17 deposition rate of 183 kg/km²/month. Salt deposition in the immediate vicinity of the energy
18 facility would be significantly higher than 3 kg/km²/month, but it would not affect agricultural
19 lands.

20
21 The Council adopts the following condition in the site certificate:

22
23 **(10) During operation, the Certificate Holder shall minimize drift from the**
24 **cooling towers through the use of high efficiency drift eliminators that allow**
25 **no more than 0.002 percent drift.**

26
27 **Conclusion**

28 The Council finds that PGE meets the soil protection standard, OAR 345-022-0022.

29
30 **D.7. PROTECTED AREAS, OAR 345-022-0040**

31 (1) Except as provided in sections (2) and (3), the Council shall not issue a site
32 certificate for a proposed facility located in the areas listed below. To issue a
33 site certificate for a proposed facility located outside the areas listed below, the
34 Council must find that, taking into account mitigation, the design, construction
35 and operation of the facility are not likely to result in significant adverse impact
36 to the areas listed below. Cross-references in this rule to federal or state statutes
37 or regulations are to the version of the statutes or regulations in effect as of
38 March 29, 2002:

39 (a) National parks, including but not limited to Crater Lake National Park
40 and Fort Clatsop National Memorial;

41 (b) National monuments, including but not limited to John Day Fossil Bed
42 National Monument, Newberry National Volcanic Monument and
43 Oregon Caves National Monument;

- 1 (c) Wilderness areas established pursuant to The Wilderness Act, 16 U.S.C.
- 2 1131 et seq. and areas recommended for designation as wilderness areas
- 3 pursuant to 43 U.S.C. 1782;
- 4 (d) National and state wildlife refuges, including but not limited to Ankeny,
- 5 Bandon Marsh, Baskett Slough, Bear Valley, Cape Meares, Cold
- 6 Springs, Deer Flat, Hart Mountain, Julia Butler Hansen, Klamath Forest,
- 7 Lewis and Clark, Lower Klamath, Malheur, McKay Creek, Oregon
- 8 Islands, Sheldon, Three Arch Rocks, Umatilla, Upper Klamath, and
- 9 William L. Finley;
- 10 (e) National coordination areas, including but not limited to Government
- 11 Island, Ochoco and Summer Lake;
- 12 (f) National and state fish hatcheries, including but not limited to Eagle
- 13 Creek and Warm Springs;
- 14 (g) National recreation and scenic areas, including but not limited to Oregon
- 15 Dunes National Recreation Area, Hell's Canyon National Recreation
- 16 Area, and the Oregon Cascades Recreation Area, and Columbia River
- 17 Gorge National Scenic Area;
- 18 (h) State parks and waysides as listed by the Oregon Department of Parks
- 19 and Recreation and the Willamette River Greenway;
- 20 (i) State natural heritage areas listed in the Oregon Register of Natural
- 21 Heritage Areas pursuant to ORS 273.581;
- 22 (j) State estuarine sanctuaries, including but not limited to South Slough
- 23 Estuarine Sanctuary, OAR Chapter 142;
- 24 (k) Scenic waterways designated pursuant to ORS 390.826, wild or scenic
- 25 rivers designated pursuant to 16 U.S.C. 1271 et seq., and those
- 26 waterways and rivers listed as potentials for designation;
- 27 (L) Experimental areas established by the Rangeland Resources Program,
- 28 College of Agriculture, Oregon State University: the Prineville site, the
- 29 Burns (Squaw Butte) site, the Starkey site and the Union site;
- 30 (m) Agricultural experimental stations established by the College of
- 31 Agriculture, Oregon State University, including but not limited to:
- 32 Coastal Oregon Marine Experiment Station, Astoria
- 33 ***
- 34 (n) Research forests established by the College of Forestry, Oregon State
- 35 University, including but not limited to McDonald Forest, Paul M. Dunn
- 36 Forest, the Blodgett Tract in Columbia County, the Spaulding Tract in
- 37 the Mary's Peak area and the Marchel Tract;
- 38 (o) Bureau of Land Management areas of critical environmental concern,
- 39 outstanding natural areas and research natural areas;
- 40 (p) State wildlife areas and management areas identified in OAR chapter
- 41 635, Division 8.
- 42
- 43 (2) Notwithstanding section (1), the Council may issue a site certificate for a
- 44 transmission line or a natural gas pipeline or for a facility located outside a
- 45 protected area that includes a transmission line or natural gas or water pipeline

as a related or supporting facility located in a protected area identified in section (1), if other alternative routes or sites have been studied and determined by the Council to have greater impacts. Notwithstanding section (1), the Council may issue a site certificate for surface facilities related to an underground gas storage reservoir that have pipelines and injection, withdrawal or monitoring wells and individual wellhead equipment and pumps located in a protected area, if other alternative routes or sites have been studied and determined by the Council to be unsuitable.

- (3) The provisions of section (1) do not apply to transmission lines or natural gas pipelines routed within 500 feet of an existing utility right-of-way containing at least one transmission line with a voltage rating of 115 kilovolts or higher or containing at least one natural gas pipeline of 8 inches or greater diameter that is operated at a pressure of 125 psig.

Discussion

The analysis area for protected areas is the area within 20 miles of the proposed energy facility site, except where an assessment of visibility is required under DEQ regulations. Pursuant to OAR 345-022-0040(3), the transmission line right-of-way is not subject to the protected areas standard because it would be routed within 500 feet of an existing utility right-of-way containing a transmission line with a voltage rating of 115 kilovolts or higher.

The protected areas shown in Table D.7-1 are within the analysis area. All of the protected areas are 2 miles or more from the proposed energy facility site, and the energy facility would not be located within any protected area.

**TABLE D.7-1
Direction and Distance to Protected Areas from Energy Facility Site**

Protected Area	Direction and Distance from Energy Facility Site
Abernathy Salmon Cultural Center, Washington	NNE, 2 miles
Beaver Creek State Fish Hatchery, Washington	NNW, 6 miles
Elochman Fish Hatchery, Washington	NNW, 7 miles
Blodgett Tract, Oregon	SW, 8 miles
Bradley State Scenic View Point, Oregon	West, 10 miles
Gnat Creek Fish Hatchery, Oregon	West, 14 miles
Big Creek Fish Hatchery, Oregon	West, 19 miles
Julia Butler Hansen National Wildlife Refuge, Washington	NW, 9 miles
Lewis and Clark Wildlife Refuge, Oregon	NW, 11 miles
Seaquest State Park, Washington	NNE, 16 miles
Fallert Creek Hatchery, Washington	SE, 18 miles
Kalama Falls Hatchery, Washington	SE, 18 miles

The Council finds that pipelines for water, reclaimed water and natural gas would be buried and distant from protected areas and would have no adverse impact on protected areas.

1
2 **Noise.** The nearest protected area, the Abernathy Salmon Cultural Center in Washington, is
3 about 10,500 feet from the proposed energy facility site. The noise assessment prepared for the
4 proposed energy facility showed the predicted noise level would be at most a 2 dBA increase to
5 35 dBA at the nearest assessment site on the Washington side of the Columbia River. That
6 assessment site is about 5,700 feet from the proposed energy facility site. Oregon DEQ
7 regulations would allow a noise level of 43 dBA at this site. There would be no change in noise
8 levels at the other two assessment sites in Washington, the nearest of which is about 6,250 feet
9 from the proposed energy facility site. The Council finds that noise from the energy facility
10 would not have a significant impact on any protected area.

11
12 **Traffic.** PGE estimates that operation of the proposed energy facility would generate a total of
13 30 daily employee vehicle trips and 10 daily delivery vehicle trips. The greatest impacts would
14 be close to the energy facility, and those impacts would result in only a small change in local
15 traffic. All of the protected areas on the Oregon side of the Columbia River are at least 8 miles
16 from the energy facility site.

17
18 Average trip generation during construction may be 350 daily trips. Traffic resulting from
19 construction activities could create delays during the peak evening hour at some intersections.
20 The protected areas are not near areas affected by traffic. The Council finds that traffic
21 generated by construction and operation of the proposed energy facility would not adversely
22 affect protected areas.

23
24 **Water Use.** The proposed energy facility would obtain water from an existing water right
25 through the Port of St. Helens. Water would be drawn from an existing water intake structure
26 that is located more than 2 miles from the nearest protected area. That protected area is on the
27 Washington side of the Columbia River. The Council finds that use of water by the proposed
28 energy facility would not adversely affect protected areas.

29
30 **Wastewater Disposal.** PGE would route storm water from roofs and paved areas to pervious
31 areas to allow for percolation into the shallow groundwater. The Port of St. Helens would
32 discharge process water from the proposed energy facility into the Columbia River near the
33 energy facility site under an NPDES permit intended to cover such discharges for occupants of
34 the Port Westward Industrial Area. The nearest protected area is 2 miles from the proposed
35 energy facility. The Council finds that wastewater discharge from the proposed energy facility
36 would not adversely affect protected areas.

37
38 **Visual Impacts.** Intervening topography and other natural and domestic features would
39 effectively screen the proposed energy facility from protected areas. Visible vapor plumes from
40 the cooling towers and exhaust stacks would occur during periods of low temperature and high
41 humidity. These plumes would be most visible during the winter months and could be visible at
42 night when the energy facility is illuminated. Because there are other visible plumes resulting
43 from existing industrial and agricultural sites in the area, the Council finds that the energy
44 facility would not significantly alter the visual character of the general area.

1 **Hazardous Materials.** Hazardous materials located at the energy facility site would include
2 solvents, lubricants and water treatment chemicals. Because of the distance to the nearest
3 protected area from the energy facility, the Council finds that the presence of hazardous
4 materials at the energy facility site would not adversely affect protected areas.
5

6 **Conclusion**

7 The Council finds that PGE meets the protected areas standard, OAR 345-022-0040.
8

9 **D.8. FISH AND WILDLIFE HABITAT, OAR 345-022-0060**

10 To issue a site certificate, the Council must find that the design, construction, operation
11 and retirement of the facility, taking into account mitigation, is consistent with the fish
12 and wildlife habitat mitigation goals and standards of OAR 635-415-0025 in effect as of
13 September 1, 2000.
14

15 **Discussion**

16 OAR 635-415-0025 describes six categories of habitat in order of their value. The rule then
17 establishes mitigation goals and corresponding implementation standards for each habitat
18 category.
19

20 **Habitat Categories**

21 Habitat Category 1 is “irreplaceable, essential habitat for a fish or wildlife species,
22 population, or a unique assemblage of species and is limited on either a physiographic
23 province or site-specific basis, depending on the individual species, population or unique
24 assemblage.” The mitigation goal for Habitat Category 1 is “no loss of either habitat
25 quantity or quality.” The implementation standard requires “avoidance of impacts
26 through alternatives to the proposed development action.”
27

28 Habitat Category 2 is “essential habitat for a fish or wildlife species, population, or
29 unique assemblage of species and is limited either on a physiographic province or site-
30 specific basis depending on the individual species, population or unique assemblage.”
31 The mitigation goal for Habitat Category 2, if impacts are unavoidable, is “no net loss of
32 either habitat quantity or quality and to provide a net benefit of habitat quantity or
33 quality.” The implementation standard is “avoidance of impact through alternatives to
34 the proposed development action” or “mitigation of impacts, if unavoidable, through
35 reliable in-kind, in-proximity habitat mitigation to achieve no net loss of either pre-
36 development habitat quantity or quality. In addition, a net benefit of habitat quantity or
37 quality must be provided.”
38

39 Habitat Category 3 is “essential habitat for fish and wildlife, or important habitat for fish
40 and wildlife that is limited either on a physiographic province or site-specific basis,
41 depending on the individual species or population.” The mitigation goal for Habitat
42 Category 3 is “no net loss of either habitat quantity or quality.” The implementation
43 standard is “avoidance of impacts through alternatives to the proposed development
44 action” or “mitigation of impacts, if unavoidable, through reliable in-kind, in-proximity

1 habitat mitigation to achieve no net loss in either pre-development habitat quantity or
2 quality.”

3
4 Habitat Category 4 is “important habitat for fish and wildlife species.” The mitigation
5 goal for Habitat Category 4 is "no net loss in either existing habitat quantity or quality.”
6 The implementation standard is “avoidance of impacts through alternatives to the
7 proposed development action” or “mitigation of impacts, if unavoidable, through reliable
8 in-kind or out-of-kind, in-proximity or off-proximity habitat mitigation to achieve no net
9 loss in either pre-development habitat quantity or quality.”

10
11 Habitat Category 5 is “habitat for fish and wildlife having high potential to become either
12 essential or important habitat.” The mitigation goal for Habitat Category 5, if impacts are
13 unavoidable, is "to provide a net benefit in habitat quantity or quality.” The
14 implementation standard is “avoidance of impacts through alternatives to the proposed
15 development action” or “mitigation of impacts, if unavoidable, through actions that
16 contribute to essential or important habitat.”

17
18 Habitat Category 6 is “habitat that has low potential to become essential or important
19 habitat for fish and wildlife.” The mitigation goal for Habitat Category 6 is "to minimize
20 impacts.” The implementation standard is to “minimize direct habitat loss and avoid
21 impacts to off-site habitat.”

22
23 For Habitat Categories 2, 3 and 4, the certificate holder must report progress towards achieving
24 the mitigation goals and standards on a schedule to which it agrees in consultation with ODFW.
25 The certificate holder must complete the fish and wildlife mitigation measures either before or
26 concurrent with the development action.

27 28 **Habitat in the Analysis Area**

29 The analysis area for fish and wildlife habitat includes, at a minimum, a “base case” analysis area
30 within 300 feet on either side of the proposed transmission line corridor and a similar distance
31 from the proposed energy facility site, water intake/discharge facilities, and temporary
32 construction zone. The analysis area for great blue heron rookeries and raptor nesting sites,
33 including spotted owl and bald eagle nesting sites, at a minimum, is the area within one-quarter
34 mile on either side of any proposed corridor alignment, the energy facility site and the temporary
35 construction zone.

36
37 Habitat Categories 2, 3, 4, and 6 occur within the analysis area. Habitat Category 2 occurs as
38 perennial streams, mainstem perennial river and purple martin nesting habitat. The Columbia
39 River and Bradford Slough are Category 2 habitat for six federally listed, proposed and candidate
40 fish species. Habitat Category 3 occurs as emergent, scrub-shrub, forested, unconsolidated
41 bottom, and open water wetlands; perennial/intermittent streams, and riverine tidal waters. It
42 serves as osprey nesting, Columbia white-tailed deer, and dusky Canada goose habitat. Habitat
43 Category 4 occurs as non-native grassland, deciduous, coniferous and mixed forest, riparian
44 forest, riparian herbaceous/deciduous shrub, clear-cut, tree farms, cropland/pasture, and drainage

1 ditches. It serves as Columbia white-tailed deer and dusky Canada goose habitat. Habitat
2 Category 6 occurs as developed and/or disturbed areas.

3
4 **Potential Impacts – Construction and Operation**

5 Direct Impacts (Habitat Quantity).

6 Construction of the energy facility would take place within and directly affect Habitat
7 Categories 3, 4 and 6. Construction and operation of the facility would not directly affect
8 Habitat Category 2. (ASC, Table P-3).

9
10 Habitat Category 3 Impacts. The energy facility would affect 0.41 acres of Habitat Category 3.
11 Of this impact, 0.38 acres would be permanent and 0.03 acres would be temporary. Impacts
12 would be to palustrine forested/scrub-shrub wetland (0.10 acre) and palustrine emergent wetland
13 (0.31 acre). In addition, less than 0.10 acre of osprey nesting habitat would be affected.

14
15 The transmission line would permanently affect 0.02 acres of Habitat Category 3 palustrine
16 emergent wetlands.

17
18 Habitat Category 4 Impacts. The energy facility footprint would permanently affect about
19 17.5 acres and temporarily affect 3.3 acres of Habitat Category 4. The permanent impacts would
20 result from the energy facility footprint, and the temporary impacts would result from
21 construction of the natural gas and water pipelines. The impacts would be to non-native
22 grassland habitat.

23
24 The transmission line would affect about 192.0 acres of Habitat Category 4. These impacts
25 would be to deciduous, mixed deciduous/conifer forest and mixed conifer forests, as well as to
26 riparian mixed deciduous/conifer forests. Impacts would result from clearing and maintenance
27 activities along the transmission line right-of-way. The impacts resulting from the clearing of
28 the right-of-way would convert forested habitats to a shrub/sapling habitat through removal of
29 taller vegetation that may interfere with the proposed transmission lines.

30
31 Habitat Category 6 Impacts. The energy facility would affect 1.6-acres of Habitat Category 6.
32 This habitat is developed/disturbed.

33
34 Indirect Impacts (Habitat Quality).

35 Indirect effects on habitat quality during construction and operation could occur due to noise,
36 traffic, human activity, maintenance activities, and operation of the energy facility.

37
38 Construction: Construction of the energy facility and the 230 kV electric transmission line could
39 indirectly affect nesting and foraging activity of wildlife, including raptors, great blue heron,
40 dusky Canada goose, Columbia white-tailed deer, and purple martins, if construction takes place
41 during the periods of breeding or rearing, and if it takes place within a “disturbance distance” of
42 nesting or rearing sites. Purple martin nest sites (Habitat Category 2) may be located at or near the
43 water intake structure and could be affected indirectly by construction activities (ASC, page P-6).
44 An artificial osprey nest platform (Habitat Category 3) is located within the “disturbance distance”
45 of the energy facility construction and potentially could be disturbed in the course of two nesting

1 seasons during construction. In addition, northern red-legged frog, western toad, and little willow
2 flycatcher could be affected by construction and operation activities.

3
4 Removal of riparian and upland vegetation along the transmission line right-of-way could also
5 indirectly affect fish and wildlife habitat through loss of foraging and nesting or rearing habitat,
6 erosion and siltation of waterways, and an increase in water temperatures. PGE anticipates that
7 most impacts would be temporary and would occur during construction. However,
8 maintenance practices, such as trimming of vegetation, equipment access, and herbicide
9 application, could also have indirect effects.

10
11 In-water construction on the water intake structure may potentially affect fish habitat through
12 siltation, chemical or petroleum contamination, or fish entrapment in the intake structure.

13
14 Operation: Potential indirect impacts from operation of the facility include noise, cooling tower
15 emissions, transmission line avian electrocution, and maintenance activities along the
16 transmission line right-of-way. Noise from operation of the energy facility would be fairly
17 constant and meet DEQ noise regulations, as well as the Washington Department of Ecology
18 regulations. PGE conducted a noise survey, and the predicted noise level of 37 dBA at the
19 potential bald eagle nesting site would be in compliance with the recommended standard from
20 the U.S. Fish and Wildlife Service (ASC, Exhibit X, page X-1). PGE anticipates that the Canada
21 dusky geese would become accustomed to the increase in noise and human activity associated
22 with the energy facility (ASC, Exhibit P, page P-36).

23
24 Cooling tower emissions could produce ground fogs and salt deposition. PGE does not expect
25 ground level fogging and salt deposition to have significant potential impacts on fish or wildlife
26 habitat (ASC, Exhibit P, page P-32).

27
28 PGE does not expect operation of the 230 kV transmission line to pose a significant hazard to
29 fish and wildlife habitat. The 230 kV transmission line does not represent an electrocution risk
30 for raptors due to the spacing of the conductors and grounded hardware. PGE would design the
31 transmission line to reduce the potential for electrocution of birds.

32
33 All pipelines would be underground and their operation would have low potential to cause
34 adverse impact to habitat.

35
36 Maintenance of the transmission line right-of-way could affect fish and wildlife habitat. The use
37 of herbicide, removal of trees, vehicular traffic, and human activity within the corridor could
38 affect nesting or rearing, foraging, and water quality.

39
40 Water supply for the energy facility would be drawn from the Bradbury Slough through an
41 existing PGE intake facility. No new water right would be needed, because non-potable water
42 from the Columbia River would be supplied under the Port of St. Helens Water Right Permit
43 No. 53677. The facility would withdraw up to 8.3 cfs of a permitted 30 cfs allowable withdrawal
44 (ASC, Exhibit O, O-3).

1 The Council finds that construction and operation of the facility is not likely to result in
2 significant adverse impact to fish and wildlife habitat.

3
4 **Potential Impacts – Retirement**

5 PGE estimated that the useful life of the facility is 30 years. Pursuant to conditions and Council
6 rules, PGE would restore the site to a useful, non-hazardous condition following permanent
7 cessation of construction or operation of the facility. Site restoration would consist primarily of
8 dismantling and removing unneeded equipment and structures. PGE would likely leave electric,
9 gas and water transmission lines in place to serve new uses at the site. (ASC, Exhibit W, page
10 W-1).

11
12 Because the facility would be built and operated in accordance with applicable standards,
13 including the conditions of the site certificate, it is unlikely that soils or groundwater at the site
14 would become contaminated. Proposed conditions in Section D.3 also address this issue. The
15 energy facility site and surrounding lands are zoned Resource Industrial-Planned Development.
16

17 In addition, as required by Council rules, the site certificate will require PGE to submit a
18 retirement plan before permanent shutdown of the facility. The plan must include measures to
19 minimize impacts to fish and wildlife habitat and assure no net loss of habitat quantity or quality
20 with respect to essential or important habitat. For these reasons, the Council finds that retirement
21 of the facility is not likely to result in a significant impact to fish and wildlife habitat.
22

23 **Mitigation**

24 PGE proposed measures to avoid and mitigate for direct and indirect impacts to fish and wildlife
25 areas disturbed by construction, operation, and retirement of the energy facility and the
26 transmission line.
27

28 PGE proposed the following mitigation measures (ASC, Exhibit P, page P-2):
29

- 30 (1) Avoiding construction at the raw water intake pump station during the critical
31 nesting period for purple martins;
- 32 (2) Monitoring for potential great blue heron rookeries within 0.25 mile of the
33 facility, during the appropriate time frame, before beginning construction of the
34 facility and implementing avoidance actions as necessary in consultation with
35 ODFW;
- 36 (3) Monitoring for potential raptor nest sites within 0.25 mile of the facility before
37 beginning construction of the facility and implementing avoidance actions as
38 necessary in consultation with ODFW; and,
- 39 (4) Re-locating an existing osprey nest platform before beginning construction of the
40 facility.
41

42 To minimize significant potential impacts to wildlife habitat, PGE proposed the following
43 mitigation measures:
44

- 1 (1) Using best management practices and erosion and sediment control techniques to
- 2 minimize impacts to water quality, wetlands, and riparian habitat;
- 3 (2) Placing transmission towers outside wetlands to the extent practical;
- 4 (3) Limiting vegetation removal from riparian zones along the right-of-way to only
- 5 what is required to prevent contact with the transmission line and revegetating if
- 6 less than 25 percent canopy coverage exists after clearing;
- 7 (4) Using existing roads for construction and maintenance of the transmission line to
- 8 the greatest extent practical;
- 9 (5) Re-seeding areas of unavoidable soil disturbance; and,
- 10 (6) Implementing appropriate actions to prevent unavoidable spills and waste
- 11 materials from entering waterways or wetlands.
- 12

13 To mitigate the unavoidable impacts of construction on 0.43 acre of emergent/scrub-shrub
14 wetlands and about 19 acres of non-native grassland habitat, PGE would protect 19 acres of on-
15 site emergent wetland from future development by means of a conservation easement. Of this
16 amount, PGE would enhance 1.5 acres to provide higher value emergent/scrub-shrub/forested
17 wetland habitat. PGE would use selective excavation and backfill techniques to restore about
18 0.03 acre of emergent wetland that would be temporarily affected during installation of the raw
19 water line. These actions are addressed in the Removal/Fill Permit, pursuant to Section E.1.b of
20 this Order and Attachment C.

21
22 The Council adopts the following conditions in the site certificate:

- 23
- 24 (1) **The Certificate Holder shall, to the extent practicable, avoid and, where**
- 25 **avoidance is not possible, minimize construction and operation disturbance**
- 26 **to areas of native vegetation and areas that provide important wildlife**
- 27 **habitat. With respect to construction of the facility, the Certificate Holder**
- 28 **shall mitigate possible impacts to wildlife by measures including, but not**
- 29 **limited to, the following:**
- 30
- 31 (a) **Posting speed limit signs throughout the energy facility construction**
- 32 **zone.**
- 33
- 34 (b) **Instructing construction personnel, including construction contractors**
- 35 **and their personnel, on sensitive wildlife of the area and on required**
- 36 **precautions to avoid injuring or destroying wildlife.**
- 37
- 38 (c) **Instructing construction personnel, including construction contractors**
- 39 **and their personnel, to watch out for wildlife while driving through**
- 40 **the facility site, to maintain reasonable driving speeds so as not to**
- 41 **harass or strike wildlife accidentally, and to be cautious and drive at**
- 42 **slower speeds in a period from one hour before sunset to one hour**
- 43 **after sunrise when some wildlife species are the most active.**
- 44

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45

- (d) **Requiring construction personnel, including construction contractors and their personnel, to report any injured or dead wildlife detected at the facility site.**
- (2) **The Certificate Holder shall construct, operate and retire the facility to minimize impacts to vegetation and habitat.**

 - (a) **The energy facility shall be located within previously disturbed Habitat Category 6, non-native grassland Habitat Category 4, and palustrine emergent and forested/scrub-shrub wetlands Habitat Category 3.**
 - (b) **The Certificate Holder shall limit Habitat Category 3 impacts to 0.43 acres of permanent impact within palustrine emergent and forested/scrub-shrub wetlands.**
- (3) **The Certificate Holder shall site transmission towers outside wetlands and waterways to the greatest extent practicable. If the Certificate Holder must site transmission towers in riparian zones or wetlands, the Certificate Holder shall use a monopole design for the transmission towers to minimize ground impacts and vegetation control, except where it would have to cross the existing BPA lines.**
- (4) **The Certificate Holder shall prohibit construction and maintenance equipment from entering perennial and intermittent streams, except as follows:**

 - (a) **Construction equipment may cross a stream if it is dry;**
 - (b) **Construction equipment may cross streams that are not dry by using temporary structures to bridge the stream in a manner that minimizes disturbance to the bed, banks and water of the stream;**
 - (c) **Construction equipment may cross a wet stream if the Certificate Holder notifies the Division of State Lands, the Oregon Department of Fish and Wildlife (“ODFW”) and the Office of its intent to cross the stream prior to the crossing and these agencies concur that the crossing is acceptable.**

 - (A) **The Certificate Holder shall return any stream bed or bank that it disturbs during construction or maintenance to conditions that are comparable to pre-disturbed conditions, including stabilizing the bed and banks and revegetating the riparian area with appropriate plant species.**

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45

(B) The Certificate Holder shall construct wet stream crossings within the ODFW-designated in-water work period.

(C) The Certificate Holder shall keep the wet stream crossing width to the minimum needed.

(5) The Certificate Holder shall take advantage of existing roads to the extent practicable.

(6) Before beginning construction of the energy facility or beginning construction of the transmission lines, and in the appropriate season, the Certificate Holder shall conduct wildlife surveys within 0.25 miles of the site to locate great blue heron rookeries. Should it locate rookeries, the Certificate Holder shall consult with ODFW and the Office to determine the action necessary to avoid adverse impacts. If it cannot avoid impacts, the Certificate Holder shall suspend construction in the affected areas during the critical nesting period of the species, as determined by the Office in consultation with ODFW.

(7) During construction of the energy facility, the Certificate Holder shall relocate the existing osprey nest platform to an ODFW-approved location for the period between October 1 and March 30.

(8) Before beginning construction of the facility, the Certificate Holder shall conduct pre-construction surveys within the analysis area and establish construction buffers around raptor nests during the nesting season, as approved by ODFW. If it is not practical for the Certificate Holder to avoid the nests of non-listed, threatened or endangered raptor species, the Certificate Holder shall implement in a timely manner a mitigation project approved by ODFW that meets the requirements of the Habitat Mitigation policy for “no net loss” appropriate to the Habitat Category.

(9) The Certificate Holder shall schedule construction at the existing raw water intake pump station to avoid the purple martin nesting season (April 1 through June 30). Before beginning construction at the existing raw water intake pump station, the Certificate Holder shall conduct a survey to determine the exact location of any purple martin nests. Should the Certificate Holder cause unavoidable impacts to occur to any purple martin nest, it shall construct, install and maintain an artificial nest site at a nearby location. It shall pick an appropriate location in consultation with ODFW and the Office.

(10) When working around riparian areas or waterways, the Certificate Holder shall use only herbicide labeled for use in those areas. The Certificate Holder shall abide by all labeling instructions when using herbicides for vegetation

1 maintenance associated with the energy facility and transmission lines rights-
2 of-way.

- 3
- 4 (11) The Certificate Holder shall locate chemical storage, servicing of
5 construction and maintenance equipment and vehicles, and overnight storage
6 of wheeled vehicles at least 330 feet from any wetland or waterway.
7
- 8 (12) The Certificate Holder shall not construct any structure (other than fences
9 and signs) within 50 feet of any Class I river, stream or the emergent
10 vegetation adjacent to such a river or stream or within 25 feet of any other
11 rivers, streams, and sloughs or the emergent vegetation adjacent to such a
12 river, stream, or slough.
13
- 14 (13) To mitigate for impacts to 19 acres of non-native grassland, the Certificate
15 Holder shall protect 19 acres of on-site emergent wetland habitat identified
16 in the ASC by execution of a conservation easement for the life of the energy
17 facility. Before beginning construction of the energy facility, the Certificate
18 Holder shall provide a copy of the conservation easement or similar
19 conveyance to the Office.
20
- 21 (14) The Certificate Holder shall restore temporary upland and wetland
22 disturbance areas by returning the areas to their original grade and seeding,
23 with appropriate seed mixes as recommended by ODFW and as shown in
24 Table P-7 (ASC, Exhibit P, page P-34), and by mulching the areas with
25 straw. The Certificate Holder shall obtain ODFW and Office concurrence
26 before changing the proposed seed mix.
27
- 28 (15) The Certificate Holder shall not clear any more riparian vegetation than is
29 necessary for the permitted land use, including clearing required for safety
30 purposes, during construction or operation of the facility.
31
- 32 (16) During construction of the transmission line(s) and maintenance of the
33 rights-of-way, the Certificate Holder shall limit clearing of vegetation in
34 riparian areas and wetlands to that needed to prevent contact with the
35 transmission line and to meet clearance standards for safety and
36 transmission line reliability.
37
- 38 (17) The Certificate Holder shall mitigate for impacts to riparian shrub and
39 forest habitat that result in canopy cover of less than 25 percent by
40 revegetating these areas with appropriate native woody species according to
41 the Typical Revegetation Plan (ASC, Exhibit Q, page Q-6.1).
42
- 43 (18) The Certificate Holder shall, as soon as practicable and appropriate after
44 completing construction in an area, implement the mitigation measures
45 specified in Conditions (13), (14) and (17).

- 1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
- (19) **The Certificate Holder shall monitor revegetated areas for a period of five years and shall ensure that new vegetation has an 80 percent survival rate.**
 - (20) **The Certificate Holder shall monitor and control nuisance and invasive plant species annually for a period of five years in areas where vegetation removal and/or revegetation has occurred in (1) riparian areas and wetlands along the transmission line rights-of-way, and (2) in areas temporarily disturbed by construction of the raw water, gas, and process water discharge lines.**
 - (21) **The Certificate Holder shall submit an annual monitoring report to ODFW and the Office during the five-year monitoring period specified in Condition (20).**
 - (22) **Within one year after completion of construction of the facility or the Port Westward to BPA Allston Substation Transmission Line, if constructed separately, the Certificate Holder shall provide a summary report to ODFW and the Office that identifies the revegetation actions it took and the results of revegetation monitoring conducted to that time.**
 - (23) **Within three months after completion of the final annual monitoring survey, the Certificate Holder shall provide a report to ODFW and the Office that presents the results of its revegetation monitoring.**
 - (24) **If revegetation is not successful at establishing appropriate plant cover and controlling erosion, the Certificate Holder shall take remedial actions as the Office directs.**

28 **Consistency with ODFW Goals**

29 The Council finds that the facility, subject to the conditions it adopts in this Order, is consistent
30 with the ODFW fish and wildlife habitat goals and standards for the reasons stated below.

- 31
- 32 · The facility would not affect Habitat Category 1.
 - 33
 - 34 · The facility would not directly affect Habitat Category 2 and would not result in any loss
35 of habitat quantity or long-term loss in habitat quality. Construction could result in a
36 short-term loss of habitat quality if it occurred during the nesting season and reduced
37 nesting success. If such a short-term loss were to occur, PGE would meet the mitigation
38 goal (no net loss plus a net benefit in quality) by providing appropriate habitat in the same
39 physiographic province (in proximity).
 - 40
 - 41 · The facility would directly affect Habitat Category 3 (emergent and forested/scrub-shrub
42 wetlands, and osprey nesting habitat). PGE would meet the mitigation goal (no net loss of
43 quantity or quality) by relocating the osprey's nesting platform, enhancing 1.5 acres of on-
44 site emergent wetland, and restoring temporary impact areas.
 - 45

- 1 · The facility would directly affect Habitat Category 4 (non-native grassland, deciduous
2 and coniferous forests, and riparian mixed deciduous /conifer forest). PGE would meet
3 the mitigation goal (no net loss of quantity or quality) by establishing a conservation
4 easement on 19 acres of existing wetlands, reseeded and/or revegetating areas where
5 native vegetation is removed by transmission line construction, restoring topsoils and
6 reseeded areas of native vegetation that are disturbed by pipeline construction, avoiding
7 construction near nesting sites during the breeding and nesting season, and minimizing
8 removal of vegetation during transmission line ROW construction and maintenance.
9
- 10 · The facility would directly affect Habitat Category 6. PGE would meet the mitigation
11 goal (minimize impacts) by confining impacts to the minimum area practicable.
12

13 **Conclusion**

14 The Council finds that PGE meets the fish and wildlife habitat standard, OAR 345-0022-0060.
15

16 **D.9 THREATENED AND ENDANGERED SPECIES, OAR 345-022-0070**

17 To issue a site certificate, the Council, after consultation with appropriate state
18 agencies, must find that:
19

- 20 (1) For plant species that the Oregon Department of Agriculture has listed as
21 threatened or endangered under ORS 564.105(2), the design, construction,
22 operation and retirement of the proposed facility, taking into account
23 mitigation:
 - 24 (a) Are consistent with the protection and conservation program, if any, that
25 the Oregon Department of Agriculture has adopted under ORS
26 564.105(3); or
 - 27 (b) If the Oregon Department of Agriculture has not adopted a protection
28 and conservation program, are not likely to cause a significant reduction
29 in the likelihood of survival or recovery of the species; and
30
- 31 (2) For wildlife species that the Oregon Fish and Wildlife Commission has listed as
32 threatened or endangered under ORS 496.172(2), the design, construction,
33 operation and retirement of the proposed facility, taking into account
34 mitigation, are not likely to cause a significant reduction in the likelihood of
35 survival or recovery of the species.
36

37 **Discussion**

38 **Threatened and Endangered Plant Species**

39 The Oregon Department of Agriculture (“ODA”) designates state-listed threatened or
40 endangered plant species under ORS Chapter 564 and OAR Chapter 603, Division 73. PGE
41 contacted ODA for information about listed plant species and any applicable protection and
42 conservation programs. PGE also consulted with the U.S. Fish and Wildlife Service (“USFWS”)
43 and National Marine Fisheries Service (“NMFS”) and with the Oregon Natural Heritage Program
44 (“ONHP”) for information about listed and sensitive species.
45

1 The analysis area for threatened and endangered plant species is, at a minimum, the area within
2 150 feet on either side of the proposed transmission line corridor and a similar distance
3 surrounding the proposed energy facility site, water intake/discharge facilities, and temporary
4 construction zone. Pursuant to the Amended Project Order, “threatened and endangered plant
5 species” means species listed as threatened or endangered by the state under ORS 564.105 and
6 by the federal government under 16 USC 1533. PGE conducted botanical field ground surveys
7 within the analysis area for the energy facility on May 30-31, 2001 (EDAW, *Threatened,*
8 *Endangered, and Sensitive Plant Survey*, March 2002). PGE conducted an aerial habitat survey
9 of the transmission line corridor and energy facility site on June 8, 2001. It conducted botanical
10 field ground surveys within the analysis area for the existing Port Westward to BPA Allston
11 Substation transmission line corridor during June 2002.

12
13 No state-listed threatened plant species are known to occur in the energy facility analysis area.
14 However, the state- and federally-listed threatened species, Nelson’s checker mallow (*Sidalcea*
15 *nelsoniana*), may occur in the proposed transmission line corridor. There is no State Protection
16 and Conservation plan for this species. Two additional species that are considered candidates for
17 state listing, Howell’s montia (*Montia howellii*) and tall bugbane (*Cimicifuga elata*), may also
18 occur in the proposed transmission line corridor.

19
20 Potential Impacts on Plants: PGE conducted species surveys for the energy facility analysis area
21 and the existing Port Westward to BPA Allston Substation transmission line corridor and found
22 none of the listed or candidate species. PGE has not yet conducted species surveys for the BPA
23 Allston Substation to Trojan transmission line corridor, where there is potential suitable habitat
24 for Nelson’s checker mallow, Howell’s montia and tall bugbane.

25 **Construction and Operation**

26 Direct Impacts (Habitat Quantity)

27 *Energy Facility Analysis Area:* Based on the above discussion, the Council finds that there will
28 likely be no direct impacts to threatened, endangered or candidate plant species or their habitat
29 on the energy facility site from construction and operation.

30
31 *Transmission Line Corridor:* Because PGE has not completed surveys of plant species along the
32 options for the transmission line corridors between the BPA Allston Substation and Trojan, the
33 Council cannot find that there would be no direct impacts to threatened, endangered or candidate
34 plant species or their habitat from construction of the transmission lines. However, with PGE’s
35 compliance with conditions in this section, the Council finds that there will likely be no direct
36 impacts to threatened, endangered or candidate plant species or their habitat in the transmission
37 line corridors.

38 Indirect Impacts (Habitat Quality)

39
40 *Energy Facility Area:* Based on the above discussion, the Council finds that there will likely be
41 no indirect impacts to threatened, endangered or candidate plant species or their habitat on the
42 energy facility site from construction and operation.

1 *Transmission Line Corridor:* Because PGE has not completed surveys of plant species along the
2 options for the transmission line corridors between the BPA Allston Substation and Trojan, the
3 Council cannot find that there would be no indirect impacts to threatened, endangered or
4 candidate plant species or their habitat from construction of the transmission lines. However,
5 with PGE’s compliance with conditions in this section, the Council finds that there will likely be
6 no direct impacts to threatened, endangered or candidate plant species or their habitat in the
7 transmission line corridors.

8
9 **Retirement**

10 Pursuant to conditions and Council rules, when PGE retires the facility, it must restore the site to
11 a useful, non-hazardous condition following permanent cessation of construction or operation of
12 the facility. Site restoration would consist primarily of dismantling and removing unneeded
13 equipment and structures. PGE would likely leave electric, gas and water transmission lines in
14 place to serve new uses at the site. Nevertheless, Section D.3 contains conditions for the
15 retirement of the transmission line as well as the energy facility.

16
17 In addition, the Council will require PGE to submit a retirement plan before permanent shutdown
18 of the facility. The plan would include measures to minimize impacts to listed threatened,
19 endangered or candidate species.

20
21 *Energy Facility Analysis Area:* The Council finds that there will likely be no impacts to
22 threatened, endangered or candidate plant species or their habitat from the retirement of the
23 energy facility.

24
25 *Transmission Line Corridor:* The Council finds that there will likely be no impacts to
26 threatened, endangered or candidate plant species or their habitat from the retirement of the
27 transmission lines.

28
29 **Avoidance/Mitigation Measures**

30 In Exhibit Q of the ASC, pages 29-31, PGE proposes measures to avoid potential impacts to
31 listed plant species by:

- 32
- 33 1. Conducting ground surveys for each species along the transmission line corridor
34 at the appropriate time of year.
 - 35 2. Avoiding wetland areas and other areas of suitable habitat during placement of the
36 transmission lines.
 - 37 3. Minimizing clearing of vegetation along the transmission line corridor.
 - 38 4. Using existing roads to the greatest extent practicable for transmission line
39 construction and maintenance.
 - 40 5. Limiting herbicide application methods and chemicals to the least detrimental to
41 non-target species.
 - 42 6. Using direct “cut and squirt” herbicide application methods near waterways and
43 wetlands.
- 44

1 The Council adopts the following conditions in the site certificate:
2

- 3 **(1) Before beginning construction of the transmission line between the BPA**
4 **Allston Substation and the Trojan Nuclear Plant, the Certificate Holder shall**
5 **direct qualified personnel to conduct species ground surveys along the**
6 **transmission line corridor and within 150 feet on either side of the**
7 **transmission line corridor at the appropriate time of year to determine the**
8 **presence of listed plant species. If listed plant species are identified in the**
9 **course of the species ground surveys, their presence shall be noted on maps,**
10 **and PGE shall provide copies of the maps to the Office and the Department**
11 **of Agriculture.**
- 12
- 13 **(2) During construction of the transmission lines, the Certificate Holder shall**
14 **manipulate construction equipment and site poles, towers and access roads to**
15 **avoid impacts, except as provided in Condition (4), to known populations of**
16 **state- or federally-listed plant species.**
- 17
- 18 **(3) The Certificate Holder shall ensure that all maintenance practices along the**
19 **transmission line corridor minimize impacts to known populations of listed**
20 **plant species.**
- 21
- 22 **(4) In the event the Certificate Holder determines that it cannot avoid known**
23 **populations of listed plant species, the Certificate Holder shall engage**
24 **qualified personnel to determine whether the proposed action has the**
25 **potential to reduce appreciably the likelihood of the survival or recovery of**
26 **the listed species, notify the Office of its findings, and obtain approval from**
27 **the Oregon Department of Agriculture before proceeding with construction**
28 **activities that affect the listed plant species. (OAR 603-073-0090).**
- 29

30 **Conclusion: Consistency with Oregon Department of Agriculture Goals**

31 The Council finds that the operation, construction and retirement of the facility are not likely to
32 have an adverse impact on any threatened, endangered or candidate plant species or their habitat.
33

34 **Threatened and Endangered Animal Species**

35 The Oregon Fish and Wildlife Commission has designated state-listed threatened and
36 endangered wildlife species under ORS 496.172. OAR Chapter 635, Division 100, provides
37 authority for adoption of the state sensitive species list and the Wildlife Diversity Plan. It
38 contains the state list of threatened and endangered wildlife species. PGE reviewed ODFW
39 sources and consulted with the USFWS, NMFS and with ONHP for information about state- and
40 federally-listed and candidate species.
41

42 The analysis area for threatened and endangered animal species, at a minimum, is a “base case”
43 analysis area within 300 feet of either side of the proposed transmission line corridor and a
44 similar distance from the proposed energy facility site, water intake/discharge facilities, and
45 temporary construction zone. The analysis area for raptor nesting sites, including spotted owl

1 and bald eagle nesting sites, at a minimum, is the area within one-quarter mile on either side of
2 any proposed corridor alignment, the energy facility site, and temporary construction zone.
3 Pursuant to the Amended Project Order, “raptor nesting sites” means nesting sites for birds of
4 prey, such as bald and golden eagles, osprey, hawks, falcons, and owls; “threatened and
5 endangered animal species” means species listed as threatened or endangered by the state under
6 ORS 496.172 and by the federal government under 16 USC 1533.

7
8 Two state-listed endangered (“LE”) species, peregrine falcon (*Falco peregrinus anatum*) (no
9 federal status) and the lower Columbia River/SW Washington ESU Coho (*Oncorhynchus*
10 *kisutch*) (federal candidate species), are known to occur in the general area of the proposed
11 energy facility, as well as five state- and federally-listed threatened (“LT”) species: bald eagle
12 (*Haliaeetus leucocephalus*); northern spotted owl (*Strix occidentalis caurina*); marbled murrelet
13 (*Brachyramphus marmoratus*); Snake River (*O. tshawytscha*) fall Chinook salmon; and Snake
14 River summer/spring Chinook salmon. (ASC, Exhibit Q, Table Q-1).

15
16 In addition, there are several state- and federally-listed threatened (“T”), endangered (“E”), or
17 candidate (“C”) species, including spotted frog (*Rana pretiosa*) (C); Columbia white-tailed deer
18 (*Odocoileus virginianus leucurus*) (E); Lower Columbia River, Upper Willamette River, and
19 Snake River Chinook salmon (*Oncorhynchus tshawytscha*) (T); Upper Columbia River Chinook
20 Salmon (E); Snake River Basin, Middle Columbia River, Lower Columbia River, and Upper
21 Willamette River steelhead (*O. mykiss*) (T); Columbia River chum salmon (*O. keta*) (T); and SW
22 Washington and Columbia River coastal cutthroat trout (*O. clarki clarki*) (proposed T). (ASC,
23 Exhibit P, Table P-2 and Exhibit Q, Table Q-1).

24
25 State sensitive vulnerable (“SV”), sensitive critical (“SC”) and sensitive undetermined (“SU”)
26 species not federally-listed include: Pacific lamprey (*Lampetra ayresi*) (SV); little willow
27 flycatcher (*Empidonax trailii brewersti*) (SV); purple martin (*Progne subis*) (SC); olive sided
28 flycatcher (*Contopus borealis*) (SV); Pacific western big-eared bat (*Plecotus townsendii*
29 *townsendii*) (SC); fringed myotis (*Myotis thysanodes*) (SV); long-eared myotis (*Myotis evotis*)
30 (SU); long-legged myotis (*Myotis volans*) (SU); white-footed vole (*Phenacomys albipes*) (SU);
31 western toad (*Bufo boreas*) (SV); northern red-legged frog (*Rana aurora*) (SU); and tailed frog
32 (*Ascaphus truei*) (SV). (ASC, Exhibit P, Table P-2).

33 34 **Potential Impacts on Animals**

35 Construction and Operation

36 Peregrine Falcon (State Listed Endangered): Peregrine falcons may occur in the analysis area
37 year-round. There are two known eyries in the vicinity of the transmission line terminus at
38 Trojan; one located 0.1 mile away and the other about 6 miles away.

39
40 Impacts to peregrine falcons may result from an increase in disturbance, loss of foraging, nesting
41 or perching habitat, and electrocution or collisions with power lines. Because peregrine falcons
42 often nest in areas with high levels of human disturbance (bridges, cooling towers, building
43 ledges) and can acclimate to noise and human activity, including construction, and because there
44 are conditions to survey for raptors and limit impacts, the Council finds that there will likely be
45 no impact to this species.

1
2 Northern spotted owl (State Listed Threatened, Federal Listed Threatened): Northern spotted
3 owl nests and home ranges are often associated with old-growth forests. During surveys, PGE
4 did not locate suitable nesting, roosting, foraging or dispersal habitat at the proposed energy
5 facility site. Along the transmission line corridor, PGE observed no suitable habitat. The
6 Council finds that there will likely be no impacts to this species.

7
8 Marbled murrelet (State Listed Threatened, Federal Listed Threatened): The marbled murrelet
9 depends on relatively unfragmented mature forests for nesting. PGE observed no suitable
10 habitat, although isolated patches of large-diameter trees may be present outside the 300-foot
11 survey area of the transmission line corridor. The Council finds that there will likely be no
12 impacts to this species.

13
14 Bald Eagle (State Listed Threatened, Federal Listed Threatened): Bald eagles are present in the
15 analysis area year-round. Their habitat depends on proximity to water, availability of food,
16 suitable trees for nesting, perching, and roosting. Six nest territories have been identified by the
17 ONHP database within 2 miles of the analysis area. The closest territory to the energy facility is
18 on Crims Island, about 1.2 miles from the proposed energy facility site. Another active nest is
19 located at Neer Cemetery, about one mile south of the transmission line corridor. Other nest
20 territories are about 2 miles from the energy facility site. No known communal winter roost sites
21 are present within the analysis area. (ASC, Exhibit Q, page Q-11).

22
23 Impacts to bald eagles may result from an increase in disturbance, loss of foraging, nesting or
24 perching habitat, and electrocution or collision with transmission lines.

25
26 PGE completed a noise impact analysis for the Crims Island nest site. The anticipated increase
27 in ambient noise is 1 dBA, well within the DEQ's allowable increase in levels. In addition, the
28 nest is on the east side of the island and not within direct line of sight of the proposed energy
29 facility. Foraging, nesting and perching habitat would not be adversely affected by the energy
30 facility. Bald eagle foraging habitat is not limited in this area of the Columbia River and none
31 exists along the transmission line corridor. PGE located no suitable perching trees on the energy
32 facility site, and it would not remove foraging or perch trees. Impacts from electrocution by
33 contact with the transmission lines would be reduced, because PGE would design the distances
34 between conductors to exceed the wingspan of the birds. Collisions with the lines are unlikely
35 due to excellent vision of the eagles and the lack of overhead ground wires. Therefore, the
36 Council finds that there will likely be no impact to this species.

37
38 Oregon Spotted Frog (State Sensitive Critical, Federal Listed Candidate): The proposed energy
39 facility site is outside the Oregon spotted frog historic range and no known occurrences are
40 within 2 miles of the analysis area. The species was not observed in the wetlands or ponds on
41 the energy facility site during field reconnaissance. Therefore, the Council finds that there will
42 likely be no impact to this species.

43
44 Columbia white-tailed deer (State Sensitive, Federal Listed Endangered): Columbia white-tailed
45 deer occur on the energy facility site year-round. The energy facility site provides a mosaic of

1 forage and cover habitat with open grassland and cottonwood stands. The tall dense grass and in
2 the forest areas in the vicinity of the energy facility site provides fawning habitat. The majority
3 of the site is disturbed non-native grassland on fill material. This is not prime habitat for the
4 deer. There is no white-tailed deer habitat along the transmission line corridor.

5
6 Potential impacts to the deer include loss of habitat, disturbance from the construction of the
7 energy facility, and disturbance from human activity, noise, traffic, and cooling tower emissions.

8
9 PGE estimates a loss of 0.12 acres of white-tailed deer habitat due to the construction of the
10 energy facility and transmission towers within the energy facility site. An additional 0.10 acres
11 of habitat would be temporarily disturbed by pipeline construction. Deer may be temporarily
12 displaced during the construction of the facility, which PGE estimates would take 24 months.
13 During operation, noise levels are anticipated to increase 4 dBA above ambient levels. The deer
14 have acclimated to the existing Beaver Generating Plant and associated noise and would be
15 likely to adapt to the increase in noise level with the proposed energy facility.

16
17 Cooling tower emissions could produce ground fogs and salt deposition. As discussed in
18 sections D.6 and E.1.c of this Order, the Council finds that ground level fogging and salt
19 deposition will not have significant impacts on fish or wildlife habitat.

20
21 Anadromous Salmonid Species (State and Federal Listed Threatened, Endangered and
22 Candidate): The lower Columbia and its tributaries contain several at-risk anadromous salmonid
23 fish species, including steelhead, Chinook and chum salmon, and coastal cutthroat trout. The
24 river is a migratory corridor and may provide seasonal rearing habitat for some species. The
25 energy facility site is within range of tidal influence, but is protected from the river by a dike.
26 However, a water intake structure is located on Bradbury Slough. The transmission line corridor
27 crosses a number of fish-bearing tributaries, including the North Fork Stewart Creek, Green
28 Creek, Beaver Creek, and an unnamed tributary. Anadromy in Beaver Creek is limited to the
29 areas downstream of Beaver Falls.

30
31 Potential sources of impacts to fish include construction and operation of the energy facility,
32 water intake structure, and electric transmission line. Potential impacts include: (1) temporary
33 and localized increase in turbidity and sediment during in-water construction; (2) risk of water
34 contamination by oil, diesel fuel, uncured concrete, or other potential contaminants during
35 construction of the energy facility and transmission line; and, (3) disturbance of riparian,
36 instream, and wetland habitats during construction of the energy facility and transmission line,
37 including access road construction.

38
39 During operation and maintenance of the energy facility and transmission lines, potential impacts
40 include: (1) entrainment or impingement on fish screens; (2) creation of artificial "reef" habitat
41 for salmonid predators around the log boom trash racks; (3) removal of water from the Columbia
42 River that may affect fish or fish habitat; and, (4) water quality impacts due to removal of
43 riparian vegetation and herbicide use.

1 Proposed conditions in this Order should ensure that any impacts during construction and
2 operation would be avoided or minimized so that they would not have a significant impact on
3 anadromous salmonid species. Therefore, the Council finds that there will likely be no
4 significant impact to this species.
5

6 **Retirement**

7 The Council will require PGE to submit a retirement plan before permanent shutdown of the
8 facility. The plan would include measures to minimize impacts to fish and wildlife habitat and to
9 ensure no impacts to threatened or endangered species. For these reasons, the Council finds that
10 retirement of the facility is not likely to result in a significant impact to listed fish and wildlife
11 species.
12

13 **Avoidance/Mitigation Measures**

14 PGE proposes measures to avoid potential impacts to listed fish and wildlife species by:
15

- 16 1. Restricting construction of the transmission line at the Trojan terminus during the
17 critical peregrine falcon nesting period from January 1 to June 30.
- 18 2. Using best available design and technology to avoid and minimize potential for
19 raptor collisions and electrocution by transmission lines.
- 20 3. Relocating proposed pipeline routes to avoid impacts to both wetlands and deer
21 habitat.
- 22 4. Establishing a conservation easement over 19 acres of wetlands adjacent to the
23 energy facility for deer habitat.
- 24 5. Planting suitable species for deer forage and cover within the wetland
25 mitigation/enhancement area.
- 26 6. Using noise reduction technology to minimize increase in ambient noise.
- 27 7. Installing deer friendly fencing on power plant site, consistent with security
28 needs.
- 29 8. Imposing speed limits and posting signs on roads for deer crossings.
- 30 9. Preparing a federal Biological Assessment to address potential impacts to listed
31 fish species.
- 32 10. Coordinating timing of in-water work with ODFW.
- 33 11. Screening water intake with approved ODFW/NMFS fish screen design.
- 34 12. Using existing log boom structure at water intake to avoid introducing new
35 artificial "reef" structure.
- 36 13. Complying with all DEQ water quality standards.
- 37 14. Locating areas for chemical storage, refueling and servicing of construction and
38 maintenance equipment and vehicles at least 330 feet from wetlands and
39 waterways.
- 40 15. Storing spoils and waste materials at least 100 feet from wetlands and waterways.
- 41 16. Minimizing wetland impacts.
- 42 17. Minimizing the removal of riparian vegetation.
- 43 18. Using existing roads for construction and maintenance of the transmission line to
44 the greatest extent practicable.

- 1 19. Implementing appropriate actions to prevent unavoidable spills and waste
2 materials from entering waterways or wetlands.
3 20. Minimizing the use of herbicide and using herbicides approved for use near water
4 in riparian areas.
5

6 The Council adopts the following conditions in the site certificate:
7

- 8 (5) **Before beginning construction of the transmission line, the Certificate Holder
9 shall employ measures to protect raptors in the design and construction of
10 transmission lines. It shall design all energized transmission conductors with
11 either a minimum separation of nine feet or other measures to reduce the
12 potential for electrocution of raptors or other birds.**
13
14 (6) **The Certificate Holder shall not construct at the transmission line terminus
15 at the Trojan Nuclear Plant during the critical peregrine falcon nesting
16 period from January 1 to June 30.**
17
18 (7) **The Certificate Holder shall plant suitable vegetative species for deer forage
19 and cover within the wetland mitigation/enhancement area.**
20
21 (8) **The Certificate Holder shall coordinate with ODFW about whether to
22 conduct site-specific fish sampling at waterways that do not have
23 confirmation of species presence or absence along the transmission line
24 corridor. If ODFW recommends that the Certificate Holder conduct site-
25 specific sampling, the Certificate Holder shall do so and report the results to
26 ODFW and the Office.**
27

28 **Conclusion**

29 The Council finds that PGE meets the threatened and endangered species standard, OAR 345-
30 022-0070.
31

32 **D.10. SCENIC AND AESTHETIC VALUES, OAR 345-022-0080**

- 33 (1) Except for facilities described in sections (2), to issue a site certificate, the
34 Council must find that the design, construction, operation and retirement of the
35 facility, taking into account mitigation, are not likely to result in significant
36 adverse impact to scenic and aesthetic values identified as significant or
37 important in applicable federal land management plans or in local land use plans
38 in the analysis area described in the project order. ***
39

40 **Discussion**

41 The analysis area for scenic and aesthetic values is the area within five miles of the site.
42

43 Significant or Important Scenic and Aesthetic Values Identified in Applicable Federal Land
44 Management Plans or in Local Land Use Plans. PGE's analysis found no applicable federal land
45 management plans pertaining to the analysis area. The Columbia County Comprehensive Plan

1 identifies one scenic resource within the analysis area that could be affected by the proposed
2 energy facility, i.e., U.S. Highway 30 between Deer Island and Rainier, Oregon. Under one
3 option, PGE would install a new 230 kV transmission line across this segment of U.S. Highway
4 30. Existing transmission lines already cross the highway at the same location, and the
5 additional transmission line would add a modest visual impact. In the State of Washington,
6 Wahkiakum County and Cowlitz County comprehensive plans do not designate any significant
7 or important scenic or aesthetic values.
8

9 Key Observations Points. Key observation points (“KOPs”) are public viewing locations
10 identified as most representative of visually sensitive locations for viewing the proposed energy
11 facility. KOPs are attractants for drawing the viewer and focusing attention on a view or vista.
12 PGE’s analysis of KOPs included identification of potential viewing locations using available
13 mapping and then field-testing each of those locations through visitation and photo
14 documentation. PGE identified and evaluated KOPs for visual sensitivity.
15

16 Key Observation Points in the Vicinity of the Proposed Energy Facility. Due to the
17 relatively isolated location of the proposed energy facility, KOPs warranting analysis
18 have only low or moderate sensitivity. KOPs on the Oregon side of the Columbia River
19 occur along Mayger Road, Kallunki Road, and U.S. Highway 30. KOPs on the
20 Washington side of the Columbia River occur along State Route 4 (“SR 4”) and pull-offs
21 along SR 4.
22

23 Approaching the energy facility site, the lowland is viewed from Mayger Road as the
24 road rounds the base of the bluffs on the south side of the Columbia River. This location
25 is of moderate sensitivity and is about one mile from the energy facility site. It is one of
26 two prominent places on the Oregon side of the Columbia River where the plume from
27 the existing Beaver Generating Plant can be seen.
28

29 The plume from Beaver can also be seen from U.S. Highway 30 just west of Clatskanie.
30 Intervening vegetation, including tree farms and trees growing along the sloughs in the
31 lowland, provides screening between the viewer and the proposed energy facility.
32 Because of that screening, coupled with distance, this location is of low sensitivity.
33

34 KOPs along Kallunki Road, which dead-ends at the entrance to the proposed energy
35 facility, are only moderately sensitive due to minimal, destination-only traffic on the
36 road. The existing transmission line parallels railroad tracks through the lowland area,
37 giving the area an industrial character. Views of the proposed energy facility site are
38 very limited from Kallunki Road due to distance and intervening vegetation. Views of
39 emissions from the road would be limited due to vegetative screening along the road.
40

41 From the Washington side of the Columbia River, along SR 4, there is little vegetative
42 screening along the road and its pull-offs. The proposed energy facility is located in an
43 existing industrial area with industrial uses in place. It would be prominent in views from
44 the Washington side of the Columbia River. However, the hills on the Oregon side of the
45 river are tall enough to provide a backdrop for the proposed energy facility so that it

1 would not be silhouetted on the skyline when viewed from the Washington side of the
2 river.

3
4 Key Observation Points along the Proposed Transmission Line Corridor. PGE would
5 construct related or supporting transmission lines in an existing transmission line corridor
6 from the proposed energy facility site to the BPA Allston Substation. At the BPA Allston
7 Substation, the transmission line would cross U.S. Highway 30 in a southerly direction
8 and then turn east to Trojan. A number of road crossings are important KOPs for the
9 proposed transmission line. However, forest cover, the steep winding nature of most of
10 the roadways, and the steep terrain serve to limit views from the roadway crossings.
11 Adding line and support towers in the corridor would not significantly alter the existing
12 visual condition of low to moderate sensitivity.

13
14 Visual Aesthetics of the Energy Facility. The proposed energy facility would be constructed on
15 a flat, open, disturbed area in the northwest corner of the Port Westward Industrial Area. The
16 elevation of the proposed energy facility is about 18 feet above mean sea level. Vegetation
17 consists of grasses and scattered native trees, such as willow and cottonwood. The shoreline
18 near the proposed energy facility has little vegetation and is open to views, especially from the
19 Washington side of the Columbia River. The proposed energy facility would consist of several
20 large buildings and two exhaust stacks. The buildings would range from 30 to 90 feet tall and
21 the exhaust stacks would be about 200 feet tall. Due to backdrop of hills on the Oregon side of
22 the river, the stacks would not be silhouetted on the skyline when viewed from the Washington
23 side of the river.

24
25 The visual impacts of the proposed energy facility would be similar to those of Beaver, although
26 the proposed energy facility would have two narrow, tall exhaust stacks compared to six wider
27 and shorter stacks at Beaver. Some buildings would be partially screened by the existing native
28 trees and tree farms in the industrial complex. Other visible impacts associated with the
29 proposed energy facility would include plumes and night lighting similar to those of Beaver.

30
31 Visual Aesthetics of the Transmission Lines. PGE would construct related or supporting
32 transmission lines parallel to existing transmission lines. This transmission line corridor
33 incorporates several roadway crossings. Forest cover, steep terrain, and the steep winding nature
34 of most of the roadways all serve to limit views from the roadway crossings. Adding line and
35 support towers in the corridor, including the crossing of U.S. Highway 30 between Deer Island
36 and Rainier, which is deemed a scenic resource in the Columbia County Comprehensive Plan,
37 would not significantly alter existing visual aesthetics.

38
39 Construction Activities. Activities associated with construction of the energy facility could
40 adversely affect scenic and aesthetic values. During the 18-month to two-year period of
41 construction, cranes and scaffolding would be present in the vicinity of the energy facility. In
42 addition, construction dust and construction lighting would be noticeable from vantage points
43 near the energy facility. Mitigation measures, including moving equipment when no longer in
44 use, applying water to control dust, and using shielding and directive devices on lighting during
45 nighttime construction, could reduce these impacts to negligible levels.

1
2 The Council adopts the following conditions in the site certificate:
3

- 4 **(1) During construction of the facility, the Certificate Holder shall ensure that**
5 **contractors move equipment out of the construction area when it is no longer**
6 **expected to be used. To the extent practical, contractors shall lower**
7 **equipment with long arms, such as cranes, bucket trucks, backhoes, when**
8 **not in use in order to minimize visibility.**
9
- 10 **(2) During construction of the facility, the Certificate Holder shall control dust**
11 **through the application of water.**
12
- 13 **(3) During construction of the energy facility, the Certificate Holder shall use**
14 **directing and shielding devices on lights to minimize off-site glare. When**
15 **there is no nighttime construction activity, the Certificate Holder shall**
16 **minimize night lighting consistent with safety and security requirements.**
17

18 Nighttime Lighting. Lighting of the proposed energy facility would increase its visibility during
19 hours of darkness. Exterior lighting is necessary for safety and security, especially on the
20 exhaust stacks. However, most lighting could be shielded or directed to minimize visual
21 impacts. Except for safety and warning type lighting, to minimize lighting and illumination seen
22 from offsite, PGE would mount night lighting fixtures to guide light downward.
23

24 The Council adopts the following condition in the site certificate:
25

- 26 **(4) During operation of the energy facility, the Certificate Holder shall use**
27 **directing and shielding devices on lights to minimize off-site glare, consistent**
28 **with safety and security requirements.**
29

30 Columbia County Recommendation: In a letter dated May 21, 2002, from Mr. Jim Holycross,
31 Planning Division, Department of Land Development Services, Columbia County, he
32 recommended that the Council adopt a condition relating to submission of outdoor lighting plans.
33 The Council adopts the following condition, based on the recommendation from Columbia
34 County:
35

- 36 **(5) Before beginning construction of the energy facility, the Certificate Holder**
37 **shall submit to Columbia County and the Office an outdoor lighting plan**
38 **that shows how it will minimize glare from the energy facility site, consistent**
39 **with Conditions (3) and (4).**
40

41 Structural Aesthetics. PGE would paint proposed structures with low-glare paint in colors
42 selected to complement the surrounding foreground and background colors.
43

44 The Council adopts the following condition in the site certificate:
45

1 **(6) The Certificate Holder shall paint structures with low-glare paint in colors**
2 **selected to complement the surrounding foreground and background colors.**

3
4 Pipelines. Pipelines for water, reclaimed wastewater and natural gas would all be installed under
5 ground. The Council finds that pipelines would have no effect on scenic or aesthetic values,
6 provided that PGE restores any areas disturbed by construction activities to their pre-construction
7 condition.

8
9 The Council adopts the following condition in the site certificate:

10
11 **(7) After completion of construction of related and supporting pipelines in an**
12 **area, the Certificate Holder shall re-vegetate any undeveloped areas**
13 **disturbed by construction activities using native species, including grasses,**
14 **shrubs, and trees. If necessary, the Certificate Holder shall water re-**
15 **vegetated areas on a regular basis until the plant species have been**
16 **successfully established.**

17
18 Vapor Plumes. During periods of low temperature and high humidity, vapor plumes from the
19 cooling towers and exhaust stacks may be visible. These plumes are most likely to be visible
20 during the winter months. Vapor plumes may also be visible during nighttime hours when the
21 energy facility is illuminated. There are other vapor plumes emanating from the existing
22 industrial uses in the vicinity of the energy facility. The Council finds that the addition of the
23 plumes emanating from the energy facility would not change appreciably the visual character of
24 this industrial/agricultural area.

25
26 The energy facility would add industrial features to an area already populated with other
27 industrial/agricultural businesses. The Council finds that the design, construction, operation and
28 retirement of the energy facility, taking into account mitigation, would not be likely to result in
29 significant adverse impact to scenic and aesthetic values identified as significant or important in
30 applicable federal land management plans or in local land use plans in the analysis area.

31
32 **Conclusion**

33 The Council finds that PGE meets the scenic and aesthetic values standard, OAR 345-022-0080.

34
35 **D.11. HISTORIC, CULTURAL AND ARCHAEOLOGICAL RESOURCES, OAR 345-022-0090**

36 (1) Except for facilities described in sections (2) and (3), to issue a site certificate,
37 the Council must find that the construction, operation and retirement of the
38 facility, taking into account mitigation, are not likely to result in significant
39 adverse impacts to:

40 (a) Historic, cultural or archaeological resources that have been listed on, or
41 would likely be listed on the National Register of Historic Places;

42 (b) For a facility on private land, archaeological objects, as defined in ORS
43 358.905(1)(a), or archaeological sites, as defined in ORS 358.905(1)(c);
44 and

1 (c) For a facility on public land, archaeological sites, as defined in ORS
2 358.905(1)(c). ***
3

4 **Discussion**

5 The analysis area for historical, cultural and archaeological resources is the site and immediate
6 vicinity. This includes the proposed energy facility, the construction lay down area, the area
7 within corridors for the new transmission lines, a high-pressure natural gas line lateral, a raw
8 water supply line, and any additional areas that would be cleared, used for vehicle parking,
9 equipment storage or staging, or would otherwise be disturbed during construction.

10
11 PGE conducted a record search, literature review, pedestrian field survey, and deep mechanical
12 augering of areas that would be potentially subject to ground disturbance in the course of
13 construction and operation of the proposed energy facility. In addition, PGE contacted
14 representatives of the Confederated Tribes of the Warm Springs Indian Reservation of Oregon,
15 the Confederated Tribes of the Grand Ronde Community of Oregon, the Confederated Tribes of
16 the Siletz Indian Reservation of Oregon, and the Chinook Tribe in Washington.

17
18 Several cultural resource sites have been previously recorded within a few miles of the proposed
19 facility. However, only one prehistoric archaeological site (35CO16) could potentially be
20 affected by the proposed facility, as noted below. The construction of the energy facility, while
21 being situated close to the archaeological site, would not affect the physical integrity of the site.
22 Thus, construction and operation of the proposed energy facility would likely have no effect on
23 historic, cultural or archeological resources.

24
25 The alignment of the raw water pipeline would extend from an existing pump station on
26 Bradbury Slough to the energy facility, following existing paved and gravel roads for nearly the
27 entire alignment. A portion of the alignment was once a railroad bed and is above the
28 surrounding grade. The area is generally covered in dredge fill. Much of the proposed
29 alignment was either included as part of an archaeological survey conducted in 1989 or formed
30 the boundary of that survey; and, no archaeological resources have been recorded within or near
31 to it. Thus, no significant archaeological resources are likely to be found in the raw water
32 pipeline alignment.

33
34 **Potential National Register of Historic Places Sites.** There is one prehistoric archaeological
35 site (35C016) in the analysis area that could potentially be affected by the proposed energy
36 facility. This site contains buried deposits that may be eligible for listing in the National
37 Register of Historic Places. The proposed energy facility would be located in close proximity to
38 the archaeological site. However, deep subsurface mechanical auger probes failed to find
39 evidence that the archaeological site extends into the proposed construction area. Construction
40 of the proposed energy facility would occur near this archaeological site, but would not affect the
41 physical integrity of the site.

42
43 South of Port Westward, the proposed transmission line corridor would cross over a segment of
44 the Burlington Northern Santa Fe Railroad, which was originally the Astoria and Columbia River

1 Railroad during the period from 1883 to 1898. This railroad is considered eligible for listing in
2 the National Register of Historic Places.

3
4 **Archaeological Objects and Archaeological Sites.** An "archaeological site" as defined by ORS
5 358.905(1)(c) is a location in Oregon that contains a group of archaeological objects and their
6 contextual associations. An "archaeological object" as defined by ORS 358.905(1)(a) is an
7 individual object that is at least 75 years old and meets several other criteria. An archaeological
8 site will contain archaeological objects, but an isolated or individual archaeological object is not
9 an archaeological site.

10
11 Private Land. PGE has not yet completed archaeological surveys for the transmission line
12 corridors connecting the proposed energy facility to the BPA Allston Substation and the BPA
13 Allston Substation to Trojan.

14
15 Portions of the transmission line corridor between the energy facility and the BPA Allston
16 Substation were surveyed in 1974, and archaeological site 35C015 was recorded along that
17 alignment. However, the standards for archaeological field survey have changed since the
18 time of the 1974 survey.

19
20 High probability areas were identified during a survey conducted in 1999 in connection with
21 a proposed natural gas pipeline. These high probability areas were either surveyed or
22 monitored during pipeline construction, and three historic-period sites and one prehistoric
23 artifact were documented. One of the historic period resources was the Astoria and
24 Columbia River Railroad corridor south of Port Westward. That resource is considered
25 significant, as noted above. The transmission lines from Port Westward to the BPA Allston
26 Substation would pass through areas that have not been surveyed or monitored for
27 archaeological sites.

28
29 The transmission line corridor between the BPA Allston Substation and Trojan has not been
30 surveyed for archaeological resources. Site 35C01 lies adjacent to the Trojan Nuclear Power
31 Plant, but it is outside of the proposed transmission line corridor and would not be affected.
32 A short segment of the transmission line corridor crosses Highway 30 and was within the
33 route of a fiber optic line that passed through Columbia County. The fiber optic alignment
34 was surveyed in 2000, but no archaeological resources were noted within the narrow area of
35 the transmission line corridor where the fiber optic line crossed.

36
37 Once PGE has determined where the transmission line would be constructed within an
38 approved corridor, it would determine the level of work necessary to identify and protect
39 significant archaeological sites. PGE would coordinate the work with federal agencies, such
40 as the Corps of Engineers, the State Historic Preservation Office, and the Office. PGE would
41 solicit information from tribes regarding cultural resources known to and of importance to
42 the tribes.

43
44 Public Land. Prehistoric archaeological site 35C016 is located on public land managed by
45 the Port of St. Helens. It is near the proposed energy facility site. This site may be eligible

1 for listing in the National Register of Historic Places, but subsurface probes determined that
2 the site does not extend into the potential construction area for the proposed energy facility.

3
4 PGE conducted field surveys and subsurface auger probes of the proposed energy facility site
5 and determined that the probability of encountering cultural resources during construction
6 would be low.

7
8 PGE would take several steps to protect cultural resources. PGE would ensure that construction
9 personnel are instructed in the identification of cultural material. They would be required to halt
10 ground-disturbing activities in the vicinity of a find until a qualified archaeologist could evaluate
11 the significance of a find. If an archaeologist found significant cultural resources, PGE would
12 make recommendations for mitigation measures in consultation with the Oregon State Historic
13 Preservation Office, the Office, and other appropriate parties. Mitigation measures could include
14 avoidance or data recovery.

15
16 The Council finds that construction of the energy facility and its related or supporting facilities
17 would have no effect on identified cultural resources.

18
19 The Council adopts the following conditions in the site certificate:

- 20
21 **(1) Before beginning construction of the Port Westward to BPA Allston Substation**
22 **Transmission Line or the BPA Allston Substation to Trojan Transmission Line,**
23 **the Certificate Holder shall complete an archaeological survey of the approved**
24 **transmission line corridors in consultation with the Oregon Historic**
25 **Preservation Office (“SHPO”), the Confederated Tribes of the Warm Springs**
26 **Indian Reservation of Oregon, the Confederated Tribes of the Grand Ronde**
27 **Community of Oregon, the Confederated Tribes of the Siletz Indian Reservation**
28 **of Oregon, the Chinook Tribe in Washington, and appropriate federal agencies,**
29 **document its findings, and present those findings to the Office.**
30
31 **(2) During construction of the facility, the Certificate Holder shall ensure that a**
32 **qualified person instructs construction personnel in the identification of cultural**
33 **materials.**
34
35 **(3) During construction of the facility, in the event any artifacts or other cultural**
36 **materials are identified, the Certificate Holder shall cease all ground-disturbing**
37 **activities until a qualified archeologist can evaluate the significance of the find.**
38 **If the archeologist determines that the materials are significant, the Certificate**
39 **Holder shall make recommendations to the Council for mitigation in**
40 **consultation with SHPO, the Office, the tribes, and other appropriate parties.**
41 **Mitigation measures shall include avoidance or data recovery. The Certificate**
42 **Holder shall not restart work in the affected area until it has demonstrated to**
43 **the Office that it has complied with the archeological permit requirements**
44 **administered by SHPO.**
45

1 (4) **The Certificate Holder shall allow monitoring by the Confederated Tribes of the**
2 **Warm Springs Indian Reservation of Oregon, the Confederated Tribes of the**
3 **Grand Ronde Community of Oregon, the Confederated Tribes of the Siletz**
4 **Indian Reservation of Oregon, and the Chinook Tribe in Washington of earth-**
5 **moving activities within any areas with a potential for containing archaeological**
6 **remains.**

7
8 (5) **Before beginning construction of the facility or of the Port Westward to BPA**
9 **Allston Substation Transmission Line separately, the Certificate Holder shall**
10 **notify the Confederated Tribes of the Warm Springs Indian Reservation of**
11 **Oregon, the Confederated Tribes of the Grand Ronde Community of Oregon,**
12 **the Confederated Tribes of the Siletz Indian Reservation of Oregon, and the**
13 **Chinook Tribe in Washington and provide their representatives the opportunity**
14 **to be available for periodic on-site monitoring during construction activities.**

15
16 **Conclusion**

17 The Council finds that PGE meets the historic, cultural and archaeological resources standard,
18 OAR 345-022-0090.

19
20 **D.12. RECREATION, OAR 345-022-0100**

21 (1) Except for facilities described in section (2), to issue a site certificate, the
22 Council must find that the design, construction and operation of a facility,
23 taking into account mitigation, are not likely to result in a significant adverse
24 impact to important recreational opportunities in the analysis area as described
25 in the project order. The Council shall consider the following factors in judging
26 the importance of a recreational opportunity:

- 27 (a) Any special designation or management of the location;
28 (b) The degree of demand;
29 (c) Outstanding or unusual qualities;
30 (d) Availability or rareness;
31 (e) Irreplaceability or irretrievability of the opportunity. ***

32
33 **Discussion**

34 The analysis area for recreational opportunities is the area within five miles of the site, including
35 recreational opportunities on the Columbia River. Fishing, hunting, water skiing, boating,
36 camping, sailing, hiking, cycling, and other day uses are recreational opportunities within and
37 around the analysis area. Hunting and other recreational activities are not allowed in the Port
38 Westward Industrial Area. The historic Lewis and Clark Trail is part of the Columbia River for
39 this stretch of the historic journey. The nearest documented Lewis and Clark campsite was Puget
40 Island about 9 miles downstream from the proposed energy facility site.

41
42 Existing recreational opportunities within the analysis area include the Columbia River,
43 Clatskanie River, and numerous sloughs between Clatskanie and Quincy. There are three county
44 parks within the analysis area. These include the County Line Park (Wakiakum County) on the
45 Washington side of the Columbia River about one-half mile from the Port Westward Industrial

1 Area, Hudson-Parcher Park (Columbia County) off Larson Road near Rainier about 2.5 miles
2 from the energy facility site, and Prescott Beach Park (Columbia County) along the Columbia
3 River at the community of Prescott. There is also a boat ramp on the Washington side at
4 Abernathy Point, about three-quarters of a mile from the energy facility site. In addition, about
5 four miles from the energy facility site, Columbia County leases the Clatskanie River Wayside
6 Park and Boat Ramp from the Oregon State Game Commission.

7
8 There is one city park in the City of Clatskanie. There are 19 city parks and playgrounds within
9 the City of Longview and within the analysis area. These parks support a wide range of
10 activities including swimming and athletic events. PGE's Trojan Park is at the east end of the
11 transmission line corridor at Trojan. It is privately-owned, but open to the public.

12
13 The Mayger Boat Ramp, owned and operated by ODFW, is about 1.5 miles southeast of the
14 proposed energy facility on the Columbia River at Bradbury Slough. There is one federal facility
15 in the analysis area: the U.S. Fish and Wildlife Service's Abernathy Salmon Culture Technology
16 Center about 3.5 miles north of the proposed energy facility in Washington.

17
18 Noise can affect recreation. There are very few sensitive noise receptors within the analysis
19 area. The closest recreation area is County Line Park in the State of Washington. A noise
20 impact study predicts noise levels from the proposed energy facility at two residences near
21 County Line Park would be within the acceptable range. Informal recreational activities, such as
22 fishing, hunting, and boating, could occur within the audible range of the proposed energy
23 facility. The energy facility would be located within an existing industrial area. The noise
24 analysis prepared for PGE predicts that operation of the energy facility would meet applicable
25 noise limits in both Oregon and Washington. The Council finds that added noise is unlikely to
26 affect recreational opportunities adversely.

27
28 PGE estimates that operation of the proposed energy facility would generate a total of 30 daily
29 employee vehicle trips and 10 daily delivery vehicle trips. The greatest impacts would be close
30 to the energy facility, and those impacts would result in only a small change in local traffic.
31 Average trip generation during construction may be 350 daily trips. Traffic resulting from
32 construction activities could create delays during the peak evening hour at some intersections.
33 This would not likely interfere with recreational activities. The Council finds that traffic
34 generated by construction and operation of the energy facility would not adversely affect
35 recreational opportunities.

36
37 PGE would obtain water for operation of the energy facility from its existing intake facility on
38 the Bradbury Slough under an existing Port of St. Helens water right. The intake facility is
39 already in place and modifications for the proposed plant would be contained in the existing
40 structure. The Council finds that operation of the energy facility would have no adverse impact
41 on water resources at existing recreational opportunities.

42
43 PGE would prevent water quality impacts to recreational areas by controlling storm water runoff
44 during construction and by returning blowdown water to the Columbia River under a Port of St.
45 Helens NPDES permit during operations. (As of the date of this Order, DEQ has not issued to

1 the Port of St. Helens an NPDES permit that would allow it to accept and discharge blowdown
2 from the energy facility.) Discharge water would be conveyed to the river via a pipe secured to
3 the river bottom just offshore from the proposed energy facility. There should be no impacts to
4 recreation or river navigation from the discharge pipeline. PGE predicts there would be no
5 degradation of water quality in the Columbia River or Bradbury Slough. The Council finds that
6 construction and operation of the energy facility would not adversely affect recreational uses of
7 water, including fishing and boating, provided that the Port of St. Helens complies with the
8 requirements of its NPDES permit.

9
10 Upper portions of the emission stacks could be visible up to two miles away based on the visual
11 terrain and accessible vantage points. The majority of the recreational opportunities in Oregon
12 would not have a view of the emission stacks. Some of the recreational opportunities in
13 Washington, including viewpoints along SR 4, Abernathy Boat Launch, and County Line Park,
14 could have views of the emission stacks. The energy facility would be located in an area already
15 occupied by other industrial facilities and would not create significant new visual intrusions on
16 recreational uses in the analysis area. The Council finds that the energy facility would have a
17 negligible impact when viewed from existing recreational opportunities.

18
19 Pipelines for water, reclaimed water and natural gas would be buried. The Council finds that
20 they will have no adverse impact on existing recreational opportunities.

21
22 The transmission lines would be constructed parallel to and within 500 feet of an existing
23 transmission line. The Council finds that these lines would have a negligible impact on existing
24 recreational opportunities.

25
26 Visible vapor plumes from the cooling towers and emission stacks would occur during periods of
27 low temperature and high humidity. These plumes would be most visible during the winter
28 months and may be visible at night when the energy facility is illuminated. There are other
29 visible plumes resulting from existing industrial facilities in the area. The Council finds that the
30 energy facility will not significantly alter the visual character of the general area and will have a
31 negligible impact on existing recreational opportunities.

32
33 Hazardous materials located at the energy facility site would include solvents, lubricants and
34 water treatment chemicals. Because of the distance to the nearest recreational opportunity from
35 the energy facility, the Council finds that the potential for adverse impacts to recreational
36 opportunities is remote.

37
38 The Council finds that proposed energy facility would not adversely affect any existing facilities
39 within the analysis area and that there would be no loss of recreational use. The proposed
40 facility would not detract from recreational opportunities generally available in the vicinity such
41 as fishing, waterfowl hunting, hiking, cycling, and boating. Hunting and other recreational
42 activities are not allowed in the Port Westward industrial area.

43 44 **Conclusion**

45 The Council finds that PGE meets the recreation standard, OAR 345-022-0100.

1
2 **D.13. PUBLIC SERVICES, OAR 345-022-0110**

- 3 (1) Except for facilities described in sections (2) and (3), to issue a site certificate,
4 the Council must find that the construction and operation of the facility, taking
5 into account mitigation, are not likely to result in significant adverse impact to
6 the ability of public and private providers within the analysis area described in
7 the project order to provide: sewers and sewage treatment, water, storm water
8 drainage, solid waste management, housing, traffic safety, police and fire
9 protection, health care and schools. ***

10
11 **Discussion**

12 The analysis area for the public services standard is the area within 20 miles of the energy
13 facility site, particularly communities along U.S. Highway 30. Oregon communities within the
14 analysis area include Clatskanie (population, about 1,528; distance, about five miles) and Rainier
15 (population, about 1,687; distance, about 15 miles). The analysis area includes the Washington
16 cities of Kelso and Longview for housing and health care services. Those cities have a combined
17 population of about 46,000 and are about 17 miles from the energy facility site.

18
19 PGE expects construction of the energy facility and related or supporting facilities would take
20 about 24 months. The average construction work force would be about 200 workers, with a peak
21 of about 300 workers. Of the total construction work force, PGE expects to draw most of the
22 workers from the regional labor pool. Local workers would be expected to commute to the
23 energy facility site from their homes in the region. They should impose little or no demand for
24 new local public services other than traffic safety. Construction activity could have a significant
25 impact on local traffic, which PGE must mitigate, as discussed below.

26
27 PGE expects that some construction workers would be drawn from outside the region. Many of
28 these workers would be likely to commute from Longview or Kelso, Washington, or St. Helens
29 or Portland, Oregon. Due to the relatively short duration of the work, PGE expects that workers
30 that relocate to the analysis area would not bring their families, so there should not be a
31 significant increase in demand for public services from new residents.

32
33 Operation of the energy facility would create about 25 full-time jobs. The new jobs would pay
34 considerably more than the average wage and would likely be attractive to current residents.
35 PGE expects that most new employees would already reside in the analysis area. In all, PGE
36 estimates that population increases during construction and operation of the proposed energy
37 facility would be small.

38
39 **Sewers and Sewage Treatment.** During construction of the energy facility, PGE would hire a
40 contractor to provide chemical toilet service or other appropriate facilities.

41
42 During operation of the energy facility, PGE would discharge domestic wastewater and sanitary
43 sewage to an engineered septic system at the rate of about 500 gallons per day. (See Section
44 E.1.d for a discussion of the Water Pollution Control Facilities permit for the engineered septic
45 system.)

1
2 PGE would hire employees from the local area to the extent practicable; therefore, the facility
3 would not measurably increase the local population nor increase demand on local sewage
4 collection and treatment systems.

5
6 The Council adopts the following condition in the site certificate:
7

- 8 **(1) During construction, the Certificate Holder shall hire a contractor to provide**
9 **chemical toilet services or other appropriate facilities for construction**
10 **personnel.**

11
12 The Council finds that construction and operation of the energy facility would not result in any
13 significant adverse impact on the ability of local sewage collection and treatment systems to
14 serve their other users.
15

16 **Water.** PGE would obtain up to 8.3 cubic feet per second (“cfs”), or 5.4 million gallons per day
17 (“mgd”), of water for the energy facility from the Port of St. Helens under an existing water right
18 that allows withdrawals of up to 30 cfs, or 19.4 mgd. That water right has a permitted point of
19 diversion on Bradbury Slough, where PGE currently withdraws water and where it would
20 withdraw water for the energy facility. PGE owns and operates the existing intake structure. To
21 serve the proposed energy facility’s average annual water demand of 4 mgd and peak average
22 water demand of 5.4 mgd, PGE would add pumps to the intake facility. This enhanced raw
23 water system would supply the proposed energy facility’s water requirements, and neither PGE
24 nor the Port of St. Helens would need to obtain new water rights.
25

26 Potable water uses for the energy facility and associated infrastructure would be about
27 0.072 mgd. PGE would produce domestic potable water for the energy facility by purifying
28 water it would obtain from the Port of St. Helens under the Port’s water right. It would install
29 purification equipment during construction of the energy facility. Potable water uses would be
30 drinking water, sanitary water needs, and other plant and personnel needs.
31

32 The Council finds that construction and operation of the facility would not result in any
33 significant adverse impact on the ability of the local water system to serve its other users.
34

35 **Solid Waste Management.** Solid waste for Clatskanie and the area of the proposed facility is
36 hauled to a transfer station in St. Helens, where the waste is compacted before being transferred
37 to the River Bend Landfill in McMinnville, Oregon. This landfill is a “Subtitle D” facility,
38 which takes about 2,000 tons per day from eight counties.
39

40 PGE estimates that construction of the energy facility would produce construction wastes at the
41 rate of about 5 tons per month. It would consist of pallets, wood packing, steel banding, steel
42 cutoffs, cardboard packing, wood cutoffs, concrete waste, and office refuse. PGE proposes to
43 separate and store recyclable material from this waste stream and to deliver such recyclable
44 waste to a recycling facility.
45

1 PGE estimates that operation of the energy facility would produce domestic solid waste at the
2 rate of about 20 tons per year. PGE proposes to separate and store recyclable material from this
3 waste stream and to deliver such recyclable waste to a recycling facility.
4

5 The capacity of the solid waste removal system for the analysis area is sufficient to manage
6 current and foreseeable waste. The facilities managing waste for Columbia County can handle
7 substantially more waste than they are currently handling. The Council finds that construction
8 and operation of the energy facility would not have a significant adverse impact on the capacity
9 of solid waste facilities in the analysis area.
10

11 **Housing.** According to statistics gathered by PGE, there are 1,346 housing units in the analysis
12 area with an average vacancy rate of 6.0 percent. While temporary housing is somewhat limited
13 (80 units) in the analysis area, there are about 50 apartments, motels, and resorts just 17 miles
14 away in the vicinity of Longview and Kelso, Washington. The local area, inclusive of Longview
15 and Kelso, Washington, would be able to provide short-term accommodations for construction
16 workers.
17

18 The demand for permanent housing in the analysis area should not increase significantly during
19 operation of the energy facility, because it would employ only about 25 full-time employees.
20 PGE stated that, to the extent practicable, it would hire these employees from local communities.
21 The Council finds that while the availability of permanent housing in the analysis area is limited,
22 sufficient housing is available in the local area to accommodate construction and operation of the
23 energy facility.
24

25 **Traffic Safety.** PGE estimates that construction of the proposed energy facility would take
26 about 24 months. During the peak construction period, PGE expects a trip generation rate of
27 about 550 daily trips (500 autos and 50 trucks) and 255 outbound trips during the PM peak hour
28 (250 autos and five trucks). It expects average trip generation during construction to be about
29 350 daily trips (330 autos and 20 trucks) and 167 outbound trips during the PM peak hour
30 (165 autos and two trucks). When operation begins, PGE expects the proposed energy facility to
31 generate about 40 daily trips (30 autos and 10 trucks) and 11 outbound trips during the PM peak
32 hour (10 autos and one truck).
33

34 PGE assumes that about 90 percent of the traffic would come from areas east of the energy
35 facility site and the remaining 10 percent would come from Clatskanie and areas to the west.
36

37 Primary access to the proposed energy facility site would be via Kallunki Road to the southeast.
38 The major travel route from the energy facility site into the City of Clatskanie and for
39 interconnection with U.S. Highway 30 (“U.S. 30”) would be southeast via Kallunki Road to its
40 connection with Quincy-Mayger Road, then south via Quincy-Mayger Road to its connection
41 with Beaver Falls Road, then southwest via Beaver Falls Road to its connection with NE 5th
42 Street (the “Quincy-Mayger Route”). Within Clatskanie, Beaver Falls Road connects with NE
43 5th Street, which feeds both Nehalem Street and Swedetown Road, both of which connect with
44 U.S. 30. Alston-Mayger Road also connects with Kallunki Road at the intersection with Quincy-

1 Mayger Road. This roadway would be an alternative route (the “Alston-Mayger Route”) that
2 connects with U.S. 30 about nine miles east of Clatskanie.

3
4 In the future, when the County has completed proposed roadway improvements, Hermo Road
5 would become the primary access route into the Port Westward Industrial Area. Hermo Road
6 connects with Quincy-Mayger Road to the south and would connect to Erickson Dike Road to
7 the north and west of the proposed energy facility site when Hermo Road is completed.

8
9 PGE hired David Evans and Associates, Inc. (“DEA”) to assess the traffic impacts of the
10 proposed energy facility. DEA’s Traffic Impact Analysis focused on the following issues:

- 11
- 12 · Review of existing studies and recommended transportation improvements.
- 13 · Evaluation of 2001 existing traffic conditions during weekday PM peak hours.
- 14 · Estimated site trip generation, distribution and assignment to the vicinity road system.
- 15 · Analysis of traffic conditions during peak construction activity, estimated to occur in
16 2003.
- 17 · Analysis of traffic conditions once the energy facility begins regular operations,
18 estimated to occur in 2004.
- 19 · Mitigation measures for any project deficiencies.
- 20

21 DEA examined four future condition scenarios for the proposed energy facility:

- 22 · The first scenario assumes that the proposed energy facility would generate the only
23 construction activity in the area.
- 24 · The second scenario assumes that construction of the Summit Project, proposed by
25 Westward Energy LLC (“Westward Energy”), and the Cascade Grain Project would
26 occur concurrently with construction of the proposed energy facility and that the period
27 of peak construction activity would overlap for all three sites.
- 28 · The third scenario assumes that concurrent construction would occur, but that
29 transportation demand management (“TDM”) measures would be used to reduce PM
30 peak hour trip generation for all three projects.
- 31 · The fourth scenario examined the operating phase, assuming that all three projects were
32 in operation.
- 33

34 Construction Scenario 1 – Port Westward Peak Construction Activity. During the peak
35 construction phase of the proposed energy facility, traffic conditions would still be
36 acceptable. Most of the intersections would operate with short delays during the PM
37 peak hour. Only one intersection movement, the southbound left-turn from Old Highway
38 30 in Alston to U.S. 30, would have long delays (about two minutes) and traffic demand
39 approaching the capacity of the movement. The county roadways would operate
40 acceptably, and the U.S. 30 segments would meet the state mobility standard.

41
42 Construction Scenario 2 – Concurrent Construction Peak Construction Activity.
43 Concurrent construction of the three projects would have impacts at many of the
44 intersections in the vicinity. Although the Nehalem Street intersection could operate with
45 relatively short delays for most movements, the heavy southbound demand anticipated

1 for this scenario would require major retiming of the traffic signal. At the Swedetown
2 Road interchange ramps, 40 percent of the outbound traffic would use the eastbound
3 ramp (southern approach) resulting in average delays of one minute and demand
4 approaching the capacity of the movement. Under this scenario, PGE assigned no traffic
5 to the Alston-Mayger Route because the critical southbound left-turn from Old Highway
6 30 in Alston to U.S. 30 would operate with delays of about 2.5 minutes. This poor
7 condition would result from increased construction traffic volumes on U.S. 30.
8

9 The Kallunki Road approach to Quincy-Mayger Road would operate with average delays
10 of about 30 seconds per vehicle, and the right-turn demand on Kallunki Road would be
11 near the capacity of the movement. The westbound left-turn movement on 5th Street at
12 Nehalem Street would have long delays and demand that exceed the capacity of the
13 movement.
14

15 The county roadway segments would accommodate the increased traffic demand, but
16 vehicles would travel in groups or platoons more than 70 percent of the time. The U.S.
17 30 segments would meet the state mobility standard.
18

19 Construction Scenario 3 – Concurrent Construction With TDM Measures. With the
20 implementation of TDM measures, the impacts of the concurrent construction scenario
21 would be greatly reduced. Most of the intersections would operate with short delays
22 during the PM peak hour. Only one intersection movement, the southbound left-turn
23 from Old Highway 30 in Alston to U.S. 30, would have longer delays. The county
24 roadways would operate acceptably, and the U.S. 30 segments would meet the state
25 mobility standard.
26

27 Operation, Scenario 4. During operation of the proposed facility and other facilities,
28 traffic conditions would be similar to existing conditions with minimal increases in delay
29 or traffic demand. The intersections would operate with short delays during the PM peak
30 hour. The county roadways would operate acceptably, and the U.S. 30 segments would
31 meet the state mobility standard.
32

33 Operation of the proposed energy facility should not cause appreciable impacts to traffic.
34 However, transportation system management (“TSM”) and TDM measures could be
35 implemented during construction to improve the overall safety of the system. Such measures
36 could include the following:
37

- 38 · Signage and striping at the mainline rail crossing on Kallunki Road could be improved
39 and maintained.
- 40 · A “DO NOT STOP ON TRACKS” sign could be installed as part of the crossing
41 improvements.
- 42 · A “safe speed on curves” study could be undertaken on Beaver Falls Road and Quincy-
43 Mayger Road and possibly Alston-Mayger Road.

- 1 · Curve warning signs and speed advisory plaques could be installed on Beaver Falls Road
- 2 and Quincy-Mayger Road and possibly Alston-Mayger Road based on the results of a
- 3 “safe speed on curves” study.
- 4 · A carpooling program that identifies and/or creates park-and-ride locations to facilitate
- 5 carpooling should be developed if construction of the proposed PGE project were to
- 6 occur simultaneously with construction for other proposed projects in Port Westward.
- 7 · If practicable, a staggered shift schedule should be developed if construction of the
- 8 proposed PGE project were to occur simultaneously with construction for other proposed
- 9 projects in the Port Westward Industrial Area.
- 10 · PGE should use barge and railroad deliveries of bulk materials to the extent practicable to
- 11 minimize the number of freight truck deliveries on local roads.

12
13 In addition to safety improvements identified in each of the foregoing scenarios, studies prepared
14 for PGE and Westward Energy by DEA and Kittelson & Associates, Inc, identified a series of
15 transportation improvements necessary to correct roadway deficiencies and transportation
16 impacts associated with the future development of the PWGP and potential development of the
17 Summit and Cascade Grain Projects.

18
19 Representatives of PGE and Westward Energy consulted regularly with Columbia County staff
20 to identify transportation improvements and to develop equitable cost-sharing arrangements.
21 Table D.13-1 provides a summary of transportation improvements proposed by the County and
22 the developers in connection with development of the Port Westward and Summit Projects,
23 together with cost estimates. Columbia County has agreed to complete the transportation
24 improvements in a timely manner. The developers and Columbia County staff would ensure that
25 developers minimize impacts to the road system and that construction of the improvements
26 would not significantly delay construction of the projects proposed for development in the Port
27 Westward Industrial Area. Both PGE and Westward Energy have entered into agreements with
28 Columbia County whereby the developers have agreed to contribute a proportionate share of the
29 costs associated with the transportation improvements identified in Table D.13-1.

30
31 Pursuant to its agreement with Columbia County, PGE must pay the County or its designee a
32 Transportation Improvement Contribution (“TIC”) within 60 days after issuance of final building
33 permits to construct the energy facility. The amount payable is dependent upon the status of
34 building permits for other projects proposed for development in the Port Westward Industrial
35 Area. If the facility is the only facility permitted, PGE must pay the County or its designee
36 \$272,034. If building permits have been issued for the Summit Project, PGE must pay the
37 County or its designee \$251,934. If building permits have been issued for the Summit Project
38 and the Cascade Grain ethanol project, PGE must pay the County or its designee \$166,971. And,
39 if building permits have been issued for the Cascade Grain ethanol project but not for the
40 Summit Project, PGE must pay the County or its designee \$184,434. Upon making this TIC,
41 PGE would be relieved of any further obligation to provide or pay for public transportation
42 system improvements in conjunction with construction or operation of the facility. In addition, if
43 one or more of the other projects proposed for development in the Port Westward Industrial Area
44 receive building permits after PGE has made its TIC, PGE would be eligible for reimbursement
45 of some portion of its TIC.

1
2
3
4

TABLE D.13-1
COLUMBIA COUNTY PROPOSED TRANSPORTATION IMPROVEMENTS

Roadway/Intersection	Description	Cost Estimate
Improvements Identified by PGE and Westward Energy		
Kallunki Road	Place a leveling course on Kallunki Road to improve pavement condition during construction.	\$ 120,000
Kallunki Road	Rebuild Kallunki Road to include a new sub-base, drainage, guardrail, and pavement.	\$ 885,000
Beaver Falls/Quincy-Mayger Road Intersection	Provide a pavement overlay and striping to channelize movements through the intersection. Add signing and a flashing yellow light.	\$ 110,000
Beaver Falls/Quincy-Mayger Road Intersection	Perform a detailed engineering study to develop a long-term solution for the intersection. The study should include a survey and would address realignment alternatives and associated right-of-way impacts.	\$ 40,000
Beaver Falls/Quincy-Mayger Road	Replace approximately 1,300 feet of existing guardrail.	\$ 45,000
Beaver Falls/Quincy-Mayger Road	Conduct an engineering study to determine locations for installing new guardrail, curve warning signs, and curve advisory signs.	\$ 20,000
5 th Street Safety Improvements	Add pedestrian crossing signs and re-stripe crosswalks near playground. Remove island at Nahalem Street/5 th Street intersection and improve channelization. Consider implementing all-way stop control.	\$ 15,000
Beaver Falls Road & Quincy-Mayger Road	Construct two to three paved pullouts per direction for school buses.	\$ 35,000
Beaver Falls Road & Quincy-Mayger Road	Construct a pavement overlay following completion of Port Westward area construction per analyses and recommendations from Pavement Services, Inc.	\$ 720,000
Improvements Identified by Columbia County		
Beaver Falls Road & Quincy-Mayger Road	Additional Phase 1 improvements that include 15,000 feet of guardrail and a refuge lane at the railroad crossing. Includes 40 percent contingency and incidentals.	\$ 483,000
5 th Street	Additional Phase 1 improvements that include overlay and pool/playground barrier. Includes a 40 percent contingency and incidentals.	\$ 164,400
Van Street	Phase 1 improvements that include widening roadway, paving and drainage. Includes a 40 percent contingency and incidentals.	\$ 133,400
Highway 30	Phase 1 improvements that include a westbound deceleration lane on Highway 30. Includes a 40 percent contingency and incidentals.	\$ 169,900
Alston-Mayger Road	Phase 1 maintenance improvements. Includes a 40 percent contingency and incidentals.	\$ 210,000
Miscellaneous	Phase 1 miscellaneous construction. Includes a 40 percent contingency and incidentals.	\$ 803,300
TOTAL		\$3,954,000

5
6

1 As part of its agreement with PGE, the County agreed to recommend to the Council that it adopt
2 three conditions in the site certificate. Section 3 of the agreement states:

3
4 “County will recommend to the Office of Energy and EFSC that, as a condition of the
5 Site Certificate for the Project: (1) Developer or any other holder of the Site Certificate
6 for the Project shall make the applicable payment required by Section 2 of this
7 Agreement; (2) the holder of the Site Certificate may not agree to amend the Agreement
8 to reduce, revoke or waive the requirement for such payment without the prior approval
9 of EFSC; and (3) the State of Oregon shall have the authority to require such payment
10 whether or not the County has brought an action at law or in equity to enforce the
11 payment requirement.”

12
13 Two of the recommended conditions are incorporated into Condition numbers (2) and (3) below.
14 Recommended condition (3) above is a statement of the Council’s authority to enforce the site
15 certificate and does not require a separate condition.

16
17 In a letter dated May 21, 2002, from Mr. Jim Holycross, Planning Division, Department of Land
18 Development Services, Columbia County, he recommended that the Council adopt the following
19 condition:

20
21 “All transportation issues shall be resolved and approved by the Board of County
22 Commissioners before the building permit for construction of the Summit/Westward
23 Project (sic) is issued.”

24
25 Because the subject line and substance of the letter related to the Port Westward Generating
26 Project, the Council assumes that PWGP was the intended subject of the recommended
27 condition. Nevertheless, the Council cannot adopt the condition that Mr. Holycross
28 recommended. ORS 469.401 provides, in part:

- 29
30 (3) ***After the site certificate or amended site certificate is issued, the only issue to be
31 decided in an administrative or judicial review of a state agency or local government
32 perm for which compliance with governing law was considered and determined in the
33 site certificate or amended site certificate proceeding shall be whether the permit is
34 consistent with the terms of the site certificate or amended site certificate.***

35
36 Transportation issues do not relate to the building permit. All substantive transportation issues
37 are decided by the Council and included as specific conditions in the site certificate. The
38 Council adopts below a series of conditions that it believes are responsive to the specific issues
39 that the County raised in its other comments and in its transportation agreement with PGE.
40 However, the Council does not adopt the specific condition that Mr. Holycross proposed on
41 behalf of Columbia County.

42
43 The Council adopts the following conditions in the site certificate:

- 1 (2) **The Certificate Holder shall pay to Columbia County or its designee the**
2 **appropriate Transportation Improvement Contribution (“TIC”) set forth in**
3 **Section 2.1 of the Agreement between Columbia County and Portland**
4 **General Electric Company dated June 5, 2002 (“Agreement”).**
5
6 (3) **The Certificate Holder shall not agree to amend the Agreement with**
7 **Columbia County to reduce, revoke or waive the requirement for payment of**
8 **the appropriate TIC without prior approval of the Council; however, such**
9 **approval by the Council shall not require an amendment to the Site**
10 **Certificate.**
11
12 (4) **Before beginning construction of the energy facility, the Certificate Holder**
13 **shall coordinate with Columbia County the improvement and maintenance**
14 **of signage and striping at the mainline rail crossing on Kallunki Road,**
15 **including the installation of “DO NOT STOP ON TRACKS” signs.**
16
17 (5) **If construction of the energy facility occurs concurrently with construction of**
18 **other projects in the Port Westward Industrial Area, the Certificate Holder**
19 **shall coordinate with other users of the Port Westward Industrial Area to**
20 **provide a carpooling program that identifies and/or creates park-and-ride**
21 **locations to facilitate carpooling.**
22
23 (6) **If construction of the energy facility occurs concurrently with construction of**
24 **other projects in the Port Westward Industrial Area, the Certificate Holder**
25 **shall coordinate with Columbia County and other users of the Port**
26 **Westward Industrial Area on the implementation of a staggered shift**
27 **schedule if Columbia County determines that traffic conditions warrant it.**
28
29 (7) **During construction of the energy facility, the Certificate Holder shall use**
30 **barge and railroad deliveries of bulk materials to the extent practicable to**
31 **minimize the number of freight truck deliveries on local roads.**
32

33 The Council finds that construction and operation of the facility, with appropriate mitigation
34 measures, would not adversely affect traffic in the analysis area.
35

36 **Police Protection.** The Columbia County Sheriff’s Department and Oregon State Police would
37 provide the facility with first response police protection. Under emergency circumstances, as
38 coordinated by the Columbia County Emergency Communications District, the Clatskanie Police
39 Department and Rainier Police Department would provide the facility with secondary police
40 protection.
41

42 The Columbia County Sheriff’s Department would provide first response to the facility. Oregon
43 State Police officers are stationed in a Regional Dispatch Center in St. Helens, Oregon, about
44 35 miles from the proposed energy facility site. The Clatskanie Police Department and the

1 Rainier Police Department would provide secondary response capabilities through their mutual
2 aid agreements with the Columbia County Sheriff's Department and the Oregon State Police.

3
4 PGE would fence the energy facility. The energy facility is within an industrial area with a
5 guarded entrance. It would operate 24 hours per day with personnel on site at all times, which
6 would minimize opportunities for theft and vandalism.

7
8 Police protection, which is provided by the Columbia County Sheriff's Department and the
9 Oregon State Police, is adequate to serve the proposed energy facility. Because most
10 construction workers would likely live in the area, stable social conditions should militate against
11 any significant increase in calls for law enforcement services during the construction period.
12 The Council finds that construction and operation of the energy facility would not place
13 significant additional demand on local police protection services.

14
15 **Fire Protection.** The Clatskanie Rural Fire Department and the St. Helens Fire District provide
16 fire protection in the analysis area. The Clatskanie Rural Fire Department has 43 mostly-
17 volunteer firefighters in four stations, and it covers the area in which the proposed energy facility
18 would be located. The main station, located in Clatskanie, is staffed. It is about eight miles from
19 the proposed energy facility site. Volunteer stations are located in Quincy, Mayger and Alston,
20 about 3, 4, and 10 miles from the proposed energy facility site, respectively. The Department is
21 equipped to handle fire, medical emergencies, and hazardous materials spills. The Department
22 has a mutual aid agreement with the St. Helens Fire District.

23
24 PGE would install a complete fire protection system within the buildings and yard areas of the
25 energy facility site. The system would be designed to meet the requirements of the Uniform Fire
26 Code, as amended by Oregon and the National Fire Protection Association, and all other
27 applicable fire protection standards. The fire protection system would include a fire water
28 system, dry chemical extinguishing system, a CO₂ extinguishing system, and portable fire
29 extinguishers. The road system within the energy facility site would be designed for access by
30 large trucks needed for equipment and material deliveries. These trucks are larger than typical
31 fire trucks. The minimum turning inside radius for roads is 40 feet.

32
33 The fire water system would include a fire water supply loop, fire hydrants, sprinkler systems,
34 and hoses placed at appropriate locations. Reserved capacity of 180,000 gallons in the fire
35 water/service water storage tank would serve as the firewater source. This reserved capacity is
36 based on a maximum fire flow demand of 1,000 gallons per minute ("gpm"), plus hose stream of
37 500 gpm, for a total of 1,500 gpm. The reserved capacity required for two hours fire flow would
38 be 180,000 gallons.

39
40 The combustion turbine generators would be protected by foam or CO₂ systems. If the systems
41 were activated, an alarm would sound and/or a visual indicator would light up on the gas turbine
42 control panel.

43
44 Portable fire extinguishers would be placed at key locations within the energy facility site. The
45 type and number of portable extinguishers would conform to code requirements.

1
2 The Council finds that construction and operation of the energy facility would not significantly
3 affect the Clatskanie Rural Fire Department’s ability to provide fire protection service within the
4 analysis area.

5
6 The Council adopts the following conditions in the site certificate:

- 7
8 **(8) The Certificate Holder shall construct a fire protection system within the**
9 **buildings and yard areas of the energy facility site that meets the**
10 **requirements of the Uniform Fire Code, as amended by Oregon and the**
11 **National Fire Protection Association standards, and all other applicable fire**
12 **protection standards in effect at the time of construction.**
13
14 **(9) The Certificate Holder shall provide a dedicated reserve capacity of 180,000**
15 **gallons in the raw water storage tank to serve as the fire suppression water**
16 **source.**
17
18 **(10) For fire truck access, the minimum inside turning radius of curves in the**
19 **road system on the energy facility site shall be 40 feet.**
20

21 **Health Care.** The St. Johns Medical Center in Longview, Washington, is the primary hospital
22 in the vicinity of the proposed energy facility. It is about 17 miles by highway and 10 miles by
23 air from the proposed energy facility site. St. Johns provides ambulance and life flight services
24 in addition to the emergency medical service provided by the Clatskanie Rural Fire Department.
25 There are numerous full-service medical facilities in the City of Portland. These facilities are
26 accessible by life flight in less than one-half hour. The Council finds that construction and
27 operation of the energy facility would not adversely affect medical services in the analysis area.
28

29 **Schools.** The proposed energy facility would be in the Clatskanie School District, consisting of
30 one elementary school serving grades K through 5 and one middle/high school serving grades
31 6 through 12. Current enrollment with a total of 930 students in both schools is significantly
32 below capacity. The proposed energy facility would create about 25 permanent jobs, most of
33 which would likely be filled by people living in the local area. Consequently, there would be no
34 significant increase in the number of households in the area. The Council finds that operation of
35 the energy facility would not adversely affect school districts in the analysis area.
36

37 PGE estimated that the small portion of the construction work force that might temporarily live
38 in the area would not include many families. Temporary increases in local population caused by
39 in-migration of construction workers over a 24-month period would not result in significant
40 increases in the student population. The Council finds that construction of the energy facility
41 would not adversely affect school districts in the analysis area.
42

43 **Summary.** The Council finds that the addition of temporary residents to the analysis area may
44 result in a modest increase in the demand for water, sewers and sewage treatment, storm water
45 drainage, solid waste management, housing, police and fire protection, health care, and schools.

1 Impacts on traffic safety can be mitigated. Further, there should be no adverse impacts on local
2 communities as a result of an increase in the permanent population. The Council finds that the
3 construction and operation of the facility would have a minimal impact on the demand for local
4 services.

6 **Conclusion**

7 The Council finds that PGE meets the public services standard, OAR 345-022-0110.

9 **D.14. WASTE MINIMIZATION, OAR 345-022-0120**

- 10 (1) Except for facilities described in sections (2) and (3), to issue a site certificate,
11 the Council must find that, to the extent reasonably practicable:
- 12 (a) The applicant's solid waste and wastewater plans are likely to minimize
13 generation of solid waste and wastewater in the construction, operation,
14 and retirement of the facility, and when solid waste or wastewater is
15 generated, to result in recycling and reuse of such wastes;
 - 16 (b) The applicant's plans to manage the accumulation, storage, disposal and
17 transportation of waste generated by the construction and operation of
18 the facility are likely to result in minimal adverse impact on surrounding
19 and adjacent areas. ***

21 **Discussion**

22 **Solid Waste.** PGE would recycle and reuse solid wastes produced during construction,
23 operation and retirement of proposed energy facility as much as practicable, with the balance to
24 be disposed of in a sanitary landfill.

25
26 Construction. During construction of the energy facility, PGE estimates it would produce
27 about 5 tons per month of solid waste. Such waste would consist of pallets, cardboard, paper,
28 packing materials, steel banding, steel cut-offs, other scrap metals, lumber, concrete waste,
29 lead-acid and nickel-cadmium batteries, mercury-containing lights, used oil, and
30 miscellaneous debris. PGE would separate recyclable materials from the solid waste stream,
31 store those materials on site until sufficient quantities exist to make recycling economic, and
32 periodically deliver or sell those materials to a recycling facility. Used oil, mercury-
33 containing lights, and lead-acid and nickel-cadmium batteries would be recycled through one
34 of several specialist firms providing this service in Oregon or Washington. Aluminum cans,
35 glass bottles, and office waste paper would be recycled using local disposal services in the
36 Portland metropolitan or Clatskanie areas. Solid waste that it is impractical to recycle would
37 be collected in roll-off bins and trucked to a landfill.

38
39 Operation. During operation of the energy facility, PGE estimates it would produce about
40 20 tons per year of domestic solid waste. Recyclable materials would be likely to include
41 aluminum cans, glass and plastic bottles, waste paper, used oil, mercury-containing lights,
42 and lead-acid and nickel-cadmium batteries. PGE would separate recyclable materials from
43 the solid waste stream, store those materials, and periodically deliver those materials to a
44 recycling facility. Used oil, mercury-containing lights, and lead-acid and nickel-cadmium
45 batteries would be recycled through a firm or firms specializing in that service. Aluminum

1 cans, bottles, and office waste paper would be recycled by the local disposal service. Solid
2 waste that is impractical to recycle would be collected in roll-off bins and trucked to a
3 landfill.

4
5 Other than batteries, mercury-containing lights, and used oils, PGE does not expect operation
6 of the proposed energy facility to produce any solid wastes classified as “special wastes.”
7 Ordinary solid waste and any “special wastes” produced by the energy facility would be
8 acceptable for recycling or for disposal at landfills designed and constructed according to the
9 standards set forth at 40 CFR 258, Subpart D.

10
11 In addition to domestic solid waste, operation of the energy facility would result in
12 production of a non-hazardous, solid waste product called “filter cake.” This filter cake is
13 the product of removing silt from the raw water supply through a combination of filtration,
14 flocculation, and clarification in a filter press system. PGE would dispose of the filter cake at
15 a suitable disposal facility.

16
17 Retirement. During retirement of the energy facility, PGE would recycle or dispose of solid
18 waste using contemporary approved methods and in accordance with the retirement plan
19 approved by the Council.

20
21 The Council adopts the following conditions in the site certificate:

- 22
23 **(1) During construction, operation and retirement of the energy facility, the**
24 **Certificate Holder shall separate recyclable materials from the solid waste**
25 **stream to the extent practicable, store those materials on site until sufficient**
26 **quantities exist to make recycling economic, and periodically deliver or sell**
27 **those materials to a recycling facility.**
28
29 **(2) During construction, operation and retirement of the energy facility, the**
30 **Certificate Holder shall segregate all used oil, mercury-containing lights, and**
31 **lead-acid and nickel-cadmium batteries, store such materials on site, and**
32 **deliver such materials to a recycling firm specializing in the proper disposal**
33 **of such materials.**
34
35 **(3) Upon completion of construction, the Certificate Holder shall dispose of all**
36 **temporary structures not required for facility operation and all timber,**
37 **brush, refuse, and flammable or combustible material resulting from**
38 **clearing of land and construction of the facility.**
39

40 **Wastewater.** PGE would discharge process water under a Port of St. Helens NPDES permit.
41 Other wastewater produced during construction, operation, and retirement of the energy facility
42 would take the form of sanitary sewage and surface water runoff.

43
44 Construction. To accommodate sanitary sewage produced during construction of the energy
45 facility, PGE would provide chemical toilets or other appropriate temporary facilities at the

1 construction site. A contractor would manage the sanitary sewage and transport it to a
2 sewage treatment plant. The sanitary sewage would be treated together with municipal
3 domestic wastewater and discharged in accordance with the treatment plant's discharge
4 permit conditions.
5

6 Operation. Operation of the energy facility would result in the production of sanitary sewage
7 and cooling system blowdown. PGE would convey sanitary sewage to a septic tank and
8 drain field system located at the energy facility site. It would obtain a Water Pollution
9 Control Facilities ("WPCF") permit from DEQ, as discussed in Section E.1.d of this Order.
10

11 To increase water use efficiency at the energy facility, PGE would use internal recycling of
12 aqueous streams. The energy facility would be equipped with a recirculating cooling system,
13 and water would be recycled about four to ten times in the cooling system before being
14 discharged. PGE would then discharge this blowdown water to the Columbia River under a Port
15 of St. Helens NPDES permit. PGE would be expected to produce a Temperature Management
16 Plan as a requirement of discharging process water under the Port of St. Helens NPDES permit.
17

18 The Council adopts the following conditions in the site certificate:
19

- 20 **(4) During operation of the energy facility, the Certificate Holder shall convey**
21 **all storm water and water discharges other than sanitary sewage to pervious**
22 **areas to allow for percolation into the shallow groundwater.**
23
- 24 **(5) During operation of the energy facility, the Certificate Holder shall use**
25 **internal recycling of aqueous streams whereby water shall be recycled**
26 **several times in the cooling system before being discharged.**
27

28 Retirement. During retirement of the energy facility, PGE would recycle or dispose of
29 wastes using contemporary approved methods and in accordance with the retirement plan
30 approved by the Council.
31

32 **Impact on Surrounding and Adjacent Areas**

33 Construction. PGE would provide that sanitary sewage produced during construction of the
34 energy facility is trucked to a sewage treatment plant. The sanitary sewage would be treated
35 together with municipal domestic wastewater and discharged in accordance with the
36 treatment plant's discharge permit conditions. PGE would provide that solid waste that
37 cannot be recycled is trucked to a suitable landfill.
38

39 Operation. During operation of the energy facility, PGE would route sanitary sewage to a
40 septic tank and drain field, pursuant to a WPCF permit. It would provide that solid waste
41 that cannot be recycled, including filter cake, is trucked to a suitable landfill. It would
42 recirculate process water about four to ten times and then discharge the cooling system
43 blowdown to the Columbia River under a Port of St. Helens NPDES permit.
44

1 Retirement. PGE would recycle or dispose of wastes using contemporary approved methods
2 and in accordance with the retirement plan approved by the Council.
3

4 **Conclusion**

5 The Council finds that PGE meets the waste minimization standard, OAR 345-022-0120.
6

7 **D.15. CARBON DIOXIDE STANDARD FOR BASE LOAD GAS PLANTS, OAR 345-024-0550**

8 To issue a site certificate for a base load gas plant, the Council must find that the net
9 carbon dioxide emissions rate of the proposed facility does not exceed 0.675 pounds of
10 carbon dioxide per kilowatt hour of net electric power output, with carbon dioxide
11 emissions and net electric power output measured on a new and clean basis. For a base
12 load gas plant designed with power enhancement or augmentation options that increase
13 the capacity and the heat rate of the plant above the capacity and heat rate that the base
14 load gas plant can achieve on a new and clean basis, the Council shall apply the
15 standard for a non-base load power plant, as described in OAR 345-024-0590, to the
16 incremental carbon dioxide emissions from the designed operation of the power
17 enhancement or augmentation options. The Council shall determine whether the base
18 load carbon dioxide emissions standard is met as follows:
19

- 20 (1) The Council shall determine the gross carbon dioxide emissions that are
21 reasonably likely to result from the operation of the proposed energy facility.
22 The Council shall base such determination on the proposed design of the energy
23 facility. The Council shall adopt site certificate conditions to ensure that the
24 predicted carbon dioxide emissions are not exceeded on a new and clean basis;
25
- 26 (2) For any remaining emissions reduction necessary to meet the applicable
27 standard, the applicant may elect to use any of the means described in OAR
28 345-024-0560, or any combination thereof. The Council shall determine the
29 amount of carbon dioxide emissions reduction that is reasonably likely to result
30 from the applicant's offsets and whether the resulting net carbon dioxide
31 emissions meet the applicable carbon dioxide emissions standard;
32
- 33 (3) If the applicant elects to comply with the standard using the means described in
34 OAR 345-024-0560(2), the Council shall determine the amount of carbon
35 dioxide emissions reduction that is reasonably likely to result from each of the
36 proposed offsets based on the criteria in subsections (a) to (c). In making this
37 determination, the Council shall not allow credit for offsets that have already
38 been allocated or awarded credit for carbon dioxide emissions reduction in
39 another regulatory setting. The fact that an applicant or other parties involved
40 with an offset may derive benefits from the offset other than the reduction of
41 carbon dioxide emissions is not, by itself, a basis for withholding credit for an
42 offset. The Council shall base its determination of the amount of carbon dioxide
43 emission reduction on the following criteria:
44 (a) The degree of certainty that the predicted quantity of carbon dioxide
45 emissions reduction will be achieved by the offset;

- (b) The ability of the Council to determine the actual quantity of carbon dioxide emissions reduction resulting from the offset, taking into consideration any proposed measurement, monitoring and evaluation of mitigation measure performance;
- (c) The extent to which the reduction of carbon dioxide emissions would occur in the absence of the offsets;

(4) Before beginning construction, the certificate holder shall notify the Office of Energy in writing of its final selection of a gas turbine vendor and shall submit a written design information report to the Office of Energy sufficient to verify the facility's designed new and clean heat rate and its nominal electric generating capacity at average annual site conditions for each fuel type. In the report, the certificate holder shall include the proposed limits on the annual average number of hours of facility operation on distillate fuel oil, if applicable. In the site certificate, the Council may specify other information to be included in the report. The Office of Energy shall use the information the certificate holder provides in the report as the basis for calculating, according to the site certificate, the amount of carbon dioxide emissions reductions the certificate holder must provide under OAR 345-024-0560.

Discussion

The proposed energy facility would be a base load gas plant as defined in OAR 345-001-0010(6). Therefore, "the Council must find that the net carbon dioxide emissions rate of the proposed facility does not exceed 0.675 pounds of carbon dioxide per kilowatt hour of net electric power output, with carbon dioxide emissions and net electric power output measured on a new and clean basis." OAR 345-024-0550.

PGE also requested that the Council approve its use of power enhancement or augmentation in the form of duct burning ("power augmentation technologies"), which would be fueled with natural gas. PGE also reported that it anticipated that the Project's use of duct burning would not exceed 3,000 hours per year on average. (ASC, page Y-1) PGE may select a different limit for annual average hours of duct firing before beginning construction, pursuant to OAR 345-024-0590(4).

The Council applies the carbon dioxide emissions standard for non-base load power plants to the incremental carbon dioxide emissions from the designed operation of the power augmentation technologies. OAR 345-024-0590. Thus, the Council must find that those incremental emissions do not exceed 0.675 pounds of carbon dioxide per kilowatt-hour ("lb. CO₂/kWh") of net electric power output, with carbon dioxide emissions and net electric output measured on a new and clean basis. PGE did not specify that it intended to use the power augmentation technologies during any particular times of the year, so the analysis of the new and clean basis is for average annual conditions.

Compliance. PGE proposed to comply with the carbon dioxide emissions standard of OAR 345-024-0550 and OAR 345-024-0590 by making payments in compliance with the monetary

1 path payment requirement of OAR 345-024-0710. It proposes to provide selection and
2 contracting funds and offset funds to The Climate Trust as allowed by OAR 345-024-0560(3)
3 and OAR 345-024-0600(3).

4
5 **Calculations.** The following discussion and Table D.15 show the example carbon dioxide
6 emissions calculations for the base-load plant and the power augmentation technologies, as
7 proposed by PGE. However, these should be considered as representative of the proposed
8 design. The conditions relating to the carbon dioxide standard and other conditions in the site
9 certificate allow PGE flexibility in its choice of equipment vendor and the facility's design,
10 within the parameters allowed pursuant to OAR 345-027-0050.

11
12 Before beginning construction of the Project, the certificate holder will submit to the Office an
13 affidavit with the design parameters that are necessary to calculate accurately the carbon dioxide
14 emissions from the Project, pursuant to OAR 345-024-0550. Those parameters determine the
15 specific amount of the monetary path payment for offset funds and selection and contracting
16 funds required, as calculated pursuant to the site certificate.

17
18 **Gross Carbon Dioxide Emissions.** The Council must determine the carbon dioxide emissions
19 that are reasonably likely to result from the operation of the proposed energy facility. For a base-
20 load gas plant, OAR 345-001-0010(7) requires calculations of the annual gross carbon dioxide
21 emissions of the facility and total carbon dioxide emissions for 30 years at 100 percent capacity.
22 "Gross carbon dioxide emissions" is defined in OAR 345-001-0010(25):

23
24 "Gross carbon dioxide emissions" means the predicted carbon dioxide emissions of
25 the proposed energy facility. The Council shall measure the gross carbon dioxide
26 emissions of a fossil-fueled power plant on a new and clean basis.***

27 Because the plant would operate with power augmentation technologies for part of the time, the
28 gross carbon dioxide emissions are the sum of the emissions when operating at base-load alone
29 and when operating with power augmentation technologies. The gross carbon dioxide emissions
30 shown in Table D.15, section F, as "Combined CO₂ Emissions" are 125,089 million pounds.

31
32 **Gross Carbon Dioxide Emissions Rate.** The gross carbon dioxide emissions rate is expressed
33 as pounds of carbon dioxide per kilowatt-hour of net electric power output. "Net electric power
34 output" is defined as "the electric energy produced or capacity made available for use excluding
35 electricity used in the production of electrical energy." OAR 345-001-0010(33).

36
37 For the gross carbon dioxide emissions rate, the table divides the combined output (kWh) into
38 the combined carbon dioxide emissions (lb. CO₂) to determine the gross carbon dioxide
39 emissions rate (lb. CO₂/kWh). The gross carbon dioxide emissions rate for the facility is
40 0.808 lb. CO₂/kWh.

Table D.15
CO₂ Standard for Port Westward Generating Project

A. CO₂ Standard

CO ₂ Standard for Base-Load Gas Plant (lb. CO ₂ /kWh)	0.675
CO ₂ Standard for Power Augmentation (lb. CO ₂ /kWh)	0.675

B. Parameters for Base Load Gas Plant

Net Power Output (kW)	558,860
New and Clean Heat Rate (Btu/kWh) HHV	6,786
Annual Hours of Operation	5,760

C. Parameters for Power Augmentation

Net Power Output (kW)	647,220
New and Clean Heat Rate (Btu/kWh) HHV	7,104
Annual Hours of Operation	3,000

Calculations**D. Base Load**

Net Power Output (kW)	558,860
Annual Hours of Operation	5,760
Annual Generation (million kWh/yr.)	3,219
Deemed Life of Plant (years) by Statute or Rule	30
Total Plant Output (million kWh for 30 years)	96,571
Heat Rate (Btu/kWh) HHV	6,786
CO ₂ Emissions Rate (lb. CO ₂ /Btu)	0.000117
Total CO ₂ Emissions (million lb.)	76,674

E. Power Augmentation

Net Power Output (kW)	647,220
Capacity Factor	34%
Annual Hours of Operation	3,000
Annual Generation (million kWh/yr.)	1,942
Deemed Life of Plant (years) by Statute or Rule	30
Total Plant Output (million kWh for 30 years)	58,250
Heat Rate (Btu/kWh) HHV	7,104
CO ₂ Emissions Rate (lb. CO ₂ /Btu)	0.000117
Total CO ₂ Emissions (million lb.)	48,415

F. Total Operations

Combined Output (million kW for 30 years)	154,821
Combined CO ₂ Emissions (million lb. for 30 years)	125,089
Gross CO ₂ Emissions Rate (lb. CO ₂ /kWh)	0.808
CO ₂ Standard (lb. CO ₂ /kWh)	0.675
Excess CO ₂ Emissions Rate (lb. CO ₂ /kWh)	0.133
Excess Tons CO ₂ (million tons over 30 years)	10.293

G. Monetary Path

Offset Fund Rate (\$/ton CO ₂)	\$ 0.85
Offset Funds Required (\$ million)	\$ 8.749
Contracting and Selection Funds (\$ million)	\$ 0.404
Monetary Path Requirement (\$ million)	\$ 9.152

1 **Net Carbon Dioxide Emissions.** “Net carbon dioxide emissions” is defined as “gross carbon
2 dioxide emissions of the proposed energy facility, less carbon dioxide emissions avoided,
3 displaced or sequestered by any combination of cogeneration or offsets.” OAR 345-001-
4 0010(32). In order to apply the standard, the Council must determine the excess carbon dioxide
5 emissions rate of the energy facility and the excess carbon dioxide emissions for 30 years.
6 Excess carbon dioxide emissions are those in excess of net carbon dioxide emissions allowed
7 under the standard.
8

9 PGE proposes to offset excess carbon dioxide emissions through the monetary path. Table D.15
10 shows the preliminary calculation of the offsets as “Excess Tons of CO₂.” Excess carbon dioxide
11 emissions for the Project are 10.29 million tons.
12

13 **Average Annual Site Conditions.** OAR 345-024-0550 requires that the carbon dioxide
14 emissions and net power output be measured on a “new and clean basis.” The Council’s
15 definition of new and clean basis specifies average annual site conditions, including temperature,
16 barometric pressure and relative humidity. OAR 345-001-0010(35). PGE did not request to
17 apply different average conditions at the time that it intends to operate the power augmentation
18 technologies, pursuant to OAR 345-024-0590(1), so calculations for all emissions are at average
19 annual conditions.
20

21 The average annual site conditions, based on data at the adjacent Beaver Generating Plant, are as
22 follows:
23

24	Temperature	51 degrees F
25	Barometric Pressure	14.69 psi
26	Relative Humidity	78 percent

27

28 **Estimated Heat Rate and Capacity.** To determine the carbon dioxide emissions from the
29 Project, it is necessary to know the estimated heat rate and capacity of the facility measured on a
30 new and clean basis for each fuel the facility would use. PGE proposes to use only natural gas as
31 fuel for the proposed energy facility.
32

33 PGE estimates that the base load net power output would be about 559 MW, with a new and
34 clean heat rate of 6,786 Btu/kWh, higher heating value. With power augmentation technologies,
35 PGE estimates that the Project would have a net power output of about 647 MW and a new and
36 clean heat rate of 7,104 Btu/kWh, higher heating value.
37

38 For a base load gas plant, the applicant must assume a 100-percent capacity factor on a new and
39 clean basis. OAR 345-001-0010(7). Based on PGE’s estimate, calculations assume that power
40 augmentation technologies (duct burning) would be used a maximum of 3,000 hours per year on
41 average. Assuming 3,000 hours per year as an annual average, power augmentation would
42 operate at a 34 percent capacity factor. Table D.15 breaks the year into two periods, 5,760 hours
43 at the base-load heat rate and capacity and 3,000 hours at the power augmentation heat rate and
44 capacity. Power augmentation is an increment of capacity above base-load, but it includes base-
45 load hours.

1
2 **Monetary Path.** PGE elected to comply with the carbon dioxide emissions standard by
3 providing offset funds to The Climate Trust as allowed by OAR 345-024-0560(3) and OAR 345-
4 024-0600(3) and in compliance with the monetary path payment requirement of OAR 345-024-
5 0710. Determination of the actual monetary path payment requirement will be in accordance
6 with site certificate conditions.
7

8 Using the parameters that PGE provided as a representative plant, Table D.15 multiplies the
9 excess tons of carbon dioxide for the Project by the offset fund rate, \$0.85 per ton of carbon
10 dioxide. That determines the offset funds needed for the monetary path payment requirement,
11 \$8.749 million.
12

13 The table then applies the formula in OAR 345-024-0710(4) to determine the selection and
14 contracting funds. The selection and contracting funds for the base load plant are \$0.404 million.
15

16 The combination of offset funds and selection and contracting funds constitutes the monetary
17 path payment requirement. The total monetary path payment requirement for the estimated
18 parameters of the facility with power augmentation is \$9.152 million (2002 dollars).
19

20 **Supplemental Offset Funds.** There will be a different situation regarding selection and
21 contracting funds and offset funds if the site certificate holder is required to provide
22 supplemental offset funds following a 5-year reporting period, pursuant to OAR 345-024-
23 0590(6). In that case, the selection and contracting funds will be calculated based on the
24 supplemental offset funds alone. The amount of required offset funds will be significantly less
25 than the amount for the base-load plant, and the selection and contracting funds will be
26 correspondingly smaller.
27

28 To ensure adequate selection and contracting funds, the Council finds that the basis for the
29 minimum payment for supplemental selection and contracting funds for each 5-year reporting
30 period in which supplemental offset funds are required should be at the rate of 20 percent of the
31 first \$250,000 in offset funds and 4.286 percent of the value of any offset funds in excess of that
32 amount. However, the Council does not set a specific minimum payment amount for
33 supplemental selection and contracting funds. The Council adopts this calculation procedure in
34 Condition (7)(b), below, pursuant to OAR 345-024-0710(4).
35

36 **Qualified Organization.** PGE proposes to provide offset funds and funds for the cost of
37 selecting and contracting for offsets to The Climate Trust. The Council has previously found
38 that The Climate Trust is a “qualified organization” in matters relating to seven other energy
39 facilities. The Council finds that The Climate Trust continues to meet the requirements of a
40 “qualified organization,” as defined by OAR 345-001-0010(46), for the following reasons:
41

- 42 · The Climate Trust is exempt from federal taxation under section 501(c)(3) of the Internal
43 Revenue Code. By letter dated November 19, 1997, the Internal Revenue Service
44 {“IRS”} determined that The Climate Trust (then the Oregon Climate Trust) is exempt

1 from taxation under section 501(c)(3). By letter dated August 3, 2002, the IRS affirmed
2 The Climate Trust's exempt status.

- 3
- 4 · The Climate Trust is incorporated in the state of Oregon. PGE attached the Articles of
5 Incorporation, filed with the Oregon Secretary of State.
- 6
- 7 · The Articles of Incorporation of The Climate Trust require that offset funds received
8 from certificate holders in accordance with ORS 469.503(2) be used for offsets projects
9 that will result in direct reduction, elimination, sequestration, or avoidance of carbon
10 dioxide emissions. The Articles of Incorporation of The Climate Trust require that
11 decisions on the use of such funds be made by a body composed of seven voting
12 members of which (1) three are appointed by the Council, (2) three are Oregon residents
13 appointed by the Bullitt Foundation or an alternative environmental organization named
14 by the board of directors, and (3) one member is appointed by applicants for site
15 certificates that are subject to ORS 469.503(2)(d) and the holders of such site certificates.
- 16
- 17 · The Climate Trust has made available on an annual basis, beginning after the first year of
18 operation, a signed opinion of an independent certified public accountant stating that the
19 qualified organization's use of funds pursuant to ORS 469.503 conforms with generally
20 accepted accounting principles.
- 21
- 22 · The Climate Trust has provided the Council with documentation showing that The
23 Climate Trust has complied with ORS 469.503(2)(e)(K)(v) by entering into contracts
24 obligating at least 60 percent of the offset funds received from the Klamath Cogeneration
25 Project ("KCP") and from the Hermiston Power Project within two years after the
26 commencement of construction of those facilities, respectively. The 2-year period has
27 not expired for other funds The Climate Trust has received.
- 28
- 29 · The Climate Trust has entered into contracts obligating 87 percent of the \$1,197,697
30 offset fund received from KCP. (The Climate Trust letter to the Office, dated June 20,
31 2002.) It is currently in the process of entering into contracts for additional offset funds it
32 has received. For the KCP funds, The Climate Trust complied with the requirement of
33 OAR 345-001-0010(1)(46)(f) (ORS 469.503(2)(e)(K)(vi)).
- 34

35 **Financial Instrument.** OAR 345-024-0710(1) requires that the applicant supply a "bond or
36 letter of credit in a form reasonably acceptable to the Council to ensure the payment of the offset
37 funds * * *." To fulfill this requirement, PGE has stated it will provide a bond or letter of credit.

38

39 **Disbursement of Offset Funds.** OAR 345-0240-0710(3) provides:

40

41 When the certificate holder receives written notice from the qualified organization
42 certifying that the qualified organization is contractually obligated to pay any funds to
43 implement offsets using the offset funds, the certificate holder shall make the requested
44 amount available to the qualified organization unless the total of the amount requested
45 and any amounts previously requested exceeds the offset funds, in which case the

1 certificate holder shall make available only the remaining amount of the offset
2 funds.***
3

4 The Council discussed its interpretation of this rule in the Final Order for the Umatilla
5 Generating Project, pages 79-81. The rule requires the certificate holder to pay any funds to
6 implement offsets when the qualified organization provides it written notice that it is
7 contractually obligated to implement offsets. The rule further imposes a restriction on the
8 qualified organization that it cannot request more than the total amount of offset funds for which
9 the certificate holder is obligated. The rule permits the qualified organization to request a partial
10 payment of the total offset funds when it requests offset funds.
11

12 In the Final Order for the Umatilla Generating Project, the Council found that OAR 345-024-
13 0710(3) provides a milestone for the release of offset funds to the qualified organization and that
14 the qualified organization may, at its discretion, request, and the certificate holder shall disburse,
15 up to the full amount of offset funds available when the qualified organization has reached the
16 milestone of being contractually obligated for any amount of money to implement offsets using
17 the offset funds. The Council adopts conditions to implement the disbursement of offset funds
18 consistent with its findings in the Final Order of the Umatilla Generating Project and further
19 adopt conditions that make explicit the disbursement mechanism for all funds of the monetary
20 path payment requirement.
21

22 **Proposed Conditions.** The following proposed conditions implement OAR 345-024-0550
23 through OAR 345-024-0710. Many conditions address the mechanics of calculating the excess
24 carbon dioxide emissions and the monetary path payment requirement. They also address the
25 information that the certificate holder must provide the Council or the Office at various times.
26 They also address the milestones for providing any increased or supplemental monetary path
27 payments, if necessary. The conditions incorporate both base load operations and use of power
28 augmentation technologies.
29

30 To retain the value of the monetary path payment requirement, the conditions index the payment
31 to 2002 dollars from the date the Council grants the site certificate to the time funds are
32 disbursed to The Climate Trust. This is similar to the requirement for the security for financial
33 assurance. A condition provides a cross-reference to the index in Condition (5)(e) in Section
34 D.3, which is based on the U.S. Gross Domestic Product Implicit Price Deflator, Chain-Weight,
35 as published by the Oregon Department of Administrative Services in its series, "Oregon
36 Economic and Revenue Forecast." That series provides a forecast of the Implicit Price Deflator
37 for several quarters in advance. That forecast is useful because historical data are usually
38 finalized at least a quarter late. Historical data are never current when The Climate Trust would
39 have to draw down a bond or letter of credit. The Council adopts this index as the most
40 generally applicable.
41

42 As discussed above, the rules require that the certificate holder provide a bond or third-party
43 letter of credit as financial assurance that it will make available the monetary path payments. In
44 addition, the Council adopts conditions that specify the details of how the certificate holder

1 would disburse funds to The Climate Trust. The conditions include Attachment A, which would
2 be made part of the site certificate.

3
4 Furthermore, the Council adopts a condition that allows the certificate holder to exercise the
5 flexibility that is built into the rules for minor changes. Specifically, OAR 345-027-0050
6 provides:

7
8 (2) Notwithstanding section (1), the Council does not require a site certificate
9 amendment if the proposed change would not violate any condition of the site
10 certificate and is a change:

11 (a) To an electrical generation facility that would increase the electrical
12 generating capacity and would not increase the number of electric
13 generators at the site, change fuel type, increase fuel consumption by
14 more than 10%, or enlarge the facility site;

15
16 OAR 345-027-0050 also requires information from the certificate holder about how the proposed
17 changes would comply with applicable standards and a determination by the Office or the
18 Council that an amendment is not required.

19
20 If a certificate holder had not yet made monetary path requirement funds available to a qualified
21 organization, it might take advantage of the flexibility that OAR 345-027-0050(2)(a) offers when
22 it certifies the capacity and heat rate of the facility. However, an increase in capacity and heat
23 rate after a certificate holder had already complied with the conditions relating to the carbon
24 dioxide standard might necessarily require an amendment.

25
26 In lieu of requiring an amendment for incremental increases that otherwise fall within the limits
27 specified in OAR 345-027-0050(2)(a) after a Certificate Holder has already complied with the
28 conditions relating to the carbon dioxide standard before beginning construction, the Council
29 adopts a condition that applies the site certificate's carbon dioxide standard condition, along with
30 the applicable carbon dioxide standard and monetary offset rate at the time that the Council
31 makes a determination that an amendment is not otherwise required. This approach achieves the
32 same result as an amendment allowing a later increase in capacity and heat rate. But, it uses the
33 structure provided by the site certificate conditions and updates it to current standards without
34 requiring an amendment process.

35
36 OAR 345-001-0010(35) includes in the definition of "new and clean basis" the requirement that
37 the Council determine the new and clean basis "by a 100-hour test that the site certificate holder
38 completes within the first 12 months of commercial operation of the energy facility." The
39 purpose of this requirement is to determine the capacity and heat rate for compliance with the
40 carbon dioxide standard for base load gas plants, OAR 345-024-0560. However, before
41 commercial operation, the facility would undergo a 100-hour "commercial acceptance test" that
42 achieves the same purpose as the test to be conducted "within the first 12 months of commercial
43 operation." There is no need to perform a second test that duplicates the first, although the rule
44 and statute give the certificate holder the opportunity to perform the 100-hour test any time
45 within the first 12 months. To avoid redundancy, the Council adopts a condition that permits the

1 certificate holder to use the 100-hour commercial acceptance test for determining the capacity
2 and heat rate on a new and clean basis.

3
4 Finally, the Council adopts a condition that clarifies that if the certificate holder begins
5 construction of the Port Westward to BPA Allston Substation Transmission Line, but no other
6 part of the facility, the certificate holder does not then have to begin compliance with the
7 conditions relating to the carbon dioxide standard. The certificate holder must meet the carbon
8 dioxide conditions only in connection with construction of any part of the facility or related or
9 supporting facilities other than the Port Westward to BPA Allston Substation Transmission Line.

10
11 The Council adopts the following conditions in the site certificate for compliance with the carbon
12 dioxide standard, along with Attachment A to this Order:

- 13
14 **(1) Before beginning construction of the energy facility, the Certificate Holder**
15 **shall submit to The Climate Trust a bond or letter of credit in the amount of**
16 **the monetary path payment requirement (in 2002 dollars) as determined by**
17 **the calculations set forth in Condition (3) and based on the estimated heat**
18 **rates and capacities certified pursuant to Condition (4) and as adjusted in**
19 **accordance with the terms of this Site Certificate pursuant to Condition**
20 **(3)(c). For the purposes of this Site Certificate, the "monetary path payment**
21 **requirement" means the offset funds determined pursuant to OAR 345-024-**
22 **0550 and -0560 and the selection and contracting funds that the Certificate**
23 **Holder must disburse to The Climate Trust, as the qualified organization,**
24 **pursuant to OAR 345-024-0710 and this Site Certificate. The offset fund rate**
25 **for the monetary path payment requirement shall be \$0.85 per ton of carbon**
26 **dioxide (in 2002 dollars). The calculation of 2002 dollars shall be made using**
27 **the Index set forth in Condition D.3(5)(e) and as required below in**
28 **subsection (g).**
- 29
- 30 **(a) The form of the bond or letter of credit and identity of the issuer shall**
31 **be subject to approval by the Council.**
- 32
- 33 **(b) The form of the Memorandum of Understanding (“MOU”) between**
34 **the Certificate Holder and the Climate Trust establishing the**
35 **disbursement mechanism to transfer selection and contracting funds**
36 **and offset funds to The Climate Trust shall be substantially in the**
37 **form of Attachment A to this Site Certificate.**
- 38
- 39 **(c) Either the Certificate Holder or The Climate Trust may submit to the**
40 **Council for the Council’s resolution any dispute between the**
41 **Certificate Holder and The Climate Trust that concerns the terms of**
42 **the bond, letter of credit, or MOU concerning the disbursement**
43 **mechanism for the monetary path payments, or any other issues**
44 **related to the monetary path payment requirement. The Council’s**
45 **decision shall be binding on all parties.**

- 1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
- (d) **The bond or letter of credit shall remain in effect until such time as the Certificate Holder has disbursed the full amount of the monetary path payment requirement to The Climate Trust. The Certificate Holder may reduce the amount of the bond or letter of credit commensurate with payments it makes to The Climate Trust. The bond or letter of credit shall not be subject to revocation before disbursement of the full monetary path payment requirement.**

 - (e) **In the event that the Council approves a new Certificate Holder for the energy facility:**
 - (A) **The new Certificate Holder shall submit to the Council for the Council’s approval the form of a bond or letter of credit that provides comparable security to the bond or letter of credit of the current Certificate Holder. The Council’s approval of a new bond or letter of credit shall not require a site certificate amendment.**

 - (B) **The new Certificate Holder shall submit to the Council for the Council’s approval the form of an MOU between the new Certificate Holder and The Climate Trust that is substantially in the form of Attachment A to this Site Certificate. In the case of a dispute between the new Certificate Holder and The Climate Trust concerning the disbursement mechanism for monetary path payments or any other issues related to the monetary path payment requirement, either party may submit the dispute to the Council for the Council’s resolution as provided in Condition (1)(c). Council approval of a new MOU shall not require a site certificate amendment.**

 - (f) **If calculations pursuant to Condition (5) demonstrate that the Certificate Holder must increase its monetary path payments, the Certificate Holder shall increase the bond or letter of credit sufficiently to meet the adjusted monetary path payment requirement within the time required by Condition (3)(c). Alternately, the Certificate Holder may disburse any additional required funds directly to The Climate Trust within the time required by Condition (3)(c).**

 - (g) **The amount of the bond or letter of credit shall increase annually by the percentage increase in the Index, and the disbursement of funds shall be pro-rated within the year to the date of disbursement to The**

1 **Climate Trust from the calendar quarter of Council approval of the**
2 **Site Certificate.**

- 3
- 4 **(2) The Certificate Holder shall disburse to The Climate Trust offset funds and**
5 **selection and contracting funds as requested by The Climate Trust. The**
6 **Certificate Holder shall make disbursements in response to requests from**
7 **The Climate Trust in accordance with subsections (a), (b), and (c).**
- 8
- 9 **(a) The Certificate Holder shall disburse all selection and contracting**
10 **funds to The Climate Trust before beginning construction.**
- 11
- 12 **(b) Upon notice pursuant to subsection (c), The Climate Trust may**
13 **request from the issuer of the bond or letter of credit the full amount**
14 **of all offset funds available or it may request partial payment of offset**
15 **funds at its sole discretion. Notwithstanding the specific amount of**
16 **any contract to implement an offset project, The Climate Trust may**
17 **request up to the full amount of offset funds the Certificate Holder is**
18 **required to provide to meet the monetary path payment requirement.**
- 19
- 20 **(c) The Climate Trust may request disbursement of offset funds by**
21 **providing notice to the issuer of the bond or letter of credit that The**
22 **Climate Trust has executed a letter of intent to acquire an offset**
23 **project. The Certificate Holder shall provide that the issuer of the**
24 **bond or letter of credit disburse offset funds to The Climate Trust**
25 **within three business days of a request by The Climate Trust for the**
26 **offset funds in accordance with the terms of the bond or letter of**
27 **credit.**
- 28
- 29 **(3) The Certificate Holder shall submit all monetary path payment requirement**
30 **calculations to the Office for verification in a timely manner before**
31 **submitting a bond or letter of credit for Council approval and before**
32 **entering into an MOU with The Climate Trust. The Certificate Holder shall**
33 **use the contracted design parameters for capacities and heat rates that it**
34 **reports pursuant to Condition (4) to calculate the estimated monetary path**
35 **payment requirement, along with the estimated annual hours of operation of**
36 **power augmentation technologies. The Certificate Holder shall use the Year**
37 **One Capacities and Year One Heat Rates that it reports for the facility**
38 **pursuant to Condition (5) to calculate whether it owes additional monetary**
39 **path payments.**
- 40
- 41 **(a) The net carbon dioxide emissions rate for the base load gas plant shall**
42 **not exceed 0.675 pounds of carbon dioxide per kilowatt-hour of net**
43 **electric power output, with carbon dioxide emissions and net electric**
44 **power output measured on a new and clean basis, as defined in OAR**
45 **345-001-0010.**

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44

(b) The net carbon dioxide emissions rate for incremental emissions for the facility operating with power augmentation technologies that increase the capacity and heat rate of the facility above the capacity and heat rate that it can achieve as a base load gas plant on a new and clean basis (“power augmentation technologies”) shall not exceed 0.675 pounds of carbon dioxide per kilowatt-hour of net electric power output, with carbon dioxide emissions and net electric power output measured on a new and clean basis, as the Office may modify such basis pursuant to Condition (4)(d).

(c) When the Certificate Holder submits the Year One Test reports required in Condition (5), it shall increase its monetary path payments if the calculation using reported data shows that the adjusted monetary path payment requirement exceeds the monetary path payment requirement for which the Certificate Holder had provided a bond or letter of credit before beginning construction, pursuant to Condition (1). The Certificate Holder shall submit its calculations to the Office for verification.

(A) The Certificate Holder shall make the appropriate calculations and fully disburse any increased funds directly to The Climate Trust within 30 days of filing the Year One Test reports.

(B) In no case shall the Certificate Holder diminish the bond or letter of credit it provided before beginning construction or receive a refund from The Climate Trust based on the calculations made using the Year One Capacities and the Year One Heat Rates.

(4) The Certificate Holder shall include an affidavit certifying the heat rates and capacities reported in subsections (a) and (b).

(a) Before beginning construction of the energy facility, the Certificate Holder shall notify the Council in writing of its final selection of a gas turbine vendor and heat recovery steam generator vendor and shall submit written design information to the Council sufficient to verify the base-load gas plant’s designed new and clean heat rate (higher heating value) and its net power output at the average annual site condition.

(b) Before beginning construction of the energy facility, the Certificate Holder shall submit written design information to the Council sufficient to verify the facility’s designed new and clean heat rate and

1 its net power output at the average annual site condition when
2 operating with power augmentation technologies.

3
4 (c) Before beginning construction of the energy facility, the Certificate
5 Holder shall specify the estimated annual average hours that it
6 expects to operate the power augmentation technologies.

7
8 (d) Upon a timely request by the Certificate Holder, the Office may
9 approve modified parameters for testing the power augmentation
10 technologies on a new and clean basis, pursuant to OAR 345-024-
11 0590(1). The Office's approval of modified testing parameters for
12 power augmentation technologies shall not require a site certificate
13 amendment.

14
15 (5) Within the first 12 months of commercial operation of the energy facility, the
16 Certificate Holder shall conduct a 100-hour test at full power without power
17 augmentation technologies ("Year One Test-1") and a test at full power with
18 power augmentation technologies ("Year One Test-2"). A 100-hour test
19 performed for purposes of the Certificate Holder's commercial acceptance of
20 the facility shall suffice to satisfy this condition in lieu of testing after
21 beginning commercial operation.

22
23 (a) Year One Test-1 shall determine the actual heat rate ("Year One Heat
24 Rate-1") and the net electric power output ("Year One Capacity-1")
25 on a new and clean basis, without degradation, with the results
26 adjusted for the average annual site condition for temperature,
27 barometric pressure, and relative humidity, and using a rate of
28 117 pounds of carbon dioxide per million Btu of natural gas fuel
29 pursuant to OAR 345-001-0010(35).

30
31 (b) Year One Test-2 shall determine the actual heat rate ("Year One Heat
32 Rate-2") and net electric power output ("Year One Capacity-2") for
33 the facility operating with power augmentation technologies, without
34 degradation, with the results adjusted for the average annual site
35 condition for temperature, barometric pressure and relative
36 humidity, and using a rate of 117 pounds of carbon dioxide per
37 million Btu of natural gas fuel pursuant to OAR 345-001-0010(35).
38 The full power test shall be 100 hours duration unless the Office has
39 approved a different duration pursuant to Condition (4)(d).

40
41 (c) The Certificate Holder shall notify the Office at least 60 days before
42 conducting the tests required in subsections (a) and (b) unless a
43 shorter time is mutually agreed upon.
44

- (d) Before conducting the tests required in subsections (a) and (b), the Certificate Holder shall, in a timely manner, provide to the Office a copy of the protocol for conducting the tests.
- (e) Within two months after completing the Year One Tests, the Certificate Holder shall provide to the Council a report of the results of the Year One Tests.

(6) If calculations pursuant to Condition (7) demonstrate that the Certificate Holder must supplement its monetary path payments (“supplemental monetary path payment requirement”), the Certificate Holder shall provide a bond or letter of credit sufficient to meet the supplemental monetary path payment requirement within the time required by Condition (7)(b). The bond or letter of credit shall not be subject to revocation before disbursement of the supplemental monetary path payment requirement. Alternately, the Certificate Holder may disburse in cash any such supplemental monetary path payments directly to The Climate Trust within the time required by Condition (7).

(7) The Certificate Holder shall submit all supplemental monetary path payment requirement calculations to the Office for verification. The Certificate Holder shall use the Year One Capacity-2 and Year One Heat Rate-2 that it reports for the facility pursuant to Condition (5)(b) to calculate whether it owes supplemental monetary path payments, pursuant to subsections (a) and (b).

(a) Each five years after beginning commercial operation of the energy facility (“five-year reporting period”), the Certificate Holder shall report to the Office the annual average hours the facility operated with power augmentation technologies during that five-year reporting period, pursuant to OAR 345-024-0590(6). The Certificate Holder shall submit five-year reports to the Office within 30 days of the anniversary date of beginning commercial operation of the energy facility.

(b) If the Office determines that the energy facility exceeds the projected net total carbon dioxide emissions calculated pursuant to Conditions (4) and (5), prorated for five years, during any five-year reporting period described in subsection (a), the Certificate Holder shall offset excess emissions for the specific reporting period according to subsection (A) and shall offset the estimated future excess emissions according to subsection (B), pursuant to OAR 345-024-0600(4). The Certificate Holder shall offset excess emissions using the monetary path as described in OAR 345-024-0710, except that contracting and selecting funds shall equal twenty (20) percent of the value of any

1 offset funds up to the first \$250,000 (in 2002 dollars) and
2 4.286 percent of the value of any offset funds in excess of \$250,000 (in
3 2002 dollars). The Certificate Holder shall disburse the funds to The
4 Climate Trust within 30 days after notification by the Office of the
5 amount that the Certificate Holder owes.
6

7 (A) In determining the excess carbon dioxide emissions that the
8 Certificate Holder must offset for a five-year period, the Office
9 shall apply OAR 345-024-0600(4)(a). The Certificate Holder
10 shall pay for the excess emissions at \$0.85 per ton of carbon
11 dioxide emissions (in 2002 dollars). The Office shall notify the
12 Certificate Holder and The Climate Trust of the amount of
13 payment required, using the monetary path, to offset excess
14 emissions.
15

16 (B) The Office shall calculate estimated future excess emissions and
17 notify the Certificate Holder of the amount of payment required,
18 using the monetary path, to offset them. To estimate excess
19 emissions for the remaining period of the deemed 30-year life of
20 the facility, the Office shall use the parameters specified in OAR
21 345-024-0600(4)(b). The Certificate Holder shall pay for the
22 estimated excess emissions at \$ 0.85 per ton of carbon dioxide (in
23 2002 dollars). The Office shall notify the Certificate Holder of
24 the amount of payment required, using the monetary path, to
25 offset future excess emissions.
26

27 (8) The combustion turbine for the base-load gas plant and power augmentation
28 technologies shall be fueled solely with pipeline quality natural gas or with
29 synthetic gas with a carbon content per million Btu no greater than pipeline-
30 quality natural gas.
31

32 (9) With respect to incremental capacity and fuel consumption increases for
33 which the Certificate Holder has not previously complied with the carbon
34 dioxide standard, the Certificate Holder shall comply substantially with
35 Conditions (1) through (8) in lieu of the Council's requiring an amendment,
36 provided that:
37

38 (a) The Council determines, pursuant OAR 345-027-0050, that the
39 Certificate Holder does not otherwise require an amendment, and
40 further provided that:
41

42 (b) The Certificate Holder shall meet the appropriate carbon dioxide
43 emissions standard and monetary offset rate in effect at the time the
44 Council makes its determination pursuant to OAR 345-027-0050.
45

1 **(10) Notwithstanding Conditions (1) through (9), if the Certificate Holder begins**
2 **construction of the Port Westward to BPA Allston Substation Transmission**
3 **Line, but no other part of the energy facility or other related or supporting**
4 **facilities, the Certificate Holder shall not be required to comply with**
5 **Conditions (1) through (9). The Certificate Holder shall comply with**
6 **Conditions (1) through (9) in connection with construction of any part of the**
7 **energy facility or related or supporting facilities other than the Port**
8 **Westward to BPA Allston Substation Transmission Line.**
9

10 **Conclusion**

11 The Council finds that PGE meets the carbon dioxide standard for base-load gas plants with
12 power augmentation technologies, OAR 345-024-0550.
13

14 **E. OTHER APPLICABLE REGULATORY REQUIREMENTS:**

15 **E.1. REQUIREMENTS UNDER COUNCIL JURISDICTION**

16 Pursuant to ORS 469.503(1)(b), the Council must determine that the proposed facility complies
17 with all other Oregon statutes and administrative rules identified in the Project Order, as
18 amended, as applicable to the issuance of a site certificate.
19

20 Applicable Oregon statutes and administrative rules identified in the Project Order that are not
21 addressed in any of the Council's standards are discussed in this Section of the Order. These
22 include DEQ's noise control regulations and Water Pollution Control Facilities permit
23 requirements, the Division of State Lands' ("DSL") Removal/Fill Permit regulations for
24 disturbance to wetlands, and the Council's statutory authority to consider protection of the public
25 health and safety.
26

27 **E.1.a. Noise**

28
29 **The Requirement.** The DEQ noise regulations for industrial and commercial noise sources will
30 apply to the proposed facility. Under the DEQ regulations, the generating facility would be
31 located on a "previously unused industrial site" and according to the regulations:
32

33 No person owning or controlling a new industrial or commercial noise source
34 located on a previously unused industrial or commercial site shall cause or permit
35 the operation of that noise source if the noise levels generated or indirectly caused
36 by that noise source increase the ambient statistical noise levels, L₁₀ or L₅₀, by
37 more than 10 dBA in any one hour, or exceed the levels specified in Table 8, as
38 measured at an appropriate measurement point. OAR 340-035-0035(1)(b)(B)(i).
39

40 **Discussion**

41 The proposed energy facility would be located near Clatskanie, Oregon, adjacent to the
42 Columbia River. Noise would radiate from the facility to residences located in Oregon and
43 across the river in Washington. The Council applies the DEQ regulations to evaluate the noise
44 radiating from the energy facility because it would be located in Oregon. However, because the

1 energy facility would also radiate noise to residences located in Washington, PGE voluntarily
2 estimated noise impacts at those residences as well. In Oregon, PGE compared the noise
3 radiating from the energy facility with the limits specified in the DEQ noise regulation. OAR
4 340-035-0035. In Washington, PGE compared the noise radiating from the energy facility with
5 the limits specified in the DEQ noise regulation and the limits specified in the Washington
6 Department of Ecology (“DOE”) noise regulation. WAC 173-60-040.
7

8 The DEQ noise regulation has two criteria that apply to a new noise source located on a
9 “previously unused industrial site.” The first criterion, presented in Table 8 of the DEQ noise
10 regulation, establishes the maximum hourly statistical noise levels that may radiate from a new
11 noise source to a “noise sensitive receiver” such as a residence, church, school, or hospital. The
12 hourly L₅₀, L₁₀ and L₀₁ noise levels are defined as the noise level equaled or exceeded
13 50 percent, 10 percent and 1 percent of the hour, respectively. The criterion limits the maximum
14 hourly L₅₀, L₁₀ and L₀₁ noise radiating from a commercial or industrial noise source to 55, 60 and
15 75 dBA respectively between 7:00 a.m. and 10:00 p.m. and 50, 55, and 60 dBA respectively
16 between 10:00 p.m. and 7:00 a.m. The criterion is often referred to as the “maximum allowable
17 noise level criterion.”
18

19 The second criterion requires that the new noise source not increase the ambient hourly statistical
20 noise levels at a noise sensitive receiver by more than 10 dBA. This criterion is intended to
21 prevent large increases in noise levels at a receiver, and it is often referred to as the "ambient
22 noise degradation rule."
23

24 The Washington DOE noise regulation, like the Oregon regulation, has a maximum allowable
25 rule that specifies the maximum noise level allowed in any hour. However, unlike the Oregon
26 regulation, the Washington regulation does not distinguish between a source located on a
27 previously used site and a source located on a previously unused site. In other words, the
28 Washington noise regulation does not include an ambient degradation rule. Thus, for a source
29 located on a previously unused site, the Washington DOE noise regulation is often less stringent
30 than the Oregon DEQ noise regulation.
31

32 PGE measured noise at five residential structures, which were the two nearest noise sensitive
33 receivers in the vicinity of the proposed energy facility site in Oregon and three representative
34 sites in Washington. In addition to the residential measurements, PGE made ambient noise
35 measurements at a potential eagle nesting area. The potential eagle nesting area was located on
36 Crims Island on the Oregon side of the Columbia River. The residence nearest to the proposed
37 energy facility site on the Oregon side of the Columbia River was located about 4,780 feet from
38 the proposed energy facility site. The other residence was located about 6,000 feet from the
39 proposed energy facility site. The potential bird-nesting measurement site was located about
40 7,050 feet away from the proposed energy facility site. On the Washington side of the Columbia
41 River, the monitoring site nearest the proposed energy facility was located about 5,700 feet from
42 the proposed energy facility site. The other two monitoring sites were located 6,250 feet and
43 10,100 feet from the proposed energy facility site. A noise consultant to the Office analyzed data
44 in the ASC to estimate the ambient noise level at other residences in Washington that are closer
45 to the proposed energy facility site than those where PGE took measurements.

1
2 Current ambient noise at residences in Oregon nearest the proposed energy facility is mainly a
3 result of the noise radiating from Beaver during daytime and nighttime hours. At times during
4 the day, the noise at the residences is influenced by intermittent traffic on local roads. Current
5 ambient noise at residences in Washington nearest the proposed energy facility is mainly a result
6 of a combination of traffic on SR 4 and Beaver during the daytime hours. At night, the ambient
7 noise at those receivers is mainly a result of Beaver.
8

9 Daytime hourly L₅₀ noise levels at the nearest residence on the Oregon side of the Columbia
10 River typically ranged between 33 and 43 dBA, while daytime hourly L₅₀ noise levels at the
11 nearest residence measured on the Washington side of the river typically ranged between 41 and
12 47 dBA. The estimated daytime hourly L₅₀ noise levels at the residences that are closer to the
13 proposed energy facility site than those actually measured is about 44 dBA. Nighttime hourly
14 L₅₀ noise levels at the nearest residence to the proposed energy facility site on the Oregon side of
15 the Columbia River typically ranged between 34 and 42 dBA, while nighttime hourly L₅₀ noise
16 levels at the nearest measured residence on the Washington side typically ranged between 35 and
17 42 dBA. The estimated nighttime hourly L₅₀ noise levels at the residences that are closer to the
18 proposed energy facility site than those actually measured is about 34 dBA.
19

20 **Operation.** Noises sources at the proposed energy facility would include the combustion
21 turbines, the generators, the heat recovery steam generator, the steam turbine, the transformers,
22 and the cooling towers. According to PGE data taken at Beaver and at its Coyote Springs
23 Cogeneration Project, the heat recovery steam generators and the cooling towers would be the
24 loudest noise sources outside the generator building. The noise radiating from those two sources
25 was found to be 70 dBA and 72 dBA at 100 feet respectively. The measured reference data were
26 included by PGE in a noise propagation program to predict the total noise level that would
27 radiate from the proposed energy facility to residences in Oregon and Washington.
28

29 Based on the prediction results, the future hourly L₅₀ noise level at Site 1 (the residence located
30 in Oregon 6,000 feet SW of the plant) and Site 3 (the eagle nesting area located in Oregon
31 7,050 feet northeast of the plant) would be about the same as that currently found. The future
32 hourly L₅₀ noise level at Site 2 (the residence located 4,780 feet southeast of the plant) would be
33 about 2 dBA higher than that currently found. In Washington, the noise radiating from the
34 proposed energy facility would have no influence on the noise found at Sites 4 and 5 (the
35 residences located 10,100 feet and 6,250 feet from the plant respectively). The future noise at
36 Site 6 (the residence in Washington located about 5,700 feet north of the proposed plant) would
37 be about 2 dBA higher than that currently found with the proposed energy facility in operation.
38 Residences in Washington that are closer to PWGP than Site 6 should also see about a 2 dBA
39 increase from the operation of PWGP.
40

41 Furthermore, the noise study considered the issue of the cumulative effect of the noise from the
42 Summit Project, PWGP, Beaver, and Beaver 8 operating at the same time. Under the scenario
43 with two new generating plants, the projected increase in noise could be 3 dBA higher, but
44 would typically be about 2 dBA higher, at Sites 1, 2, and 6 and less at the other sites. Residences

1 in Washington that are closer to PWGP than Site 6 should also see about a 3 dBA increase with
2 all plants operating. All increases are within the Oregon and Washington standards.

3
4 Because PGE would operate the energy facility on a 24-hour basis, the noise radiating from the
5 proposed energy facility must comply with nighttime noise limits as well as daytime noise limits.
6 With the consideration of the ambient degradation rule noise limit and the nighttime maximum
7 hourly noise limits, the noise from the proposed energy facility would be limited to an hourly L₅₀
8 level as shown in Table E.1.

9
10 The noise radiating from the proposed energy facility would, generally speaking, be relatively
11 constant during an hour. As a result, the hourly L₀₁, the hourly L₁₀ and the hourly L₅₀ noise level
12 radiating from the facility would be about the same. Because the hourly L₅₀ noise level criterion
13 is the lowest criterion of the three hourly statistical level criteria, the hourly L₅₀ criterion would
14 be the most limiting criterion of the three in this case. PGE predicts the hourly L₅₀ noise level
15 radiating from the facility would be significantly below that allowed at each receiver. Thus,
16 since the noise radiating from the facility is relative constant in level, the hourly L₁₀ and L₀₁
17 noise levels radiating from the facility would also likely be significantly below the allowed by
18 the DEQ regulation. Therefore, the Council finds that PGE would comply with the hourly L₅₀,
19 L₁₀ and L₀₁ noise limits at all sites in Oregon and Washington.

20
21 **Table E.1**
22 **DEQ Hourly L₅₀ Criteria**
23

Site	DEQ Hourly L ₅₀ Criteria
1	50
2	43
3	47
4	47
5	50
6	44

24
25
26 The findings of the Council are based on predictions. It is necessary to test the operating energy
27 facility to determine that it actually complies with the noise standard. The Council requires the
28 certificate holder to conduct a compliance test within the first six months of operation of the
29 energy facility. The purpose of the test is to ensure that the increase in the ambient level of noise
30 with PWGP operating is not greater than 10 dBA. DEQ rules specify the testing protocol. A six-
31 month window for testing is necessary to allow the test to be conducted under appropriate
32 atmospheric conditions. If the energy facility demonstrates compliance with the DEQ standard
33 under the appropriate testing conditions, there is no need for subsequent tests. On-going
34 enforcement of the noise rules is the responsibility of DEQ. Sections B.1 and B.2 of this Order
35 contain further discussion of issues relating to noise testing.
36

1 **Construction.** Construction of the energy facility should produce noise levels similar to those
2 from any large construction project. Construction of the energy facility would involve the
3 operation of construction equipment, including light and heavy trucks, backhoes, bulldozers,
4 graders, cranes, air compressors, welding machines, and power hand tools. The DEQ noise
5 standard exempts noise that originates from construction activities. However, to reduce noise
6 impacts on nearby residences during construction of the energy facility, PGE would schedule
7 most construction work for daylight hours when people are generally less sensitive to noise.
8

9 **Contested Case Proceeding**

10 Otto Moosburner was the sole party objecting to any part of the proposed order at the hearing.
11 Moosburner owns a residence in Washington across the Columbia River from the site of the
12 proposed Port Westward Generating Plant. Site (6) for the noise tests was the Moosburner
13 residence.
14

15 At the commencement of the hearing, the parties were provided with a recitation of procedural
16 rights under the Administrative Procedure Act. Throughout the hearing, the parties were given
17 opportunity to examine and cross-examine witnesses, present documentary evidence and make
18 legal arguments.
19

20 Moosburner addressed the first two issues preserved for contested case proceeding:
21

- 22 1. Whether the condition requiring one-time monitoring during the first six months
23 of operation to ensure compliance with applicable DEQ and noise operating
24 standards is adequate.
25
- 26 2. Whether the lack of a requirement of a continuous monitoring plan by the
27 applicant, PGE is adequate.
28

29 No evidence or argument was presented at the contested case hearing addressing the third issue
30 preserved for hearing regarding construction noise. Accordingly, that issue is not addressed in
31 the following findings and conclusions.
32

33 *Procedural History*

34 The procedural history of the contested case proceeding is reported in part B.4 of this Order.
35

36 *Rulings*

37 The Hearing Office made various rulings as recorded in the Pre-hearing Order, the Order On
38 Issues for Hearing and at the contested case proceeding. After review of Moosburner's
39 exceptions and the responses, the Council finds that all rulings of the hearing officer were
40 correct.
41

42 *Findings of Fact*

- 43 1. PGE retained Albert G. Duble, P.E., to undertake a noise assessment to ascertain whether
44 the proposed plant would comply with DEQ noise standards. Duble concluded that the

1 plant would meet such standards and prepared a report documenting his assessment and
2 the basis for his conclusions. (PGE-2.)
3

4 2. Power plants, including the proposed plant, are steady noise sources. The proposed plant
5 is therefore expected to operate in steady state and generate a steady and predictable level
6 of noise. (Duble, Direct at 3.)
7

8 3. Duble predicted the effect of the proposed plant on the ambient noise level by adding
9 together a theoretical computer predicted value of noise from the plant and the actual
10 measured ambient noise level. (Duble, Tr. at 24.)
11

12 4. To ascertain the actual measured ambient noise level, Duble measured the existing noise
13 on a calm day. There was no wind at site (6), and the wind at site (5) was less than
14 10 mph. (Duble, Tr. at 25, 30.)
15

16 5. Duble's predicted value of additional noise was taken from a computer model and
17 assumed a calm day. The model did not factor in wind because the wind effect is too
18 complex. (Duble, Tr. at 31.)
19

20 6. Residence at site (6) sits on a bluff. Its location on a bluff would tend to attenuate or
21 reduce noise. Such location was not taken into account in the model. Because the model
22 does not account for such a location, the resulting prediction value offers a conservative
23 result, overstating the effect of the plant's noise on site (6). (Duble, Tr. at 26.)
24

25 7. Wind from the southeast could increase noise from the proposed plant at site (6).
26 Depending on the wind speed, velocity and other characteristics, the wind could increase
27 the noise up to 1 to 5 decibels. (Duble, Tr. at 32-34.)
28

29 8. Such an increase in noise caused by wind from the southeast would not necessarily result
30 in a violation of the ambient degradation standard of DEQ at site (6). Noise would have
31 to increase 8dBA to reach DEQ standard and that is highly unlikely over a sustained
32 period of time. (Duble, Tr. at 36-37; Standlee, Tr. at 59-60.)
33

34 9. The DEQ noise standards regulate noise levels over sustained periods and not short
35 bursts. Sustained winds and corresponding increase in noise levels exceeding 5 dBA are
36 highly unusual. (Standlee, Tr. at 59-60.)
37

38 10. Conditions at the proposed plant and noise generated by the plant can be expected to be
39 steady and vary very little from day to day if power conditions are the same. (Standlee,
40 Tr. at 51.)
41

42 11. Because the L-50 existing ambient level reported at page 8/Table 3 of PGE-2 (34 dBA
43 for site (6)) was taken in calm conditions, such amount is not the correct L-50 ambient
44 level to use in determining compliance with the ambient degradation standard when
45 measuring during wind conditions. (Standlee, Tr. at 59-60.)

- 1
2 12. Even applying the L-50 existing ambient level at page 8 or Table 3 of PGE-2 (34 dBA for
3 site (6)) as the L-50 ambient level to use in determining compliance with the ambient
4 degradation standard when measuring during wind conditions, the DEQ standard is not
5 likely to be violated. (Standlee, Tr. at 59-60.)
6
7 13. It is possible for the noise from the plant to increase over time as mufflers or silencers on
8 plant equipment wear. Such wear could result in a change of 3 or 4 dBA over a 10-year
9 period. Mufflers and silencers are and would have to be replaced periodically. (Standlee,
10 Tr. at 51.)
11
12 14. Continuous monitoring is not necessary nor undertaken on industrial noise sources,
13 especially for continuous process plants such as power plants. So long as the power plant
14 is operating in typical mode without extreme weather conditions, there is no or very small
15 variation in noise over time. (Duble, Direct at 4; Standlee, Direct at 6.)
16
17 15. Continuous monitoring is not considered useful or reliable because it measures overall
18 noise with no basis for identifying the noise source. Continuous monitoring is
19 undertaken at airports where noise source can be identified based on the airport's tracking
20 of incoming and outgoing flights. (Duble, Direct at 4-5; Standlee, Direct at 4.)
21
22 16. DEQ requires neither continuous monitoring nor repeated monitoring of industrial plants.
23 (Standlee, Direct at 6-8.)
24

25 [The *Findings of Fact* omits redundant statements identified in the Hearing Officer's Comments
26 on Exceptions.]
27

28 *Conclusions of law*

- 29 1. PGE satisfied its burden of proving a *prima facie* case of compliance with noise standards
30 for Oregon and Washington based on the information contained in the Office of Energy's
31 Proposed Order, Section E.1.a., the Duble's written direct testimony (PGE-3), and Duble's
32 Environmental Noise Assessment Report dated July 2001 (PGE-2).
33

34 Moosburner presented evidence through cross-examination of the PGE and Office of
35 Energy's experts that it may be possible to exceed 44 dBA at site (6) occasionally and in
36 short bursts under certain conditions and assumptions. First, one would have to assume
37 that the existing noise level at site (6) in very windy conditions would have to be the
38 same as measured on a calm day. Second, the wind would have to be in the right
39 direction, from the southeast, and very strong. Third, the mufflers and silencers on the
40 equipment of the proposed plant would have to be not properly maintained.
41

42 Duble, however, testified that the DEQ standards would not likely be violated. He had
43 never experienced weather conditions that would cause such an increase of 5 or 6 over a
44 sustained period of time necessary to show a violation of the L50 standard. Duble 35-36.
45 Standlee confirmed Duble's conclusion. 58-59.

1
2 Moosburner thus failed to establish that DEQ standards would likely be violated even
3 under this scenario. No other basis for finding a violation of DEQ standards was
4 presented.
5

- 6 2. PGE also established that power plants, including the proposed plant, will operate in a
7 steady state and that there is little likelihood of change over time sufficient to result in
8 violation of noise standards. Accordingly, one-time monitoring following completion of
9 construction and when all systems are functioning to show compliance with DEQ
10 standards should be sufficient. (Duble, Direct at 3-4.)
11
12 3. There is no basis for requiring continuous monitoring.
13
14 4. The evidence presented at the contested case proceeding requires no conditions to address
15 noise other than those set forth below.
16

17 The Council adopts the following conditions in the site certificate:
18

- 19 **(1) During construction of the facility, the Certificate Holder shall schedule most**
20 **heavy construction to occur during daylight hours. Construction work at**
21 **night shall be limited to work inside buildings and other structures when**
22 **possible.**
23
24 **(2) During construction of the facility, the Certificate Holder shall require**
25 **contractors to equip all combustion engine-powered equipment with exhaust**
26 **mufflers.**
27
28 **(3) During construction of the energy facility, transmission lines or other related**
29 **or supporting facilities, the Certificate Holder shall establish a complaint**
30 **response system at the construction manager's office to address noise**
31 **complaints.**
32
33 **(4) Within six months after the start of commercial operation of the energy**
34 **facility, the Certificate Holder shall retain a qualified noise specialist to**
35 **measure noise levels associated with the energy facility operation when**
36 **environmental conditions are expected to result in maximum sound**
37 **propagation between the source and the receivers and when the energy**
38 **facility is operating in a typical operations mode that produces maximum**
39 **noise levels.**
40
41 **(a) The specialist shall measure noise levels at sites (1), (2), (5), and (6), as**
42 **described in Exhibit X of the ASC, to determine if actual noise levels**
43 **are within the levels specified in the applicable noise regulations in**
44 **OAR 345-035-0035(1)(b)(B)(i).**
45

1 (b) The Certificate Holder shall report the results of the noise evaluation
2 to the Office.

3
4 (c) If actual noise levels do not comply with applicable DEQ regulations,
5 the Certificate Holder shall take those actions necessary to comply
6 with the regulations as soon as practicable.

7
8 (d) If initial measurements show that actual noise levels increase at
9 site (5) by 7 dBA or more, the Certificate Holder shall measure the
10 noise levels as specified in this condition and shall repeat the process
11 outlined in subsections (a), (b), and (c) for site (5) within six months
12 after completion of the initial measurements.

13
14 (5) The Certificate Holder shall install silencers on short duration noise sources
15 (e.g. steam vents) from the heat recovery steam generator.

16
17 **Conclusion**

18 The Council finds that PGE meets the Department of Environmental Quality noise standard,
19 OAR 340-035-0035(1)(b)(B)(i).

20
21 **E.1.b. Wetlands and Removal/Fill Permit**

22
23 **The Requirement.** The Council does not have a specific standard for wetlands. However,
24 pursuant to OAR 345-021-0010(1)(j), PGE must submit specific information about the proposed
25 facility’s “significant potential impacts” on wetlands within state jurisdiction under ORS Chapter
26 196. The Oregon Removal/Fill Law (ORS 196.800 through 990) and regulations adopted by the
27 Oregon Division of State Lands (“DSL”) (OAR 141-085-0005 through 141-085-0090) apply to
28 the proposed facility.

29
30 A Removal/Fill Permit is required if 50 cubic yards or more of material is removed, filled or
31 altered within any “waters of the state” at the proposed site. Under the Removal/Fill Law,
32 “waters of the state” include wetlands. The proposed facility would affect regulated waters and
33 would require a removal/fill permit in accordance with DSL regulations. Pursuant to OAR 345-
34 021-0010(1)(j)(D), the Council must determine that a required Removal/Fill Permit can be issued
35 to the proposed facility in compliance with ORS 196.800 *et seq.*

36
37 **Discussion**

38 The analysis area for wetlands is the site, including construction laydown areas.

39
40 PGE conducted on-site delineation field studies for the energy facility site in May, June, and
41 October, 2001, and in February, 2002, with follow-up visits in February and March, 2002; for the
42 Port Westward to BPA Allston Substation transmission line corridor in October, 2001, with
43 follow-up visits in February, 2002; for the BPA Allston Substation area in February, 2002; and
44 for the BPA Allston Substation to Trojan transmission line corridor in October, 2001, with
45 follow-up visits in February and March, 2002. DSL concurred with the final delineation on

1 April 3, 2002, (DSL Determination #01-0459) for all but the “southern option” of the BPA
2 Allston Substation to Trojan transmission line corridor. DSL concurred with the southern
3 corridor on June 20, 2002 (DSL Determination #01-0459 Addendum, App. # 25248).

4
5 Within the analysis area of the energy facility site and the immediately adjacent related or
6 supporting facilities, PGE identified five wetlands covering an area of 51.6 acres (ASC, Exhibit
7 P, Table P-3, page P-19). It identified 29 wetlands along the transmission corridors with a total
8 area of 115.1 acres (ASC, Exhibit J, Table J-2, page J-4). PGE described each wetland in the
9 ASC (ASC, Exhibit J, Appendix J-1 and Revised Appendix J-3).

10
11 The wetlands within the analysis area include palustrine emergent, palustrine scrub shrub,
12 palustrine forested, palustrine open water, palustrine unconsolidated bottom, and riverine
13 unconsolidated bottom. Other regulated waters include perennial and intermittent streams.

14
15 **Wetland Impacts.** Based on the delineation, the facility would have an impact on 0.43 acres of
16 palustrine wetlands (ASC, Exhibit J, Table 1, page J-2). Construction of the facility would cause
17 permanent impacts to 0.30 acres of emergent wetland and 0.10 acres of palustrine scrub shrub
18 wetland and temporary impacts to 0.03 acres of palustrine emergent wetlands. PGE estimates
19 that a total of about 3,000 cubic yards of material would be placed within a wetland for the
20 facility, and 4,500 cubic yards would be removed from wetlands for the mitigation area (ASC,
21 Exhibit J, page J-5). The wetlands that would be affected are within Wetland Area 4 on the
22 energy facility site and immediately adjacent related or supporting facilities and in 14 tower
23 locations along the transmission line corridors (six within Wetland 4 and nine between the
24 energy facility and the BPA Allston Substation) (ASC, Exhibit J, page J-5; Revised Appendix J-
25 3, page 1 and Figure J-3.1).

26
27 Anticipated impacts to wetlands and proposed mitigation measures to avoid, minimize, and
28 compensate for impacts are described in the Draft Removal/Fill Permit (Attachment C to this
29 Order) and the Wetland Mitigation Plan for the Port Westward Generating Project (ASC, Exhibit
30 J, Revised Appendix J-3).

31
32 **Proposed Mitigation.** PGE proposes to implement the following mitigation measures:

33
34 **Avoidance and Minimization.** PGE has redesigned the facility and modified the location of
35 transmission line towers to avoid and minimize potential impacts to regulated “waters of the
36 state.” Redesign elements include: (1) shifting the energy facility location; (2) reducing the
37 area of fill in Wetland 4; and, (3) locating all related or supporting linear facilities within existing
38 roads or upland areas to the greatest extent possible.

39
40 **Mitigation Plan.** The Wetland Mitigation Plan (ASC, Exhibit J, Revised Appendix J-3)
41 describes the proposed mitigation, mitigation goals, design implementation, proposed grading,
42 planting and seeding plans, and monitoring.

43
44 PGE proposes to compensate for 0.43 acres of unavoidable permanent impacts by enhancing
45 1.5 acres of palustrine emergent wetlands (with a scrub shrub component) on the facility site.

1 The mitigation area would be located in Wetland 4, west of the energy facility and north of the
2 existing Beaver Generating Plant (ASC, Exhibit J, Revised Appendix J-3, Figure J-3.1).

3
4 PGE would enhance the existing wetland by altering the hydrology to provide for a longer period
5 of inundation or saturation, planting trees, shrubs and emergents to provide habitat diversity,
6 palustrine scrub shrub and forested areas, and reducing reed canarygrass coverage. Hydrology to
7 the wetland would be primarily from direct precipitation and groundwater. PGE would excavate
8 the mitigation area to provide varying depths of water, and PGE would construct a berm and
9 weir to increase the duration of inundation and provide for water overflow exchange between the
10 existing wetland and the proposed mitigation site during periods of high precipitation. PGE
11 would control reed canarygrass by excavation, mowing and spraying with Rodeo, an EPA-
12 approved herbicide. PGE would plant the mitigation site with tree, shrub, herb, and grass species
13 (ASC, Exhibit J, Revised Appendix J-3, Tables J-3.1 and J-3.2). PGE would also place large
14 woody debris within the wetland to provide wildlife and amphibian habitat.

15
16 PGE would monitor the mitigation site for five years and would provide an annual report to DSL
17 documenting wetland conditions and plant coverage. The monitoring report would include field
18 data, hydrology monitoring, photographs taken from established points, data analysis, and
19 recommendations for maintenance or remedial actions.

20
21 Temporary impacts would be alleviated by returning the impact area to the original grade,
22 restoring the original topsoil, and re-seeding with an appropriate wetland seed mix.

23
24 **Contingency Plan.** The vegetative cover within the emergent portion of the mitigation area
25 would comprise at least 80 percent native wetland plants at the end of the monitoring period, and
26 the planted trees and shrubs would have an 80 percent survival (ASC, Exhibit J, Revised
27 Appendix J-3, page 9).

28
29 In consultation with DSL, the Council has analyzed the proposed fill against the legal standards
30 imposed by the Removal/Fill Law and applicable administrative rules. Through this Order, the
31 Council directs DSL to issue a Removal/Fill Permit that authorizes the fill of up to 3,000 cubic
32 yards of material and the removal of 4,500 cubic yards of material, provided that all unavoidable
33 wetland impacts are fully mitigated in compliance with approved mitigation plans pursuant to the
34 conditions in this Order and the Removal/Fill Permit.

35
36 **Statutory Standards, ORS 196.825**

37 ORS 196.825(2) provides the overall decision standard for permitting wetland fills. It provides
38 that a permit shall be issued for filling waters of this state only after a determination that “the
39 proposed fill would not unreasonably interfere with the paramount policy of this state to preserve
40 the use of its waters for navigation, fishing and public recreation.”

41
42 The Council finds that the proposed wetland removals and fills meet this standard because:

- 43
44 (a) The impacted wetlands do not now offer significant values related to public
45 navigation, fishing, and recreation;

- 1 (b) The proposed energy facility was redesigned to avoid or minimize wetland impacts;
2 and,
3 (c) PGE proposes to compensate for 0.43 acres of unavoidable impacts to wetlands by
4 enhancing 1.5 acres of palustrine emergent and scrub shrub riverine flow-
5 through/depressional wetlands on the site.
6

7 ORS 196.825(3) requires consideration of certain factors in determining whether to grant a
8 removal/fill permit:
9

- 10 (a) The public need for the proposed fill and the social, economic or other public benefits
11 likely to result from the proposed fill ***.
12

13 This factor addresses the public need for the proposed “fill” and not the need for the
14 proposed “facility.” This consideration takes the proposed facility as a given. The public
15 need for the proposed fill is demonstrated because it is likely that some fill activity would
16 be necessary to allow any industrial development at the proposed site.
17

18 Columbia County’s acknowledged comprehensive land use plan contains a section called
19 the Port Westward Exception Statement. The County found in this statement that there is a
20 public need for land zoned RIPD and that the nearly 900-acre tract known as the Port
21 Westward industrial area contained certain features making it uniquely appropriate for that
22 zone. The social, economic and other public benefits from this zoning are described in
23 detail in the County Comprehensive Plan at page 147. LCDC has acknowledged those
24 findings, and they need not be reproduced here.
25

26 Based on site inspections by the Office and DSL, the Council finds that that any industrial
27 development that completely avoids wetlands would be unlikely within the Port Westward
28 industrial area because of the high incidence of wetlands in the area. PGE has made every
29 effort to configure the facility to avoid wetlands at the site, but it could not do so entirely.
30 Therefore, the Council finds that the proposed fill is needed for the facility to go forward,
31 and in fact some removal-fill activity would be needed for any use of this land in the
32 manner for which it is zoned.
33

- 34 (b) The economic cost to the public if the proposed fill is not accomplished.
35

36 PGE has redesigned and reconfigured the proposed facility to avoid and minimize impacts to
37 waters of the state. Additional redesign efforts are unlikely to eliminate completely the need
38 for the proposed fill. The economic cost to the public if the proposed fill is not accomplished
39 is that the land that the County designated RIPD could not be fully developed. The County,
40 in the Port Westward Exception Statement, noted that Columbia County has a shortage of
41 industrial land and that the Port Westward industrial area has features that make it uniquely
42 suitable for that use.
43

- 44 (c) The availability of alternatives to the project for which the fill is proposed.
45

1 PGE proposed the fill in conjunction with construction and operation of PWGP. "Project"
2 means "any removal and/or fill activity or both in waters of the state. * * * " OAR 141-085-
3 0010(31). PGE evaluated two sites adjacent to Beaver, one to the south (Site #1) and one to the
4 north (Site #2). (See Figure J-4.6 in the ASC.). PGE rejected other sites within the 852-acre
5 area that are not adjacent to the existing plant because the development of infrastructure (roads,
6 gas, and raw water pipelines, etc.) would create a higher level of environmental impact.
7 Geotechnical evaluation revealed that the soils at the site to the south of Beaver were unsuitable
8 for the plant foundation. The site to the north of Beaver will provide a suitable foundation and
9 is PGE's proposed location for PWGP.

10
11 PGE shifted the conceptual plant location identified in Figure J-4.6 slightly to avoid wetland
12 impacts. PGE shifted the north site location (Site #2) further toward the northeast in order to
13 minimize impacts to Wetland 4. PGE eliminated the corners of the original fill proposal
14 (Fig J-4.2) to avoid even more wetland.

15
16 Approaching the generating plant, the transmission corridor traverses a broad area of flat terrain,
17 much of which is wetlands. PGE aligned the towers to avoid utility conflicts with the process
18 water discharge line (Towers T- 65 to T-70) and the U.S. Gypsum gas pipeline (Towers T-56 to
19 T- 61), resulting in their placement within wetlands.

20
21 (d) The availability of alternative sites for the proposed fill.

22
23 PGE has undertaken alternative site design and transmission tower alignment to avoid and
24 minimize potential impacts to waters of the state to the maximum extent practicable.
25 Redesigned elements include: (1) shifting the energy facility location; (2) reducing the area
26 of fill in Wetland 4; and, (3) locating all related or supporting linear facilities, including the
27 natural gas pipeline, transmission line and water supply pipeline, within existing roads or
28 upland areas to the greatest extent possible.

29
30 (e) Whether the proposed fill conforms to sound policies of conservation and would not
31 interfere with public health and safety.

32
33 Sound conservation policies include impact avoidance, mitigation of unavoidable impacts,
34 and, in general, compliance with relevant natural resource policies. The proposed energy
35 facility would be consistent with the sound policies of conservation because opportunities to
36 avoid impacts to wetlands and aquatic resources have been evaluated and incorporated in the
37 site selection and final design layout. Siting of the energy facility and related or supporting
38 facilities avoids sensitive habitats related to wetlands and riparian areas to the maximum
39 extent practicable. The proposed fill would be located within an area zoned RIPD and would
40 not interfere with public health and safety.

41
42 (f) Whether the proposed fill is in conformance with existing public uses of the waters
43 and with uses designated for adjacent land in an acknowledged comprehensive plan
44 and zoning ordinances.

1 The proposed fill is in conformance with existing public uses of the waters of the state. The
2 area of proposed fill is within a privately owned wetland. Construction and operation of the
3 facility would not result in a net loss of wetland function because PGE's mitigation plan
4 would replace wetland functions by enhancing existing wetlands at a greater than 3:1 ratio
5 within the facility site. The construction of a seasonal ponded, palustrine emergent/scrub
6 shrub wetland would provide wildlife and amphibian habitat.

7
8 The energy facility site and surrounding lands have a zoning designation of RIPD (ASC,
9 Exhibit K, page K-5). The facility would be compatible with the adjacent existing and
10 planned land uses.

11
12 (g) Whether the proposed fill is compatible with the acknowledged comprehensive plan
13 and land use regulations for the area where the proposed fill is to take place.

14
15 The proposed fill would affect land zoned RIPD. Conditional uses permitted in the RIPD
16 zone include the storage and distribution of services, a function interpreted by the Columbia
17 County Planning Department to include the storage and distribution of electricity service. As
18 part of the site design review approval process, PGE must demonstrate that alteration of a
19 wetland or riparian area would be in compliance with state and federal laws, a condition that
20 would be satisfied upon showing that the removal/fill permit should be issued.

21
22 (h) Whether the proposed fill is for streambank protection.

23
24 The proposed fill has no relation to streambank protection.

25
26 **Administrative Rule Standards, OAR 141-085-0050**

27 OAR 141-085-0050(2) requires an evaluation of probable impacts, including cumulative
28 impacts, of the proposed fill activity and its intended use on the water resources by considering
29 certain factors in addition to those required by the statute:

30
31 (a) The environmental and economic consequences of the proposed fill or removal.

32
33 The proposed fill would have minimal environmental impact. PGE would implement
34 specific mitigation measures to minimize impact to waters of the state and wildlife habitat.
35 Additional mitigation measures and wetland replacement would be implemented to fully
36 compensate for any unavoidable adverse impacts. There appear to be no adverse economic
37 consequences of the fills.

38
39 (b) Direct and indirect effects of the fill or removal on submerged and/or submersible
40 lands.

41
42 The proposed fill would have no direct or indirect effects on submerged and submersible
43 lands.

1 (c) Effects of the fill or removal on the hydraulic characteristics of the fill or removal site
2 and surrounding areas, such as water circulation, tidal fluctuation, current patterns
3 and flood hazards.
4

5 Impacts related to construction and operation of the facility would include filling 0.43 acres
6 of emergent/scrub shrub wetlands. Elimination of this portion of the wetland would not
7 interfere with surrounding naturally-occurring and manmade flow regimes, or the flow
8 patterns off the facility site. There would be no impacts to the Beaver Drainage District
9 irrigation canals. Therefore, no permanent effect is expected on circulation, hydraulic
10 characteristics, current patterns, or flood hazard.
11

12 (d) Effects of the fill or removal on special aquatic sites and refuges, sanctuaries and
13 scenic waterways.
14

15 The proposed fill would not affect refuges, sanctuaries, or scenic waterways. PGE has
16 determined that the existing on-site wetlands have only moderate functional levels. They are
17 and have been historically disturbed and are dominated by non-native grasses, and they do
18 not appear to possess the characteristics of "special aquatic sites."
19

20 (e) Effects of the fill or removal on water supply, water access, public recreation and
21 aesthetics.
22

23 The proposed fill would not interfere with water supply, water access, or public recreation.
24

25 (f) Effects of the fill or removal on water quality and aquatic life and habitats.
26

27 PGE would fill 0.43 acres of wetlands that currently provide a limited contribution to the
28 area's water quality and were rated as having a sediment-trapping function that would be
29 affected by the fill. Though waterfowl may graze the wetland to be affected, the proposed
30 compensatory mitigation plan would adequately compensate for water quality functions by
31 providing a palustrine emergent/scrub shrub wetland to replace lost functions and values.
32

33 (g) Whether the proposed fill or removal activity adversely affects the health, safety and
34 welfare of the people of this state.
35

36 The proposed fill would not adversely affect the public health, safety and welfare.
37

38 OAR 141-085-0050(3) requires consultation with local governments to determine that the
39 proposed fills are consistent with the local comprehensive plan and ordinances and planning
40 goals. PGE elected to obtain a Council determination of compliance with the statewide planning
41 goals adopted by the Land Conservation and Development Commission under ORS
42 469.504(1)(b). The Council finds that PGE has satisfied this requirement as demonstrated in
43 Section D. 4 and Appendix D of this Order, Land Use Standard Analysis.
44

1 OAR 141-085-0050(4) provides that no permit to fill or remove material shall be issued until
2 certain determinations have been made:

- 3
4 (a) The project is consistent with the water quality and toxic effluent standards of the
5 State of Oregon as administered by the Oregon Department of Environmental Quality
6 and would not result in significant degradation of the waters of the state
7

8 Federal regulations and the state of Oregon require PGE to obtain an NPDES General Permit
9 1200-C for discharges of storm water runoff during construction of the facility. To obtain
10 this permit, PGE must develop a Storm Water Pollution Prevention Plan (“SWPPP”) for the
11 entire construction site. The main purpose of the SWPPP is to protect local water quality by
12 reducing pollutants in storm water discharges from the construction site.
13

14 As more fully described in Section D.7 of this Order and the conditions imposed under that
15 Section, PGE would implement measures to control wastewater during construction,
16 operation, and retirement of the facility. As described in Section E.1.d of this Order and the
17 conditions imposed under that section, PGE would obtain a WPCF Permit for sanitary waste
18 before beginning operation of the energy facility. And, as described in Section D.2.d of this
19 Order and the conditions imposed under that section, PGE would discharge non-sanitary
20 wastewater from the energy facility site by means of a wastewater treatment facility to be
21 constructed by the Port of St. Helens under an NPDES permit that the Port will obtain from
22 DEQ. Upon satisfaction of those conditions, PGE would be consistent with state water
23 quality and toxic effluent standards.
24

- 25 (b) The project meets historical and archaeological site preservation requirements of
26 ORS 390.235
27

28 As more fully described in Section D.11 of this Order, PGE has demonstrated that no
29 archaeological sites were identified in the analysis area for PWGP. Conditions imposed
30 under that section are designed to ensure compliance with relevant state and federal laws and
31 regulations in the event unanticipated archaeological or historical resources are encountered
32 during construction of the facility.
33

- 34 (c) There is no practicable alternative to the proposed fill or removal which would have
35 less adverse impact on the water resources of the State of Oregon.
36

37 Avoidance of impacts on water resources was a primary consideration in selection of the
38 final site design. PGE evaluated several design layout options in an effort to identify an
39 alignment that minimized impacts to the environment, including wetlands and other aquatic
40 resources. PGE selected a final site layout that provides the best balance between the
41 multiple requirements contained in the Council’s energy facility siting process. Redesign of
42 the energy facility and related or supporting facilities was implemented to avoid impacts to
43 jurisdictional wetlands and other regulated waters to the maximum extent practicable, while
44 accommodating constraints placed on the facility by existing roads, utilities, structures, and

1 manufacturer design criteria. The final design layout of the facility reflects the avoidance
2 and minimization of temporary and permanent impacts to water resources.

3
4 (d) The project would not adversely affect rare, threatened or endangered species in the
5 State of Oregon.

6
7 As more fully discussed in Sections D.8 and D.9 of this Order, PGE has evaluated the
8 analysis area for the presence of rare, threatened, and endangered species. Based on the
9 findings and subject to the conditions recommended in Sections D.8 and D.9 of this Order,
10 PWGP would not adversely affect rare, threatened, or endangered species in the State of
11 Oregon.

12
13 (e) The project individually or collectively would not cause significant degradation of
14 municipal water supplies; aquatic life and habitats; functions of the aquatic
15 ecosystem; or recreational, aesthetic and economic values of the water resources of
16 the state.

17
18 As more fully discussed in Sections D.6 and D.13 of this Order, PGE has demonstrated that
19 construction and operation of the facility would not cause significant degradation of
20 municipal water supplies. All unavoidable impacts of the proposed fill would be offset by
21 compensatory mitigation through enhancement of existing wetlands at a 3:1 ratio in close
22 proximity to the energy facility site. The construction of an enhanced emergent and scrub
23 shrub wetland would provide waterfowl cover and fawning habitat for Columbia white-tailed
24 deer, as well as habitat for amphibians and birds. Waters of the state affected by the
25 proposed fill are not used for navigation, fishing or recreation.

26
27 (f) Appropriate and practicable steps have been taken which will minimize adverse
28 impacts of the fill or removal on aquatic life and habitats.

29
30 PGE redesigned the energy facility and related or supporting facilities to avoid impacts to
31 jurisdictional wetlands, streams, and ditches to the maximum extent practicable, while
32 accommodating constraints placed on the facility by existing roads, utilities, structures, and
33 manufacturer design criteria. The final design layout of the facility reflects the avoidance
34 and minimization of temporary and permanent impacts to aquatic life and habitats.

35 36 **Consistency with DSL Statutes and Rules**

37 The Council finds that, subject to the conditions stated in this Order, PWGP is consistent with
38 DSL's removal/fill permit and mitigation requirements for the reasons stated below:

- 39
40
- 41 · PGE has sought to avoid and minimize impacts to jurisdictional waters;
 - 42 · The affected wetlands do not now offer uses related to fishing, navigation, or recreation;
 - 43 · No navigable waters will be affected by PWGP;
 - 44 · Proposed impacts are primarily to low quality, reed-canarygrass-dominated wetlands and
higher quality wetlands have been avoided;

- 1 · PGE has addressed DSL permit application requirements and submitted the appropriate
- 2 fees to the agency;
- 3 · DSL concurred on the wetlands delineation that PGE provided;
- 4 · DSL would issue a Removal/Fill Permit as directed by the Council;
- 5 · Mitigation for impacts to wetlands would be on-site and in-kind and would replace lost
- 6 functions and values;
- 7 · No rare, threatened or endangered species would be adversely affected by the PWGP;
- 8 · Monitoring would be conducted for five years with an annual monitoring report
- 9 submitted to DSL; and
- 10 · Contingency measures would be implemented to ensure the mitigation area meets
- 11 mitigation goals and permit conditions.

12
13 The Council adopts the following conditions in the site certificate:

- 14
15 **(1) Before beginning construction of the energy facility or the Port Westward to**
- 16 **BPA Allston Substation Transmission Line, as appropriate, the Certificate**
- 17 **Holder shall obtain a U.S. Army Corps of Engineers and Oregon Division of**
- 18 **State Lands Joint Removal/Fill Permit substantially in the form of the**
- 19 **Removal/Fill Permit in Attachment C; provided, that mitigation required**
- 20 **under the Removal/Fill Permit shall allow for accommodation of Corps of**
- 21 **Engineers mitigation requirements, subject to the concurrence of the Office,**
- 22 **in consultation with the Division of State Lands and affected federal agencies.**
- 23
24 **(2) The Certificate Holder shall comply with state laws and rules applicable to**
- 25 **the Removal/Fill Permit that are adopted in the future to the extent that such**
- 26 **compliance is required under the respective statutes and rules.**
- 27

28 **Conclusion**

29 The Council finds that PGE complies with OAR 345-021-0010(1)(j) and ORS 196.800-990,
30 subject to issuance of a Removal/Fill Permit substantially in the form of Attachment C to this
31 Order.

32 **E.1.c. Public Health and Safety**

33 **The Requirement.** Pursuant to ORS 469.310, the Council is charged with ensuring that the
34 “siting, construction and operation of energy facilities shall be accomplished in a manner
35 consistent with protection of the public health and safety***.” State law further provides that
36 “the site certificate shall contain conditions for the protection of the public health and
37 safety***.” ORS 469.401(2).
38

39 **Discussion**

40 The site certificate will contain conditions for the protection of the public health and safety with
41 respect to several Council standards. However, certain public health and safety issues that are
42 not otherwise addressed in Council standards warrant special attention: (1) the potential for
43 cooling tower fogging and icing to affect driving conditions on public roads; (2) the potential
44 health concerns regarding electric and magnetic fields from high-voltage transmission lines; (3)
45

1 the certificate holder’s coordination with the Oregon Public Utility Commission (“PUC”) to
2 ensure that the certificate holder designs and builds the electrical transmission lines and natural
3 gas pipelines in accordance with the appropriate codes and standards; and, (4) pipeline safety
4 monitoring pursuant to OAR 345-027-0020(3)(b). These four issues are discussed below.
5

6 **Cooling Tower Fogging and Icing.** The energy facility would include two mechanical-draft
7 cooling towers, each tower containing five cells. The cooling towers are located along the
8 northwest side of the site. The 10 cells are oriented in a line running from southeast to
9 northwest. This is a well-selected orientation because the wind is predominantly from directions
10 that are not parallel to this line, thereby aiding dispersion of the water vapor.
11

12 Ground level fogging occurs when the cooling tower plume approaches ground level. Icing can
13 occur during periods when ground level fogging coincides with freezing surface temperatures.
14 Either event may adversely affect local driving conditions.
15

16 PGE prepared a modeling analysis that showed an average of about 139 hours of ground level
17 fogging per year over the five-year period for which meteorological data were studied (1986-
18 1990). (Because local data were not available, PGE used data from the Portland airport.)
19 Ground level fogging would be predominantly over water to the north and north-northeast of the
20 plant. The model also predicted ground level fogging would occur about 47 hours in an average
21 year generally to the west, west northwest, and northwest of the plant, much of which is over
22 land. Most of that ground level fogging would occur in the range of 200 meters to 500 meters
23 from the cooling towers.
24

25 The analysis predicted icing would occur during only one year of the five-year period analyzed.
26 During that year, icing was predicted to occur 8.4 hours. PGE predicted that all icing would
27 occur to the west-northwest of the cooling towers.
28

29 PGE stated that the modeling analysis yields conservative estimates of ground level fogging and
30 icing. That is, actual fogging and icing could be less than is predicted by the model. Actual
31 weather conditions could also differ from the conditions during the 5-year period used in the
32 modeling analysis. While the likelihood of ground level fogging or icing is small, it is not zero.
33

34 Erickson Dike Road and Kallunki Road pass within areas predicted by the model to experience
35 fogging and icing. However, they are not public roads in the vicinity of the proposed energy
36 facility and are lightly used. The model does not predict any ground level fogging or icing on
37 public roads.
38

39 Because weather patterns may vary from those applied in the modeling analysis, the Council
40 adopts the following condition:
41

- 42 **(1) If local public safety authorities notify the Certificate Holder and the Office that**
43 **the operation of the energy facility is contributing significantly to ground level**
44 **fogging or icing along public roads and is likely to pose a significant threat to**
45 **public safety, the Certificate Holder shall cooperate with local public safety**

1 **authorities regarding the posting of warning signs on affected roads and the**
2 **implementation of other reasonable safety measures.**

3
4 The Council finds that ground level fogging and icing along public roads from the operation of
5 the energy facility is not likely and is not likely to pose a significant threat to public safety.
6

7 **Transmission Lines.** As discussed in Section C.1.b, PWGP and the Summit Project present a
8 unique situation regarding the transmission lines for their facilities. Because the Council is
9 reviewing the applications for both projects simultaneously, because they would use the same
10 towers, and because the same company would build and operate the transmission lines, the
11 Council has consolidated the reviews within this Order and is placing conditions for the
12 combined lines in the site certificate for the Port Westward Generating Project.
13

14 The transmission line can be seen as two long sections and several short interconnecting
15 segments. There are two main sections:
16

- 17 (1) A double-circuit, 230 kV line for PWGP and the Summit Project. The section runs
18 in the existing Port Westward to BPA Allston Substation right-of-way ("ROW,"
19 both singular and plural) from the Summit Project tie-in adjacent to that plant to
20 the vicinity of the BPA Allston Substation (about 10 miles long). It is entirely
21 within the existing ROW. This line would include only a single circuit if only one
22 energy facility, PWGP or the Summit Project, were constructed.
23
- 24 (2) The PWGP single-circuit, 230 kV line between the vicinity of the BPA Allston
25 Substation and Trojan (also about 10 miles long).
26

27 PGE proposed two options for the line between the BPA Allston Substation and Trojan. Each
28 option would require a new ROW:
29

- 30 · One option would be adjacent to the BPA ROW on the north side,
- 31 · The other option is adjacent to the BPA ROW on the south side.
32

33 There are short interconnecting segments:
34

- 35 (a) A single-circuit from PWGP to the point of the tie-in with the Summit Project on
36 the section of the line into the BPA Allston Substation; and
37
- 38 (b) Separate short segments for both PWGP and the Summit Project into the BPA
39 Allston Substation in the vicinity of the BPA Allston Substation.
40

41 **Electric Fields.** Strong electric fields can induce electric voltages in nearby objects, such as
42 fences. If proper precautions are not taken, these induced voltages might result in electric
43 shocks.
44

1 The Council has adopted a limit for electric fields from transmission lines of 9 kV per meter at
2 one meter above the ground surface in areas that are accessible to the public. OAR 345-024-
3 0090(1). The BPA guidelines for its transmission lines limit electric fields to a maximum of
4 9 kV per meter within the ROW, 5 kV per meter at the edge of the ROW, and 5 kV per meter at
5 highway crossings. (BPA Red Book, 1993)

6
7 PGE calculated electric fields one meter above grade under existing conditions along the existing
8 Port Westward to BPA Allston Substation ROW and along the BPA Allston Substation to Trojan
9 ROW. The calculations showed the following.

- 10
11 (a) Under existing conditions, the maximum electric field is less than 3.5 kV/meter
12 along the existing Port Westward to BPA Allston Substation ROW and about
13 4.5 kV/meter along the BPA Allston Substation to Trojan ROW. At the edges of
14 the ROW, electric fields are less than 1 kV/meter.
15
16 (b) The addition of a single-circuit line to the existing Port Westward to BPA Allston
17 Substation ROW would increase the maximum field strength to about 4 kV/meter.
18 At the edges of the ROW, the electric field strength would remain about
19 1 kV/meter. The single-circuit line could be used for either PWGP or the Summit
20 Project.
21
22 (c) The addition of a single-circuit line adjacent to the BPA Allston Substation to
23 Trojan ROW would have a negligible effect on the electric field strength within,
24 and at the edges of, the existing BPA ROW. Within the new PGE ROW, the
25 electric field strength would be about 4 kV/meter everywhere and less than
26 0.5 kV/meter at the edges.
27
28 (d) The addition of a double-circuit line to the existing Port Westward to BPA
29 Allston Substation ROW would yield maximum field strengths not exceeding
30 4 kV/meter within the ROW. Fields at the edges of the ROW would remain less
31 than 1 kV/meter.
32

33 Because the calculated electric fields would be about 5 kV/meter at all locations within the ROW
34 under all of the modeled conditions, BPA and Council standards would be met if any of the
35 proposed transmission lines within the ROW were built.

36
37 PGE did not calculate the electric field strength resulting from interconnecting line segments
38 outside of existing ROW for the existing Port Westward to BPA Allston Substation
39 Transmission Line. These segments include the line from PWGP to the existing ROW for the
40 existing Port Westward to BPA Allston Substation line and the short segments connecting
41 PWGP and the Summit Project at the BPA Allston Substation. The magnitudes of voltage and
42 current along these segments would be the same as those along the segments for which electric
43 field strengths were calculated. Therefore, the Council does not expect electric field strengths
44 along these segments to exceed 5 kV/meter, so PGE would meet BPA and Council standards.

1 For double-circuit lines, PGE modeled the lines in an A-B-C, C-B-A configuration so that the
2 fields cancel. That is the configuration PGE uses to construct double-circuit lines.

3
4 Electric fields can induce voltages in structures, causing electric shock when the structure is
5 touched. That is, the induced voltage causes an unwanted current to flow in a person contacting
6 the structure. Protection can be effected by either isolating the structure to prevent contact or by
7 grounding and/or bonding the structure. Grounding and/or bonding provides a free path for
8 electric current through a conducting wire or metal rod to the ground, serving a function similar
9 to that of a lightning rod. Electricity follows the path of least resistance to ground, thereby
10 reducing the possibility of a shock hazard due to stray currents.

11
12 In addition to electrical fields, which can result in induced voltages, magnetic fields from
13 transmission lines can induce currents in metal objects such as fences and buried pipelines. The
14 Council has a standard that the certificate holder must be able to design, construct and operate
15 proposed transmission lines so that induced currents will be as low as reasonably achievable.
16 OAR 345-024-0090(2). In the ASC, PGE did not propose specific measures to minimize
17 induced currents that may result from the interaction of electric fields with structures such as
18 fences. In reply to an information request from the Office, PGE verified that, if a double circuit
19 line were constructed, it would orient the conductors so that the fields tend to cancel.
20 Furthermore, the design and operation of the transmission line must comply with Title 49, Code
21 of Federal Regulations, Part 192, which requires that the certificate holder ensure that the
22 cathodic protection system in the transmission line not interfere with other existing facilities.
23 Finally, the Oregon Public Utility Commission, through the coordination required in
24 Condition (8), below, will ensure that the transmission line is designed to minimize induced
25 currents and voltage.

26
27 PGE has proposed a conductor arrangement that tends to cancel fields, where possible; and,
28 proposed Conditions would require PGE to use good utility practices to minimize induced
29 voltage and currents. Therefore, the Council finds that PGE can design, construct and operate
30 the proposed transmission lines so that induced currents from it will be as low as reasonably
31 achievable.

32
33 The Council adopts the following conditions:

- 34
35 **(2) The Certificate Holder shall design the transmission lines so that alternating**
36 **current electric fields shall not exceed 9 kV per meter at one meter above the**
37 **ground surface in areas accessible to the public.**
38
39 **(3) The Certificate Holder shall design the transmission lines so that induced**
40 **currents and voltage resulting from the transmission lines are as low as**
41 **reasonably achievable.**
42
43 **(4) The Certificate Holder shall develop and implement a program that provides**
44 **reasonable assurance that all fences, gates, cattle guards, trailers, or other**
45 **objects or structures of a permanent nature that could become inadvertently**

1 **charged with electricity are grounded or bonded throughout the life of the**
2 **transmission line.**

3
4 **(5) The Certificate Holder shall restore or mitigate the reception of radio and**
5 **television at residences and commercial establishments in the primary**
6 **reception area to the level present before operation of the transmission line at**
7 **no cost to residents or businesses experiencing interference resulting from**
8 **the transmission line.**

9
10 **(6) The Certificate Holder shall design, construct and operate the transmission**
11 **lines in accordance with the requirements of the National Electrical Safety**
12 **Code.**

13
14 The Council finds that the proposed transmission lines are consistent with protecting public
15 health and safety in regard to electric fields and induced currents.

16
17 **Magnetic Fields.** In addition to concerns about induced currents from magnetic fields, there has
18 been concern that human exposure to magnetic fields might cause health risks. This issue has
19 been the subject of considerable scientific research and discussion. The Council received public
20 comments about the issue, as discussed in Section B.1 above.

21
22 The Council previously considered this issue. Based on its review, the Council concluded that
23 the credible evidence relating low levels of exposure to health risks was inconclusive and that
24 there was insufficient information upon which to set “health based” limits for exposure to
25 magnetic fields. The Council recommended that, given the uncertainty as to health
26 consequences, those who propose transmission lines under the Council’s jurisdiction should use
27 low-cost ways to reduce or manage public exposure to magnetic fields. This approach is
28 sometimes referred to as “prudent avoidance.”

29
30 Several other authorities have considered this issue and have reached conclusions similar to
31 those of the Council. As part of the 1992 Energy Policy Act, the U.S. Congress authorized the
32 Electric and Magnetic Fields Research and Public Information Dissemination Program. It
33 culminated in a report by the National Institute of Environmental Health Sciences (“NIEHS”) in
34 May, 1999, entitled “Health Effects from Exposure to Power-Line Frequency Electric and
35 Magnetic Fields” (NIH Publication No. 99-4493).

36
37 The NIEHS report includes the following conclusions.

- 38
39 1. The scientific evidence suggesting that extremely low frequency electric and
40 magnetic fields (“ELF-EMF”) exposures pose any health risk is weak. The only
41 health impacts of concern are childhood leukemia and chronic lymphocytic
42 leukemia in occupationally exposed adults. Epidemiological studies of humans
43 show a pattern of small increased risk of leukemia with increasing exposure to
44 ELF-EMF.

- 1 2. Mechanistic studies and experimental studies on non-humans do not indicate any
2 increase in leukemia as a result of exposure to ELF-EMF, although sporadic
3 findings of increases in other forms of cancer in experimental animals have been
4 reported. A causal link that would explain the weak epidemiological evidence of
5 increased leukemia has not been found.
6
- 7 3. ELF-EMF cannot be recognized as entirely safe. However, the evidence that
8 exposure may pose a leukemia hazard is too weak to warrant aggressive
9 regulatory concern. Passive regulatory action is warranted.
10

11 In its ASC, PGE included guidelines regarding public exposure to magnetic fields recommended
12 by the International Radiation Protection Association (IRPA). The guideline for continuous
13 public exposure to magnetic fields is 830 milliGauss (“mG”). PGE also tabulated limits on
14 magnetic field strengths imposed by several states. PGE showed that only Florida has limits on
15 magnetic field strengths. Those limits are 200 mG for 500 kV lines at the edge of the ROW;
16 250 mG for double-circuit 500 kV lines at the edge of the ROW; and 150 mG for 230 kV and
17 smaller lines at the edge of the ROW.
18

19 PGE calculated the potential magnetic field strengths within the ROW and at the edges of the
20 ROW for several possible line configurations. For purposes of this discussion of magnetic field
21 strengths at the edges of the ROW, only the exterior edges of the ROW are of concern where the
22 proposed PGE ROW is adjacent to the existing BPA ROW. The interior edges become, in
23 effect, the centerline of the combined ROW. PGE’s calculations showed the following.
24

- 25 (a) Under existing conditions, the maximum magnetic field is about 350 mG in the
26 existing Port Westward to BPA Allston Substation ROW and about 130 mG along
27 the BPA Allston Substation to Trojan ROW. At the exterior edges of the ROW,
28 the magnetic fields do not exceed 84 mG.
29
- 30 (b) The addition of a single-circuit line to the existing Port Westward to BPA Allston
31 Substation ROW would decrease the maximum field strength. It would increase
32 the field strength at the edges of the ROW to no greater than 143 mG. The single
33 circuit line could be used for either PWGP or the Summit Project.
34
- 35 (c) The addition of a double circuit line to the existing Port Westward to BPA Allston
36 Substation ROW would not increase the maximum field strength in the ROW. It
37 would increase the magnetic field at the edges of the ROW to no greater than
38 150 mG.
39
- 40 (d) The addition of a single-circuit line adjacent to the BPA Allston Substation to
41 Trojan ROW would yield a maximum field strength no greater than 208 mG
42 within either right of way. At the outer edges of the combined ROW, the field
43 strength would not exceed 133 mG.
44

1 The magnetic field at the edges of the ROW in all cases meets or is lower than the most
2 restrictive limit imposed by Florida (150 mG) and is much lower than the IRPA guideline.

3
4 It is reasonable to surmise that the short segments of line that PGE proposed to locate outside of
5 existing ROW would create magnetic fields at ground level not exceeding the maximum
6 calculated field strength within the ROW. The maximum projected field strengths would be less
7 than the IRPA guidelines.

8
9 In response to an inquiry from the Office, PGE stated that on double-circuit lines it places one
10 circuit in a reverse orientation to provide a lower magnetic field. That is, the C-phase conductor
11 would be placed at the top of one line and at the bottom of the other and the A-phase conductor
12 at the bottom of one line and at the top of the other. This approach takes advantage of the fact
13 that electric and magnetic fields from multiple conductors can tend to cancel each other.

14
15 The Council adopts the following site certificate condition.

- 16
17 **(7) The Certificate Holder shall take reasonable steps to reduce or manage**
18 **exposure to electromagnetic fields (EMF), consistent with Council findings**
19 **presented in the “Report of EMF Committee to the Energy Facility Siting**
20 **Council,” March 30, 1993, and subsequent findings. Effective on the date of**
21 **this Site Certificate, the Certificate Holder shall provide information to the**
22 **public, upon request, about EMF levels associated with the energy facility**
23 **and related transmission lines.**
24

25 The Council finds that the proposed transmission lines are consistent with protecting public
26 health and safety in regard to magnetic fields.

27
28 **Coordination with the PUC.** The Oregon Public Utility Commission Safety and Reliability
29 Section (“PUC”) has previously requested that the Council ensure that certificate holders
30 coordinate with PUC staff on the design and specifications of electrical transmission lines and
31 the natural gas pipelines. The PUC has explained that others in the past have made inadvertent,
32 but costly, mistakes in the design and specifications of power lines and pipelines that could have
33 easily been corrected early if the developer had consulted with the PUC staff responsible for the
34 safety codes and standards.

35
36 The Council adopts the following condition in the site certificate to ensure timely consultation:

- 37
38 **(8) At least 30 days before beginning preparation of detailed design and**
39 **specifications for the electrical transmission line(s) or the natural gas**
40 **pipeline, the Certificate Holder shall consult with the Oregon Public Utility**
41 **Commission staff to ensure that its designs and specifications are consistent**
42 **with applicable codes and standards.**
43

1 **Natural Gas Pipeline Safety.** OAR 345-027-0023 provides conditions that the Council may
2 include in the site certificate as appropriate. The Council adopts the following conditions in the
3 site certificate:
4

- 5 (9) **With respect to the related or supporting natural gas pipeline, the Certificate**
6 **Holder shall design, construct and operate the pipeline in accordance with**
7 **the requirements of the U.S. Department of Transportation as set forth in**
8 **Title 49, Code of Federal Regulations, Part 192.**
9

10 **Conclusion**

11 The Council finds that the siting, construction and operation of the energy facility are consistent
12 with protection of the public health and safety, pursuant to ORS 469.310.
13

14 **E.1.d. Water Pollution Control Facilities Permit**

15 **The Requirement.** The development of an onsite sewage treatment system incorporating a
16 septic tank, dosing tank, and bottomless sand filter is considered a form of wastewater discharge
17 that requires a Water Pollution Control Facilities (“WPCF”) permit from DEQ. The WPCF
18 permit is a state level permit that falls under Council jurisdiction. Pursuant to ORS 469.401, the
19 Council must determine whether, and under what conditions, DEQ should issue the WPCF
20 permit. However, once DEQ has issued the permit, it continues to exercise enforcement
21 authority over the permit.
22

23 **Discussion**

24 After completion of construction of the PWGP, PGE expects it would employ about 25 people
25 fulltime. Sanitary facilities would produce a maximum of about 1,200 gallons per day, an
26 average of about 500 gallons per day, and a minimum of 90 gallons per day on an intermittent
27 basis.
28

29 Treatment of this waste would be by means of one septic tank and one dosing tank. The septic
30 tank would be a dual compartment, pre-manufactured fiberglass unit sized at 3,000 gallons
31 nominal capacity. Septic tank effluent would flow by gravity through effluent screens to the
32 dosing tank. The dosing tank would be a pre-manufactured concrete tank fitted with a duplex
33 pump package incorporating float-actuated single-impeller centrifugal pumps. The nominal
34 capacity of the dosing tank would be 2,000 gallons. Effluent from the dosing tank would be
35 pumped on intermittent dosing cycles to a bottomless sand filter via a flow meter and diversion
36 valve. Final disposition of the liquid component of treated sanitary sewage would occur as the
37 effluent flows by gravity through a sand filter profile and through the underlying soil profile.
38 The basal area of the sand filter would be 1,200 square feet. Final disposition of the solid
39 component of treated sanitary sewage would occur as part of the regular operations and
40 maintenance of the system. Solids and scum would be removed by a state-licensed septage
41 hauler and disposed of at a permitted septage receiving facility.
42

43 **DEQ Requirements.** Pursuant to OAR Chapter 340, Division 71, Section 130(5), persons
44 proposing a sand filter system to serve a commercial facility must obtain a WPCF permit from

1 DEQ. PGE submitted its Application for New WPCF Individual Permit to DEQ on March 29,
2 2002 (Application No. 986243). It submitted supplemental materials to DEQ on April 9, 2002.

3
4 **DEQ Recommendation**

5 After review of the PGE application and an on-site evaluation by Columbia County staff, DEQ
6 confirmed the evaluation of the site in relation to the proposed energy facility. See Attachment
7 B.2. However, in the course of its groundwater prioritization, DEQ observed that the proposed
8 drain field may be located in an area zoned such that drinking water wells may be installed
9 within 1,000 feet of the drain field in the future. DEQ recorded the following observations:

- 10
11 · All domestic wells are over the 100-foot setback required by OAR Chapter 340,
12 Division 71. In fact, there are no wells within one-half mile of the project. The initial
13 groundwater in this area is essentially the Columbia River and can be expected to
14 discharge to the river.
15
16 · The projected sewage flow from this facility is 1,200 gallons per day, equivalent to
17 2.6 residential homes located on a parcel of 19 acres. Sand filter effluent is expected
18 to produce 10 milligrams per liter (“mg/l”) biological oxygen demand (“BOD”) and
19 10 mg/l total suspended solids (“TSS”), reduce bacteria counts by 98 to 99 percent,
20 and lower total nitrogen by about 50 percent. The site meets Division 71 onsite rules
21 criteria for approval of a bottomless sand filter. The proposed flows would be low.
22 The potential to adversely affect groundwater would be negligible.

23
24 DEQ recommended that the Council approve the WPCF permit with conditions contained in
25 Schedules A, B, D, and F of the draft WPCF permit (Attachment B.1). The Council adopts the
26 following conditions in the site certificate:

- 27
28 **(1) Before beginning commercial operation of the energy facility, the Certificate**
29 **Holder shall demonstrate that the DEQ has issued to the Certificate Holder a**
30 **Water Pollution Control Facilities Permit, substantially in the form of**
31 **Attachment B.1, allowing for on-site sanitary waste disposal.**
32
33 **(2) The Certificate Holder shall comply with state laws and rules applicable to**
34 **Water Pollution Control Facilities Permits that are adopted in the future to**
35 **the extent that such compliance is required under the respective statutes and**
36 **rules.**

37
38 **Conclusion**

39 The Council finds that the Port Westward Generating Project meets the requirements for a
40 WPCF permit for sanitary waste, with the conditions contained in Attachment B.1; and, the
41 Council orders DEQ to issue PGE a WPCF permit substantially in the form contained in
42 Attachment B.1.

1 **E.2. REQUIREMENTS THAT ARE NOT UNDER COUNCIL JURISDICTION**

2
3 **E.2.a. Federally-Delegated Programs**

4 The Council does not have jurisdiction for determining compliance with those statutes and rules
5 for which the permitting decision has been delegated by the federal government to a state agency
6 other than the Council. However, pursuant to ORS 469.505(1):

7
8 [a]ny permit application for which the permitting decision has been delegated by the
9 federal government to a state agency other than the Energy Facility Siting Council shall
10 be reviewed, whenever feasible, simultaneously with the Council's review of the site
11 certificate application. Any hearings required on such permit applications shall be
12 consolidated, whenever feasible, with hearings under ORS 469.300 to 469.563 and
13 469.590 to 469.619.

14
15 The Council concludes that the following programs are not within the Council's jurisdiction
16 because they are federally delegated programs:

- 17
18 (1) The Air Contaminant Discharge Permit ("ACDP") program administered by
19 DEQ, which includes the federally delegated new source review requirements of
20 the Clean Air Act and the Prevention of Significant Deterioration program. This
21 authority is in ORS Chapter 468A; OAR Chapter 340, Divisions 20, 21, 22, 25,
22 and 31. The Council notes that DEQ issued an ACDP, No. 05-0008, for the
23 facility to PGE on January 16, 2002.
24
25 (2) The National Pollutant Discharge Elimination System permit program
26 administered by DEQ - Water Quality Division, which regulates and permits
27 storm water runoff and discharges to public waters; and
28
29 (3) The program regulating the design, operation, monitoring and removal of
30 underground storage tanks that contain certain toxic and hazardous materials,
31 including petroleum products, administered by DEQ, under ORS Chapter 466;
32 OAR 340, Division 150.
33

34 **E.2.b. Requirements That Do Not Relate to Siting**

35 Under ORS 469.401(4), the Council does not have jurisdiction for determining compliance with
36 state and local government programs that address design-specific construction or operating
37 standards and practices that do not relate to siting. However, the Council may rely on the
38 determinations of compliance and the conditions in the permits issued by these state agencies and
39 local governments in making its determinations as to whether the standards and requirements
40 under the Council's jurisdiction are met.

41
42 The Council concludes that, for the proposed facility, the following state and local government
43 programs are not within the Council's jurisdiction because the programs address design-specific
44 construction or operating standards and practices not related to siting:
45

- 1 (1) The Oil Spill Contingency and Prevention Plan program, administered by DEQ
2 Water Quality Division under ORS 468B and OAR Chapter 340, Division 47,
3 which regulates the transport, storage, handling, and spill control and prevention
4 of petroleum products;
- 5 (2) Regulations of building, structure design and construction practices by the Oregon
6 Building Codes Division under ORS Chapters 447, 455, 460, 476, 479, and 480;
7 OAR Chapter 918, Divisions 225, 290, 301, 302, 400, 440, 460, 750, 770, and
8 780;
- 9 (3) Various programs addressing fire protection and fire safety and the storage, use,
10 handling, and emergency response for hazardous materials and community right
11 to know laws for hazardous materials, administered by the Oregon State Fire
12 Marshal's Office, under ORS Chapters 453, 476, and 480; OAR Chapter 837,
13 Divisions 40 and 90;
- 14 (4) The program addressing design and safety standards for natural gas pipelines and
15 electric transmission lines administered by the Oregon Public Utilities
16 Commission, Safety Section under ORS Chapter 757; OAR Chapter 860,
17 Division 24;
- 18 (5) Regulations on the size and weight of truck loads on state and federal highways
19 administered by the Oregon Department of Transportation under ORS Chapter
20 818; OAR Chapter 743, Division 82;
- 21 (6) The program regulating the possession, use and transfer of radioactive materials
22 administered by the Oregon State Health Division (OSHD) under ORS Chapter
23 453; OAR Chapter 333, Divisions 100-119;
- 24 (7) Regulations of domestic water supply systems regarding potability administered
25 by OSHD under ORS Chapter 448;
- 26 (8) Permits required from ODOT to place a structure within, or to cross a state
27 highway right-of-way.
- 28 (9) Building permits required and administered by Columbia County.
- 29 (10) Federal Aviation Administration Form 7460-1, Notice of Proposed Construction
30 or Alteration, concerning the impact of the height of the structure on navigable
31 airspace.

32 33 **F. CONDITIONS REQUIRED OR RECOMMENDED BY COUNCIL RULES**

34 The following conditions are specifically required or recommended by OAR 345, Divisions 24,
35 26 and 27, to address project and site-specific conditions and requirements. These conditions
36 shall apply and should be read together with the additional specific conditions recommended in
37 Sections "D" and "E" of this Order to ensure compliance with the siting standards of OAR 345,
38 Divisions 22, 23 and 24, and to protect the public health and safety.

39
40 In addition to all other conditions stated in this Order, the site certificate holder is subject to all
41 conditions and requirements contained in the rules of the Council and local ordinances and state
42 law in effect on the date the site certificate is executed, except: (1) that upon a clear showing of
43 a significant threat to the public health, safety or the environment that requires application of
44 later-adopted laws or rules, the Council may require compliance with such later-adopted laws or
45 rules; and, (2) that the site certificate shall provide for facility compliance with applicable state

1 and federal laws adopted in the future to the extent that such compliance is required under the
2 respective state agency statutes and rules. ORS 469.401(2).

3
4 The Council recognizes that many specific tasks related to the design, construction, operation
5 and retirement of the facility would be undertaken by the site certificate holder's agents or
6 contractors. However, the site certificate holder shall be responsible for compliance with all
7 provisions of the site certificate.

8
9 **F.1. MANDATORY CONDITIONS IN SITE CERTIFICATES**

10 OAR 345-027-0020 details mandatory conditions that the Council must impose in every site
11 certificate. This Order imposes several of the mandatory conditions within the discussion of
12 specific conditions to which they relate. However, some mandatory conditions are not otherwise
13 addressed in this Order. Therefore, the Council adopts the following conditions in the site
14 certificate.

- 15
16 **(1) The Council shall not change the conditions of the Site Certificate except in**
17 **accordance with the applicable provisions of OAR 345, Division 27, in effect**
18 **on the date of the Council action.**
- 19
20 **(2) Before beginning construction of the energy facility, the Certificate Holder**
21 **shall submit to the Office a legal description of the site, except as provided in**
22 **OAR 345-027-0023(6).**
- 23
24 **(3) The Certificate Holder shall design, construct, operate, and retire the**
25 **facility:**
- 26
27 **(a) Substantially as described in the Site Certificate;**
- 28
29 **(b) In compliance with the requirements of ORS Chapter 469, applicable**
30 **Council rules, and applicable state and local laws, rules and**
31 **ordinances in effect at the time the Council issues the Site Certificate;**
32 **and,**
- 33
34 **(c) In compliance with all applicable permit requirements of other state**
35 **agencies.**
- 36
37 **(4) Except as necessary for the initial survey or as otherwise allowed for**
38 **transmission lines or pipelines in this condition, the Certificate Holder shall**
39 **not begin construction, as defined in OAR 345-001-0010, or create a clearing**
40 **on any part of the site until the Certificate Holder has construction rights on**
41 **all parts of the site. For the purpose of this condition, "construction rights"**
42 **means the legal right to engage in construction activities. For transmission**
43 **lines or pipelines, if the Certificate Holder does not have construction rights**
44 **on all parts of the site, the Certificate Holder may nevertheless begin**
45 **construction or create a clearing on a part of the site if:**

- 1
2 (a) **The Certificate Holder has construction rights on that part of the site;**
3 **and,**
4
5 (b) **The Certificate Holder would construct and operate part of the**
6 **facility on that part of the site even if a change in the planned route of**
7 **the transmission line or pipeline occurs during the Certificate**
8 **Holder's negotiations to acquire construction rights on another part**
9 **of the site.**

10
11 **Beginning and Completing Construction.** The proposed facility would include among its
12 related or supporting facilities a transmission line that would contain two circuits. One circuit
13 would interconnect PWGP to the BPA Allston Substation or to Trojan. The second circuit would
14 interconnect the Summit Project to the BPA Allston Substation. The Council treats the
15 transmission line with both circuits as a related or supporting facility for PWGP for purposes of
16 compliance with Council standards. If PGE were not proposing to construct and operate the Port
17 Westward Generating Project, the Council would require that the Summit Project include the
18 transmission line as a related or supporting facility in its site certificate.
19

20 Because construction of the Summit Project may proceed before construction of PWGP, PGE
21 may begin construction of the transmission line to the BPA Allston Substation before beginning
22 construction of its energy facility. It is also possible that PGE might decide not to proceed with
23 construction of its energy facility at all. In the event that PGE did not begin construction of the
24 energy facility at PWGP by the date specified in the site certificate or in the event that PGE
25 failed to complete construction of the facility by the date specified in its site certificate, then
26 PGE or the Council would terminate the site certificate for PWGP. In any case in which the
27 transmission line for the Summit Project were not part of a current site certificate, the Council
28 would require Summit/Westward to amend its site certificate to include the Summit Project to
29 BPA Allston Substation transmission line. Therefore, it is necessary that the PWGP site
30 certificate distinguish between beginning construction of the transmission line and beginning
31 construction of the energy facility, as well as define completion of construction.
32

33 Given these special circumstances, the Council adopts the following conditions in the site
34 certificate:
35

- 36 (5) **The Certificate Holder shall begin construction of the energy facility by**
37 **November 8, 2004. Beginning construction of the Port Westward to BPA**
38 **Allston Substation Transmission Line shall not satisfy this requirement.**
39
40 (a) **The Certificate Holder shall report promptly to the Office the date**
41 **that it began construction of the facility, as defined in OAR 345-001-**
42 **0010. In reporting the beginning of construction, the Certificate**
43 **Holder shall briefly describe all work on the site performed before**
44 **beginning construction, including work performed before the Council**
45 **issued the Site Certificate and work performed to construct the Port**

1 Westward to BPA Allston Substation Transmission Line, and shall
2 state the cost of that work, pursuant to OAR 345-026-0048.

3
4 (b) If the Certificate Holder begins construction of the Port Westward to
5 BPA Allston Substation Transmission Line, as defined in OAR 345-
6 001-0010, prior to beginning construction of the energy facility, it
7 shall promptly report to the Office the date it began construction of
8 the transmission line.

9
10 (6) The Certificate Holder shall complete construction of the facility by May 8,
11 2007. The completion of construction date is the day by which (1) the facility
12 is substantially complete as defined by the Certificate Holder's construction
13 contract documents; (2) acceptance testing is satisfactorily completed; and,
14 (3) the energy facility is ready to commence continuous operation consistent
15 with the Site Certificate. Completion of construction of the Port Westward
16 to BPA Allston Substation Transmission Line separately shall not satisfy this
17 requirement.

18
19 (a) The Certificate Holder shall report promptly to the Office the date it
20 completed construction of the facility.

21
22 (b) If the Certificate Holder completes construction of the Port Westward
23 to BPA Allston Substation Transmission Line separately before
24 completing construction of the facility, it shall promptly report that
25 date to the Office.

26
27 (c) Separate completion of construction of Port Westward to BPA Allston
28 Substation Transmission Line shall be the date that PGE makes it
29 available to the Summit/Westward Project to transmit energy.

30
31 **F.2 OTHER CONDITIONS BY RULE**

32 This section contains conditions based on the Council's rules. In some cases, the rules propose
33 conditions; in other cases the Council adopts the conditions, based on its rules, to make explicit
34 certain obligations of the site certificate holder.

35
36 **Incident Reports.** Pursuant to OAR 345-027-0023(2), the Council adopts the following
37 condition in the site certificate:

38
39 (1) With respect to the related or supporting natural gas pipeline, the Certificate
40 Holder shall submit to the Office copies of all incident reports required
41 under 49 CFR §192.709 that involve the pipeline.

42
43 **Rights-of-Way.** Pursuant to OAR 345-027-0023(6), the Council adopts the following condition
44 in the site certificate:

- 1 (2) **Before beginning operation of the energy facility, the Certificate Holder shall**
2 **submit to the Office a legal description of the permanent right-of-way where**
3 **the Certificate Holder has built a pipeline or transmission line within an**
4 **approved corridor. The site of the pipeline or transmission line subject to the**
5 **Site Certificate is the area within the permanent right-of-way. However, if**
6 **the Certificate Holder completes construction of the Port Westward to BPA**
7 **Allston Substation Transmission Line before beginning construction of the**
8 **energy facility, the Certificate Holder shall submit to the Office a legal**
9 **description of the permanent right-of-way for that segment of that**
10 **transmission line, notwithstanding OAR 345-027-0023(6).**

11
12 **Monitoring Programs.** Pursuant to OAR 345-027-0028, the Council adopts the following
13 conditions for the site certificate:

- 14
15 (3) **If the Certificate Holder becomes aware of a significant environmental**
16 **change or impact attributable to the facility, the Certificate Holder shall, as**
17 **soon as possible, submit a written report to the Office describing the impact**
18 **on the facility and its ability to comply with any affected Site Certificate**
19 **conditions.**

20
21 **Compliance Plans.** Pursuant to OAR 345-026-0048, the Council adopts the following condition
22 in the site certificate:

- 23
24 (4) **Before beginning construction of the facility, the Certificate Holder shall**
25 **implement a plan that verifies compliance with all Site Certificate terms and**
26 **conditions and applicable statutes and rules. The Certificate Holder shall**
27 **submit a copy of the plan to the Office. The Certificate Holder shall**
28 **document the compliance plan and maintain it for inspection by the Office or**
29 **the Council. However, if the Certificate Holder begins construction of the**
30 **Port Westward to BPA Allston Substation Transmission Line before**
31 **beginning construction of the energy facility, the applicable compliance plan**
32 **shall relate to that phase of construction.**

33
34 **Reporting.** Pursuant to OAR 345-026-0080, the Council adopts the following conditions in the
35 site certificate:

- 36
37 (5) **Within six months after beginning any construction, and every six months**
38 **thereafter during construction of the energy facility and related or**
39 **supporting facilities, the Certificate Holder shall submit a semi-annual**
40 **construction progress report to the Council. In each construction progress**
41 **report, the Certificate Holder shall describe any significant changes to major**
42 **milestones for construction. When the reporting date coincides, the**
43 **Certificate Holder may include the construction progress report within the**
44 **annual report described in Condition (6).**

1 **(6) The Certificate Holder shall, within 120 days after the end of each calendar**
2 **year after beginning construction, submit an annual report to the Council**
3 **that addresses the subjects listed in OAR 345-026-0080(2). The Council**
4 **secretary and the Certificate Holder may, by mutual agreement, change the**
5 **reporting date.**

6
7 **(7) To the extent that information required by OAR 345-026-0080(2) is**
8 **contained in reports the Certificate Holder submits to other state, federal or**
9 **local agencies, the Certificate Holder may submit excerpts from such other**
10 **reports. The Council reserves the right to request full copies of such**
11 **excerpted reports.**

12
13 **Schedule Modification.** Pursuant to OAR 345-026-0100, the Council adopts the following
14 condition in the site certificate:

15
16 **(8) The Certificate Holder shall promptly notify the Office of any changes in**
17 **major milestones for construction, decommissioning, operation, or**
18 **retirement schedules. Major milestones are those identified by the**
19 **Certificate Holder in its construction, retirement or decommissioning plans.**

20
21 **Correspondence with Other State or Federal Agencies.** Pursuant to OAR 345-026-0105, the
22 Council adopts the following condition in the site certificate:

23
24 **(9) The Certificate Holder and the Office shall exchange copies of all**
25 **correspondence or summaries of correspondence related to compliance with**
26 **statutes, rules and local ordinances on which the Council determined**
27 **compliance, except for material withheld from public disclosure under state**
28 **or federal law or under Council rules. The Certificate Holder may submit**
29 **abstracts of reports in place of full reports; however, the Certificate Holder**
30 **shall provide full copies of abstracted reports and any summarized**
31 **correspondence at the request of the Office.**

32
33 **Notification of Incidents.** Pursuant to OAR 345-026-0170, the Council adopts the following
34 condition in the site certificate:

- 35
36 **(10) The Certificate Holder shall notify the Office within 72 hours of any**
37 **occurrence involving the facility if:**
38
39 **(a) There is an attempt by anyone to interfere with its safe operation;**
40
41 **(b) A natural event such as an earthquake, flood, tsunami or tornado, or**
42 **a human-caused event such as a fire or explosion affects or threatens**
43 **to affect the public health and safety or the environment; or,**
44
45 **(c) There is any fatal injury at the facility.**

1
2 **G. GENERAL CONDITIONS**

3 The following general conditions are based on the representations by PGE in the ASC that are
4 not otherwise addressed or relate to procedural matters not otherwise addressed in conditions.
5 The Council adopts the following conditions in the site certificate:
6

- 7 (1) **The general arrangement of the Port Westward Generating Project shall be**
8 **substantially as shown in the ASC.**
9
10 (2) **The Certificate Holder shall ensure that related or supporting facilities are**
11 **constructed in the corridors described in this Order and as shown in ASC and**
12 **in the manner described in this Order and the ASC.**
13
14 (3) **During construction and operation of the energy facility, the Certificate**
15 **Holder shall house the combustion turbine in an enclosure that provides**
16 **thermal insulation, acoustical attenuation, and fire extinguishing media**
17 **containment and that would allow access for routine inspection and**
18 **maintenance.**
19

20 **Successors and Assigns.** Ownership of the site certificate or energy facility may change over
21 time. The Council adopts the following condition:
22

- 23 (4) **Before any transfer of ownership of the facility or ownership of the**
24 **Certificate Holder, the Certificate Holder shall inform the Office of the**
25 **proposed new owners. The requirements OAR 345-027-0100 shall apply to**
26 **any transfer of ownership that requires a transfer of the Site Certificate.**
27

28 **Severability and Construction.** The Council adopts the following condition:
29

- 30 (5) **If any provision of this Site Certificate is declared by a court to be illegal or**
31 **in conflict with any law, the validity of the remaining terms and conditions**
32 **shall not be affected, and the rights and obligations of the parties shall be**
33 **construed and enforced as if the Site Certificate did not contain the**
34 **particular provision held to be invalid. In the event of a conflict between the**
35 **conditions contained in the Site Certificate and the Council's Order, the**
36 **conditions contained in this Site Certificate shall control.**
37

38 **Governing Law and Forum.** The Council adopts the following conditions:
39

- 40 (6) **This Site Certificate shall be governed by the laws of the State of Oregon.**
41
42 (7) **Any litigation or arbitration arising out of this agreement shall be conducted**
43 **in an appropriate forum in Oregon.**
44

1 **H. GENERAL CONCLUSION**

2 The Council makes the following findings:

- 3
- 4 (1) That the facility complies with the standards adopted by the Council pursuant to
5 ORS 469.501;
- 6 (2) That the energy facility is a base load gas plant that complies with the applicable
7 carbon dioxide emissions standard, OAR 345-024-0550;
- 8 (3) That except for those statutes and rules for which the decision on compliance has
9 been delegated by the federal government to a state agency other than the
10 Council, the facility complies with all other Oregon statutes and administrative
11 rules identified in the Project Order, as amended, as applicable to the issuance of a
12 site certificate for the proposed facility adopted by the Council or enacted by
13 statute; and,
- 14 (4) That an exception to statewide planning Goal 4 is justified and that the facility
15 otherwise complies with the statewide planning goals adopted by the Land
16 Conservation and Development Commission, pursuant to ORS 469.503(4).
- 17

18 The Council concludes that PGE meets these requirements and that it should issue a site
19 certificate for the Port Westward Generating Project.

21 **I. ORDER**

22 Based on the above findings of fact, discussions and conclusions of law, the Council determines
23 that it shall approve the Application for a Site Certificate for the Port Westward Generating
24 Project and that the chairperson of the Council shall execute the Site Certificate in the form of
25 the "Site Certificate for the Port Westward Generating Project." The Site Certificate for the Port
26 Westward Generating Project is attached to this Order and incorporated by reference into this
27 Order. The Council directs the Oregon Department of Environmental Quality to issue a Water
28 Pollution Control Facilities permit to the Certificate Holder that is substantially in the form of
29 Attachment B.1 and it directs the Division of State Lands to issue a Removal/Fill Permit that is
30 substantially in the form of Attachment C.

31
32 Ordered this 8th day of November, 2002

33
34
35
36
37 By: 

38 Dr. Roslyn Elms-Sutherland, Chair
39 Oregon Energy Facility Siting Council

40
41
42 **ATTACHMENT A**

43 MEMORANDUM OF UNDERSTANDING: MONETARY PATH PAYMENT REQUIREMENT

1 **ATTACHMENT B**
2 WATER POLLUTION CONTROL FACILITIES PERMIT (B.1) AND ANALYSIS (B.2)

3
4 **ATTACHMENT C**
5 REMOVAL/FILL PERMIT

6
7 **ATTACHMENT D**
8 LAND USE STANDARD ANALYSIS

9
10 **Notice of the Right to Appeal**

11 You have the right to appeal this order to the Oregon Supreme Court pursuant to ORS 469.403.
12 To appeal you must file a petition for judicial review with the Supreme Court within 60 days
13 from the day this order was served on you. If this order was personally delivered to you, the date
14 of service is the date you received this order. If this order was mailed to you, the date of service
15 is the date it was mailed, not the day you received it. If you do not file a petition for judicial
16 review within the 60-day time period, you lose your right to appeal.

17 /
18 /
19 /

