



PUBLIC NOTICE

South Dunes Power Plant

Complete Application for Site Certificate

Introduction


The Oregon Department of Energy (the department), staff to the Energy Facility Siting Council (EFSC), received an application for site certificate from Jordan Cove Energy Project, L.P. (JCEP), for the construction and operation of South Dunes Power Plant, a natural gas-fueled energy facility with a nominal generating capacity of 420 megawatts. Under Oregon law, the applicant must obtain a site certificate from EFSC before constructing and operating the proposed facility. The department determined the application complete on December 23, 2014 and the applicant submitted and filed a final application on December 29, 2014.

Public Information Meeting

The department will hold a public information meeting on February 12, 2015 to provide the public with more information about the South Dunes application and the site certificate review process.

Date: February 12, 2015
Time: 6:00 p.m.
Location: Hales Performing Arts Center
Southwestern Oregon Comm. College
1988 Newmark Ave.
Coos Bay, OR 97420

The information meeting *is not* a public hearing. Department staff and the applicant will be available to answer questions after the presentation, but public testimony will not be taken at this point in the process. As described below, EFSC will hold a public hearing after the department issues a draft proposed order on the application.



Location of Proposed Facility

The South Dunes Power Plant is proposed to be located in Coos County on the North Spit of Coos Bay.

For detailed maps, please see the department website at the link below or Exhibit B of the Application for Site Certificate.

Description of the Proposed Facility

The South Dunes Power Plant would consist of two, 210-megawatt blocks of combined-cycle combustion turbine generation, with duct firing capability. Each block would include three combustion turbine generators, three heat recovery steam generators and one steam turbine generator. In addition, the energy facility includes the following related and supporting facilities:

- Electrical switchyard/transmission lines
- Gas pipeline/gas metering station
- Relocated substation
- Water system connection and distribution
- Water treatment facilities
- Roads

- Temporary construction facilities
- Accessory buildings
- Barge berth

Carbon Dioxide Emissions Standard

As a fossil-fueled power plant, South Dunes Power Plant must meet the carbon dioxide emissions standard cited under Oregon Administrative Rule (OAR) 345-024-0550 for-base load gas plants. The applicant has elected to comply with this standard by providing offset funds to the Climate Trust under the “monetary path,” as allowed by OAR 345-024-0600(3) and in compliance with the monetary path payment requirements of OAR 345-024-0710. Please note, the applicant proposes to provide thermal energy for process use at the JCEP LNG facility’s gas conditioning facility and intends to use this thermal energy for cogeneration to lower its net carbon dioxide emissions rate.

EFSC Review Process

The site certificate process is a consolidated, comprehensive siting process. The applicant must demonstrate that the proposed facility meets EFSC standards established under Oregon Revised Statute 469.501 and set forth in OAR Chapter 345, divisions 22 and 24, as well as all other applicable Oregon statutes, rules and standards. The department serves as staff to EFSC and conducts the application review process.

Upcoming Review Phases

The department is reviewing the application and comments received from state agencies, tribes, local governments and others identified as “reviewing agencies” under EFSC rules and statutes. Upon completing its review, the department will issue a draft proposed order describing the department’s analysis and recommendations on the application to EFSC. If the department recommends issuance of the site certificate, the draft proposed order will include recommended site certificate conditions.

After issuance of the draft proposed order, the department will open a public comment period and EFSC will conduct a public hearing on the order. *You must provide oral or written comment*

on the record of that public hearing to preserve your right to participate in the contested case proceeding and subsequent appeals of EFSC’s decision. The department anticipates issuing the draft proposed order in early 2015. The department will provide notice of the public hearing and comment period when it issues the draft proposed order.

More Information

More information about the proposed facility and the EFSC review process is available through:

The department’s siting analyst for South Dunes Power Plant:

Andrea Goodwin
625 Marion Street NE
Salem, OR 97301
503-373-0076
andrea.goodwin@state.or.us

The department’s webpage:

<http://www.oregon.gov/energy/Siting/Pages/SDP.aspx>

Updates by email:

Subscribe to email updates on the South Dunes Power Plant or other energy facilities under EFSC jurisdiction through GovDelivery. For more information, please visit <http://tinyurl.com/EFSC-email>.

In hardcopy:

Copies of the application for site certificate are available for public inspection at:

Coos Bay Public Library
525 Anderson Ave.
Coos Bay, OR 97420

Accessibility Information

The department is committed to accommodating people with disabilities. If you require any special accommodations, or need information in an alternate format, please contact Matt Lawyer at 503-378-3895, toll-free in Oregon at 800-221-8035, or via e-mail at matthew.lawyer@state.or.us. TTY users should call the Oregon Relay Service at 711.