

| PWSID | PWS_NAME | SAMPLE DATE | SAMPLE RESULT | UNITS | Oregon status notes | Not on Oregon list - reason |
|-----------|-------------------------------------|-------------|---------------|-------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|
| OR4100029 | PERIWINKLE MOBILE HOME PARK | 25-Jun-13 | 0.033 | mg/L | Resolved | |
| OR4100059 | FERNHILL COMMUNITY WTR SYSTEM | 16-Sep-14 | 0.035 | mg/L | Need to finish two 6-month rounds and WQP by June 30, 2016. | |
| OR4100063 | WICKIUP WATER DISTRICT | 18-Sep-13 | 0.018 | mg/L | Resolved - installed soda ash | |
| OR4100187 | CLACKAMAS RIVER WATER - CLACKAMAS | 12-Jun-13 | 0.017 | mg/L | Resolved - installed soda ash | |
| OR4100594 | CLACKAMAS RIVER WATER - CLAIRMONT | 9-Apr-13 | 0.017 | mg/L | Resolved - soda ash | |
| OR4100260 | DRAIN, CITY OF | 17-Sep-15 | 0.0224 | mg/L | Sent a compliance letter; System is collecting WQP and taking 6-month rounds. City sent out public education info (3/24/16) | |
| OR4100567 | HILAND WC - WESTWOOD | 10-Dec-13 | 0.0175 | mg/L | Resolved, below AL for 2 6-month rounds. | |
| OR4100574 | WILDWOOD ESTATES | 19-Oct-11 | 0.0183 | mg/L | Added CC in 2013 & now below AL, need to set min WQPs. still on 6 month schedule. | |
| OR4100581 | OAKLAND, CITY OF | 8-Aug-13 | 0.016 | mg/L | Sent a compliance letter; System is collecting WQP and taking 6-month rounds. City sent out education info (3/8/16) | |
| OR4100609 | PACIFIC CITY JOINT WATER - SAN AUTH | 5-Aug-14 | 0.026 | mg/L | Resolved, two 6-mo rounds under AL. | |
| OR4100610 | TIERRA DEL MAR WATER CO | 15-Sep-15 | 0.025 | mg/L | WQPs and PE done. Need to determine appropriate CCTX & do source monitoring. Doing 6-mo rounds; first round under AL so will suspend CCTX if 2nd round is under AL. | |

| PWSID | PWS_NAME | SAMPLE DATE | SAMPLE_RESULT | UNITS | Oregon status notes | Not on Oregon list - reason |
|-----------|--------------------------------|-------------|---------------|-------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------|
| OR4101092 | USFS TILLER RANGER STATION | 7-Aug-14 | 0.018 | mg/L | Sent a compliance letter; System is collecting WQP and taking 6-month rounds due 12/31/16. | |
| OR4100898 | TIMBER WATER ASSOCIATION | 21-Jun-15 | 0.0158 | mg/L | WQPs and PE done. Need to determine appropriate CCTX & do source monitoring. Doing 6-mo rounds; first round under AL so will suspend CCTX if 2nd round is under AL. On a compliance schedule. | |
| OR4101173 | WATSECO-BARVIEW WATER DISTRICT | 16-Sep-14 | 0.023 | mg/L | | Merged with city of Garibaldi (00311) |
| OR4101515 | ROW RIVER VALLEY WATER DIST | 24-Jun-14 | 0.024 | mg/L | Resolved, last 2 rounds < AL for lead and copper. | |
| OR4105201 | COLD SPRINGS WATER CO | 5-Sep-13 | 0.016 | mg/L | Resolved, Did PRP. | |
| OR4190170 | MT ANGEL ABBEY | 13-Jun-13 | 0.079 | mg/L | County sent letter 1/23/13 w/ deadlines for installing CCTX, PE; none of deadlines met. Another letter sent 1/26/15 putting them on 6-month rounds. Pre-enforcement letter sent 2/18/16 with new deadlines. PE done. | |

| PWSID | PWS_NAME | SAMPLE DATE | SAMPLE_RESULT | UNITS | Oregon status notes | Not on Oregon list - reason |
|----------------|------------------------------------|-------------|---------------|-------|------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------|
| OR4192048 | SALMON RIVER RV PARK | 18-Dec-13 | 0.11 | mg/L | | Resolved, On 3-year schedule - invalidation granted in dec 2013, due to space #5 was not used for months. |
| OR4192104 | DIAMOND LAKE LODGE/RESORT | 16-Sep-14 | 0.018 | mg/L | System is collecting WQP and taking 6-month rounds, due 12/31/16. | |
| OR4193427 | DYNO NOBEL INC | 11-Jul-11 | 0.063 | mg/L | | AL exceeded before Oregon list - system resolved LCR issue |
| OR4193614 | MID VALLEY REHABILITATION WOOD PRD | 29-Sep-11 | 0.031 | mg/L | Need to finish two 6-month rounds and WQP by Dec 31, 2016. No CCTx | |
| OR4194063 | WEST LINN/WILSONVILLE | 24-Sep-14 | 0.0372 | mg/L | Did plumbing replacement, awaiting two six month round results. | |
| OR4194317 | WAYNE BUCK WATER SYSTEM | 21-Sep-14 | 0.019 | mg/L | Awaiting 2nd round, due by 6/30/16. | |
| OR4194336 | MONROVIA NORTH | 18-Sep-12 | 0.017 | mg/L | Need to finish two 6-month rounds and WQP by Dec 31, 2016. has 3 rounds < AL | |
| SCHOOLS | | | | | | |
| OR4191681 | KIDCO HEAD START-SUNNYSIDE | 26-Sep-13 | 0.022 | mg/L | Plumbing replacement in Oct 2015 at classroom 2; Need two 6M rounds | |
| OR4191681 | KIDCO HEAD START-SUNNYSIDE | 26-Feb-14 | 0.158 | mg/L | | |
| OR4191681 | KIDCO HEAD START-SUNNYSIDE | 17-Sep-14 | 0.086 | mg/L | | |
| OR4191681 | KIDCO HEAD START-SUNNYSIDE | 25-Sep-15 | 0.085 | mg/L | | |

| PWSID | PWS_NAME | SAMPLE DATE | SAMPLE_RESULT | UNITS | Oregon status notes | Not on Oregon list - reason |
|-----------|-----------------------------------------|-------------|---------------|-------|-----------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------|
| OR4192040 | EDDYVILLE CHARTER SCHOOL | 12-Mar-14 | 0.0314 | mg/L | Resolved, system installed a new calcite contactor after multiple attempts at plumbing replacements. Need one more 6-month round. | |
| OR4192040 | EDDYVILLE CHARTER SCHOOL | 26-Feb-13 | 0.0231 | mg/L | | |
| OR4192040 | EDDYVILLE CHARTER SCHOOL | 21-Sep-11 | 0.0216 | mg/L | | |
| OR4192040 | EDDYVILLE CHARTER SCHOOL | 6-Aug-13 | 0.0191 | mg/L | | |
| OR4193711 | CORVALLIS WALDORF ASSOCIATION | 13-Sep-13 | 0.095 | mg/L | Resolved, orthophosphate and plumbing replacement, two six month rounds are now below AL. | |
| OR4193711 | CORVALLIS WALDORF ASSOCIATION | 13-Mar-14 | 0.095 | mg/L | | |
| OR4193711 | CORVALLIS WALDORF ASSOCIATION | 17-Mar-15 | 0.0573 | mg/L | | |
| OR4193711 | CORVALLIS WALDORF ASSOCIATION | 12-Sep-14 | 0.0501 | mg/L | | |
| OR4193750 | WILLOWCREEK ELEM SD #84 | 28-Sep-12 | 0.031 | mg/L | Did some plumbing replacement, may need to do more, consulting with circuit rider, continue on 6 month rounds. | |
| OR4193750 | WILLOWCREEK ELEM SD #84 | 13-May-15 | 0.0306 | mg/L | | |
| OR4193750 | WILLOWCREEK ELEM SD #84 | 16-Sep-15 | 0.0159 | mg/L | | |
| OR4193764 | VALLEY INQUIRY CHARTER SCHOOL | 19-Sep-14 | 0.0257 | mg/L | Did PRP after 2011 exceedance, > AL in 2014, working on replacing copper pipes. One six month round is below AL, second round is due 6/30/16. | |
| OR4193764 | VALLEY INQUIRY CHARTER SCHOOL | 29-Sep-11 | 0.0205 | mg/L | | |
| OR4191504 | ELK TRAIL SCHOOL Inactive June 27, 2012 | Inactive | 0.0268 | mg/L | | Inactive |
| OR4190529 | MOLALLA RIVER SD RURAL DELL ELEM | 26-Feb-13 | 0.048 | mg/L | Resolved, CCTx installed, mins set | |
| OR4191712 | SEVEN OAK MIDDLE SCHOOL | 7-Jun-12 | 0.0584 | mg/L | Resolved, except for excursion problems | |
| OR4193968 | CENTRAL VALLEY CHRISTIAN SCHOOL | 30-Aug-11 | 0.0155 | mg/L | Resolved, performed plumbing replacement and now below action level. | |
| OR4194208 | LEBANON UNION HIGH-LAND LAB | 22-Sep-15 | 0.0195 | mg/L | Plumbing replacement, awaiting two six month rounds. | |

| PWSID | PWS_NAME | SAMPLE DATE | SAMPLE_RESULT | UNITS | Oregon status notes | Not on Oregon list - reason |
|------------------------|--------------------------------------|-------------|---------------|-------|-------------------------------------------------------------------------------------------------------------------|-----------------------------|
| OR4195379 | EMERALD CHRISTIAN ACADEMY | 25-Jul-13 | 0.027 | mg/L | Changed injection point location for better mixing, await next 6 month rounds to see if that corrected it. | |
| OR4195488 | SCAPPOOSE ADVENTIST SCHOOL | 30-Dec-13 | 0.021 | mg/L | Sampling issues. System has taken 1st 6 month round (< AL) in Nov 2015, will take 2nd round before June 30, 2016. | |
| PORTLAND | JOINT MONITORING PLAN SYSTEMS | | | | | |
| OR4100657 | PORTLAND WATER BUREAU | 9-Nov-13 | 0.0159 | mg/L | PWB JMP | |
| OR4100360 | PLEASANT HOME WATER DISTRICT | " | 0.0159 | mg/L | PWB JMP | |
| OR4100660 | WEST SLOPE WATER DISTRICT | " | 0.0159 | mg/L | PWB JMP | |
| OR4100357 | GRESHAM PWO-WATER SECTION | " | 0.0159 | mg/L | PWB JMP | |
| OR4100653 | PALATINE HILL WATER DISTRICT | " | 0.0159 | mg/L | PWB JMP | |
| OR4100661 | VALLEY VIEW WATER DISTRICT | " | 0.0159 | mg/L | PWB JMP | |
| OR4100662 | LORNA PORTLAND WATER LLC | " | 0.0159 | mg/L | PWB JMP | |
| OR4100665 | TUALATIN VALLEY WATER DISTRICT | " | 0.0159 | mg/L | PWB JMP | |
| OR4100667 | RALEIGH WATER DISTRICT | " | 0.0159 | mg/L | PWB JMP | |
| OR4100668 | ROCKWOOD PUD | " | 0.0159 | mg/L | PWB JMP | |
| OR4100786 | SKYVIEW ACRES WATER CO-OP | " | 0.0159 | mg/L | PWB JMP | |
| OR4100878 | TIGARD, CITY OF | " | 0.0159 | mg/L | Going off PWB June 2016 (see LCR over 50K.xls for details) | |
| OR4100906 | TUALATIN, CITY OF | " | 0.0159 | mg/L | PWB JMP | |
| OR4100644 | BURLINGTON WATER DISTRICT | " | 0.0159 | mg/L | PWB JMP | |
| Not on EPA list | | | | | | |
| OR4100460 | LAKE GROVE WATER DISTRICT | " | 0.0159 | mg/L | PWB JMP | |
| OR4100248 | DALLAS, CITY OF | 2/11/2011 | 0.016 | mg/L | Resolved | |
| OR4193712 | MUDDY CREEK CHARTER SCHOOL | 1/21/2011 | 0.0221 | mg/L | Resolved in 2011, orthophosphate and plumbing replacement. | |
| OR4191865 | PISGAH PUBLIC MARKET | | | | Resolved, below AL for past 18 mo. | |