

OREGON DRINKING WATER QUALITY STANDARDS

Spring, 2000

INSIDE THIS ISSUE:

OREGON DRINKING WATER QUALITY STANDARDS 1

- Types of Drinking Water Contaminants 1
- Drinking Water Standards and Health Protection 1
- Public Drinking Water Regulatory Program 2
- Oregon Public Water Systems 2
- Measuring Progress 3
- For More Information 3

CURRENT STANDARDS 3

- Coliform Bacteria 3
- Surface Water Treatment 4
- Disinfection By-products 6
- Lead and Copper 7
- Inorganic Contaminants 8
- Organic Chemicals 10
- Radiologic Contaminants 12
- Review and Update of Current Standards 13

FUTURE STANDARDS 14

- Microbial Standards - Enhanced Surface Water
 - Treatment, Filter Backwash, Groundwater 14
- Disinfectants and Disinfection By-products 14
- Arsenic 15
- Radionuclides (except Radon) 15
- Radon 15
- Drinking Water Contaminant Candidate List (DWCCCL) ... 16



OREGON DRINKING WATER QUALITY STANDARDS Winter, 2000

This summary provides a broad overview of current and future drinking water quality standards which public water systems in Oregon must meet through the year 2005. It is organized in two major sections - Section I: Current Standards, and Section II: Future Standards. The summary of current standards is for reference only, and is not a substitute for the actual statutes and regulations that govern public water supply in Oregon. Future standards described here are still under development at the national level, and are subject to change.

Types of Drinking Water Contaminants

The sources of drinking water, both tap water and bottled water, include rivers, lakes, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases natural radioactive materials, and can pick up substances from the presence of animals or from human activities.

Drinking water contaminants are any substances present in drinking water that could adversely affect human health if present in high enough concentrations. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily mean that the water presents a health risk.

There are now drinking water quality standards for 96 different contaminants. They can be grouped into the following general categories:

- **Microbial Contaminants** - such as viruses, bacteria, and parasites which can come from sewage treatment plants, septic systems, agricultural and livestock operations, and wildlife.
- **Disinfectants and Disinfection By-Products** - chemical disinfectants used in water treatment to kill harmful microbes, and the chemical by-products formed from the reaction of disinfection treatment chemicals with natural substances in the water.
- **Inorganic Chemicals** - such as salts or metals, which can be naturally-occurring or can result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. Includes lead and copper leached into the water from household plumbing and fixtures.
- **Organic Chemicals** - Pesticides and herbicides which may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses. Also includes synthetic and volatile chemicals which are used in industrial processes and petroleum production and can come from gas stations, urban stormwater runoff, and septic systems.
- **Radiologic Contaminants** - Naturally occurring or resulting from oil and gas production or mining operations.

Every drinking water supply is vulnerable to microbial or chemical contaminants of one type or another from a variety of sources. Disease-causing microorganisms (bacteria, viruses, parasites) can be present in surface water (lakes and streams) or from groundwater (wells or springs) from human or animal feces. Microorganisms can also enter the water system through pipe breaks or cross connections. Organic chemicals (industrial solvents, pesticides) are mainly man-made and can enter drinking water supplies as a consequence of chemical production, storage, use, or disposal in the water source area. Inorganic chemicals can be introduced by human activities (nitrate from fertilizer) but more often result from natural occurrence in rocks, soils, and mineral deposits (radon, arsenic). Drinking water treatment which is essential to remove microbes and chemicals can also add or form contaminants in drinking water, such as disinfectant chemicals themselves, byproducts of disinfectants with other materials in the water, and treatment chemicals used in filtering water. Finally, water storage tanks, pipes, and household plumbing that are in direct contact with water can contribute contaminants from either the material used in the tanks and pipes or from internal coatings used to protect the materials from contact with the water.

Drinking Water Standards and Health Protection

To protect health, national regulations set by the US Environmental Protection Agency limit the amounts of certain contaminants in tap water provided by public water systems. Other regulations set by the federal Food and Drug Administration establish limits for contaminants in bottled water which must provide the same level of protection of public health.

Drinking water standards have several forms and components:

- **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health, allowing for a margin of safety. All regulated contaminants must have a MCLG.
- **Maximum Contaminant Level (MCL)** - The highest level of a contaminant allowed in drinking water, set as close the MCLG as feasible using the best available treatment technology. Most MCLs are expressed in concentration units called "milligrams per liter" (mg/L), which for drinking water is the same as parts per million (ppm). MCLs can be expressed in a variety of other measurement units.

- **Treatment Technique (TT)** - A required treatment process intended to reduce the level of a contaminant in drinking water. For any contaminant that can not be effectively measured or detected in drinking water, the standard may be a treatment technique requirement, which means that all water systems at risk of the contaminant must provide continuous water treatment to remove the contaminant at all times.
- **Action Level (AL)** - The concentration of a contaminant, which when exceeded, triggers treatment or other requirements which a water supplier must follow.

In addition, Performance Standards (PS) are used to determine whether or not a water system is meeting a specific treatment technique requirement. Performance Standards are measurements of water quality parameters related to specific treatment processes, such as turbidity, disinfectant residual, pH, or alkalinity.

Public water suppliers and bottled water producers must sample for contaminants routinely to ensure that standards are met, and report the results of that sampling to the regulatory agency. Sampling frequencies for public water systems vary by the type of drinking water contaminant. Contaminants that are associated with immediate health impacts, like bacteria and nitrates, must be sampled often, such as every month, quarter, or year. Contaminants that are associated with health effects that could develop from very long-term exposures, like arsenic, are sampled less frequently, such as every three or four years.

Some people may be more vulnerable to drinking water contaminants than the general population. Immune-compromised persons, such as persons with cancer and undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from microbial infections. These people should seek advice from their health care provider. USEPA and the federal Centers for Disease Prevention and Control (CDC) developed guidelines on appropriate measures to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants. These are available from the national Drinking Water Hotline (800-426-4791).

Public Drinking Water Regulatory Program

The first national public drinking water standards, called the National Interim Primary Drinking Water Regulations (NIPDWR), were adopted on December 24, 1975, by the US Environmental Protection Agency (USEPA) under the 1974 Safe Drinking Water Act. By 1986, drinking water quality standards were in place for 23 different contaminants. The 1986 Safe Drinking Water Act mandated USEPA to set standards for 83 contaminants within 3 years, and 25 more contaminants every three years thereafter. The 1996 Safe Drinking Water Act significantly redirected this standard-setting schedule to a new one focusing on the highest remaining risks to health.

In Oregon, public drinking water systems are subject to the Oregon Drinking Water Quality Act (ORS 448 - Water Systems). The primary purpose of the 1981 Oregon Act is to “assure all Oregonians safe drinking water”. According to the Oregon Act, safe drinking water means water which is “sufficiently free from biological, chemical, radiological, or physical impurities such that individuals will not be exposed to disease or harmful physiological effects”. Under the Oregon Act, the Health Division has broad authority to set water quality standards necessary to protect public health through insuring safe drinking water within a public water system. To accomplish this, the Division is directed under the Act to require regular water sampling by water suppliers. These samples must be analyzed in laboratories approved by the Division, and the results of laboratory tests on those samples must be reported by the water supplier to the Division. The Division must investigate water systems that fail to submit samples, or whose sample results indicate levels of contaminants that are above maximum allowable levels. Water suppliers who fail to sample the water or report the results, or whose water contains contaminants in excess of allowable levels must take corrective action and notify water users.

Since 1986, the Division has exercised primary responsibility for administering the federal Safe Drinking Water Act in Oregon, an arrangement called Primacy. The Health Division adopts and enforces standards that are no less stringent than the federal standards, and in return, the USEPA gives the Division the regulatory responsibility for public drinking water systems and partial financial support for the Oregon program operation.

In practice, the Oregon drinking water standards match the national standards established under the Safe Drinking Water Act by the USEPA. This is because setting maximum levels for drinking water contaminants to protect human health involves considerable development of health effects information and other scientific research that is best carried out at the national level. The Health Division concentrates its efforts on implementing the national standards at Oregon public water systems.

Oregon Public Water Systems

Today, there are 2,652 public water systems in Oregon subject to regulation under the federal Safe Drinking Water Act. They serve 25 or more people at least 60 days per year. Of these, 885 are community water systems, which means the systems serve at least 15 connections used by year-round residents. These systems perform the most frequent water sampling for the greatest number of contaminants, because the people served have the most ongoing exposure to the drinking water. **Community water systems** in Oregon serve a total of about 2.7 million people and range in size from 15-home subdivisions and mobile home parks up to and including the City of Portland. **Nontransient noncommunity water systems** serve nonresidential populations consisting of the same people every day, such as a school or

workplace with its own independent water supply system. There are 329 of these in Oregon. **Transient noncommunity water systems** serve transient populations. Examples are campgrounds, parks, or restaurants with their own independent water supply systems, and there are 1,438 of these in Oregon.

An additional 965 very small systems, serving 10-24 people each, are subject only to the Oregon Act. About 500,000 Oregonians get their drinking water from **individual home wells**, which are not subject to either state or federal public drinking water standards.

Oregon public water systems get their water either from wells or springs (called groundwater) or from rivers, lakes, or streams (called surface water). Of the 3,617 public water systems in Oregon, 3,230 get their water exclusively from groundwater. 387 water systems get their water in whole or in part from surface water supplies. Generally speaking, surface water requires much more treatment and processing to ensure safety for drinking than does groundwater.

There are many small water systems in Oregon. About 90% of the public water systems in Oregon serve 500 or fewer people each.

Measuring Progress

The Oregon Safe Drinking Water Benchmark, stated below, is intended to measure progress of public water suppliers toward meeting safe drinking water standards in Oregon:

The percentage of Oregonians served by public drinking water systems that meet all health-based standards continuously during the year

Meeting all health-based standards at all times during the year is an important indicator of drinking water safety. The benchmark includes the following health-based standards, listed from highest to lowest health risk:

- E. Coli (or fecal coliform) bacteria maximum level
- Surface water treatment performance levels (filtration and disinfection)
- Nitrate/Nitrite maximum levels
- Chemical/Radiological maximum levels
- Lead action level
- Total coliform bacteria maximum level
- Copper action level

Included in the benchmark are about 1,300 public water systems that serve the majority of the state's population, including all community systems, all nontransient noncommunity systems, and the larger transient noncommunity systems (serving over 500 people per day).

The Oregon benchmark goal is to reach 95% by 2005. Results for the last four years are 1994-49%, 1995-50%, 1996-56%, 1997-89%, 1998-90%. Note that progress toward the benchmark goal is likely to be affected by revisions to existing standards and establishment of standards for additional contaminants that are scheduled for the coming years, described in Section II.

For More Information

Visit the Oregon Drinking Water Web Page for drinking water information and publications (<http://www.ohd.hr.state.or.us/dwp>). You can use "links" at this site to access many other sources of drinking water information. In addition, contact names and phone numbers of state and county program staff are listed.

County staffs are responsible for community water systems serving 3,300 people or fewer and using groundwater sources as well as all nontransient noncommunity and transient noncommunity systems. Questions about these systems should be directed to the respective county health department.

State staff are responsible for all community water systems serving more than 3,300 people and all community systems that use surface water sources. In counties without drinking water programs, state staff are responsible for all public water systems. State staff also serve as a technical resource for county drinking water programs as needed.

Compliance with drinking water standards is summarized for each calendar year on a statewide basis in the Oregon Annual Compliance Report, which is prepared in June and distributed via the PIPELINE newsletter shortly thereafter. Each community water system must distribute to users an annual Consumer Confidence Report, detailing the levels of contaminants detected in the water system and their significance, listing any violations of standards or sampling requirements that occurred, and providing information on the water sources used by the community.

Visit the Drinking Water Web Query page, where you can look at past and current water sample test results and regulatory compliance status information for all Oregon public water systems (<http://159.121.19.167>).

I. CURRENT STANDARDS

There are now drinking water quality standards for 96 contaminants, including 9 microbials, 10 disinfection by-products, 18 inorganics (including lead and copper), 53 organics, and 6 radiologic contaminants. These standards either have established MCLs or treatment techniques, and are summarized in this Section.

Microbial Contaminants - Coliform Bacteria

Purpose: Coliform bacteria is the primary measure of the microbial quality of drinking water. They are used as indicators of the possible presence of pathogenic, or disease-causing, microorganisms. Coliforms do not normally cause illness themselves. Routine samples collected by Oregon public water suppliers are analyzed for total coliform bacteria. Samples that show the presence of total coliforms are further examined for fecal coliforms or *E. coli*, which are more specific indicators of fecal contamination.

Health effects: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms present in more samples than allowed is a warning of potential problems. Fecal coliforms and *E. Coli* are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term health effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.

Application: All public water systems must regularly test for coliform bacteria from locations in the distribution system, identified in a coliform sampling plan.

Monitoring: All community systems, and noncommunity systems using surface water sources or serving over 1,000 people, must sample monthly:

<u>Population</u>	<u>Number of Monthly Samples</u>
up to 1,000	1
1,001-2,500	2
2,501-3,300	3
3,301-4,100	4
4,101-4,900	5
>4,900	see rules

All other systems must test for coliform bacteria once per quarter.

Compliance: All coliform sample results are reported as “coliform absent” (negative) or “coliform present” (positive). A set of 3-4 repeat samples is required for each positive coliform sample (so that a total of at least five samples is collected during the month). Repeat sampling continues until the maximum contaminant level is exceeded or a set of repeat samples with negative results is obtained. Small systems (fewer than 40 samples/month) are allowed no more than one positive sample per month. Larger systems are allowed no more than 5% positive samples in any month. Confirmed presence of fecal coliform or *E. coli* is considered an acute health risk and requires immediate notification of the public to take protective actions such as boiling or using bottled water.

Water Treatment/control measures: Use of disinfection processes for source waters, such as chlorination, ozonation, and ultraviolet light. Other control measures include maintaining a disinfectant residual in the distribution system, protection of the source water area, proper well construction, maintaining distribution system pressure, and cross connection control.

Rule history:

- Federal rule - 12/24/75 (National Interim Primary Drinking Water Regulation)
- Oregon rule - 9/24/82
- Federal rule - 6/29/89 (Total Coliform Rule)
- Oregon rule - 1/1/91

Microbial Contaminants - Surface Water Treatment

Purpose: Control pathogenic microorganisms and indicators in surface water sources, including *Giardia lamblia*, enteric viruses, heterotrophic plate count bacteria (HPC) and *Legionella*. Control level of particulate matter from soil runoff (turbidity). Control the microbial parasite *Cryptosporidium* in surface water sources used by large water systems, and at the same time, assure that disinfection by-products control does not increase the risk of waterborne disease at large water systems.

Health effects: Pathogenic organisms in drinking water can cause acute gastrointestinal disease in humans (see Table 1). These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. Turbidity has no direct health effects, however, turbidity can interfere with disinfection treatment or provide a medium for microbial growth. Turbidity may also indicate the presence of disease-causing organisms. EPA estimates that 199,000 cases of waterborne disease per year are avoided in the U.S. by meeting these requirements.

Application: All public water systems using surface water sources. Also all public water systems using groundwater sources determined by the Division to be under the “direct influence of surface water”, as indicated by:

- Significant similarities in water characteristics such as turbidity, temperature, conductivity, or pH between the groundwater source and nearby surface water, and if so,
- A significant occurrence of insects or other macroorganisms, algae, organic debris, or large pathogens like *Giardia*, as indicated by microscopic particulate analysis.

Compliance: All water systems must provide a total level of treatment to remove/inactivate 99.9% (3-log) of *Giardia lamblia*, and to remove/inactivate 99.99% (4-log) of viruses. In addition, filtered water systems serving 10,000 or more people must achieve 99% (2-log) removal of *Cryptosporidium*, and large unfiltered systems must include *Cryptosporidium* control in their watershed control programs. Filtration performance standards for turbidity and CxT [concentration x time] calculations for disinfection are used to determine if a water system is meeting the required removal/inactivation levels.

Compliance can be achieved by:

- Filtration plus disinfection treatment meeting performance standards, or
- Disinfection treatment plus meeting criteria to remain unfiltered, or
- Disinfection plus “natural filtration” plus wellhead/ source water protection (for groundwater sources under the direct influence of surface water).

Filtration performance standards (fewer than 10,000 people served):

- Turbidity measurements of filtered water every four hours by grab sampling or continuous monitoring.
- 95% of turbidity readings less than or equal to 0.5 ntu (nephelometric turbidity units), 1 ntu for alternative technologies.
- All turbidity readings less than or equal to 5 ntu.
- Minimum 2-log removal/inactivation, based on meeting turbidity performance standards.

Filtration performance standards (10,000 or more people served):

- Turbidity measurements of filtered water every four hours by grab sampling or continuous monitoring.
- 95% of turbidity readings less than or equal to 0.3 ntu (1 ntu for alternative technologies).
- All turbidity readings less than or equal to 1 ntu (5 ntu for alternative technologies).
- Minimum 2-log removal/inactivation, based on meeting turbidity performance standards.

Individual filter monitoring for systems using conventional or direct filtration (10,000 or more people served):

- Continuous turbidity monitoring of individual filters, recorded every 15 minutes.
- Specific followup actions required if any individual filter has:
 - Turbidity > 1.0 ntu in two consecutive measurements 15 min. apart, or
 - Turbidity > 0.5 ntu in two consecutive measurements 15 min. apart after 4 hours of operation following backwash, or
 - Turbidity > 1.0 ntu in two consecutive measurements 15 min. apart in each of three consecutive months, or
 - Turbidity > 2.0 ntu in two consecutive measurements 15 min. apart in two consecutive months.

Disinfection performance standards (all systems):

- Continuous recording of disinfectant residual at the entry point to the distribution system (small systems can substitute 1-4 grab samples per day).
- Daily calculation of CxT (disinfectant concentration x time) at highest flow
- CxT sufficient to meet needed removal/inactivation levels.
- Continuous minimum 0.2 mg/L disinfectant residual at entry point.
- Minimum detectable disinfectant residual in 95% of distribution system samples (collected at coliform bacteria monitoring points).

Disinfection profiling and benchmarking (10,000 or more people served):

- Develop four quarters of total trihalomethane (TTHM) and haloacetic acid (HAA5) data, from 3/99 to 3/00.

- If TTHM \geq 0.064 mg/L, or HAA5 \geq 0.048 mg/L, develop disinfection profile.
- If profile developed, calculate disinfection benchmark and consult with Division before changing disinfection process.

Compliance dates:

- | | |
|-------|---|
| 12/91 | Unfiltered systems meet requirements to remain unfiltered |
| 6/93 | Filtration or alternate water source in place. Filtered systems meet performance requirements |
| 6/94 | Division determines which community groundwater systems are under direct influence of surface water |
| 12/95 | Surface-influenced community systems meet treatment performance requirements |
| 3/99 | Large systems begin TTHM, HAA5 quarterly monitoring |
| 6/99 | Division determines which noncommunity groundwater systems are under direct influence of surface water |
| 12/99 | Large systems submit TTHM, HAA5 monitoring results |
| 3/00 | Large systems begin to develop disinfection profile, based on TTHM, HAA5 results |
| 12/00 | Surface-influenced noncommunity systems meet treatment performance requirements |
| 3/01 | Large systems complete disinfection profile |
| 1/02 | Large systems must meet strengthened turbidity performance standards and start individual filter monitoring |

Cost: Total US cost estimated to be \$518M/yr. Additional cost to large water systems to control *Cryptosporidium* are considered minimal.

Rule history:

- Federal rule - 12/24/75 (National Interim Primary Drinking Water Regulation - turbidity)
- Oregon rule - 9/24/82
- Federal rule - 6/29/89 (Surface Water Treatment Rule - SWTR)
- Oregon rule - 1/1/91 (SWTR)
- Federal rule - 12/16/98 (Interim Enhanced Surface Water Treatment Rule - IESWTR)
- Oregon rule - 12/16/00 (IESWTR)

TABLE 1 - MICROBIAL CONTAMINANTS

Contaminant	MCL, mg/L	Potential Health Effects	Source of Drinking Water Contamination
<i>Giardia lamblia</i>	TT ¹	Gastrointestinal disease	Human and animal fecal wastes
<i>Cryptosporidium</i>	TT	Gastrointestinal disease	Human and animal fecal wastes
<i>Legionella</i>	TT	Legionnaires disease	Natural waters, can grow in water heating systems
Heterotrophic plate count (HPC)	TT	Indicates water quality, effectiveness of disinfection treatment	Naturally occurring bacteria
Turbidity	PS ²	Interferes with disinfection, indicator of filtration treatment performance	Particulate matter from soil runoff
Viruses	TT	Gastrointestinal disease	Human fecal wastes
Total coliforms	<5% positive ³	General indicator of the presence of pathogens	Bacteria naturally present in the environment, human and animal fecal wastes
Fecal coliforms	Confirmed presence	More specific indicator of the presence of pathogens	Human and animal fecal wastes, some natural environmental sources
<i>E. Coli</i>	Confirmed presence	Most specific indicator of the presence of pathogens	Human and animal fecal wastes

¹ Treatment Technique, filtration plus disinfection of surface water, or equivalent

² Performance Standard, see text

³ No more than one positive routine sample per month (or quarter) for systems collecting fewer than 40 samples/month

Disinfectants and Disinfection By-products

Purpose: Protect people from disease-producing (pathogenic) organisms in water supplies while at the same time limiting the exposure of people to chemical disinfectant residuals and ten chemical by-products of disinfection treatment present as a result of disinfection treatment practices. Disinfection treatment used to kill microorganisms in drinking water can react with naturally occurring organic and inorganic matter in water to form disinfection by-products. The challenge is to apply levels of disinfection treatment needed to kill microorganisms while limiting the levels of disinfection by-products produced.

Health Effects: See Table 2.

Application: All community and nontransient noncommunity water systems that apply a disinfectant to the drinking water for primary or residual water treatment. In addition, transient noncommunity systems that use chlorine dioxide are also affected.

Monitoring: Disinfectant residuals must be monitored at the same locations and frequency as coliform bacteria. Disinfection by-products must be monitored throughout the distribution system at frequencies daily, monthly, quarterly or annually, depending on the population served, type of water source, and the specific disinfectant applied, and in accordance with an approved monitoring plan.

Compliance: Compliance is determined based on meeting maximum levels for disinfectant residual and disinfection by-products over a running 12-month average of the sample results, computed quarterly. See Table 2 for MCLs. Maximum

Residual Disinfectant Levels (MRDLs) are:

- Chloramines (total chlorine residual) - 4 mg/L (as Cl₂)
- Chlorine (free chlorine residual) - 4 mg/L (as Cl₂)
- Chlorine dioxide - 0.8 mg/L (as ClO₂)

Compliance dates:

- 1/02 Surface water systems serving 10,000 or more people.
- 1/04 Surface water systems serving less than 10,000 people, and all groundwater systems.

Water treatment/control measures: Control treatment processes to reduce disinfectant demand and residuals. DBPs can be reduced by moving the point of chlorine application from prior to filtration to after filtration, where many of the natural organic compounds in the water have been reduced, and by enhanced coagulation treatment. Alternative disinfectants such as chlorine combined with ammonia or ozone disinfection can reduce DBP levels.

Cost: Total cost US is estimated at \$702M/yr (1998). Benefits difficult to quantify due to uncertainties in health data. Benefits are believed to exceed costs.

Rule history:

- Federal rule - 11/29/79 (Total Trihalomethanes - TTHM, MCL=0.10 mg/L)
- Oregon rule - 9/24/82 (TTHM)
- Federal rule - 12/16/98 (Stage 1 Disinfectants/Disinfection By-products Rule - D/DBP)
- Oregon rule - 12/16/00 (Stage 1 D/DBP)

TABLE 2 - DISINFECTANT RESIDUALS, AND DISINFECTION BY-PRODUCTS

Contaminant	MCL, mg/L	Potential Health Effects	Source of Drinking Water Contamination
Bromate	0.010	Cancer	Drinking water ozonation by-product
Bromodichloromethane	(see total trihalomethanes, TTHMs)	Cancer; liver, kidney, and reproductive effects	Drinking water chlorination by-product
Bromoform	(see TTHMs)	Cancer; nervous system, liver and kidney effects	Drinking water chlorination by-product
Chlorite	1.0	Oxidative effects to red blood cells	By-product of disinfection using chlorine dioxide
Chloroform	(see TTHMs)	Cancer; liver, kidney, reproductive effects	Drinking water chlorination by-product
Dibromochloromethane	(see TTHMs)	Nervous system, liver, kidney, reproductive effects	Drinking water chlorination by-product
Dichloroacetic acid	(see HAA5)	Cancer; reproductive, developmental effects	Drinking water chlorination by-product
Haloacetic acids (HAA5) ¹	0.060	Cancer and other effects	Drinking water chlorination by-products
Trichloroacetic acid	(see HAA5)	Liver, kidney, spleen developmental effects	Drinking water chlorination by-product
Total Trihalomethanes (TTHMs) ²	0.080	Liver, kidney, central nervous system effects, increased risk of cancer	Drinking water chlorination by-products

¹ Sum of the concentrations of mono-, di-, and trichloroacetic acids and mono- and dibromoacetic acids

² Sum of the concentrations of chloroform, bromoform, dibromochloromethane, and bromodichloromethane

Lead and Copper

Purpose: Set treatment technique requirements to control lead and copper in drinking water at the customer tap. Although lead and copper are naturally present in geologic deposits, they are rarely present in Oregon at significant levels in surface water or groundwater sources. They are primarily from corrosion of plumbing and plumbing fixtures in homes and buildings. Lead comes from lead solder and brass fixtures, and copper comes from copper tubing and brass fixtures. Copper is also used as a wood preservative.

Health effects-Lead: Infants and young children are typically more vulnerable to lead in drinking water than the general population. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. EPA considers lead a probable human carcinogen.

Health effects-Copper: Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short period of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson’s Disease should consult their health care provider.

Application: All community and nontransient noncommunity systems

Monitoring: Samples are collected from “high-risk” homes; those with lead-soldered plumbing built prior to the 1984 prohibition of lead solder in Oregon. One-liter samples of standing water (first draw after 6 hours of non-use) are collected at homes identified in the water system sampling plan. The number of samples required for initial and subsequent monitoring is summarized below:

Water System Population	Initial Sample Sites	Reduced Sampling Sites
>100,000	100	50
10,001-100,000	60	30
3,301-10,000	40	20
501-3,300	20	10
101-500	10	5
<101	5	5

Two rounds of initial sampling were required during 1992-94, collected at six-month intervals. Subsequent annual sampling from the reduced number of sites is required after

demonstration that lead and copper action levels are met. After three rounds of annual sampling, samples are required every three years. Water systems practicing corrosion control treatment must also monitor for water quality parameters (such as pH, temperature, alkalinity) and comply with target levels as specified by the Division.

Compliance: In each sampling round, 90% of samples from homes must have lead levels less than or equal to the Action Level of 0.015 mg/L, and copper levels less than or equal to the Action Level of 1.3 mg/L. Water systems with lead above the Action Level must conduct periodic public education, and either install treatment, change water sources, or replace plumbing.

Water Treatment/Control Measures: Water systems that can not meet the Action Levels must either install corrosion control treatment or develop alternate sources of water by January, 1998. Water treatment alternatives include adding chemicals to adjust pH, alkalinity, or both (soda ash, caustic soda) or adding sequestering agents such as polyphosphates. If levels are not met even after treatment installation and optimization, then continuing public education efforts are required, along with replacement of any lead service lines. It is possible that lead levels in a particular home may be higher than at other homes in the community as a result of the materials used in that home's plumbing. People who are concerned about elevated lead levels can arrange to test their water and if the results are high, can flush taps for 30 seconds to two minutes before using tap water, especially after periods of extended non-use.

Rule history:

- Federal rule - 12/24/75 (Nation Interim Primary Drinking Water Regulation - Lead MCL - 0.05 mg/L)
- Oregon rule - 9/24/82
- Federal rule - 6/7/91 (Lead and Copper)
- Oregon rule - 12/7/92
- Technical corrections to federal rule - 7/15/91, 7/15/92, 6/30/94
- Minor revisions to federal rule - 1/12/00

Inorganic Contaminants

Purpose: Control levels of sixteen metals and minerals in drinking water, both naturally-occurring and resulting from agricultural or industrial use. Inorganic contaminants most often come from the source of water supply, but can also enter water from contact with materials used for pipes and storage tanks. See Table 3.

Health effects: For most inorganic contaminants, health concerns are related to long-term or even lifetime exposures (see Table 3). Nitrate and nitrite, however, can seriously affect infants in short-term exposures by interfering with the transfer of oxygen from the lungs to the bloodstream. Infants below the age of six months who drink water

containing nitrate or nitrite in excess of the MCLs could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome. Arsenic is a naturally-occurring mineral known to cause cancer in humans at high concentrations.

Application: All public water systems. The exception is the asbestos standard which applies to community and nontransient noncommunity systems.

Monitoring: Nitrate - community and nontransient noncommunity systems must sample quarterly for surface water sources and annually for groundwater sources. All noncommunity and state-regulated water systems must sample annually. **Asbestos** - community and nontransient noncommunity systems with asbestos-cement water pipes or with water sources in geologic asbestos deposit areas must sample every nine years. **All other inorganics** - community and nontransient noncommunity systems must sample surface water sources annually and groundwater sources every three years. All noncommunity and state-regulated water systems must sample once.

Compliance: Water systems must meet the established maximum contaminant levels (Table 3). Systems that can not meet one or more MCLs must either install water treatment systems or develop alternate sources of water.

Water Treatment: A variety of water treatment processes are available for reducing levels of specific inorganic contaminants in drinking water, including ion exchange and reverse osmosis.

Rule history:

- Federal rule - 12/24/75 (National Interim Primary Drinking Water Regulation)
- Oregon rule - 9/24/82 (NIPDWR)
- Federal rule - 4/2/86 (fluoride)
- Federal rule - 1/30/91 and 7/1/91 (Phase II)
- Federal rule - 7/19/92 (Phase V)
- Oregon rule - 6/9/92 (Phase II), and 1/14/94 (Phase V)

TABLE 3 - INORGANIC CONTAMINANTS

Contaminant	MCL, mg/L (or as noted)	Potential Health Effects	Sources of Drinking Water Contamination
Antimony	0.006	Blood cholesterol increases, blood sugar decreases	Discharge from petroleum refineries, fire retardants, ceramics, electronics, solder
Arsenic	0.05	Skin damage, circulatory system effects, increased cancer risk	Erosion of natural deposits of volcanic rocks, runoff from orchards, runoff from glass and electronics production wastes
Asbestos	7 million fibers per liter (>10 um fiber size)	Increased risk of developing benign intestinal polyps	Erosion of natural geologic deposits, decay of asbestos-cement water pipes
Barium	2	Increase in blood pressure	Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits
Beryllium	0.004	Intestinal lesions	Discharge from metal refineries and coal-burning factories, discharge from electrical, aerospace, and defense industries
Cadmium	0.005	Kidney damage	Corrosion of galvanized pipes, erosion of natural deposits, discharge from metal refineries, runoff from waste batteries and paints
Chromium (total)	0.1	Allergic dermatitis	Discharge from steel and pulp mills, erosion of natural deposits
Cyanide	0.2	Thyroid, nervous system damage	Discharge from steel/metal factories, discharge from plastic and fertilizer factories
Fluoride	4 ¹	Bone disease, mottled teeth	Erosion of natural deposits, discharge from fertilizer and aluminum industries, drinking water additive promoting strong teeth
Mercury (total inorganic)	0.002	Kidney damage	Erosion of natural deposits, discharges from refineries and factories, runoff from landfills, runoff from cropland
Nickel	0.1 ²	Heart and liver damage	Metal alloys, electroplating, batteries, chemical production
Nitrate (as N)	10	Methemoglobinemia (“blue baby syndrome”) in infants below the age of six months	Runoff from fertilizer use, leaching from septic tank/drain fields, erosion of natural deposits
Nitrite	1	Methemoglobinemia (“blue baby syndrome”) in infants below the age of six months	Runoff from fertilizer use, leaching from septic tank/drain fields, erosion of natural deposits (rapidly converted to nitrate)
Nitrate + nitrite	10	Methemoglobinemia (“blue baby syndrome”) in infants below the age of six months	Runoff from fertilizer use, leaching from septic tank/drain fields, erosion of natural deposits (rapidly converted to nitrate)
Selenium	0.05	Hair and nail loss, numbness in fingers and toes, circulatory problems	Discharge from petroleum and metal refineries, erosion of natural deposits, discharge from mines
Thallium	0.002	Hair loss, blood changes, and kidney, liver, intestinal effects	Leaching from ore processing sites, discharge from electronics, drugs, and glass factories

¹Note: a secondary standard for fluoride is set at 2.0 mg/L to control tooth discoloration

²Oregon regulatory standard only, federal standard withdrawn 2/23/95

Organic Chemicals

Purpose: Control levels of 53 different organic contaminants (see Table 4). Organic contaminants are most often associated with industrial or agricultural activities that affect sources of drinking water supply. Major types of organic contaminants include industrial and commercial solvents and chemicals, and pesticides used in agriculture and landscaping. Organic contaminants can also enter drinking water from materials in contact with the water such as pipes, valves, and paints and coatings used inside water storage tanks.

Health effects: For organic contaminants, health concerns are related to long-term or even lifetime exposures to low levels of contaminant (see Table 4).

Application: Community and nontransient noncommunity water systems.

Monitoring: One test for each contaminant from each water source is required during every 3-year compliance period. Quarterly followup testing is required for any contaminants that are detected. The exceptions are dioxin and acrylamide/epichlorohydrin. Only those systems determined by the Division to be at risk of contamination must monitor for dioxin. Water systems using polymers containing acrylamide

or epichlorohydrin in their water treatment processes must keep their dosages below specified levels.

Compliance: Water systems must meet the established maximum contaminant levels (Table 4). Systems that can not meet one or more MCLs must either install or modify water treatment systems or develop alternate sources of water.

Water Treatment: A variety of water treatment processes are available for reducing levels of specific organic contaminants in drinking water, including activated carbon and aeration.

Rule history:

- Federal rule - 12/24/75 (National Interim Primary Drinking Water Regulation)
- Oregon rule - 9/2/82
- Federal rule - 7/8/87 (Phase I Volatile Organic Chemicals)
- Oregon rule - 11/13/89 (Phase I)
- Federal rule - 1/30/91 and 7/1/91 (Phase II Synthetic Organic Chemicals)
- Federal rule - 7/19/92 (Phase V Synthetic Organic Chemicals)
- Oregon rule - 6/9/92 (Phase II); and 1/14/94 (Phase V)

TABLE 4 - ORGANIC CONTAMINANTS

Contaminant	MCL, mg/L	Potential Health Effects	Sources of Drinking Water Contamination
Acrylamide	TT ¹	Central nervous system and blood effects, increased risk of cancer	Added to water during water and sewage treatment
Alachlor	0.002	Eye, liver, kidney, spleen effects, anemia, increased risk of cancer	Runoff from herbicides used on row crops
Atrazine	0.003	Cardiovascular and reproductive effects	Runoff from herbicides used on row crops
Benzene	0.005	Decreased blood platelets, anemia, increased risk of cancer	Discharge from factories, leaching from landfills and gas storage tanks
Benzo(a)pyrene (Polycyclic aromatic hydrocarbons)	0.0002	Reproductive difficulties and increased risk of cancer	Leaching from linings of water storage tanks and water pipes
Carbofuran	0.04	Blood, nervous system, and reproductive system effects	Leaching of soil fumigant used on rice and alfalfa
Carbon tetrachloride	0.005	Liver effects and increased risk of cancer	Discharge from chemical plants and other industrial activities
Chlordane	0.002	Liver and nervous system effects, increased risk of cancer	Residue of banned termiticide
Chlorobenzene	0.1	Kidney and liver effects	Discharge from chemical and agricultural chemical factories
2,4-D	0.07	Liver, adrenal gland, and kidney damage	Runoff from herbicides used on row crops
Dalapon	0.2	Minor kidney effects	Runoff from herbicides used on rights of way

TABLE 4 - ORGANIC CONTAMINANTS (continued)

Contaminant	MCL, mg/L	Potential Health Effects	Sources of Drinking Water Contamination
Dibromochloro- propane (DBCP)	0.0002	Reproductive difficulties and increased risk of cancer	Runoff from soil fumigant used on soybeans, cotton, pineapples, orchards
o-Dichlorobenzene	0.6	Liver, kidney, circulatory system damage	Discharge from industrial chemical factories
p-Dichlorobenzene	0.075	Liver, kidney, spleen damage, anemia, blood effects	Discharge from industrial chemical factories
1,2-Dichloroethane	0.005	Increased risk of cancer	Discharge from industrial chemical factories
1,1-Dichloroethylene	0.007	Liver damage	Discharge from industrial chemical factories
cis 1,2-Dichloroethylene	0.07	Liver damage	Discharge from industrial chemical factories
trans 1,2-Dichloroethylene	0.1	Liver damage	Discharge from industrial chemical factories
Dichloromethane (methylene chloride)	0.005	Liver damage and increased risk of cancer	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane	0.005	Increased risk of cancer	Discharge from industrial chemical factories
Di(2-ethylhexyl) adipate	0.4	General toxic and reproductive effects	Discharge from chemical factories
Di(2-ethylhexyl) phthalate	0.006	Liver effects, reproductive difficulties, increased risk of cancer	Discharge from chemical and rubber factories
Dinoseb	0.007	Reproductive difficulties	Runoff from herbicide used on soybeans and vegetables
Dioxin (2,3,7,8-TCDD)	3 x10 ⁻⁸	Reproductive difficulties and increased risk of cancer	Emissions from waste incineration and other combustion, discharge from chemical factories
Diquat	0.02	Cataracts	Runoff from herbicide use
Endothall	0.1	Stomach, intestine effects	Runoff from herbicide use
Endrin	0.002	Liver damage	Residue of banned insecticide
Epichlorohydrin	TT ¹	Stomach effects and increased risk of cancer	Discharge from industrial chemical factories, impurity in some water treatment chemicals
Ethylbenzene	0.7	Liver, kidney damage	Discharge from petroleum refineries
Ethylene dibromide	0.00005	Liver, stomach, kidney, reproductive system effects, and increased risk of cancer	Discharge from petroleum refineries
Glyphosate	0.7	Kidney, reproductive system effects	Runoff from herbicide use
Heptachlor	0.0004	Liver damage, increased risk of cancer	Residue of banned termiticide
Heptachlor epoxide	0.0002	Liver damage, increased risk of cancer	Breakdown of heptachlor
Hexachlorobenzene	0.001	Liver, kidney, reproductive system effects, and increased risk of cancer	Discharge from metal refineries and agricultural chemical factories
Hexachloro- cyclopentadiene	0.05	Kidney, stomach damage	Discharge from chemical factories
Lindane	0.0002	Liver, kidney effects	Runoff/leaching from insecticide used on lumber, gardens, cattle
Methoxychlor	0.04	Reproductive difficulties	Runoff/leaching from insecticide used on fruits, vegetable, alfalfa, livestock

TABLE 4 - ORGANIC CONTAMINANTS (continued)

Contaminant	MCL, mg/L	Potential Health Effects	Sources of Drinking Water Contamination
Oxamyl (Vydate)	0.2	Slight nervous system effects	Runoff/leaching from insecticide used on apples, potatoes, tomatoes
Pentachlorophenol	0.001	Liver and kidney effects, increased risk of cancer	Discharge from wood preserving operations
Picloram	0.5	Liver damage	Herbicide runoff
Polychlorinated biphenyls (PCBs)	0.0005	Skin, thymus gland, reproductive system, and nervous system effects, immune deficiencies, increased risk of cancer	Runoff from landfills, discharge of waste chemicals
Simazene	0.004	Blood effects	Herbicide runoff
Styrene	0.1	Liver, kidney, circulatory system damage	Discharge from rubber and plastic factories, leaching from landfills
Tetrachloroethylene	0.005	Liver damage and increased risk of cancer	Discharge from factories and dry cleaning
Toluene	1	Liver, kidney, nervous system effects	Discharge from petroleum refineries
Toxaphene	0.003	Kidney, liver, thyroid effects, increased risk of cancer	Runoff/leaching from insecticide used on cattle, cotton
2,4,5-TP (Silvex)	0.05	Liver damage	Residue of banned herbicide
1,2,4-Trichlorobenzene	0.07	Adrenal gland changes	Discharge from textile finishing factories
1,1,1-Trichloroethane	0.2	Liver, nervous system, circulatory system effects	Discharge from metal degreasing sites and other factories
1,1,2-Trichloroethane	0.005	Kidney, liver, immune system damage	Discharge from industrial chemical factories
Trichloroethylene	0.005	Liver damage and increased risk of cancer	Discharge from metal degreasing sites and other factories
Vinyl chloride	0.002	Increased risk of cancer	Leaching from PVC pipe, discharge from plastics factories
Xylenes (total)	10	Nervous system damage	Discharge from petroleum factories, discharge from chemical factories

¹Treatment technique requirement (limit dosage of polymer treatment chemicals)

Radiologic Contaminants

Purpose: Limit exposure to six radioactive contaminants in drinking water (see Table 5). These contaminants are both natural and man-made.

Health effects: Primarily increased cancer risk from long-term exposure.

Application: All community water systems.

Monitoring: One sample from each source every four years. Only communities serving over 100,000 people or with sources potentially impacted by man-made radiation sources

designated by the Division must sample for beta/photon radiation.

Compliance: Community water systems that can not meet MCLs must install treatment or develop alternate water sources.

Water treatment: Variety of treatment processes will reduce radiologic contaminants, including ion exchange and reverse osmosis.

Rule history:

Federal rule - 7/9/76

Oregon rule - 9/24/82

TABLE 5 - RADIOLOGIC CONTAMINANTS

Contaminant	MCL, pCi/L (picocuries per liter), unless otherwise noted	Potential Health Effects	Sources of Drinking Water Contamination
Gross alpha	15	Increased risk of cancer	Erosion of natural deposits
Beta and photon emitters ¹	50 (4 mrem/yr)	Increased risk of cancer	Decay of natural and man-made deposits
Iodine-131 ²	3	Increased risk of cancer	Power production
Radium 226+228 ³	5	Increased risk of cancer	Erosion of natural deposits
Strontium 90 ²	8	Increased risk of cancer	Power and weapons production
Tritium ²	20,000	Increased risk of cancer	Power and weapons production

¹ Sampling required only if designated by the Division - Gross beta + photon emitters not to exceed 4 millirems per year

² State standards only, sampling required only if designated by the Division

³ Sampling only if gross alpha result exceeds 5 pCi/L

Review and Update of Current Standards

The 1996 Safe Drinking Water Act requires EPA to review and revise as appropriate each current standard at least every six years. A final rule listing standards to be revised, presenting agency analysis and conclusions, and presenting a timetable for proposal and finalizing revisions is scheduled for August, 2002.

Unregulated Contaminant Monitoring

Purpose: Develop occurrence data on 30 new contaminants (see Table 6) in order to support development of future drinking water standards in 2005.

Health effects: Not fully characterized at present. Research on health effects is in progress.

Application: All community water systems serving over 10,000 people, plus a random selection of community water systems serving fewer than 3,300 people.

Monitoring: Quarterly sampling during 2001-2003.

Compliance: Large water systems must collect samples, have them analyzed at approved labs, and report results to EPA. Small systems must collect samples and ship them to EPA approved labs. All water systems with unregulated contaminant results must present the data in their annual Consumer Confidence Reports.

Rule history:

Federal rule - 9/17/99

Oregon rule - Not applicable, rule to be enforced by EPA

TABLE 6 - UNREGULATED CONTAMINANTS

Tier 1 List - Assessment - Methods Available	Tier 2 List - Screening Survey - Methods Available Soon	Tier 3 List - Prescreening - Methods to be Developed
2,4-dinitrotoluene	Diuron	Algae and Toxins
2,6-dinitrotoluene	Linuron	Echoviruses
DCPA mono acid	2,4,6-trichlorophenol	Coxsackieviruses
DCPA di acid	2,4-dichlorophenol	Heliobacter pylori
4,4' -DDE	2,4-dinitrophenol	Microsporidia
EPTC	2-methyl-1-phenol	Caliciviruses
Molinate	Alachlor ESA	Adenoviruses
MTBE	1,2-diphenylhydrazine	Lead 210
Nitrobenzene	Diazinon	
Terbacil	Disulfoton	
Acetochlor	Fonofos	
Perchlorate	Terbofos Aeromonas Hydrophilia Polonium 210 RDX Prometon	

II. FUTURE STANDARDS

New and revised drinking water quality standards are mandated under the federal 1996 Safe Drinking Water Act. This Section is intended to summarize and preview these standards, currently under development by USEPA and not yet final. The future standards include:

- Microbial standards - Enhanced surface water treatment, filter backwash, groundwater
- Disinfectants and disinfection by-products
- Arsenic
- Radon and radionuclides
- Contaminant candidate list - next five contaminants

USEPA is expected to complete an ambitious adoption schedule for these standards during 2000-2005. Water suppliers should be aware of and familiar with these mandates and deadlines, and plan strategically to meet them. The Health Division, under the Primacy Agreement with USEPA, has up to two years to adopt each federal rule after it is finalized.

Microbial Standards - Enhanced Surface Water Treatment, Filter Backwash, Groundwater

Purpose: Increase protection of people from disease-producing (pathogenic) organisms in both groundwater and surface water supplies. The primary additional organism of concern in surface water supplies is *Cryptosporidium*. All surface water supplies are considered at some risk of containing microorganisms at any given time. Human enteric viruses from human fecal matter is of concern in groundwater supplies. Available data suggests that 8-10% of public wells may be at risk of virus contamination, so requirements will focus on identification of at-risk wells and either reducing the risk or providing adequate levels of disinfection treatment to kill viruses.

To increase microbial occurrence data in US public water systems, larger utilities collected microbiological data under the Information Collection Rule (ICR) during 1998-99. ICR data is being used to design future microbial drinking water standards. Recently established microbial standards focused on improvements in health protection that can be achieved by optimizing existing large water system facilities without major capital costs (see Interim Enhanced Surface Water Treatment Rule described under Section I- Current Standards). Future standards are likely to require major capital investments, based on the public health needs demonstrated by analysis of the ICR data. The remaining regulatory "stages" are summarized below:

- Long-term Stage 1 Enhanced Surface Water Treatment (LT1ESWTR) - Increased filtration and disinfection performance standards for surface water systems serving 10,000 or fewer people
- Filter Backwash Rule (FBR) - Requirements on recycling of filter backwash water to control microbials

- Groundwater Rule (GWR) - New disinfection treatment performance standards or alternative practices for all systems with groundwater at risk of virus contamination
- Long-term Stage 2 Enhanced Surface Water Treatment (LT2ESWTR) - Further increased filtration and disinfection performance standards for all systems
- Revisions to current coliform bacteria standards - if needed.

Health effects: Gastrointestinal illness. Actual numbers of illness cases are very difficult to quantify - typically, only large and sudden outbreaks are likely to be recognized. Smaller outbreaks and low constant levels of illness are unlikely to be recognized. EPA estimates that, nationally, 463,000 cases of cryptosporidiosis per year could be avoided with enhanced treatment of surface water, and that as many as 115,000 cases of gastrointestinal illness per year could be avoided for groundwater sources.

Application: All public water systems using groundwater or surface water sources of supply.

Monitoring: Monitoring is likely to be required for specific pathogenic organisms and/or indicator organisms. Additional monitoring of and stricter performance standards for surface water treatment processes is also likely. Identification of sanitary defects and hazards for well installations will be required.

Compliance: Compliance is demonstrated by either meeting MCLs, meeting treatment technique requirements or correcting sanitary defects.

Costs: Significant costs to water systems are expected, dependent on the scope and content of the final rules.

Federal regulation dates:

Proposed LT1ESWTR and Filter Backwash Rule:
March, 2000

Final LT1ESWTR and Filter Backwash Rule:
November, 2000

Proposed Groundwater Rule: April, 2000
Final Groundwater Rule: November, 2000

Final LT2ESWTR: May, 2002

Coliform bacteria rule revision: 2002

Disinfectants and Disinfection By-products

Purpose: Further reduce exposure of people to disinfectant residuals and disinfection by-products (D-DBPs). Disinfection treatment used to kill or inactivate microorganisms in drinking water can react with naturally occurring organic and inorganic matter in water to form disinfection by-products. The challenge is to apply levels of disinfection treatment needed to kill microorganisms while limiting the levels of disinfection by-products produced, so these requirements are linked with development of microbial standards described above.

To increase D-DBP occurrence data in US public water systems, larger utilities collected data under the Information Collection Rule (ICR) during 1998-99. ICR data is being used to design future D-DBP drinking water standards. Recently established microbial standards focused on improvements in health protection that can be achieved by optimizing existing large water system facilities without major capital costs (see Stage 1 D-DBP Rule, Section I- Current Standards). Future standards are likely to include reduced MCLs and require major capital investments, based on the public health needs demonstrated by analysis of the ICR data.

Health Effects: Possible chronic and reproductive effects.

Application: All water systems that apply disinfectants.

Monitoring: Further monitoring for both disinfectants and by-products.

Compliance: Meet reduced MCLs and new MCLs, to be established based on results from the Information Collection Rule.

Costs: Significant capital costs to water systems are expected.

Federal regulation dates:

Final Stage 2 Disinfectants/Disinfection By-products (Stage 2 D/DBP): May, 2002

Arsenic

Purpose: Revise existing Maximum Contaminant Level (MCL) for arsenic based on health effects research suggesting that arsenic may present an internal organ cancer risk at low levels of exposure. EPA finalized a comprehensive arsenic health research plan to reduce uncertainties in assessing health risks of arsenic, but the results are not expected to be complete before the scheduled adoption of the new standard. Arsenic in Oregon is a naturally occurring inorganic contaminant that is associated with volcanic geologic deposits. Groundwater is more likely to contain arsenic than surface water.

Health effects: Current MCL (0.05 mg/L) is based on risk of skin thickening and possible skin cancer. Revised MCL to take into account risk of bladder, lung, and skin cancer.

Application: Community and nontransient noncommunity systems, surface water and groundwater sources.

Monitoring: To be determined in rule.

Compliance: Meet revised MCL. EPA is expected to propose an MCL of 0.005 mg/L.

Occurrence in Oregon: 250 water systems have reported at least one test result for arsenic above 0.005 mg/L.

Water treatment: Adsorption, ion exchange, reverse osmosis

Costs: National annual costs of meeting a range of possible MCLs are: 0.0005 mg/L, \$120B; 0.002 mg/L, \$4.2B; 0.010 mg/L, \$710M; 0.020 mg/L, \$330M; 0.050 mg/L, \$120M.

Federal regulation dates:

Proposed rule: June, 2000

Final rule: January, 2001

Radionuclides (except Radon)

Purpose: Set new or revised MCLs for radium-226, radium-228, uranium, alpha emitters, and beta and photon emitters.

Health effects: Primarily cancer

Application: Community and nontransient noncommunity systems, surface water and groundwater sources.

Monitoring: To be determined in rule.

Compliance: Based primarily on meeting MCLs. Existing MCLs for radium-226 and 228 are unlikely to be raised, as was earlier expected, from 5 pCi/L to 20 pCi/L. Uranium MCL proposed in 1991 at 0.02 mg/L.

Costs: Likely small impact in Oregon. Oregon water systems rarely detect levels of radionuclides above low natural background levels.

Federal regulation dates:

Notice of Data Availability: March, 2000

Final rule: November, 2000

Radon

Purpose: Reduce exposure of people to both indoor air radon and radon in drinking water. Radon is a naturally occurring gas formed from the decay of uranium-238. Radon enters indoor air primarily from soil under homes, and tap water from groundwater sources is a relatively small source of radon in air. Surface water systems are unlikely to contain radon.

Health effects: Inhalation of radon and its decay products causes lung cancer, with smokers at particular risk. Ingestion of radon in drinking water presents a small risk of stomach cancer. EPA estimates that 20,000 deaths per year in the US result from indoor air radon. 168 deaths are likely due to radon in drinking water (19 from ingestion, 149 from inhalation).

Application: All community water systems using groundwater sources.

Monitoring: Quarterly initial sampling at distribution system entry points, for one year. Subsequent sampling once every 3 years.

Compliance: Meet MCL of 300 pCi/L. An alternative MCL (AMCL) of 4,000 pCi/L is proposed, if the Division adopts an EPA-approved statewide Multi-Media Mitigation program (MMM). Elements of the MMM program include public participation in MMM development, quantitative goals for remediation of existing homes and radon-resistant new construction, strategies for achieving goals, and tracking and reporting of results. Finally, local communities have the option of developing an EPA approved local MMM program, in the absence of a statewide MMM program, and meeting the drinking water AMCL.

Occurrence in Oregon: Oregon radon data from 65 deep community wells collected in 1981 showed 23 with radon greater than 300 pCi/L, and none greater than 4,000 pCi/L. Oregon geologic mapping and results of voluntary indoor air testing in

homes suggest that a maximum of 4% of Oregon homes may exceed the EPA indoor air action level.

Water treatment: Aeration, granular activated carbon.

Cost: Estimated national annual costs of radon MCLs: 300 pCi/L, \$408M/yr; 4,000 pCi/L, \$43M/yr.

Federal regulation dates:

Proposed rule: November, 1999

Final rule: August, 2000

Drinking Water Contaminant Candidate List (DWCCCL)

Purpose: Identify chemical and microbiological contaminants known or anticipated to occur in public water systems, for possible future regulation. The first DWCCCL was published in March, 1998. In Tables 7 and 8, the list is broken into two groups. The first group includes twenty contaminants that are priorities for regulation, and will be the source for EPA regulatory decisions for five contaminants in August, 2001. The second group includes forty additional contaminants which require further research on health, treatment, and/or analytical methods, or need further occurrence data collection. For each contaminant, its classification is shown along with the Chemical Abstract System Number

(CASN), if applicable, for use in locating additional information on the contaminant. The list must be updated every five years.

In addition, the tables indicate the contaminants on the DWCCCL for which EPA Health Advisories have been published. These advisories contain known information on health risks, and specify ranges of concentrations that are acceptable for drinking over different lengths of time. Advisories are generally used to evaluate specific contaminant exposures at specific sites, such as chemical spills.

Monitoring: To support identification of contaminants, the EPA established the National Contaminant Occurrence Database (NCOD) in August, 1999. The Unregulated Contaminant Rule (see Current Standards) requires monitoring and reporting by large public water systems and certain smaller systems for up to 30 unregulated contaminants for inclusion in the database.

Regulating contaminants: EPA must publish a decision on whether or not to regulate at least five contaminants (including sulfate) from the DWCCCL by August, 2001, and from each updated DWCCCL every five years. For any contaminants from the first DWCCCL for which a decision is made to regulate, the final rule is due by February, 2005, with compliance required by water systems by February, 2008.

TABLE 7 - CONTAMINANT CANDIDATE LIST - REGULATORY DETERMINATION PRIORITIES (20)

Contaminant	Classification	Chemical Abstract Number	Health Advisory Published
Acanthamoeba	microbiological	_____	
1,1,2,2-tetrachloroethane	organic	630-20-6	
1,1-dichloroethane	organic	75-34-3	
1,2,4-trimethylbenzene	organic	95-63-6	
1,3-dichloropropene	pesticide	542-75-6	
2,2-dichloropropane	organic	594-20-7	
Aldrin	pesticide	309-00-2	X
Boron	inorganic	7440-42-8	
Bromobenzene	organic	108-86-1	
Dieldrin	pesticide	60-57-1	X
Hexachlorobutadiene	organic	87-68-3	
p-Isopropyltoluene	organic	99-87-6	
Manganese	inorganic	7439-96-5	
Metolachlor	pesticide	51218-45-2	
Metribuzin	pesticide	21087-64-9	
Naphthalene	organic	91-20-3	
Organotins	organic	_____	
Triazines & degradation products (including Cyanazine, Atrazin-desethyl)	pesticide	_____	
Sulfate	inorganic	_____	
Vanadium	inorganic	7440-62-2	

TABLE 8 - CONTAMINANT CANDIDATE LIST - RESEARCH AND OCCURRENCE PRIORITIES (40)

Contaminant	Classification	Chemical Abstract Number	Health Advisory Published
Adenoviruses	microbiological	_____	
Aeromonas hydrophilia	microbiological	_____	
Cyanobacteria (Blue-green algae) and their toxins	microbiological	_____	
Caliciviruses	microbiological	_____	
Coxsackieviruses	microbiological	_____	
Echoviruses	microbiological	_____	
Helicobacter pylori	microbiological	_____	
Microsporidia	microbiological	_____	
1,1-dichloropropene	organic	563-58-6	
1,2-diphenylhydrazine	organic	122-66-7	
1,3-dichloropropane	organic	142-28-9	
2,4,6-trichlorophenol	organic	88-06-2	
2,4-dichlorophenol	organic	120-83-2	
2,4-dinitrophenol	organic	51-28-5	
2,4-dinitrotoluene	organic	121-14-2	
2,6-dinitrotoluene	organic	606-20-2	
2-methyl-phenol	organic	95-48-7	
Alachlor ESA	pesticide	_____	
Aluminum	inorganic	7429-90-5	
Acetochlor	pesticide	34256-82-1	
DCPA (Dacthal) mono-acid & degradates	pesticide	887-54-7	
DCPA (Dacthal) di-acid degradates	pesticide	2136-79-0	
DDE	pesticide	72-55-9	
Diazinon	pesticide	333-41-5	X
Disulfoton	pesticide	298-04-4	X
Diuron	pesticide	330-54-1	X
EPTC (s-Ethyl-dipropylthiocarbonate)	pesticide	759-94-4	
Fonofos	pesticide	944-22-9	X
Linuron	pesticide	330-55-2	
Methyl bromide	organic	74-83-9	
Molinate	pesticide	2212-67-1	
Mycobacterium avium intercellulare (MAC)	microbiological	_____	
MTBE	organic	1634-04-4	X
Nitrobenzene	organic	98-95-3	
Perchlorate	inorganic	_____	
Prometon	pesticide	1610-18-0	
RDX	organic	121-82-4	X
Sodium	inorganic	7440-23-5	
Terbacil	pesticide	5902-51-2	X
Terbufos	pesticide	13071-79-9	X



Department of Human Services
Oregon Health Division
Drinking Water Program
P.O. Box 14450
Portland OR 97293-0450



PERIODICALS
POSTAGE
PAID
PORTLAND, OR.

PIPELINE is intended to provide useful information on technology, training, and regulatory and policy issues to those involved with the state's public water systems to improve the quality of drinking water in Oregon. **PIPELINE** may be copied or reproduced without permission provided credit is given.

PIPELINE is published quarterly free of charge by the staff of the Oregon Health Division, Drinking Water Section, 800 NE Oregon St., Portland OR 97232, Phone (503) 731-4010. Periodicals postage paid at Portland OR. POSTMASTER: Send address changes to **PIPELINE**, P.O. Box 14450 Portland OR 97293-0450.

IF YOU WOULD LIKE THIS IN AN ALTERNATE FORMAT, PLEASE CALL (503) 731-4010