



Housekeeping

- Please let us know if you cannot hear, etc.
- Mute your phone/computer
- Ask questions in chat box
- This presentation is being recorded








Training Outline

- Cyanotoxins monitoring in Oregon drinking water incl. recent rule revisions - Gregg
 - OAR 333-061-0510 to 333-061-0580
- 2022 monitoring season recap Nathan
- Updates to 2023 monitoring Nathan
- Step-by-step guide to sampling Nathan
 - Field collection
 - Shipping samples to DEQ
 - Lab analysis and reporting
 Questions and Discussion all







Who to contact

Oregon Health Authority roles:

- Drinking water safety
- OAR 333-061-0510
- Contact recreation safety
- Issue advisories

OHA is your go-to for questions about:

- Drinking water rules
- Regulations
- Resources

DEQ Laboratory roles:

- Provide lab support for OHA drinking water rule
- Coordinate with DW facility operators
- Provide training, supplies, shipping, lab analyses and report results to OHA

DEQ is your go-to for questions about:

- Logistical issues (shipping, training, etc.)
- Sampling (schedule, protocol, etc.)
- Interpreting results





Who to contact

OHA

Gregg Baird 503-936-1657 (cell)

New email: gregg.c.baird@oha.oregon.gov



DEQ Lab

Nathan Reetz 503-706-9572 (cell) | 503-693-5756 (office)

Nathan.REETZ@deq.oregon.gov





Health Advisory Levels

Cyanotoxins monitored in Oregon: microcystins, cylindrospermopsin

Cyanotoxin	For Vulnerable People (ug/L or ppb)	For Anyone (ug/L or ppb)				
Total Microcystins	0.3	1.6				
Cylindrospermopsin	0.7	3				

Health effects include: upset stomach, diarrhea, vomiting, long-term liver/kidney damage



Cyanotoxins Rulemaking History

- Temporary rules effective July 1, 2018
- Permanent rules effective December 27, 2018
- Revised rules effective February 1, 2023



Rule revisions: Trigger levels

- Raw water trigger levels for weekly raw/finished monitoring:
 - Lowers microcystins trigger level to 0.20 ug/L (was 0.3 ug/L)
 - Sets cylindrospermopsin trigger level at 2 significant figures to 0.30 ug/L (was 0.3 ug/L)
 333-061-0540(1)(a) Cyanotoxin Monitoring
 - (B) If at any time either total microcystins concentration is detected at greater than or equal to 0.20 μg/L or cylindrospermopsin concentration in raw water are is detected at greater than or equal to 0.30 μg/L in raw water, or there is a recreational use health advisory in a water body upstream, water suppliers must immediately increase raw water monitoring of cyanotoxins to weekly.
 - (C) Water suppliers may resume raw water monitoring every two weeks if there is not a recreational use health advisory upstream and cyanotoxin levels are not detected or are less than 0.20 μg/L for total microcystins and 0.30 μg/L for cylindrospermopsin in at least two consecutive weekly samples.

Rule revisions: SAES kit equivalency

- Clarifies that using the SAES kit is considered equivalent within the method 546
- Allows a lower minimum reporting limit for microcystins

333-061-0550 Analytical Methods

- (1) A water supplier must use a laboratory accredited according to OAR chapter 333, division 64 and the Oregon Environmental Laboratory Accreditation Program (ORELAP), or the Oregon Department of Environmental Quality Laboratory to analyze samples required by OAR 333-061-0510 to 333-061-0580.
- (2) For total microcystins, a water supplier must ensure that samples are analyzed using EPA method 546, or another EPA-approved method that applies at the time samples are analyzed. The Eurofins Abraxis SAES ELISA kits (520011SAES) are equivalent to the ELISA kits (520011OH) discussed in Section 6.1 of EPA Method 546.



Rule revisions: Finished water results taken in response to raw water result over trigger level

- 0560(3): requires faster reporting of entry point results taken in response to raw water result over the trigger level
- Clarifies reporting of detections
 - (d) Laboratories must report any entry point analytical result taken in response to a raw water analytical result with a detection greater or equal to 0.20 μg/L for total microcystins or 0.30 μg/L for cylindrospermopsin to the Authority and the water supplier within one business day of validation;
 - (de) Laboratories must report any analytical result with a detection greater or equal to 0.20 μg/L for total microcystins or 0.30 μg/L for cylindrospermopsin cyanotoxins to the Authority and the water supplier within one business day of validation;
 - (ef) Laboratories must report all other analytical results <u>not detected or</u> less than 0.20 µg/L for total <u>microcystins or 0.30 µg/L for cylindrospermopsin</u> to the Authority within 10 days of the end of the month the sample was collected; and
 - (fg) Analyses required by OAR 333-061-0540 must be uploaded by the laboratory to the Authority in an approved XML format or submitted in a format approved by the Authority.



Rule revisions: Sampling outside May to October window

 Requires any samples collected at any time from a compliance location during normal operations and analyzed by an accredited lab with an approved method to be reported.

(4) Samples collected at any time from the raw water sample point, entry point, or distribution system that are analyzed for cyanotoxins by an ORELAP-accredited lab or the Oregon Department of Environmental Quality Laboratory using the analysis methods in OAR 333-061-0550 must be reported per OAR 333-061-0560.



Rule revisions: Criteria to stop EP monitoring: MISTAKE!

- Final rules (old rule):
 - (D) Water suppliers may cease entry point monitoring if the results from two
 consecutive samples of the raw water are less than 0.3 μg/L and is not detected in two
 consecutive entry point or distribution samples.
- Intention:
 - (D) Water suppliers may cease entry point monitoring if the results from two consecutive samples of the raw water not detected or are less than 0.20 μg/L for total microcystins and 0.30 μg/L for cylindrospermopsin and cyanotoxins are not detected in two consecutive entry point or distribution samples.



Summary of rule revisions

- 333-061-540 Cyanotoxin Monitoring:
 - Lowered total microcystins trigger level to 0.20 ug/L (from 0.3 ug/L)
 - Changed cylindrospermopsin trigger level to 0.30 ug/L (from 0.3 ug/L)
- 333-061-0550 Analytical Methods:
 - Added language indicating that Eurofins Abraxis SAES kit is equivalent to standard kit mentioned in EPA Method 546
- 333-061-0560 Reporting:
 - Requires faster reporting of finished water results taken in response to raw water result over the trigger level
 - Requires samples collected outside the May to October monitoring season that otherwise meet the rules to be reported



Overview of cyanotoxin monitoring rules (incl. recent revisions)



Who is required to monitor?

- Sources deemed susceptible by OHA, DEQ
 - 60 sources (59 PWSs) currently meet the rule criteria for conducting routine monitoring ("susceptible source"):
- "Susceptible" means:
 - Source has had harmful algal blooms (HAB) or cyanotoxin detections in the past
 - Intake is downstream from a water body with past HAB or cyanotoxin detections
 - Source water on 303(d) list for limiting factors of algae and aquatic weeds
 - If OHA determines source is susceptible based on characteristics of the source



Table 1. Public Water Systems (PWSs) susceptible to harmful algae blooms (HABs) and subject to OAR 333-061-0510 to 333-061-0580 for OHA-DWS Permanent Cyanotoxin Rules

version: March 8, 2022, subject to change


Notes:

- (1) Includes surface water intake and groundwater under the direct influence of surface water (GWUDI) sources. Systems that purchase water from wholesale providers (*) can be identified in OHA's Data Online for each individual PWS.
- (2) System Type: C = Community; NTNC = Non-Transient Non-Community; NC=Transient Non-Community; OVS= Oregon Very Small system
- (3) Previous HAB Detection or Advisory based on Recreational HABs from OHA, 2011, updated with data from OHA Recreational HAB Website for 2012-2021; Previous cyanotoxin detections based on 2018 or earlier PWS or watershed data.
- (4) DEQ Water Quality Limited (WQL) listing indicates the waterbody is impaired and needs a Total Maximum Daily Load to calculate amount of pollutant a water body can receive and still meet Oregon water quality standards. Based on Category 4 and 5 listings in most recent OR DEQ Integrated Report and 303(d) list (2018/2020 approved by EPA Nov 12, 2020). Note that DEQ's Intergrated Report methodology for Aquatic Weeds and Algae includes 303(d) water quality limited listings for Harmful Algal Blooms, Aquatic Weeds, Chlorophyll-a or Excess Algal Growth.
- (5) GU Groundwater under the direct influence of surface water refers to a groundwater source that is located close enough to nearby surface water (e.g., a river or lake) to receive direct surface water recharge. Since a portion of the groundwater source's recharge is from surface water, the groundwater source is considered at risk of contamination from pathogens and viruses that are not normally found in true groundwaters and the water source is subject to the surface water treatment rule.

				System Type ^[2]	Population Served	"Susceptible" Water Source (OAR 333-061-0510 (2)) risk criteria/factors identified in the Drinking Water Source Area			
PWS ID#	PWS Name (1)	Drinking Water Source	County			Previous Documented HAB or Cyanotoxin Detection ⁽³⁾ OAR 333-061-0510 (2a and 2c)	DEQ Water Quality Limited (WQL) listing for algae and aquatic weeds (4) OAR 333-061-0510 (2b and 2c)		
Susceptibl	le Water Source per	OAR 333-061-0510 (2)							
OR4100012	Albany, City of (*)	Santiam River	Linn	с	54,945	x	x		
OR4101483	Angler's Cove/SCHWC	Rogue River	Jackson	с	80	х	x		
OR4100047	Ashland Water Department	Ashland Creek	Jackson	С	20,700	х			
OR4101174	Buell-Red Prairie Water District	Gooseneck Creek	Polk	С	788	x			
OR4191786	Camp Baker BSA	Infiltration Gallery (Silcoos Lake)	Lane	NC	75	х	x		
OR4100157	Canby Utility	Common header for Molalla River, IG and Springs Gallery	Clackamas	c	16,866	x			
OR4100187	Clackamas River Water - Clackamas (*)	Clackamas River	Clackamas	С	41,338	x	x		



Sampling locations



- **SRC** = Source, from intake prior to any treatment ("raw" water)
- **CH** = Common header; after all sources combine, as it enters the treatment plant (also "raw" water)
- **EP** = Entry point to the distribution, representing treated or finished water
- **Distribution system** = sample at representative distribution locations





Monitoring requirements

- Raw water monitoring every 2 weeks (May to October)
- If recreational HAB advisory upstream, raw water weekly
- If raw water microcystins ≥ 0.20 ug/L or cylindrospermopsin ≥ 0.30 ug/L, raw and finished water weekly
- If toxins detected in the finished water, finished water daily
- If > Health Advisory Levels (HAL) in finished water:
 - Confirmation sample asap
 - If confirmation > HAL = issue a Do-Not-Drink advisory






Cyanotoxin Monitoring Requirements

For Sources Determined to be Susceptible

Oregon Health Authority February 2023







Public Notification & Advisories

- Health Advisory if confirmed > HAL
 - PWS and any purchasers
 - Press release
 - If advisory is delayed with OHA approval (rare), PWS must issue press release stating results but no advisory
- To lift advisory:
 - 2 daily samples at EP < or = HAL and</p>
 - Distribution samples < or = HAL for 2 days</p>
- Must publish EP & DIST detections in annual CCR





Reporting results

- PWS must ensure labs analyze and report results > HAL within 2 business days
- Finished water samples taken in response to raw water detection over the trigger must be reported within 1 business day
- Finished water samples > HAL must be reported to OHA & purchasers within 24 hrs
- Confirmation samples > HAL must be reported to OHA & purchasers within 8 hrs
- Report results to lift an advisory to OHA within one business day
- Report all other results to OHA by 10th of following month





Purchasing water systems

- No routine sampling required
 - Purchasers only monitor if under an advisory (in order to lift the advisory)
- Seller must notify purchasers within 24 hours of initial finished water sample over HAL ("heads up")
- Seller must notify purchasers within 8 hours if confirmation is over HAL (joint advisory issued)





Cyanotoxins sample results

Viewable on OHA Data Online webpage: https://yourwater.oregon.gov/

Data Results:


Sample Location:

Reset Form

Cyanotoxin Sample Results

County

Regulating Agency





Bipartisan Infrastructure Law (BIL) – Emerging Contaminants Funding

- BIL provides grants through the State Revolving Fund for reducing exposure to PFAS or other emerging contaminants in drinking water
- Can be used by water systems with EC detections to provide treatment, develop a new source, or connect to another public water system
- 25% of funds must go to disadvantaged communities
 - Defined as having an MHI below the state median household income
- Covers planning, design, and construction costs
- Set-asides can be used for administration of the funds or additional testing.
- No state match is required
- Oregon's annual allotment for next 5 years: \$9,940,000
- Cyanotoxins-related projects are eligible for funding!!!



www.healthoregon.org/dwcyanotoxins

Cyanotoxin Resources for Drinking Water

Drinking Water Services

Water System Operations

Surface Water Treatment

Capacity Development

Public Notice Templates and Resources

Fact Sheets & Best Management Practices

Water System Surveys & Outstanding Performance

Circuit Rider Program

ePipeline Newsletter


Emerging Contaminants in Drinking Water

Per - and Polyfluoroalkyl Substances (PFAS)

Contact Us

Rules for Cyanotoxin Monitoring in Drinking Water

Oregon Health Authority (OHA) has developed regulations that require drinking water systems using surface water sources susceptible to harmful algae blooms to routinely test for two cyanotoxins that these blooms produce and notify the public about the test results.



O	For Vulnerable People	For Anyone (ug/l or ppb)		
Cyanotoxin	(ug/L or ppb)			
Total Microcystins	0.3	1.6		
Cylindrospermopsin	0.7	3		



OHA is encouraging water systems not subject to the cyanotoxin monitoring rules that serve surface water and have had algae issues in the past to voluntarily test for cyanotoxins and notify the public about the results. If analysis is performed for anatoxin-a or saxitoxins and found in the raw or finished water, please contact OHA-Drinking Water Services for guidance and recommendations.

Rules Resources

- Rules for Cyanotoxin Monitoring for Public Water Systems Revised rules effective February 1, 2023
- List of Susceptible Sources required to monitor for cyanotoxins March 8, 2022, subject to change
- Cyanotoxin Monitoring Flowchart Updated February 2023

testing that were effective July 1, 2018 through December 27, 2018.

- Cvanotoxin Rules Fact Sheet Updated February 2023
- Cyanotoxin Sampling DEQ & OHA Presentation from 4/20/22 (webinar recording from 4/20/22)
- . Cyanotoxin Health Advisory for Vulnerable People Frequently Asked Questions
- Cyanotoxin Health Advisory for All Consumers Frequently Asked Questions
- . Guidance for Health Care Providers and Facilities Frequently Asked Questions







What you can do now

- Understand monitoring requirements, including if detections are found
- Determine potential distribution sampling sites
- Evaluate best treatment optimization steps if needed
- Update contact lists (internal, purchasers, state)
- Know where to get public notice templates and resources





Take away messages

- Public needs to know if they are at risk, even without federal regulation
 - Report as soon as possible
- Testing water only way to know for sure
- Tell people what you know when you know it
- Establish relationships with local stakeholders & agencies to mitigate risk
 - How to reach vulnerable populations
 - Where to obtain water hauling trucks
 - Messaging plans

Consider treatment options if your system is at risk





Summary of 2022 monitoring results


- 2022: 5th year of monitoring since rules adopted
- 39 raw water microcystins detections at 10 PWSs (about average)
- 0 raw water cylindrospermopsin detections
- 24 of 39 total microcystins detections were at 2 PWSs:
 - Josephine County Pks Lake Selmac 1 & 2.
 - Buell-Red Prairie in Polk County had the next highest number of raw water detections at 6.
- 3 PWSs had raw water detections high enough to be triggered into finished water monitoring this year;
 - No finished water detections since the rules were implemented in 2018



Summary of 2022 monitoring results (cont.)

- Mid to late July blip: microcystins detected at 5 PWSs on the South Umpqua River in Douglas County (first time).
 - 1 detection at each PWS during that time period.
- October blip: microcystins detected at 2 PWSs in the mid-Willamette Valley (Cottage Grove and Creswell) with 4 detections total.
- No detections on the North Santiam River (unusual)
- Overall, 2022 was a quieter season than expected.
- Anticipated seeing increased bloom frequency and intensity and increased cyanotoxins detections in 2021 and 2022 due to increased nutrients being flushed into surface water sources after the 2020 wildfires, but we just haven't seen that.









2022 - Drinking Water Monitoring

2022 Source Water Microcystin Detections





2021 vs. 2022





2023 sampling schedule and collection instructions

Week#	Group A	Group B	Notes
1	5/1/2023	250	
2		5/8/2023	
3	5/15/2023		
4		5/22/2023	
5	5/30/2023	**	Memorial Day – sample on Tuesday, 5/30/2023
6		6/5/2023	
7	6/12/2023		
8		6/20/2023	Juneteenth – Sample Tuesday, 6/20/2023
9	6/26/2023		
10		7/5/2023	Independence Day – sample on Wednesday, 7/5/2022
11	7/10/2023	- 100 No.	7,007 V207 V2 V207 V2 V207 V20 V207 V207 V
12		7/17/2023	
13	7/24/2023	65 N	
14	200 100	7/31/2023	
15	8/7/2023		
16	10.000	8/14/2023	
17	8/21/2023	W 55	
18	3,772,800,772,5	8/28/2023	
19	9/5/2023		Labor Day – sample on Tuesday, 9/5/2023
20	W 75 %	9/11/2023	5 04 88 84 25 080 080 Wei
21	9/18/2023		
22		9/25/2023	
23	10/2/2023	W 8	
24	10	10/09/2023	
25	10/16/2023	10.00	
26		10/23/2023	
27	10/30/2023	- F - 1 F 1 S 1 S 1 S 1 S 1 S 2 S 2 S 2 S 2 S 2 S	



Sampling protocol - cyanotoxins

Unpack box and inspect kits. Each box will contain the following:

- 8 coolers in cardboard boxes
- 32 ice packs (4/cooler) freeze these before collecting samples!
- 8 Amber Glass 125mL bottles
- 8 bubble bags (1/glass bottle)
- 8 lab paperwork packets (1/cooler)
- 8 prepaid UPS return labels





Labeling bottles

Check appropriate water type

- "Raw water" = SRC or CH
- "Finished water" = EP
 - You will only collect EP sample if requested by DEQ





OR4101174

Buell-Red Prairie Water Association

Sampling Point: PWS01174:SRC-AA

Date: 5/3/2021 Time: 1105

"Sampling Point" should exactly match ID on COC





Additional samples – by request only

- Weekly raw water (source or common header) samples
- Weekly finished water (entry point) samples





Oregon Facility: Address:	Salem 1410	Public Works - OI 20TH ST SE BLDG	62	Chain of	Custody	Record	L	Affix V	*Office use Only* Vork Order Barcode	: Here	
Facility C	Salem ontact:	OR 97: Dwayne Barnes	302 Facility Pho	ne: (503)	588-6483)		Qtime:	Survey:		
Sample C Sampling							DEO	ontact: Alison	Minerovic		
				3	ampie Inf	ormatic	on				
Item		Sampling Point ID) Water Facilit State Code		or Finished Circle one)		Collec		ion Address distribution)	С	omments
P	WS007	31:SRC-AA	Not Applicable	Source	e Water			North Santi	am River I.G.		
				s	F						
				s	F						
				s	F						
			•			•		•			
	Kelinqu	ished By:	Agency/Company	Date	e/Time		Rece	ived By:	Agency/Comp	any	Date/Time
									1		
			Sam	ple Rece	ipt Check	list *Off	fice Us	se Only*			
Yes	No	Sampled Same	Day?				Т	emperature C	heck (IR/Sampl	e):	с
Yes	No	Cooler Contain	ed Ice?			Yes	No	Sample preserv	ation checked at t	ime of	sample receipt
Yes	No	Samples collec	ted in the appropria	te containe	rs?	Yes	No	If yes were all	samples properly	preserv	ed?
Yes	No	Sample contain	ners clearly and prop	erly labele	d?	Yes	No	COC form prop	erly signed?		
Yes	No	Samples receiv	ed intact and withou	ut damage?	?			Sample F	Receipt Comme	nts	
Yes	No	Sample volume	es sufficient for requ	ested anal	vses?						

All samples received within their holding times?

Yes

No





Packing and shipping to DEQ Lab

- Pack 4 frozen ice packs/cooler
- Double-check bottle labels. Are they both complete, labeled correctly?
- Double-check COC form(s). Are they circled, signed, dated?
- Wrap glass bottles in bubble packs
- Place lab COC(s) in Ziploc bag
- Fill empty space with packing material







Notes about shipping

- Labels are prepaid; each may only be used once (do not photocopy)
- No sample receiving on Saturdays, Sundays, holidays
- Double-check shipping drop-off times
 - Next-day delivery to Hillsboro





Invalid samples

- Too warm (>10° C)
 - Freeze ice packs early
- Too old (>48 hours after collection)
 - Ship ASAP after sampling
- Broken/leaking bottle
 - Check for broken bottles upon receipt
 - Pack in bubble packs carefully
 - Make sure lid is tightened

Invalid samples cannot be analyzed. You will need to resample



Reporting results

- Data management software automatically emails results
- Nathan will call facility contacts if extra sampling required (>trigger)
 - Thursday or Friday
- Nathan will email OHA with results >trigger
 - Thursday or Friday
- All results will be uploaded to OHA data repository weekly
 - Friday afternoon





Lab methods

- Samples must be analyzed by an accredited lab
 - DEQ lab is accredited
 - Please contact Nathan if not using DEQ lab
- Analyze using following methods:

Toxin	Screening method	Confirmation		
Total Microcystins	EPA method 546 (ELISA)	n/a		
Cylindrospermopsin	OR DEQ 18-LAB-0050 (ELISA)	EPA method 545 (LC MS/MS)		





Additional lab analyses

- DEQ Lab can analyze additional samples for a fee
 - Expired IGAs renewed until 2024 (contact Nathan if you are unsure)
 - Cost depends on sample load. OHA samples are priority

Contact Nathan if you are interested in additional sampling





Questions?

OHA

Gregg Baird 503-936-1657 (cell)

New email: gregg.c.baird@oha.oregon.gov



DEQ Lab

DEQ Lab

Nathan Reetz

503-706-9572 (cell) | 503-693-5756 (office)

Nathan.REETZ@deq.oregon.gov



