

# OPERATIONS



Wickiup Water District, Oregon



2013, North Clackamas County Water Commission, OR. SSF Cleaning  
(photo taken by Chris Johnsen, NCCWC)

# CRITICAL VARIABLES THAT CAN IMPACT PERFORMANCE

## Critical Variables

1. Raw water characteristics (temperature, particle characteristics, color, algae, nutrients, organic compounds, oxygen content).
2. Sand size ( $d_{10}$ ) and uniformity (U)
3. Flow control and air binding
4. Head loss allowed
5. Sand bed depth
6. Filtration rate and variability
7. Maturity of the sand bed and biological organisms
8. Filter cleaning (frequency, length of time the filter is out of operation, ripening period)

As previously mentioned, there are a number of variables that can have a big impact on performance. This segment will touch on the operation and maintenance of slow sand filters.

# FILTRATION RATE

## Filtration rate should be continuous

1. Good for dissolved oxygen
2. Good for nutrient supply
3. Good for biological mechanisms
4. Influent flow should not scour sand surface
5. 0.1 gpm/ft<sup>2</sup> maximum filtration rate
6. 0.03 gpm/ft<sup>2</sup> minimum filtration rate
7. Cold temperatures may need lower filtration rates (e.g., 0.05 gpm/ft<sup>2</sup> when water temp < 5°C)
8. Controls should be in place to prevent the tail water (effluent side) from dropping below the sand bed during operation (e.g., an effluent weir) – this helps prevent vacuum conditions and air entrainment.



The filtration rate should be continuous with rate changes needed to accommodate system demands made gradually over a period of several days or weeks. Operating this way keeps a constant supply of nutrients and dissolved oxygen needed for healthy biological activity. Filtration rates should not exceed 0.1 gpm/ft<sup>2</sup> and should not drop below 0.03 gpm/ft<sup>2</sup>.

# FLOW CONTROL –INLET VS OUTLET

Flow control can be practiced at the inlet or outlet. Inlet flow control can be either operated as constant rate or declining rate modes.

## 1. Inlet flow Control – Constant Rate

Uses a throttling valve plus a flowmeter or V-notch weir prior to each filter. The operator uses the flow control valve to set the desired filtration rate. As the resistance of the filter bed increases, the water level rises. When it reaches the overflow pipe the bed should be cleaned.

- Requires less operator involvement
- Ensures a more constant rate of filtration
- Allows operator to see headloss development as headwater rises
- Low headwater at the beginning of filter runs may make filters more vulnerable to freezing in the winter if filters are not covered or insulated


## 2. Inlet Flow Control – Declining Rate

Uses a hydraulic control valve with a flowmeter and valve at the raw water line prior to each filter that regulates flow while maintaining a constant water surface elevation above the filter. Effluent flow decreases as the filter plugs.

- Headwater level is not indicative of headloss development (piezometers or pressure gages are needed)
- Decline in effluent rate or approach to terminal headloss indicates cleaning

## CONSTANT RATE INLET CONTROL

- Starts off with a lower headwater level
- Influent valve is set to the desired rate (e.g., 0.1 gpm/ft<sup>2</sup>)
- Outlet valve is fully open
- The filter will need to be cleaned when the headwater approaches the overflow



In inlet controlled filters, the rate of filtration is set by the filter inlet valve. Once the desired rate is set, no further adjustment of the valve is needed. At first the headwater level will be relatively low, but will gradually rise as the filter plugs. Once the level has reached the scum outlet or overflow, the filter has to be cleaned. Inlet control reduces the amount of work and keeps a constant rate of delivery of water into the filter.

## FLOW CONTROL –INLET VS OUTLET


### 3. Outlet Flow Control (declining rate)

Uses a control valve and flowmeter on the outlet pipe from each filter. As the filter plugs, the filtration rate will decrease, even if the headwater level is increased. The level of water on top of the filter can be controlled by using float switches to turn on and off raw water pumps or control inlet control valves. Excess water can also be diverted out an overflow and directed back to the source.

- Most common
- Fairly simple control method although operator involvement is higher if no automation is used
- Higher rates may be implemented faster for emergency situations, since you don't have to wait for headwater to rise as with constant rate influent control.
- Ability to maintain higher headwater level provides better protection from freezing.
- Higher headwater level provides raw water storage should influent flows be interrupted due to power failure or intake shutdown due to damage or to avoid high turbidity events.
- Headwater level is not indicative of headloss development (piezometers or pressure gages are needed)

## DECLINING RATE OUTLET CONTROL

- Starts off with a higher headwater level
- Influent valve is adjusted to keep filter from overflowing
- Outlet valve is partially closed at first and then is gradually opened as the yield drops due to filter plugging
- The filter will need to be cleaned when the yield cannot keep up with demands



What goes into the filter will go out of the filter (Excess can be overflowed if needed)  
Headloss builds up towards the end of the filter run as it plugs up causing headwater to rise  
Cleaning unplugs filter allowing headwater to drop and yield to recover  
Influent water is balanced with effluent or excess can be overflowed from headwater

In outlet control, the effluent is restricted at the beginning of the filter run to keep flows down to 0.1 gpm/sf or less, while the headwater level is maintained by adjusting the filter inlet. Daily or every couple of days the valve has to be opened a little further to compensate for the increase in headloss, causing a slight variation in the rate of filtration. Inlet and outlet flows have to be adjusted regularly to balance flows into and out of the filter throughout the filter run.

# FLOW MEASUREMENTS

Flow can be measured using weirs (square, v-notch), orifice plates, or flow meters.




Flow calculation for V-notch weir with a 60 degree angle:

$$Q = 1.44 H^{5/2}$$

Where:

$Q = \text{ft}^3/\text{second}$

$H = \text{height of water level above weir crest (ft)}$



Outlet flow measurements can be made whether using weirs, orifice plates, or flow meters.



# FLOW MEASUREMENTS

Flow calculation for rectangular weir:

$$Q = C_w * (2 * g)^{0.5} * b * H^{3/2}$$

Where:


$Q = \text{ft}^3/\text{second}$

$H = \text{height of water level above weir crest (ft)}$

$g = 32.2 \text{ ft/s}^2$  (gravity)

$b = \text{length of weir crest (ft)}$

$C_w = \text{weir coefficient where } C_w = 0.40 + (0.05 * (H/P))$  where  $P = \text{distance in feet from floor of channel to weir crest}$




This is the formula for flow measurements made from a rectangular weir.

# FLOW MEASUREMENTS

## Rectangular weir flow determinations:

Flow calculations for rectangular weir – Yellow cells indicate acceptable range of filtration rates from 0.03 – 0.1 gpm/ft<sup>2</sup> (with unit conversions for H & P in inches and Q in gpm, MGD, or gpm/ft<sup>2</sup>)



$$Q = C_w * (2 * g)^{0.5} * b * H^{3/2} \quad C_w = 0.40 + (0.05 * (H/P))$$

Weir Parameters			Q (gpm)			Q (MGD)			Q (gpm/ft <sup>2</sup> ) w/ 1,000 ft <sup>2</sup> Filter Area		
H (inches)	P (in)	C <sub>w</sub> (ft <sup>3</sup> /s)	b = 1 ft	b = 2 ft	b = 3 ft	b = 1 ft	b = 2 ft	b = 3 ft	b = 1 ft	b = 2 ft	b = 3 ft
0.25	72	0.4002	4.3	8.7	13.0	0.006	0.012	0.019	0.004	0.009	0.013
0.5	72	0.4003	12.3	24.5	36.8	0.018	0.035	0.053	0.012	0.025	0.037
0.75	72	0.4005	22.5	45.1	67.6	0.032	0.065	0.097	0.023	0.045	0.068
1	72	0.4007	34.7	69.4	104.1	0.050	0.100	0.150	0.035	0.069	0.104
1.25	72	0.4009	48.5	97.1	145.6	0.070	0.140	0.210	0.049	0.097	0.146
1.5	72	0.4010	63.8	127.7	191.5	0.092	0.184	0.276	0.064	0.128	0.192
1.75	72	0.4012	80.5	160.9	241.4	0.116	0.232	0.348	0.080	0.161	0.241
2	72	0.4014	98.4	196.7	295.1	0.142	0.283	0.425	0.098	0.197	0.295

This table shows flow measurements made using the formula for a rectangular weir. Some of the unit conversions have been incorporated into the results (e.g., H & P in inches rather than feet and Q in gpm or MGD rather than ft<sup>3</sup>/second).

# CLEANING (SCRAPING/HARROWING)

## Factors that impact filter cleaning:

1. Cleaning method (scraping or harrowing)
2. Cleaning mechanisms (hand shovel or larger equipment)
3. Presence of 2 or more filter beds (the more filters, the smaller the area to be cleaned at any one time)
4. Room to stage equipment, stockpile sand, etc.
5. Other provisions to minimize down time during cleaning
6. Monitoring capability (individual and combined filter effluent turbidity, taps to sample for individual filter effluent coliform bacteria, turbidity, and other parameters, and filter-to-waste effluent taps for monitoring coliform and turbidity during the ripening period)
7. Ability to measure sand bed depth (keyway, staff gage (shown), etc.)



Many factors impact effective cleaning. Cleaning can be accomplished by scraping or harrowing and can be done either by hand or using machines, depending upon the size of the beds. Either way, cleaning efforts should strive to minimize the time a filter is off-line, which is facilitated by the presence of a sufficient number of filters, which not only provides for redundancy, but also reduces the size of the filter area to be cleaned at any one time. Access to the filter beds is dictated by the cleaning method. Storage should also be provided for equipment and stockpiled sand. Ideally, the design should include on-line instrumentation to monitor individual and combined filter effluent turbidity as well as providing taps for sampling of filter-to-waste water for determining when a newly cleaned filter is ready to be put back into service. Provisions should also exist to determine how much sand is remaining in the filter bed, which is typically reduced with each cleaning.

# WHEN TO CLEAN

Cleaning is needed when either terminal head loss is reached (i.e., headwater reaches the overflow level) or when filter effluent is unable to keep up with system demands.

This graph shows head loss increase, while permeability decreases towards the end of each filter run.




Figure B-7 of 37 - SSF-Perm&dP


Cleaning is needed when either terminal head loss is reached or when filter effluent is unable to keep up with system demands. This graph shows head loss increase, while permeability decreases towards the end of each filter run. This graph is from the Bureau of Reclamation's August 2000 report entitled *Alternatives for Using Central Arizona Project Water in the Northwest Tucson Area*.

# PREDICTING WHEN TO CLEAN

Daily measurement of headwater (influent or supernatant water) and tailwater (effluent or permeate water) levels can be used to develop plots of headloss versus time (like the one shown below), which can then be used to predict when the filter will need to be cleaned.

*Note: The clean bed headloss through 4-ft of media is only about 10 inches, depending on effective size and filtration rate, which only amounts to a decrease in filter run of 2-3 days as compared with a 3-ft deep bed (HL ~ 8 inches)*

$$\text{Headloss} = \text{headwater elevation} - \text{tailwater elevation}$$




For the graph shown, if the terminal headloss = 5-ft  
then cleaning is predicted to be needed in 50 days = 5-ft / (0.1ft/day)

Daily measurement of headwater and tailwater levels can be used to develop plots of headloss versus time, which can then be used to predict when the filter will need to be cleaned.

# PREDICTING WHEN TO CLEAN

Headloss development is exponential towards the end of a filter run

Headloss = headwater elevation – tailwater elevation



Headloss development is exponential, increasing rapidly towards the end of a filter run.

# CLEANING METHOD

Cleaning can be accomplished by either:

1. Scraping or
2. Harrowing



2009. Wickiup Water District in Clatsop County, OR

When the filter becomes clogged and effluent flows can no longer meet system demands, the filters must be cleaned. One method is to scrape the schmutzdecke and clogged portion of the sand off. The other method is wet harrowing. This photo shows a filter for the Wickiup Water District located in Clatsop County, Oregon drained and ready to be scraped.

# SCRAPING PROCESS

## Scraping Process (also called dry skimming)




- 1) Water is lowered to approximately 2-12" below the sand level (to be able to safely walk and maneuver machinery around);
- 2) Schmutzdecke and plugged sand (1-2 cm) is scraped with either flat shovels or specially designed machinery;
- 3) The debris is then conveyed out of the filter bed using a wheel borrow or dump truck;
- 4) The beds are leveled;
- 5) Slowly re-filled from the bottom with filtered unchlorinated water to about 12" above the sand (this prevents sand scour that may occur from top filling)
- 6) Slowly filled from the top the remaining amount; and
- 7) Filtered to waste until fully ripened.

When the filters are cleaned by scraping (or dry skimming) Water is lowered to approximately 2 feet below the sand level and scraped with either flat shovels or specially designed machinery. The debris is then conveyed to a wheel borrow or dump truck. The beds are leveled, re-filled, and filtered to waste until fully ripened.



# SCRAPING PHASE 1


Shut off raw water inlet  
and let filter drain down  
(overnight for larger filters)  
Or use supernatant drain  
for smaller filters



The first phase in scraping a filter is to shut off raw water inlet and let filter drain down (overnight for larger filters) or use the supernatant drain for smaller filters.

## SCRAPING PHASE 2


- Shut off the effluent valve to the clear well;
- Open the supernatant drain to drain off any remaining water; and
- Drop the weir to lower the water level 2-24" below the sand.



The next step is to shut off the effluent valve to the clear well, open the supernatant drain to drain off any remaining water and drop the weir to lower the water level 2-24" below the sand.

## SCRAPING PHASE 3

- Scrape the schmutzdecke and roughly  $\frac{1}{4}$  -  $\frac{1}{2}$  inch (0.635 – 1.27 cm) of sand from the filter.
- Close the supernatant drain, raise the weir and then begin re-filling from the bottom with filtered water at a rate below that which would fluidize the sand (around 0.3-0.6 ft/hr (0.1 – 0.18 m/hr or 0.0374 – 0.0748 gpm/ft<sup>2</sup>)) This purges air from the sand bed.
- Continue filling until the supernatant water is 12 inches above the sand bed – this prevents scouring when raw water is introduced from the top.




Then the following steps are carried out:

- Scrape the Schmutzdecke and roughly  $\frac{1}{4}$  -  $\frac{1}{2}$  inch (0.635 – 1.27 cm) of sand from the filter.
- Close the supernatant drain, raise the weir and then begin re-filling from the bottom with filtered water at a rate below that which would fluidize the sand (around 0.3-0.6 ft/hr (0.1 – 0.18 m/hr or 0.0374 – 0.0748 gpm/ft<sup>2</sup>)) This purges air from the sand bed.
- Continue filling until the supernatant water is 12 inches above the sand bed – this prevents scouring when raw water is introduced from the top.

# SCRAPING PHASE 4

- Stop filling from the bottom and introduce raw water from the top to fill to a supernatant depth of 4-5 feet.
- Begin filtering to waste at around 0.1 gpm/ft<sup>2</sup> for 24-48 hrs for ripening until turbidity is  $\leq 1$  NTU and coliform counts are  $\leq 10$  CFU/100 ml.



Once filling from the bottom is stopped, raw water is introduced from the top to fill to a supernatant depth of 4-5 feet. The filtered is then filtered to waste at around 0.1 gpm/ft<sup>2</sup> for 24-48 hrs for ripening until turbidity is  $\leq 1$  NTU and coliform counts are  $\leq 10$  CFU/100 ml.

# SCRAPING

## Scraping

Schmutzdecke on the left and sand on the right



2013. North Clackamas County Water Commission, OR. SSF Cleaning (photo taken by Chris Johnsen, NCCWC)

This photo shows the difference when the schmutzdecke has been scraped off of a filter cell at the North Clackamas County Water Commission plant (photo credit Chris Johnsen).

# SCRAPING METHOD

## Scraping Method

1. hand shovel
2. larger equipment



Photo courtesy of Stephen Baker, WA DOH



2013. North Clackamas County Water Commission, OR. SSF Cleaning (photo taken by Chris Johnsen, NCCWC)

Scraping, can be accomplished either by hand or using machines, depending upon the size of the beds. Either way, cleaning efforts should strive to minimize the time a filter is off-line. Design should account for this and allow for ways to identify when too much sand has been removed through progressive cleanings. Storage should also be provided for equipment and stockpiled sand. Design should consider access to the filter beds, as dictated by the cleaning method of choice. Ideally, the design should include on-line instrumentation to monitor individual and combined filter effluent turbidity as well as providing for sampling of filter-to-waste water for determining when a newly cleaned filter is ready to be put back into service.

# SCRAPING BY HAND

## Hand Scraping Tools

1. Asphalt lute (top)
2. Snow shovel (lower right)
3. Flat blade, square point transfer shovels (lower left)
4. Wheelbarrow or 5-gal buckets (for removal from filter bed)




Flat, square bladed shovels, snow shovels or asphalt rakes have all been used to scrape filters. This photograph shows a fairly large filter being scraped by hand using a flat bladed shovel. Photo provided by Stephen Tanner, ret. Idaho DEQ.

## SCRAPING BY HAND

Hand scraping at Empire, Colorado, filter:

1. Scrape schmutzdecke and top 0.5 cm of sand bed into windrows using asphalt lute
2. Shovel scraped material from windrows into 5-gallon buckets [or could use wheelbarrow] for removal
3. Cleaning Rate = 205 ft<sup>2</sup> / person / hr



Note:

- Avoid treading directly on schmutzdecke
- Use plywood and planks to keep from treading on or running wheelbarrows on sand bed

Hand scraping was performed at the Empire, Colorado filter plant, in which the schmutzdecke and the top 0.5 cm of sand was scraped into windrows using asphalt lutes. The scraped material was then shoveled into 5-gallon buckets for removal. The cleaning rate for this operation was estimated to be 205 ft<sup>2</sup> of filter area per person per hour. Avoid treading directly on the schmutzdecke by using plywood and plants to tread and/or operate wheelbarrows on.



# SCRAPING BY HAND

Hand scraping filter:




# SCRAPING BY HAND

## Scraping

### 1. hand shovel



Photos courtesy of Stephen Baker, WA DOH



Manual cleaning operations eliminate the risk of spilled oils or hydraulic fluid from tractors or other motorized or hydraulic equipment, not to mention the capital and O&M costs of such equipment. This photo shows sand being scraped off of a slow sand filter using shovels and loaded into a water powered eductor (shown below) where it is then “sucked” into the sand washer (shown at right). These photos were taken by Stephen Baker at the Washington Department of Health.

# SCRAPING BY HAND





FIG. 32. HYDRAULIC SAND EJECTOR



From: Fair, G.M. & Geyer, J.C. (1954) *Water supply and waste-water disposal*, New York, John Wiley.

The “eductor” is described as a “hydraulic sand ejector” in the World Health Organization’s “Slow Sand Filtration” Manual from 1974.

# WASHING SAND

## Washing Sand

hand shovel => eductor =>

Washer =>

Sand filter or stockpile




Photos courtesy of Stephen Baker, WA DOH

From the eductor, sand and water are transported to the sand media washer. This photo was also taken by Stephen Baker at the Washington Department of Health.

# SAND WASHING PROCESS

This diagram illustrates the sand washing and grading process



This diagram illustrates the basic sand washing, screening, and stockpiling of used sand.

# SCRAPING MACHINES

## Scraping

1. larger equipment




2013. North Clackamas County Water Commission, OR. SSF Cleaning (photo taken by Chris Johnsen, NCCWC)

This photo shows cleaning a slow sand filter cell at the North Clackamas County Water Commission using a DeJong Products, Inc. “sand cleaner”, now marketed as a “Filter Bed Refurbisher” (photo credit Chris Johnsen, DeJong Products is located in Sheridan, OR. <http://www.dejongproducts.com/>).

# SCRAPING MACHINES

Scraping  
scraping blade

The blade height  
can be set for  
precise filter  
media skimming  
thickness  
tolerances



2013. North Clackamas County Water Commission, OR. SSF Cleaning (photo taken by Alan Schacht, NCCWC)

Scraping machines can allow for the blade height to be set for precise filter media skimming thickness tolerances. This photo shows the scraping blade for the DeJong sand cleaner or “filter bed refurbisher” at the North Clackamas County Water Commission (photo credit Alan Schacht, NCCWC).

# SCRAPING MACHINES

## Scraping

### 1. larger equipment



2013, North Clackamas County  
Water Commission, OR. SSF  
Cleaning (photo taken by Chris  
Johnsen, NCCWC)



Note the tires used on cleaning machines are designed to distribute the weight minimizing compaction and ruts.



# SCRAPING MACHINES

## USG Puma 2400 "Sand Skimmer"

skimming thickness tolerances between 0-100 mm (0 – 4 inches) at a rate of up to 16,000 ft<sup>2</sup>/hr (4,240 ft<sup>3</sup>/hr)



2011, City of Salem, OR SSF Cleaning Machine  
USG Puma 2400 "Sand Skimmer"



Larger equipment may be used to clean filter beds, like this USG Puma 2400 "Sand Skimmer" designed in the United Kingdom and used by the City of Salem (USG Umwelservice GmbH & Co KG, <http://www.puma2400.de/en/component/content/frontpage>). An adjustable blade allows for precise skimming at a fairly fast rate (16,000 ft<sup>2</sup>/hr to remove 4" sand depth. Typically only ~1/4 – 1/2 an inch of sand is removed at any one cleaning)



Scraping  
USG Puma 2400



[www.youtube.com/embed/g25gQNQRbDY](http://www.youtube.com/embed/g25gQNQRbDY)

USG Puma 3000

[www.youtube.com/embed/AtX65tbf1q8](http://www.youtube.com/embed/AtX65tbf1q8)



Scraping  
USG Puma 2400



[www.youtube.com/embed/g259QNQRbDY](http://www.youtube.com/embed/g259QNQRbDY)

USG Puma 3000

[www.youtube.com/embed/AtX65tbf1q8](http://www.youtube.com/embed/AtX65tbf1q8)



Scraping  
USG Puma 2400



[www.youtube.com/embed/g259QNQRbDY](http://www.youtube.com/embed/g259QNQRbDY)

USG Puma 3000

[www.youtube.com/embed/AtX65tbf1q8](http://www.youtube.com/embed/AtX65tbf1q8)



Scraping  
USG Puma 2400



[www.youtube.com/embed/g259QNQRbDY](http://www.youtube.com/embed/g259QNQRbDY)

USG Puma 3000

[www.youtube.com/embed/AtX65tbf1q8](http://www.youtube.com/embed/AtX65tbf1q8)



Scraping  
USG Puma 2400



[www.youtube.com/embed/g259QNQRbDY](http://www.youtube.com/embed/g259QNQRbDY)

USG Puma 3000

[www.youtube.com/embed/AtX65tbf1q8](http://www.youtube.com/embed/AtX65tbf1q8)

Scraping  
USG Puma 2400




[www.youtube.com/embed/g259QNQRbDY](http://www.youtube.com/embed/g259QNQRbDY)

USG Puma 3000

[www.youtube.com/embed/AtX65tbf1q8](http://www.youtube.com/embed/AtX65tbf1q8)

# HARROWING PROCESS



## Harrowing Process (also called wet harrowing)

1. Water is lowered to approximately 6" above the sand level;
2. Water is introduced to provide a cross flow at a rate of about 20 gpm/ft<sup>2</sup> of cross-sectional area (e.g., 1,000 gpm for 6" water depth in a 100-ft long filter);
3. Filtered, unchlorinated water is introduced from the bottom to provide a "backflow", which keeps debris from sinking into the filter bed;
4. Stiff tined rake or harrow equipment is run over the top of the sand;
5. The debris (not sand) is then conveyed out of the filter bed from a harrow drain located just above the sand bed;
6. The beds are leveled;
7. Slowly re-filled from the bottom to about 12" above the sand (this prevents sand scour that may occur from top filling)
8. Slowly filled from the top the remaining amount; and
9. Filtered to waste until fully ripened, which is typically shorter than scraping.

Wet harrowing is a common method of cleaning small filters. This is often accomplished with just a stiff-tined garden rake. With the water level lowered to about 6" above the sand, the top 2-3 inches of sand is agitated. The material suspended by the raking action is then decanted from the top of the filter through a harrowing valve and waste piping. A slow backflush using filtered (but unchlorinated water) helps keep the suspended material from being driven down into the filter.



# HARROWING EQUIPMENT

## Harrowing Equipment

Wet harrowing can be done with a chain harrow, comb-toothed harrow, or a stiff tined rake.



Wet harrowing can be done with a chain harrow or a comb-toothed harrow.

## HARROWING SMALL FILTERS

Wet harrowing is a common method of cleaning small filters.

Basic process:

1. Lower water level to ~6" above the top of the sand.
2. Use a rake or rake-like Mechanism
3. agitate top 2" -3" of sand while slowly backflushing with filtered, but unchlorinated water



Wet harrowing is a common method of cleaning small filters.

# HARROWING SMALL FILTERS

Harrowing small  
3-gpm filters using a  
stiff-tined  
garden rake.




2012. Jewell School District #8 in Clatsop County Oregon.

This shows harrowing in process of a small, 3-gpm filter. [This photo is Jewell School District #8 in Clatsop, Oregon.]

# HARROWING PIPING

Blue Future Filters rely on a wet harrowing process



This diagram shows the harrowing valve and underdrain piping in a modular filter design marketed as Blue Future filters.

# HARROWING VALVE

Harrowing




Harrowing Valve  
and Waste Line

2012. Camp Yamhill in Yamhill County Oregon.

This shows the location of a harrowing valve and waste line, situated just above the sand bed, which allows the backflushed debris to be wasted. This photo is from Camp Yamhill in Yamhill County, Oregon.

# HARROWING VALVE WASTE LINE



This shows the location of the inlet float control valve as well as the harrowing waste line on the inside of the filter. [This photo is also from Camp Yamhill in Yamhill County, Oregon.]

# HARROWING

**Harrowing**  
As seen before,  
the  
schmutzdecke  
is different in  
covered filters



2012. Camp Yamhill in Yamhill County Oregon.

As seen before, the schmutzdecke is more of a brownish layer in a covered filter rather than a filamentous mat as oftentimes observed in uncovered filters exposed to sunlight. [This photo is also from Camp Yamhill in Yamhill County, Oregon.]

# ENSURE ADEQUATE ACCESS

## Access to Filters

Make sure ample room exists to enable cleaning. Protection from the elements not only facilitates cleaning operations, but also prevents freezing and longer ripening times.



2009. Jewell School District #8, OR. "Blue Future" covered filter (left) and raw water control tank (right)

This photo shows a covered "Blue Future" filter installed at the Jewell School District #8 in 2009. The green tank on the left is the filter, the taller green tank on the right is the raw water control tank, and the small grey tank in the middle is the effluent control tank. These filters are also designed to be harrowed rather than scraped and were later fully enclosed inside a building.



# SCRAPED VS HARROWING

Parameter	Scraped	Harrowed (wet harrowed)
Biomass Development	Biomass and schmutzdecke take longer to develop due to the removal of biomass	Biomass and schmutzdecke restore at a faster rate, however, the sudden release of nutrients can cause dissolved oxygen to dip as microbial grazing intensifies. Keeping influent water flowing and filtering to waste at a higher initial rate can help to replenish depleted oxygen levels.
Removal Efficiency	Equivalent once filter is properly ripened	Equivalent once a filter is properly ripened – usually takes less time to accomplish this.
Filter life	Impacted by removal of top ~2 cm of plugged sand layer	Little media loss leads to longer filter life. Media is more susceptible to deep bed clogging if not done properly.

There are pros and cons to the use of either scraping or harrowing methods and although harrowing seems to have many benefits such as faster ripening times and less depletion of sand, if not done properly, harrowing can lead to deep bed clogging and depleted oxygen levels. Harrowing also requires a lot more water for flushing, which may make it unfeasible for some larger applications where availability of filtered water and storage of wastewater are limited.

# FILTER RIPENING

1. Turbidity
2. Coliform Counts (CFU/100 ml)



Incubator



IDEXX Quanti-Tray Sealer

Turbidity and coliform counts in terms of colony forming units per 100/ml are used to determine when the filter has sufficiently ripened (or recovered) from a cleaning. This can all be done in-house. This example shows an IDEXX Quanti-Tray sealer (right) and incubator (left).

# FILTER RE-SANDING

## Two methods

1. Trenching or “throw-over” method
2. Full replacement



City of Astoria Re-sanding effort =>

There are two methods commonly used to re-sand filters. One method is called the trenching or “throw-over” method, where some of the old sand is re-used and the other is just a full replacement of the sand, where all the sand is excavated and replaced.

## FILTER RE-SANDING


### Trenching or "throw-over" method:

1. Sand bed is cleaned (scraped or harrowed)
2. Most of the sand is removed and set aside for later reuse from a strip along one wall, forming a trench (underlying gravel is left undisturbed by leaving 4-6 inches (10-15 cm) of sand).
3. Fresh sand (either new or washed) is placed in the trench to a thickness, with the residual sand, equals the depth of the sand in the filter prior to re-sanding.
4. Residual sand from the next strip is "thrown over" on top of the freshly placed sand in the first strip.
5. This process is repeated until the last row. New sand is placed in the last row and the sand excavated from the first row is then placed on top of the new sand in the last row.

The trenching method or "throw-over" method is described here.

# FILTER RE-SANDING

Trenching or "throw-over" method




Note: Burying old sand under new sand can cause taste and odor issues as the biological material dies off and decays.

This is an illustration of how the trenching method is carried out.

# RIPENING OF RE-SANDED CELL

Ripening of newly sanded filters can take 3 or more weeks as evidenced by total coliform counts. Oftentimes it takes more than a month to wash out fines and ripen the filter.




Once re-sanded, the filter should be filtered-to-waste until it is fully ripened. This can take several weeks to months to accomplish. This graph shows a newly sanded filter cell #2 for the City of Astoria, OR. Data to the left of the vertical green line shows filter performance before the filter was taken off-line for re-sanding. Data to the right of the green line shows coliform removal and sand bed ripening during filter-to-waste after re-sanding.


# RIPENING OF RE-SANDED CELL

## HISTORICAL PERFORMANCE

JANUARY 2010 - NOVEMBER 2010



This graph shows historical turbidity performance data for Astoria's re-sanded Cell #1. 1 NTU is shown as the regulatory "goal" or limit. Data to the left of the vertical green line shows filter performance before the filter was taken off-line for re-sanding. Data to the right of the green line shows turbidity removal and sand bed ripening during filter-to-waste after re-sanding.



This graph shows turbidity performance data during the filter-to-waste and ripening for Astoria’s re-sanded cell #1. This is just a close-up view of the data shown on the previous slide to better see the performance improvement during ripening. Again, data to the right of the green line shows turbidity removal and sand bed ripening during filter-to-waste after re-sanding.



## NEED FOR OPTIMIZATION GOALS & PRACTICES

1. Misunderstood removal mechanisms
2. Used in small communities (limited resources/expertise)
3. Turbidity is not a good indicator of filter performance
4. Good operating practices are the key to optimal performance
5. Goals were developed through literature review and comments received from experts in the field.

Based on the reasons cited here, staff from several states in the northwest (ID, OR, AK, WA, and UT) recognized a need to have clear water quality goals and operational guidelines if slow sand filters were to be maintained in operated in an optimal manner. Working with EPA and Process Applications, Inc., a literature review was undertaken to acquire available information. Goals were then developed and provided to experts in the field of slow sand filtration to get input. The goals provided in this training are intended as guidelines as site-specific situations may dictate otherwise.

# KEY PUBLICATIONS - 1974

"Slow Sand Filtration", World Health Organization, 1974 [ISBN 92-4-154037-0](https://doi.org/10.1186/92-4-154037-0)  
[http://www.who.int/water\\_sanitation\\_health/publications/ssf9241540370.pdf](http://www.who.int/water_sanitation_health/publications/ssf9241540370.pdf)

## SLOW SAND FILTRATION

L. HUISMAN

*Professor of Sanitary Engineering, Department of Civil Engineering,  
Technological University, Delft, Netherlands*

W.E. WOOD, F.I.C.E.

*Formerly Chief, Community Water Supply,  
World Health Organization, Geneva*



WORLD HEALTH ORGANIZATION


GENEVA

1974

# KEY PUBLICATIONS - 1987

[Raman, A., Paramasivam, R., Heijnen, H.A. and Visscher, J.T., 1987. Slow sand filtration for community water supply : planning, design, construction, operation and maintenance. \(Technical paper series / IRC; no. 24\). The Hague, The Netherlands: IRC International Water and Sanitation Centre.](#)

<http://www.irc.nl/docsearch/title/108720>



## KEY PUBLICATIONS - 1991


"Manual of Design for Slow Sand Filtration". David Hendricks. American Water Works Association, 1991. ISBN 978-0898675511



# KEY PUBLICATIONS - 2009


"Technical Guidelines for the Construction and Management of Slow Sand Filters". UNICEF, 2009.

<http://www.bsf-south-sudan.org/sites/default/files/SS+Tech+Guide--Slow+Sand+Filters.pdf>





## KEY PUBLICATIONS - 2012


"Water Treatment Plant Design, 5<sup>th</sup> Edition". Stephen J. Randtke, Ph.D., P.E.; Michael B. Horsley, P.E. Co-published by the American Water Works Association; Environmental and Water Resources Institute of American Society of Civil Engineers; McGraw-Hill Professional. 2012. ISBN: 9780071745727



# INPUT FROM EXPERTS



<= Dr. Robin Collins



Gary S. Logsdon, P.E.

# INPUT STATE EXPERT STAFF

## Slow Sand Filtration

Optimization Workshop  
Region 10 AWOP

*Steve Tanner*  
*DEQ CDA Regional Office*  
*March 3, 2010*  
*Portland, Oregon*



Stephen Tanner, Idaho DEQ



Stephen Baker  
Washington  
DOH





# OPERATIONAL GUIDELINES

## Operational Guidelines for Normal Operation

Operate slow sand filters continuously without filter effluent flow rate changes. If filter effluent flow changes are needed, ensure that the flow changes are made gradually to minimize detachment of particles from the sand with no more than a 50% variation in flow in a 24-hr period. Use filter effluent flow controls to accommodate changes in system demands (e.g., set the filtration rate high enough to meet anticipated peak day demands and divert excess water to waste or filter headwater influent during low demand periods). Intermittent operation of slow sand filters should not be used as a means of rate control.

Influent water should be introduced into the headwater at least 1-ft of clearance above the sand bed and filter walls.


Ensure filter effluent rates (Hydraulic Loading Rates, or HLR) of between 0.03 - 0.10 gpm/ft<sup>2</sup> (0.07 – 0.24 m/hr). Filtration rates may need to be lowered should raw water quality deteriorate with lower temperatures. A flow rate of 0.05 gpm/ft<sup>2</sup> may be used with water temperatures less than 5°C.

In order to prevent air binding within the filter, the tail water elevation must always be maintained at or above the level of the sand bed. Filtration rates and effluent weir levels should be routinely checked and adjusted only if needed.

Operational guidelines stress the importance of flow control to ensure continuous operation of between 0.03 – 0.10 gpm/ft<sup>2</sup>, with minimal flow changes (e.g., weekly, as opposed to multiple times a day).

# OPERATIONAL GUIDELINES

**FILTRATION RATE GUIDELINE**  
**0.03 - 0.10 GPM/FT<sup>2</sup>**



This graph shows the filtration rate goals at the far right as compared to filtration rates recommended by various sources.

# WATER QUALITY GOALS

## Optimization Goals for Normal Operating Conditions

IFE & CFE Turbidity  $\leq 1.0$  NTU in 95% of the highest daily readings, measured at least once daily.

IFE & CFE Turbidity  $\leq 5.0$  NTU, measured at least once daily.

IFE Total Coliform  $\leq 10$  MPN/100 ml, measured at least weekly.

Water entering the distribution system is absent of total coliform bacteria (measure weekly when IFE or CFE turbidity  $> 1$  NTU)

IFE = Individual Filter Effluent

CFE = Combined Filter Effluent


NTU = Nephelometric Turbidity Units

TC = Total Coliform, Most Probable Number (MPN) or Colony Forming Units (CFU) per Standard Methods.

Turbidity is not necessarily a good indicator of performance, since fine colloids may pass causing turbidity spikes that do not necessarily indicate deficiencies in pathogen removal, the turbidity “goal” was set no less stringent than the regulatory requirement. Coliform removal, however, is a good indicator of performance, since it better reflects the biological mechanisms at work in slow sand filters. A total coliform goal of less than or equal to 10 colony forming units (or MPN) per 100 ml of water at the effluent of each filter was established. Water entering the distribution system, after disinfection, should also be absent of total coliforms.

# WATER QUALITY GOALS


City of Salem, Oregon  
Slow Sand Data  
Jan 2006 – Dec 2010



This graph from data obtained from the City of Salem illustrates that turbidity can be maintained at very low levels, well within the regulatory limit of 1 NTU.

# WATER QUALITY GOALS

## Logan, Utah Full-Scale Research Slow Sand Plant



This graph is data obtained from a full-scale research slow sand plant in Logan, Utah. The data shows how coliform removal is effective, even with colder temperatures.

# FILTER SCRAPING GUIDELINES



## Operational Guidelines for Cleaning - Scraping

Scraping should be done when:

1. Headwater depth reaches the headwater overflow level;
2. The achievable filter production rate decreases to  $0.03 \text{ gpm/ft}^2$  ( $0.073 \text{ m/hr}$ ); or
3. Daily demands are anticipated to not be met.

When removing a filter from service for cleaning, schedule the event to avoid overloading the remaining filters.

Minimize the time a de-watered filter is off-line.

Do not de-water the filter more than necessary in order to safely clean the filter (e.g. 2-12 inches below the sand surface).

Filter scraping guidelines stress minimizing down-time and the amount of the sand bed that is allowed to be de-watered.

# FILTER SCRAPING GUIDELINES CONTINUED



## Operational Guidelines for Cleaning - Scraping

Remove the schmutzdecke and no more than  $\frac{1}{4}$ " -  $\frac{1}{2}$ " (0.635-1.27 cm) of sand with each cleaning. Depending upon the effective size ( $d_{10}$ ) and applied water quality, more sand may need to be scraped ( $\frac{1}{2}$ " -  $1$ " ) in order to remove the plugged portion of the filter, allowing clean bed headloss to recover. Operators should monitor headloss before and after each scraping in order to determine how much sand is needed to be removed to maximize filter recovery while avoiding excessive sand removal. Monitoring headloss development by plotting daily headloss readings for each filter should be used to schedule filter cleanings during times of low demands and higher applied water temperatures (above  $5^{\circ}\text{C}$ ). Scheduling cleanings during low systems demands will help ensure that demands are able to be met without overloading adjacent filters. Scheduling cleanings during times of warmer water temperature will help minimize the adverse effects of cold temperatures on the filter biota. The minimum permissible sand bed depth should be no less than 20-24 inches.

# FILTER SCRAPING GUIDELINES CONTINUED



## Operational Guidelines for Cleaning - Scraping

Remove the schmutzdecke and no more than  $\frac{3}{4}$  -  $\frac{1}{2}$  inch (0.635 – 1.27 cm) of sand with each cleaning. Keep the sand bed to within a minimum of 20 – 24 inches in depth.

Avoid walking or driving directly on the schmutzdecke during cleaning.

After the filter has been cleaned, slowly refill the filter from the bottom at a rate of 0.3-0.6 ft of bed depth per hour (0.1 – 0.18 m/hr or 0.0374 – 0.0748 gpm/ft<sup>2</sup>) in order to purge entrained air. Refill with non-chlorinated filtered water from one of the other filters until the headwater is 1-ft above the sand to minimize scouring of the sand bed when filling from the top begins. Then fill from the top at a rate that minimizes disturbing the sand bed.

*Note: To convert ft/hr to gpm/ft<sup>2</sup>, multiply (ft/hr) by (1 hr/60 min) and then multiply by (7.48 g/ft<sup>3</sup>). Example: 0.3 ft/hr x (1 hr/60 min) x (7.48 gpm/ft<sup>3</sup>) = 0.0347 gpm/ft<sup>2</sup>.*



# FILTER SCRAPING GUIDELINES CONTINUED




## Operational Guidelines for Cleaning - Scraping

Begin filtering to waste at the same rate as was used prior to cleaning, or at the anticipated rate needed when the filter is brought back on-line. Do not exceed the design flow rate and keep the rate  $\leq 0.1$  gpm/ft<sup>2</sup>.

Filter to waste one hour for each hour that the filter is off-line, but for no less than 24 hours. Filter to waste until the optimization goals following filter cleaning have been met.

# FILTER SCRAPING GUIDELINES

MINIMUM SAND DEPTH GUIDELINE  
20 - 24 INCHES



# FILTER HARROWING GUIDELINES

## Operational Guidelines for Cleaning - Harrowing

Lower water level to the level of the harrowing waste valve (e.g., about 6" (15 cm) above the sand bed). This is done to keep the head pressure low in order to minimize migration of debris down into the filter during the raking process.

Open the harrowing waste valve and begin introducing filtered unchlorinated water from the bottom of the filter at a rate of 0.16 ft/hr (0.02 gpm/ft<sup>2</sup>) and low enough to prevent the sand from being fluidized. This serves to suspend debris, and keeps it from settling back into the filter bed during raking.

Introduce water into the top of the filter at a rate low enough to prevent sand migration, but high enough to flush the debris to waste during raking. For rectangular filters, a typical flow rate of about 20 gpm times the depth of water above the sand during harrowing times the length of the filter that is perpendicular to the incoming flow will work. For example, 1,000 gpm will work with 6 inches of water depth in a 100-ft wide filter provided the flow path is directed across the width of the filter. For other filters, influent flow should be adjusted to maintain a steady water level above the sand during raking. In either case, it is important to maintain a constant water level above the sand throughout the harrowing process by balancing flows into and out of the filter.

Using a stiff tined rake or harrowing equipment, gently agitate the top 2 – 3" (5 – 8 cm) of sand until the headwater begins to clarify, as indicated by the ability to see the sand bed when the raking is stopped.

# FILTER HARROWING GUIDELINES

## Operational Guidelines for Cleaning - Harrowing

After it has been cleaned, slowly refill the filter from the bottom at a rate of 0.3-0.6 ft of rise per hour (0.1 – 0.18 m/hr or 0.0374 – 0.0748 gpm/ft<sup>2</sup>) in order to purge entrained air. Refill with non-chlorinated filtered water from one of the other filters until the headwater is 1-ft above the sand to minimize scouring of the sand bed when filling from the top begins. Then fill from the top at a rate that minimizes disturbing the sand bed.

*Note: To convert ft/hr to gpm/ft<sup>2</sup>, multiply (ft/hr) by (1 hr/60 min) and then multiply by (7.48 g/ft<sup>3</sup>). Example: 0.3 ft/hr x (1 hr/60 min) x (7.48 gpm/ft<sup>3</sup>) = 0.0347 gpm/ft<sup>2</sup>.*

Begin filtering to waste at the same rate as was used prior to cleaning, or at the anticipated rate needed when the filter is brought back on-line. Do not exceed the design flow rate and keep the rate  $\leq 0.1$  gpm/ft<sup>2</sup>.

Filter to waste one hour for each hour that the filter is off-line, but for no less than 24 hours. Filter to waste until the optimization goals following filter cleaning have been met.

# FILTER RIPENING GUIDELINES

## Optimization Goals Following Filter Cleaning (scraping or harrowing)

Filter to waste for each hour that the filter is off-line, but no less than 24 hours, until sampling demonstrates that the goals below have been met

Filter not to be brought on-line until:

IFE TC  $\leq$  5/100 ml (MPN or CFU)

(sample no earlier than 24 hours after the start of filtering to waste)

IFE NTU  $\leq$  1.0 NTU

IFE = Individual Filter Effluent

CFE = Combined Filter Effluent

NTU = Nephelometric Turbidity Units


TC = Total Coliform, Most Probable Number (MPN) or Colony Forming Units (CFU)

This table summarizes the coliform and turbidity levels used to indicate when the filter has had sufficient time to ripen.

# FILTER RIPENING GUIDELINES

“Scraping invariably reduces a filter’s ability to remove E. coli.”  
(Unger & Collins, 2008)

“Total coliform was the most suitable surrogate...borne out by data in which there was the closest correspondence between removals of total coliform and Giardia cysts [and serves as] an index that the filter is biologically mature”. (Hendricks, 1984)



Data has shown that scraping does have an impact on coliform removal, which has also been correlated to the removal of Giardia cysts.

# RECOMMENDED MEDIA SPECS FOR RE-SANDING

Silica Filter Sand Specification	Recommended Range
Effective Diameter (d10)	0.2 – 0.35 mm
Uniformity Coefficient (U)	1.5 – 3.0
% fines passing #200 sieve	< 0.3% by Wt.
Acid Solubility	< 5%
Apparent Specific Gravity	≥ 2.55
Minimum Depth	20-24 inches
Delivery/Installation	Sand should be washed prior to installation
NSF-61	Certified or equivalent

This table summarizes some of the main specifications for sand and bed depth when re-sanding becomes necessary.

# OPERATION & MAINTENANCE MANUAL

An O&M Manual should include procedures for...

1. Determining filtration rate
2. Changing filtration rate
3. Determining when to clean filters
4. Draining and refilling filters
5. Cleaning (scraping/harrowing)
6. Assuring adequate filter ripening
7. Dealing with seasonal changes  
(e.g., cold winters, high NTU, algae blooms, etc.)
8. Determining sand bed depth and when to re-sand
9. Re-sanding (including media specifications and handling)
10. Maintaining/operating disinfection system



An operation and maintenance manual is critical to producing consistent water quality and maintaining facilities year after year. This documentation becomes especially important during changes of operational staff or staff functions. At a minimum, the manual should include procedures listed here.



## O&M MANUALS



### Other procedures include:

- Instrument calibration methods and frequency
- Data handling/reporting  
(Monitoring for regulatory requirements and process control)
- Chemical dosage determinations
- CT determinations
- Responding to abnormal conditions (emergency response plan)

# MAINTENANCE TASKS

Frequency	Labor (person hours)	Slow Sand Filter Maintenance Task
Daily	1 - 3	<ul style="list-style-type: none"> <li>Check raw water intake</li> <li>Check/adjust filtration rate</li> <li>Check water level in filter</li> <li>Check water level in clear well</li> <li>Sample &amp; check water quality (raw/finished NTU, raw temp)</li> <li>Check pumps</li> <li>Enter observations in logbook</li> </ul>
Weekly	1 - 3	<ul style="list-style-type: none"> <li>Check &amp; grease any pumps &amp; moving parts</li> <li>Check/re-stock fuel</li> <li>Sample &amp; check water quality (coliform)</li> <li>Enter observations in logbook</li> </ul>
1 - 2 months	5 / 1,000 ft <sup>2</sup> 50 / 1,000 ft <sup>2</sup> /12 inches of sand for re-sanding (Letterman & Cullen, 1985)	<ul style="list-style-type: none"> <li>Scrape filter beds</li> <li>Wash scrapings &amp; store retained sand</li> <li>Check &amp; record sand bed depth</li> <li>Enter observations in logbook</li> </ul>

The O&M manual should also include a table of maintenance tasks including daily & weekly activities, as well as general cleaning frequency, which take place about every 1-2 months. This table shows the amount of labor that can be expected to be spent on these various tasks.

# MONITORING

The recommended minimum location points for recording and monitoring include:

## Source water for:

- Turbidity
- Flow
- Temperature
- pH
- Grab sampling of coliform, TOC, or other water quality parameters

## Supernatant for:

- Level (for filter headloss)
- Grab sampling of coliform, TOC, or other water quality parameters



# MONITORING

## Individual filter effluent for:

- Flow rate and quantity
- Turbidity
- Grab sampling of coliform, TOC, or other water quality parameters
- Pressure (for filter headloss)



## Combined filter effluent for:

- Flow rate and quantity
- Turbidity
- Grab sampling of coliform, TOC, or other water quality parameters

## Finished water (post disinfection and storage used for disinfection contact time) for:

- Flow rate and quantity
- pH
- Temperature
- Chlorine residual
- Grab sampling of coliform, TOC, or other water quality parameters



## Finished water storage for:

- Effluent flows
- Level

# COLIFORM COUNTS

1. Membrane Filtration (CFU/100 ml) – SM 9221A,B – exact count
2. Multiple-Tube Fermentation (MPN/100 ml) – SM 9222A,B,C – statistical estimate
3. ONPG-MUG Test or "Autoanalysis Colilert" (MPN/100 ml) – SM 9223 – estimate

## Most Probable Number (MPN/100 ml)

(both examples below use statistical MPN)

### Multiple-tube fermentation (MTF)


(e.g., 10-tube Standard Methods MTF)

- Test tubes (20 x 150 mm)
- Culture media (e.g., R2A agar)
- Scale to measure media
- Autoclave to sterilize media
- Incubator
- Formation of gas first indicates

presumptive positive results,  
which are then confirmed

### IDEXX Quanti-Tray and Quanti-Tray/2000

- Quanti-Tray Sealer & Incubator (35°C)
- IDEXX Quanti-Tray Range: 1-200 CFU/100 ml (95% confidence)
- IDEXX Quanti-Tray/2000 Range: 1 – 2,419 CFU/100 ml (95% confidence)
- Ortho-nitrophenyl-β-galactopyranoside (ONPG) reagent
- 4-methylumbelliferyl-β-D-glucuronide (MUG) - only *E.coli* produce an enzyme that reacts with MUG




# COLIFORM COUNTS

1. Membrane Filtration (CFU/100 ml) – SM 9221A,B – exact count
2. Multiple-Tube Fermentation (MPN/100 ml) – SM 9222A,B,C – statistical estimate
3. ONPG-MUG Test or “Autoanalysis Colilert” (MPN/100 ml) – SM 9223 - estimate

## Membrane Filtration (Colony Forming Units/100 ml)

- A sample of water is filtered through a membrane (0.22-0.45  $\mu\text{m}$  pore size)
- Filter is removed and placed on growth medium (nutrients feed colony growth)
- Number of colonies are counted (each colony arises out of 1 coliform)




Photographs of plates with countable colonies (left), too few colonies to count (middle) and too numerous colonies to count (right). Colonies are the white circular forms and theoretically arise from a single cell called a colony forming unit.

(A Photographic Atlas for the Microbiology Laboratory. Michael J. Leboffe and Burton E. Pierce. 2<sup>nd</sup> Edition. Pp 83-85, Morton Publishing Co, Englewood, CO).

In the membrane filtration technique, water samples are drawn through a membrane filter with a particular pore size. Most filters used in this process have pore sizes of 0.22 or 0.45 microns ( $\mu\text{m}$ ). The pores allow matter smaller than 0.22 or 0.45  $\mu\text{m}$  to pass through the filter, whereas matter/cells that is larger gets caught on top of the filter. Therefore, microorganisms that are usually 1.0  $\mu\text{m}$  and larger are caught on top of the filter. The filter is then removed and placed on top of a growth medium. The nutrients freely diffuse through the membrane and the microbial cells are able to grow on top of the membrane. The photographs show plates with countable colonies (left), too few colonies to count (middle) and too numerous colonies to count (right). Colonies are the white circular forms and theoretically arise from a single cell called a colony forming unit.

## MULTIPLE-TUBE FERMENTATION (SM 9222 A,B,C)

1. Membrane Filtration (CFU/100 ml) – SM 9221A,B – exact count
2. Multiple-Tube Fermentation (MPN/100 ml) – SM 9222A,B,C – statistical estimate
3. ONPG-MUG Test or "Autoanalysis Colilert" (MPN/100 ml) – SM 9223 – estimate



The **most probable number test**, also called the multiple tube fermentation assay, is an alternative to plate counts or membrane techniques, especially for samples with higher turbidity. The MPN procedure is a tube-dilution method using a nutrient-rich medium, which is less sensitive to toxicity and supports the growth of environmental-stressed organisms. The MPN method detects and estimates the bacteria in water samples (and can be applied to foods and soils) by the multiple fermentation tube technique. The number of bacteria per 100 ml of sample is estimated by the use of probability tables. The method has two test stages: The Presumptive Test, and the Confirmed Test. The presumptive tests are designed to grow the target bacteria. The media used in the confirmed tests are designed to validate the growth of target bacteria in the presumptive test. Confirmed test conditions are usually more stringent than presumptive conditions. Thus, the presumptive test provides a preliminary estimate of bacterial density based on enrichment in minimally restrictive tube media. The results of this test are never used without further analysis; the MPN must be carried through the Confirmed Test for valid results. The MPN per 100 ml is calculated from the MPN table based upon the Confirmed Test results.

**ONPG-MUG TEST. EXAMPLE: IDEXX COLILERT QUANTI-TRAY® (SM 9223 B)**

1) Collect 100-ml sample



2) Added Colilert Reagent



3) Turn on Quanti-Tray Sealer



4) Add Sample to Quanti-Tray tray





5) Insert tray into sealer



6) Incubate at 35°C for 24 hrs (or 18-hrs with Colilert-18)



7) Count total coliform positive wells



<http://www.idexx.com/view/xhtml/en-us/water/products/quantitrays.jsf>

8) Count fluorescent e-coli positive wells (use black light)

9) Use MPN table to determine MPN/100-mls

In the ONPG-MUG test, a 100 mL water sample is added to a flask containing the MMO-MUG powder, mixed, and incubated at  $35 \pm 0.5^\circ \text{C}$  for 24 hours (or 18-hrs using Colilert-18). The formation of a yellow color denotes the presence of total coliforms. E-coli is indicated by those yellow cells in the Quanti-tray that fluoresce in the presence of a black light. Coliform react with Ortho-nitrophenyl- $\beta$ -galactopyranoside (ONPG) resulting in the yellow color and and only E.coli produce an enzyme that reacts with 4-methylumbelliferyl- $\beta$ -D-glucuronide (MUG) causing the fluorescence under a black light (long-wave UV light), therefore the ONPG-MUG test can be used to detect both total coliform and E. coli.



# MONITORING HEAD LOSS

## Head loss Measurement

On smaller facilities, routine visual observation of the supernatant depth and recording of the flow rate may be sufficient to monitor filter head loss development.

On larger facilities, screened probes at the top and bottom of the filter sand can allow easy measurement of head loss with simple **piezometers mounted outside the filter**, or through the use of a differential pressure transducer connected to the facility's SCADA system.

Tracking this data will allow the operator to predict and plan filter cleanings.



# QUESTIONS ABOUT OPERATIONS?



Wickiup Water District, Oregon

Photo is of cleaning in progress at the Wickiup Water District, Oregon.