

---

# Essentials of Surface Water Treatment (Part 2 of 2)

Oregon Health Authority  
Drinking Water Services  
[www.healthoregon.org/dws](http://www.healthoregon.org/dws)



# Overview of Course:

## Part 1:

- ✓ Background of Surface Water Treatment Rules
- ✓ Filtration
- ✓ Disinfection
- ✓ Operations

## Part 2:

1. Review of Part 1
2. Reporting Requirements
3. Emerging Issues
4. Resources for Operators

## Part 1 – Review

# Filtration Types:

- Conventional Filtration (CF) & Direct Filtration (DF) – a.k.a. “Rapid Rate”
  - Granular media filtration (Backwashed every 1-2 days)
- Slow sand
  - Sand filtration (scraping/harrowed every 1-6 months)
  - Ripening (24-hr filter-to-waste)
- Membrane
  - Pore size dictates removal (backwash every 30-90 minutes)
  - Chemical cleaning
- Cartridge/bag
  - Discard/replace clogged filters based on pressure differential
- Diatomaceous Earth (DE)
  - Diatoms (remove and replace cake layer)

# Part 1 - Review

## 1989 SWTR

### Surface Water Treatment Rule

- Required filtration for most SW and GWUDI (Groundwater Under Direct Influence).
  - States were required to identify GWUDI sources.
- Required pathogen removal/inactivation:  
*3-log Giardia* (99.9%) & *4-log virus* (99.99%)
- Limited turbidity in filtered water (combined filter effluent):
  - Slow sand/DE/membrane/cartridge/bag:  
*95% of turbidity readings ≤ 1 NTU; all < 5 NTU*
  - CF/DF:  
*95% of turbidity readings ≤ 0.5 NTU; all < 5 NTU (replaced under LT1)*
- Required detectable disinfectant residual.
- *Did not address Cryptosporidium.*

## Part 1 – Review

### 1998 IESWTR

#### Interim Enhanced Surface Water Treatment Rule

- Addressed concerns about *Cryptosporidium*  
required **2-log Crypto** (99%) removal)
- Lowered turbidity standard for CF/DF systems:  
95% of readings  $\leq 0.3$  NTU, all readings  $< 1$  NTU for systems with population  $\geq 10,000$  (**later extended to all CF/DF systems under LT1**)
- Required Individual Filter Effluent (IFE) turbidimeters

## Background (continued)

### 2002 LT1

#### Long-Term 1 Enhanced SW Treatment Rule

- Extended 0.3 NTU requirement to CF/DF systems with <10,000 population.

### 2006 LT2

#### Long-Term 2 Enhanced SW Treatment Rule

- Requires additional Crypto treatment for systems with  $\geq 0.075$  oocysts/L in their source water.
- Very few systems are required to install additional treatment in Oregon.

## Part 1 – Review

# Disinfection Requirements for Surface Water

- Surface Water Treatment Rule (SWTR) requires 3-log reduction of *Giardia* using a combination of **disinfection** and **filtration**
- 2.0 to 2.5-log removal is achieved through **filtration**
- 0.5 to 1.0-log inactivation is achieved through **disinfection**
- Determines which column of EPA tables used to calculate CTs (0.5 or 1.0-log)

## Part 1 – Review

# What are CT's?

- It's a way to determine if disinfection is adequate

**CT** = Chlorine **C**oncentration x Contact **T**ime

- Do not confuse “CT” and “Contact Time”



## Part 1 – Review


# How do we calculate CT's?

- We use the EPA tables to determine the CTs needed to inactivate *Giardia* ( $CT_{\text{required}}$ )
  - We need to know pH, temperature, and free chlorine residual at the first user in order to use the EPA tables.
- Then we compare that with the CTs achieved in our water system ( $CT_{\text{actual}}$ )
- $CT_{\text{actual}}$  must be equal to or greater than  $CT_{\text{required}}$

## Part 1 – Review


# Tracer Studies and Contact Time:

- Used to determine contact time (T) which is used in calculating CT's
- Determines the time that chlorine is in contact with the water from the point of injection to the point where it is measured (sometimes referred to as the “CT segment”)
  - May be at or before the 1<sup>st</sup> user
  - May be more than one CT segment
- Estimates of contact time are not allowed for calculating CT's for surface water!
  - *The degree of short-circuiting is only approximately known until a tracer study is conducted.*



So if we were conducting a tracer study, this is the segment we would be looking at and determining the contact time  $T$  for.

# The shorter the path, the shorter the contact time (T)



**Superior Circulation**  
Baffling Efficiency = 70%



**Perfect Circulation**  
Baffling Efficiency = 100%  
Plug flow through a length of pipe

## Part 1 – Review

# Tracer studies (continued):

- Must redo if peak hour demand flow increases more than 10% of the maximum flow used during the tracer study
- Community water systems with populations <10,000 and non-profit non-community systems can use the circuit rider to perform a tracer study
- Must submit a proposal to DWS for approval prior to conducting the tracer study (even if using the circuit rider).

## Part 1 – Review

# Operations & Maintenance Manual

Keep written procedures on:

- Instrument calibration methods and frequency
- Data handling/reporting
- Chemical dosage determinations
- Filter operation and cleaning
- CT determinations
- Responding to abnormal conditions (emergency response plan)

# REPORTING REQUIREMENTS

## (Part 2)

# Overview

- How to fill out the monthly SWTR operating reports
  - How often to record turbidities
  - Highest turbidity of the day
  - Peak hourly demand flow
  - CT calculations
- Common mistakes
- What to do when things go wrong



# How to fill out the monthly SWTR reports

- There are 4 forms:
  - Conventional/Direct
  - Slow Sand / Membrane / DE / Unfiltered
  - Cartridge
  - UV (if used for *Giardia* credit)
- Must use correct form because each has questions that must be answered that are specific to the filtration type

# How to fill out the monthly SWTR reports

Forms have places to report:

- Turbidity
- Peak Hourly Flow
- CT calculations
- Log inactivation requirement (0.5 or 1.0-log, CF/DF only)

# Turbidity

- Record how often?
  - Conventional and direct: every 4 hours
  - SSF, DE & Alternative: daily
- Report CFE turbidities
- Answer questions about IFEs
- Highest turbidity of the day (can be between the 4 hour readings)

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:  
Conventional or Direct Filtration**

<b>System Name:</b>	<b>ID #:</b>	<b>WTP-:</b>	<b>Month/Year:</b>
---------------------	--------------	--------------	--------------------

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:  
Conventional or Direct Filtration**

<b>System Name:</b>	<b>ID #:</b>	<b>WTP-:</b>	<b>Month/Year:</b>
---------------------	--------------	--------------	--------------------

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back) Yes / No	All Cl <sub>2</sub> residuals at entry point $\geq$ 0.2 mg/l? Yes / No
All the 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No		
All turbidity readings < IFE <sup>2</sup> triggers?	Yes / No <sup>2</sup>		
Notes:		PRINTED NAME:	
		SIGNATURE:	DATE:
		PHONE #: (       )	CERT #:

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum.      <sup>2</sup> IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

# Peak hourly flow

- Report the Peak Hourly Flow
  - greatest volume of water passing through the system during any one hour in a consecutive 24 hr period
- Not the same as Peak Instantaneous Flow
- Report demand flow: flow leaving the clearwell, not plant flow (in most cases)

# Method for determining peak hourly demand flow


- On a daily basis, use the best available operational data to identify the hour within the 24 hr period that had the highest demand flow
- For the hour of highest demand flow:
  - Calculate the average flow rate within the one hour period (i.e., add the flow rates and divide by the number of data points).
  - Use as many data points as possible, preferably no less than four data points taken at 15 minute intervals




# Method for determining peak hourly demand flow (continued)

- For systems that only have a flow totalizer, spot check throughout the day to determine the time of peak demand
- Once that time has been identified (e.g., 8am or 9pm for residential; mid-day for industrial), then record how much water is used during that hour each day and divide by 60 minutes to get a peak hour demand






Here's an example chart, meant to represent continuous readings that shows demand flow through a reservoir used for contact time. The time period shown is from 7am to 9am. What would you say the peak hourly demand flow is?



Again, the peak hourly demand flow is the hour within the 24-hr period of the highest demand flow. The red line represents the span of 1 hour: **7:30 am to 8:30 am – the peak hour**. The avg. of the 4 data points equals **4125 gpm - the peak hourly demand flow**.

Peak instantaneous flow



◆ Demand Flow (gpm)

*Peak hour was from 7:30 am to 8:30 am.*

*Peak hourly flow = 4125 gpm*

The highest flow point, **5000 gpm**, is the **peak instantaneous flow**, not the peak hourly demand flow.

# Exercise #4


- Calculate peak hourly demand flow based on continuous flow rate data

## Questions:


- At what 1-hour interval did PHD occur?
- What is the peak hourly demand flow (gpm)?
- What was the peak instantaneous demand flow (gpm)?

## Bonus questions:

- Is it ok to use the peak instantaneous flow instead for calculating time T?
- If so, what are the advantages/disadvantages?
- Is it ok to use the average daily flow instead for calculating time T?  
Why or why not?



# Peak Hourly Demand Flow (gpm)



## Questions:


- At what 1-hour interval did PHD occur?
- What is the peak hourly demand flow (gpm)?
- What was the peak instantaneous demand flow (gpm)?

## Bonus questions:

- Is it ok to use the peak instantaneous flow instead for calculating time T?
- If so, what are the advantages/disadvantages?
- Is it ok to use the average daily flow instead for calculating time T? Why or why not?

# Demand Flow (gpm)

Peak Instantaneous Demand






## Questions:

At what 1-hour interval did PHD occur? **7:00 am to 8:00 am**

What is the peak hourly demand flow (gpm)? **6375 gpm (sum 4 data pts & divide by 4)**

What was the peak instantaneous demand flow (gpm)? **7500 gpm**



- Example of calculate a running hourly average by averaging the previous 4 data points every 15 minutes.

Time (min)	Demand Flow (gpm)	Running Hourly Average Flow (gpm)
5:00 AM	500	
5:15 AM	900	
5:30 AM	1000	
5:45 AM	1000	850.0
6:00 AM	1525	1,106.3
6:15 AM	1800	1,331.3
6:30 AM	3300	1,906.3
6:45 AM	5000	2,906.3
7:00 AM	5500	3,900.0
7:15 AM	7500	5,325.0
7:30 AM	6000	6,000.0
7:45 AM	5800	6,200.0
8:00 AM	6200	6,375.0 <= Peak Hour Demand

## Exercise #4: Calculating Peak Hourly Demand Flow

### Bonus questions:

Is it ok to use the peak instantaneous flow instead for calculating time T?

**Yes - it's more conservative**

If so, what are the advantages/disadvantages?

**Advantage - easy to determine.**

**Disadvantage - may exceed tracer study flow by more than 10%**

Is it ok to use the average daily flow instead for calculating time T?

**No**

Why or why not?

**Averaging the whole day would not be conservative enough (it would not account for sustained period of high flow which is when it is important for CTs to be met)**

# How to use the EPA CT tables to figure out $CT_{\text{required}}$

- There are six EPA CT tables based on temp
- Find the correct table based on your water temperature in degrees Celsius.
  - $^{\circ}\text{C} = 5/9 \times (^{\circ}\text{F} - 32)$
- If water temp is between values, then round down
  - Example: for water temp of  $12^{\circ}\text{C}$ , use the  $10^{\circ}\text{C}$  table
  - *Even if the water temp is  $14.9^{\circ}\text{C}$ , round down to  $10^{\circ}\text{C}$*
- *Water gets more viscous the colder it gets and chemical reactions take longer, so rounding temp down is more conservative.*

CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT **10° C**

10°C - 14.9°C

Chlorine Concentration mg/L < =	PH < 6						6.1 - 6.5 PH = 6.5						6.6 - 7.0 PH = 7.0					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	12	24	37	49	61	73	15	29	44	59	73	88	17	35	52	69	87	104
0.6	13	25	38	50	63	75	15	30	45	60	75	90	18	36	54	71	89	107
0.8	13	26	39	52	65	78	15	31	46	61	77	92	18	37	55	73	92	110
1	13	26	40	53	66	79	16	31	47	63	78	94	19	37	56	75	93	112
1.2	13	27	40	53	67	80	16	32	48	63	79	95	19	38	57	76	95	114
1.4	14	27	41	55	68	82	16	33	49	65	82	98	19	39	58	77	97	116
1.6	14	28	42	55	69	83	17	33	50	66	83	99	20	40	60	79	99	119
1.8	14	29	43	57	72	86	17	34	51	67	84	101	20	41	61	81	102	122
2	15	29	44	58	73	87	17	35	52	69	87	104	21	41	62	83	103	124
2.2	15	30	45	59	74	89	18	35	53	70	88	105	21	42	64	85	106	127
2.4	15	30	45	60	75	90	18	36	54	71	89	107	22	43	65	86	108	129
2.6	15	31	46	61	77	92	18	37	55	73	92	110	22	44	66	87	109	131
2.8	16	31	47	62	78	93	19	37	56	74	93	111	22	45	67	89	112	134
3	16	32	48	63	79	95	19	38	57	75	94	113	23	46	69	91	114	137

Chlorine Concentration mg/L < =	7.1 - 7.5 PH < 7.5						PH = 8.0						PH = 8.5					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	21	42	63	83	104	125	25	50	75	99	124	149	30	59	89	118	148	177
0.6	21	43	64	85	107	128	26	51	M	102	128	153	31	61	92	122	153	183

# How to use the EPA CT tables (cont.)

- There are 7 sections for pH on each table
- Find the section that corresponds to your water's pH level
- If your pH is between the choices, then round up to the higher pH
  - Example: if pH of water is 6.8, use the pH 7.0 section

# CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 10° C

10°C - 14.9°C

Chlorine Concentration mg/L < =	PH < 6						6.1 - 6.5 PH = 6.5						6.6 - 7.0 PH = 7.0					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	12	24	37	49	61	73	15	29	44	59	73	88	17	35	52	69	87	104
0.6	13	25	38	50	63	75	15	30	45	60	75	90	18	36	54	71	89	107
0.8	13	26	39	52	65	78	15	31	46	61	77	92	18	37	55	73	92	110
1	13	26	40	53	66	79	16	31	47	63	78	94	19	37	56	75	93	112
1.2	13	27	40	53	67	80	16	32	48	63	79	95	19	38	57	76	95	114
1.4	14	27	41	55	68	82	16	33	49	65	82	98	19	39	58	77	97	116
1.6	14	28	42	55	69	83	17	33	50	66	83	99	20	40	60	79	99	119
1.8	14	29	43	57	72	86	17	34	51	67	84	101	20	41	61	81	102	122
2	15	29	44	58	73	87	17	35	52	69	87	104	21	41	62	83	103	124
2.2	15	30	45	59	74	89	18	35	53	70	88	105	21	42	64	85	106	127
2.4	15	30	45	60	75	90	18	36	54	71	89	107	22	43	65	86	108	129
2.6	15	31	46	61	77	92	18	37	55	73	92	110	22	44	66	87	109	131
2.8	16	31	47	62	78	93	19	37	56	74	93	111	22	45	67	89	112	134
3	16	32	48	63	79	95	19	38	57	75	94	113	23	46	69	91	114	137

Chlorine Concentration mg/L < =	7.1 - 7.5 PH < 7.5						PH = 8.0						PH = 8.5					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	21	42	63	83	104	125	25	50	75	99	124	149	30	59	89	118	148	177
0.6	21	43	64	85	107	128	26	51	M	102	128	153	31	61	92	122	153	183

# How to use the EPA CT tables (cont.)

- Use the 0.5 log inactivation column if your plant is rated at 2.5 log removal for *Giardia*
- All others use the 1.0 log inactivation column
- Note: unfiltered surface water must achieve the 3-log inactivation through disinfection



# CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 10° C

10°C - 14.9°C

Chlorine Concentration mg/L < =	PH < 6						6.1 - 6.5 PH = 6.5						6.6 - 7.0 PH = 7.0					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	12	24	37	49	61	73	15	29	44	59	73	88	17	35	52	69	87	104
0.6	13	25	38	50	63	75	15	30	45	60	75	90	18	36	54	71	89	107
0.8	13	26	39	52	65	78	15	31	46	61	77	92	18	37	55	73	92	110
1	13	26	40	53	66	79	16	31	47	63	78	94	19	37	56	75	93	112
1.2	13	27	40	53	67	80	16	32	48	63	79	95	19	38	57	76	95	114
1.4	14	27	41	55	68	82	16	33	49	65	82	98	19	39	58	77	97	116
1.6	14	28	42	55	69	83	17	33	50	66	83	99	20	40	60	79	99	119
1.8	14	29	43	57	72	86	17	34	51	67	84	101	20	41	61	81	102	122
2	15	29	44	58	73	87	17	35	52	69	87	104	21	41	62	83	103	124
2.2	15	30	45	59	74	89	18	35	53	70	88	105	21	42	64	85	106	127
2.4	15	30	45	60	75	90	18	36	54	71	89	107	22	43	65	86	108	129
2.6	15	31	46	61	77	92	18	37	55	73	92	110	22	44	66	87	109	131
2.8	16	31	47	62	78	93	19	37	56	74	93	111	22	45	67	89	112	134
3	16	32	48	63	79	95	19	38	57	75	94	113	23	46	69	91	114	137

Chlorine Concentration mg/L < =	7.1 - 7.5 PH < 7.5						PH = 8.0						PH = 8.5					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	21	42	63	83	104	125	25	50	75	99	124	149	30	59	89	118	148	177
0.6	21	43	64	85	107	128	26	51	M	102	128	153	31	61	92	122	153	183

# How to use the EPA CT tables (cont.)

- Match your free chlorine residual on the far left column
- If in between, then round up
  - Rounding chlorine residual up is more conservative because as chlorine residual increases at a given pH, more CT is required
- The point where it intersects with the log inactivation column is the  $CT_{\text{required}}$ 
  - Example: free chlorine residual is 0.6 ppm

# CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 10° C

10°C - 14.9°C

*6.1 - 6.5*  
PH = 6.5

*6.6 - 7.0*  
PH = 7.0

Chlorine Concentration mg/L < =	PH < 6						PH = 6.5						PH = 7.0					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	12	24	37	49	61	73	15	29	44	59	73	88	17	35	52	69	87	104
0.6	13	25	38	50	63	75	15	30	45	60	75	90	18	36	54	71	89	107
0.8	13	26	39	52	65	78	15	31	46	61	77	92	18	37	55	73	92	110
1	13	26	40	53	66	79	16	31	47	63	78	94	19	37	56	75	93	112
1.2	13	27	40	53	67	80	16	32	48	63	79	95	19	38	57	76	95	114
1.4	14	27	41	55	68	82	16	33	49	65	82	98	19	39	58	77	97	116
1.6	14	28	42	55	69	83	17	33	50	66	83	99	20	40	60	79	99	119
1.8	14	29	43	57	72	86	17	34	51	67	84	101	20	41	61	81	102	122
2	15	29	44	58	73	87	17	35	52	69	87	104	21	41	62	83	103	124
2.2	15	30	45	59	74	89	18	35	53	70	88	105	21	42	64	85	106	127
2.4	15	30	45	60	75	90	18	36	54	71	89	107	22	43	65	86	108	129
2.6	15	31	46	61	77	92	18	37	55	73	92	110	22	44	66	87	109	131
2.8	16	31	47	62	78	93	19	37	56	74	93	111	22	45	67	89	112	134
3	16	32	48	63	79	95	19	38	57	75	94	113	23	46	69	91	114	137

*7.1 - 7.5*  
PH < 7.5

PH = 8.0

PH = 8.5

Chlorine Concentration mg/L < =	PH < 7.5						PH = 8.0						PH = 8.5					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	21	42	63	83	104	125	25	50	75	99	124	149	30	59	89	118	148	177
0.6	21	43	64	85	107	128	26	51	M	102	128	153	31	61	92	122	153	183

# In review:

- temp of 12°C,
- pH of 6.8,
- free chlorine residual of 0.6
  - $CT_{\text{required}} = 36$
- Remember...
  - $CT_{\text{achieved}}$  must be  $> CT_{\text{required}}$

(CT achieved = chlorine concentration x contact time)

# 15 Minute Break



# 15 Minute Break

- 10 minutes left



# 15 Minute Break

- 5 minutes left



# Exercise #5

- Using EPA CT tables to calculate CTs required



# Exercise #5

- There are six EPA CT tables based on temp


## APPENDIX TABLE 4-1.

### CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 0.5° C

Chlorine Concentration mg/L < =	PH < 6						PH = 6.5						PH = 7.0					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	23	46	69	91	114	137	27	54	82	109	136	163	33	65	98	130	163	195
0.6	24	47	71	94	118	141	28	56	84	112	140	168	33	67	100	133	167	200
0.8	24	48	73	97	121	145	29	57	86	115	143	172	34	68	103	137	171	205
1	25	49	74	99	123	148	29	59	88	117	147	176	35	70	105	140	175	210
1.2	25	51	76	101	127	152	30	60	90	120	150	180	36	72	108	143	179	215
1.4	26	52	78	103	129	155	31	61	92	123	153	184	37	74	111	147	184	221
1.6	26	52	79	105	131	157	32	63	95	126	158	189	38	75	113	151	188	226
1.8	27	54	81	108	135	162	32	64	97	129	161	193	39	77	116	154	193	231
2	28	55	83	110	138	165	33	66	99	131	164	197	39	79	118	157	197	236
2.2	28	56	85	113	141	169	34	67	101	134	168	201	40	81	121	161	202	242
2.4	29	57	86	115	143	172	34	68	103	137	171	205	41	82	124	165	206	247
2.6	29	58	88	117	146	175	35	70	105	139	174	209	42	84	126	168	210	252
2.8	30	59	89	119	148	178	36	71	107	142	178	213	43	86	129	171	214	257
3	30	60	91	121	151	181	36	82	109	145	181	217	44	87	131	174	218	261

## Exercise #5: Using EPA CT tables to calculate CTs required

Example #1: Conventional filter plant (2.5-log)



Example #2: Slow sand filter plant (2-log)




Example #3: Membrane filter plant (2.5-log)



# CT parameters measured at the first user are provided below

## Example #1: Conventional filter plant (2.5-log)

- Temperature: 10° C
- pH: 7.0
- Free chlorine residual: 0.8 ppm
- Contact time T: 100 minutes



## Example #2: Slow sand filter plant (2-log)

- Temperature: 16° C
- pH: 6.6
- Free chlorine residual: 0.5 ppm
- Contact time T: 46 minutes



## Example #3: Membrane filter plant (2.5-log)


- Temperature: 8° C
- pH: 7.3
- Free chlorine residual: 1.3 ppm
- Contact time T: 100 minutes



**Directions:** Use the data provided in the examples to determine the CTs required for giardia inactivation at the treatment plant for that day

[Example #1: Conventional filter plant \(2.5-log\)](#)

- Temperature: 10° C
- pH: 7.0
- Free chlorine residual: 0.8 ppm
- Contact time T: 100 minutes



[Example #2: Slow sand filter plant \(2-log\)](#)

- Temperature: 16° C
- pH: 6.6
- Free chlorine residual: 0.5 ppm
- Contact time T: 46 minutes




[Example #3: Membrane filter plant \(2.5-log\)](#)

- Temperature: 8° C
- pH: 7.3
- Free chlorine residual: 1.3 ppm
- Contact time T: 100 minutes



# Answer 3 questions for each example...

1. What are the CTs required for that day?
2. What was the CT achieved?
3. Were CTs met?



Example #1: Conventional filter plant (2.5-log)



Example #2: Slow sand filter plant (2-log)

Example #3: Membrane filter plant (2.5-log)



# Exercise #5

- Remember to set the bar high for  $CT_{\text{required}}$

CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 10° C *10°C - 14.9°C*

Chlorine Concentration mg/L < =	PH < 6						<i>6.1 - 6.5</i> PH = 6.5						<span style="border: 1px solid red; padding: 2px;">PH = 7.0</span> <i>6.6 - 7.0</i>					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	<span style="border: 1px solid red; padding: 2px;">1.0</span>	1.5	2.0	2.5	3.0
0.4	12	24	37	49	61	73	15	29	44	59	73	88	17	35	52	69	87	104
0.6	13	25	38	50	63	75	15	30	45	60	75	90	18	<span style="border: 1px solid blue; padding: 2px;">36</span>	54	71	89	107
0.8	13	26	39	52	65	78	15	31	46	61	77	92	18	37	55	73	92	110
1	13	26	40	53	66	79	16	31	47	63	78	94	19	37	56	75	93	112
1.2	13	27	40	53	67	80	16	32	48	63	79	95	19	38	57	76	95	114
1.4	14	27	41	55	68	82	16	33	49	65	82	98	19	39	58	77	97	116
1.6	14	28	42	55	69	83	17	33	50	66	83	99	20	40	60	79	99	119
1.8	14	29	43	57	72	86	17	34	51	67	84	101	20	41	61	81	102	122
2	15	29	44	58	73	87	17	35	52	69	87	104	21	41	62	83	103	124
2.2	15	30	45	59	74	89	18	35	53	70	88	105	21	42	64	85	106	127
2.4	15	30	45	60	75	90	18	36	54	71	89	107	22	43	65	86	108	129
2.6	15	31	46	61	77	92	18	37	55	73	92	110	22	44	66	87	109	131
2.8	16	31	47	62	78	93	19	37	56	74	93	111	22	45	67	89	112	134
3	16	32	48	63	79	95	19	38	57	75	94	113	23	46	69	91	114	137

# Exercise #5

Avoid common mistakes for  $CT_{\text{required}}$ ...

- Must round down for temperature
- Must round up for pH
- Must round up for free chlorine residual

# Exercise #5: Use EPA CT tables to calculate CTs required

## Example #1: Conventional filter plant (2.5-log)

- Temperature: 10° C
- pH: 7.0
- Free chlorine residual: 0.8 ppm
- Contact time T: 100 minutes

## Example #2: Slow sand filter plant (2-log)

- Temperature: 16° C
- pH: 6.6
- Free chlorine residual: 0.5 ppm
- Contact time T: 46 minutes

## Example #3: Membrane filter plant (2.5-log)

- Temperature: 8° C
- pH: 7.3
- Free chlorine residual: 1.3 ppm
- Contact time T: 100 minutes



For each example:

1. What are the CTs required for that day?
2. What was the CT achieved?
3. Were CTs met?



# Exercise #5: Use EPA CT tables to calculate CTs required

## Example #1: Conventional filter plant (2.5-log)

- Temperature: 10° C
- pH: 7.0
- Free chlorine residual: 0.8 ppm
- Contact time T: 100 minutes

## Example #2: Slow sand filter plant (2-log)

- Temperature: 16° C
- pH: 6.6
- Free chlorine residual: 0.5 ppm
- Contact time T: 46 minutes

## Example #3: Membrane filter plant (2.5-log)


- Temperature: 8° C
- pH: 7.3
- Free chlorine residual: 1.3 ppm
- Contact time T: 100 minutes



For each example:

1. What are the CTs required for that day?
2. What was the CT achieved?
3. Were CTs met?

# Example #1: Conventional Filter Plant (2.5-log)



**CT Required = 18**

Temp = 10° C

pH = 7.0

Residual = 0.8 ppm

## APPENDIX TABLE 4-3.

CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT **10° C**

Chlorine Concentration mg/L < =	PH < 6						PH = 6.5						PH = 7.0					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	12	24	37	49	61	73	15	29	44	59	73	88	17	35	52	69	87	104
0.6	12	25	38	50	62	75	15	30	45	60	75	90	18	36	54	71	89	107
<b>0.8</b>	<b>13</b>	<b>26</b>	<b>39</b>	<b>52</b>	<b>65</b>	<b>78</b>	15	31	46	61	77	92	<b>18</b>	37	55	73	92	110
1	13	26	40	53	66	79	16	31	47	63	78	94	19	37	56	75	93	112
1.2	13	27	40	53	67	80	16	32	48	63	79	95	19	38	57	76	95	114
1.4	14	27	41	55	68	82	16	33	49	65	82	98	19	39	58	77	97	116
1.6	14	28	42	55	69	83	17	33	50	66	83	99	20	40	60	79	99	119
1.8	14	29	43	57	72	86	17	34	51	67	84	101	20	41	61	81	102	122
2	15	29	44	58	73	87	17	35	52	69	87	104	21	41	62	83	103	124
2.2	15	30	45	59	74	89	18	35	53	70	88	105	21	42	64	85	106	127
2.4	15	30	45	60	75	90	18	36	54	71	89	107	22	43	65	86	108	129
2.6	15	31	46	61	77	92	18	37	55	73	92	110	22	44	66	87	109	131
2.8	16	31	47	62	78	93	19	37	56	74	93	111	22	45	67	89	112	134
3	16	32	48	63	79	95	19	38	57	75	94	113	23	46	69	91	114	137


## Example #1: Conventional Filter Plant (2.5-log)

Temp = 10° C

pH = 7.0

Residual = 0.8 ppm

Contact Time = 100 min



1. What are the CTs required for that day? **18 (EPA Table)**
2. What was the CT achieved? **80 (0.8 ppm x 100 min)**
3. Were CTs met? **Yes (CT achieved > CT required)**

# Example #2: Slow Sand Filter Plant (2.0-log)



**CT Required = 24**

Temp = 16° C

pH = 6.6

Residual = 0.5 ppm

## APPENDIX TABLE 4-4.

CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT **15° C**

Chlorine Concentration mg/L < =	PH < 6						PH = 6.5						PH = 7.0					
	Log Inactivations						Log Inactivations						Log Inactivations					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	8	16	25	33	41	49	10	20	30	39	49	59	12	23	35	47	58	70
0.6	8	17	25	33	42	50	10	20	30	40	50	60	12	24	36	48	60	72
0.8	9	17	26	35	43	52	10	20	31	41	51	61	12	24	37	49	61	73
1	9	18	27	35	44	53	11	21	32	42	53	63	13	25	38	50	63	75
1.2	9	18	27	36	45	54	11	21	32	43	53	64	13	25	38	51	63	76
1.4	9	18	28	37	46	55	11	22	33	43	54	65	13	26	39	52	65	78
1.6	9	19	28	37	47	56	11	22	33	44	55	66	13	26	40	53	66	79
1.8	10	19	29	38	48	57	11	23	34	45	57	68	14	27	41	54	68	81
2	10	19	29	39	49	58	12	23	35	46	58	69	14	28	42	55	69	83
2.2	10	20	30	39	50	59	12	23	35	47	58	70	14	28	43	57	71	85
2.4	10	20	30	40	51	60	12	24	36	48	60	72	14	29	43	57	72	86
2.6	10	20	31	41	51	61	12	24	37	49	61	73	15	29	44	59	73	88
2.8	10	21	31	41	52	62	12	25	37	49	62	74	15	30	45	59	74	89
3	11	21	32	42	53	63	13	25	38	51	63	76	15	30	46	61	76	91

## Example #2: Slow Sand Filter Plant (2.0-log)



Temp = 16° C

pH = 6.6

Residual = 0.5 ppm

Contact Time = 46 min

1. What are the CTs required for that day? **24 (EPA Table)**
2. What was the CT achieved? **23 (0.5 ppm x 46 min)**
3. Were CTs met? **No (CT achieved < CT required)**

# Example #3: Membrane Filter Plant (2.5-log)



**CT Required = 31**

Temp = 8° C

pH = 7.3

Residual = 1.3 ppm

## APPENDIX TABLE 4-2.

### CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 5.0° C

Chlorine Concentration mg/L < =	PH < 7.5						PH = 8.0						PH = 8.5					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	28	55	83	111	138	166	33	66	99	132	165	198	39	79	118	157	197	236
0.6	29	57	86	114	143	171	34	68	102	136	170	204	41	81	122	163	203	244
0.8	29	58	88	117	146	175	35	70	105	140	175	210	42	84	126	168	210	252
1	30	60	90	119	149	179	36	72	108	144	180	216	43	87	130	173	217	260
1.2	31	61	92	122	153	183	37	74	111	147	184	221	45	89	134	178	223	267
1.4	31	62	94	125	156	187	38	76	114	151	189	227	46	91	137	183	228	274
1.6	32	64	96	128	160	192	39	77	116	155	193	232	47	94	141	187	234	281
1.8	33	65	98	131	163	196	40	79	119	159	198	238	48	96	144	191	239	287
2	33	67	100	133	167	200	41	81	122	162	203	243	49	98	147	196	245	294
2.2	34	68	102	136	170	204	41	83	124	165	207	248	50	100	150	200	250	300
2.4	35	70	105	139	174	209	42	84	127	169	211	253	51	102	153	204	255	306
2.6	36	71	107	142	178	213	43	86	129	172	215	258	52	104	156	208	260	312
2.8	36	72	109	145	181	217	44	88	132	175	219	263	53	106	159	212	265	318
3	37	74	111	147	184	221	45	89	134	179	223	268	54	108	162	216	270	324

### Example #3: Membrane Filter Plant (2.5-log)



Temp = 8° C

pH = 7.3

Residual = 1.3 ppm

Contact Time = 100 min

1. What are the CTs required for that day? **31 (EPA Table)**
2. What was the CT achieved? **130 (1.3 ppm x 100 min)**
3. Were CTs met? **Yes (CT achieved > CT required)**

## Exercise #5: Using EPA CT tables to calculate CTs required

**Directions:** Use the data provided in the examples below to determine the CTs required for giardia inactivation at the treatment plant for that day

### Example #1: Conventional filter plant (2.5-log)

CT parameters measured at the 1<sup>st</sup> user as follows:

- Temperature: 10° C
- pH: 7.0
- Free chlorine residual: 0.8 ppm
- Contact time T: 100 minutes

What are the CTs required for that day? **18**

What was the CT achieved? **80**

Were CTs met? **Yes**

### Example #2: Slow sand filter plant (2-log)

CT parameters measured at the 1<sup>st</sup> user as follows:

- Temperature: 16° C
- pH: 6.6
- Free chlorine residual: 0.5 ppm
- Contact time T: 46 minutes

What are the CTs required for that day? **24**

What was the CT achieved? **23**

Were CTs met? **No**

### Example #3: Membrane filter plant (2.5-log)

CT parameters measured at the 1<sup>st</sup> user as follows:

- Temperature: 8° C
- pH: 7.3
- Free chlorine residual: 1.3 ppm
- Contact time T: 100 minutes

What are the CTs required for that day? **31**

What was the CT achieved? **130**

Were CTs met? **Yes**



**Bonus:** Use the data provided below to determine the CTs required for virus inactivation at the treatment plant for that day

CT parameters measured at the 1<sup>st</sup> user as follows:

- Temperature: 10° C
- pH: 7.0



Table A-7. CT Values for Inactivation of Viruses by Free Chlorine<sup>1</sup>

Temperature (C)	pH=> 6-9	Log Inactivation					
		2.0-log		3.0-log		4.0-log	
		6-9	10	6-9	10	6-9	10
0.5	6	45	9	66	12	90	
5	4	30	6	44	8	60	
10	3	22	4	33	6	45	
15	2	15	3	22	4	30	
20	1	11	2	16	3	22	
25	1	7	1	11	2	15	

1. What log inactivation is required for viruses in surface water?
2. What are the CTs required for viruses that day?
3. Assuming a contact time T of 30 minutes, what free chlorine concentration is needed to meet the CT required above?
4. What does this tell you about meeting the CT requirements for viruses compared to meeting the CT requirements for giardia?

**Bonus:** Use the data provided in the examples below to determine the CTs required for virus inactivation at the treatment plant for that day

CT parameters measured at the 1<sup>st</sup> user as follows:  
 •Temperature: 10° C  
 •pH: 7.0

Table A-7. CT Values for Inactivation of Viruses by Free Chlorine<sup>1</sup>

Temperature (C)	pH=> 6-9	Log Inactivation					
		2.0-log		3.0-log		4.0-log	
		6-9	10	6-9	10	6-9	10
0.5	6	45	9	66	12	90	
5	4	30	6	44	8	60	
10	3	22	4	33	6	45	
15	2	15	3	22	4	30	
20	1	11	2	16	3	22	
25	1	7	1	11	2	15	

1. What log inactivation is required for viruses in surface water? **4.0-log**
2. What are the CTs required for viruses that day? **6**
3. Assuming a contact time T of 30 minutes, what free chlorine concentration is needed to meet the CT required above? **0.2 ppm**
4. What does this tell you about meeting the CT requirements for viruses compared to meeting the CT requirements for giardia? **If you meet CT requirements for giardia, then you automatically meet them for viruses (i.e. it takes more CTs to inactivate Giardia than it does for viruses)**

# Filling out the monthly surface water quality report form

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

<b>System Name:</b>	<b>ID #:</b>	<b>WTP-:</b>	<b>Month/Year:</b>	<b>Log Requirement (Circle One): 0.5 / 1.0</b>
---------------------	--------------	--------------	--------------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]
1 /								
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								

So here's our reporting form (available for download on our website...)

Every day you must calculate the CTs required using the tables and record it on this form.

So let's enter our data from the example into the form starting w/ temp...

9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

# Filling out the monthly surface water quality report form

Picking up where we left off when determining required CT, these same parameters will be used to fill out the monthly surface water quality form.

- temp of 12°C,
- pH of 6.8,
- free chlorine residual of 0.6
- $CT_{\text{required}} = 36$

# Filling out the monthly surface water quality report form

Picking up where we left off when determining required CT, these same parameters will be used to fill out the monthly surface water quality form.

- temp of 12°C,
- pH of 6.8,
- free chlorine residual of 0.6
- $CT_{\text{required}} = 36$

Yet to be determined is...

- $CT_{\text{actual}} = \text{contact time} \times \text{chlorine residual}$
- Contact time
- Peak hour demand flow
- Turbidity data

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]
1 /				12				
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

Here's where we enter temp

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]
1 /				12	6.8			
2 /								
3 /								
4 /	Here's where we enter pH							
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]
1 /	0.6			12	6.8			
2 /								
3 /								
4 /	Here's where we enter free chlorine residual							
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								



## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]
1 /	0.6			12	6.8	36		
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

And here's where we enter CT required 36,  
which we found from the EPA tables

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]	
1 /	0.6			12	6.8	36			
2 /									
3 /									
4 /									
5 /									
6 /									
7 /									
8 /									
9 /									
10 /			OK. We now we need to calculate						
11 /			the actual CTs achieved and compare						
12 /			it to the CTs required of 36 to						
13 /			determine if CTs were met for the						
14 /			day.						
15 /									
16 /									
17 /									
18 /									
19 /									

# Filling out the monthly surface water quality report (cont.)

- Remember:
  - $CT \text{ achieved} = \text{Chlorine Concentration} \times \text{Contact Time}$
- We know the free chlorine residual at the first user is 0.6 ppm
- Contact Time (T) obtained from a disinfection *tracer study*
  - Example: tracer study shows our contact time to be 110 minutes

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]
1 /	0.6	110		12	6.8	36		
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

Here's where we enter contact time T from our tracer study

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup> [ppm or mg/L]	Contact Time ( T ) [minutes]	Actual CT <b>C X T</b>	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6	110		12	6.8	36		
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /	_____ So free chlorine residual C of 0.6 ppm times 110 _____							
10 /	_____ minutes of contact time = ? _____							
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]	
1 /	0.6	110	66	12	6.8	36			
2 /									
3 /									
4 /									
5 /									
6 /	CT achieved by the plant is 66. So now we compare this to CT required.								
7 /									
8 /									
9 /									
10 /									
11 /									
12 /									
13 /									
14 /									
15 /									
16 /									
17 /									
18 /									
19 /									

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]	
1 /	0.6	110	66	12	6.8	36			
2 /									
3 /									
4 /									
5 /									
6 /									
7 /	In order for CTs to be met, CT <sub>actual</sub> must be greater than CT <sub>required</sub> , which it is.								
8 /									
9 /									
10 /									
11 /									
12 /									
13 /									
14 /									
15 /									
16 /									
17 /									
18 /									
19 /									

## OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:	ID #:	WTP-:	Month/Year:	Log Requirement (Circle One): 0.5 / 1.0
--------------	-------	-------	-------------	--

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) <sup>3</sup>	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		Use tables	Yes / No	[GPM]	
1 /	0.6	110	66	12	6.8	36	Yes		
2 /									
3 /									
4 /									
5 /	So in the CT MET column we write YES.								
6 /	CTs were met for this day.								
7 /									
8 /									
9 /									
10 /									
11 /									
12 /									
13 /									
14 /									
15 /									
16 /									
17 /									
18 /									
19 /									



# Common mistakes:

- Rounding errors:
  - Must round down for temperature
  - Must round up for pH
  - Must round up for free chlorine residual
- Bad formulas in excel spreadsheets:
  - Make sure you understand your formula
  - Wilkes Equation not allowed, must use Regression Equation

# Common mistakes (continued):

- Not calculating CT's daily
  - Don't wait until the end of the month to do the calculations because if you discover you didn't meet CT's, it's too late!
- If adjusting contact time according to flow rate, use the demand flow, not the plant flow.
- Failure to answer questions at bottom of form correctly (or at all)
- Always answering "Yes" to the questions at the bottom of the form without actually looking at the numbers

# Conventional or Direct: Answer all the yes/no questions

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <b>Yes / No</b> All the 4-hour turbidity readings $\leq$ 1 NTU? <b>Yes / No</b> All turbidity readings $<$ IFE <sup>2</sup> triggers? <b>Yes / No</b> <sup>2</sup>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residuals at entry point $\geq$ 0.2 mg/l? <b>Yes / No</b>
<b>Notes:</b>	<b>PRINTED NAME:</b>	
	<b>SIGNATURE:</b>	<b>DATE:</b>
	<b>PHONE #:</b> (       )	<b>CERT #:</b>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE = Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

# Slow Sand/Membrane/DE/Unfiltered

Answer all the yes/no questions

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 1 NTU? <sup>2</sup> <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? <b>Yes / No</b>	
All daily turbidity readings $\leq$ 5 NTU? <b>Yes / No</b>	<b>PRINTED NAME:</b>		
<b>Notes:</b>	<b>SIGNATURE:</b>		<b>DATE:</b>
	<b>PHONE #:</b> (       )		<b>CERT #:</b>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

# Cartridge/Bag

Answer all the yes/no questions

<b>Cartridge Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l?
All daily turbidity readings $\leq$ 5 NTU?	Yes / No	Yes / No	Yes / No
<b>Notes: PSI = pounds per square inch</b> <b>PSID = pounds per square inch difference (before filter – after filter)</b> <b>PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.</b>		<b>PRINTED NAME:</b>	
		<b>SIGNATURE:</b>	<b>DATE:</b>
		<b>PHONE #: (       )</b>	<b>CERT #:</b>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.


# Everyone needs to fill out the CT section!

<b>Cartridge Filtration</b>	<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings $\leq$ 1 NTU? <b>Yes / No</b> All daily turbidity readings $\leq$ 5 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? <b>Yes / No</b>
<b>Notes:</b> PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.	<b>PRINTED NAME:</b>	
	<b>SIGNATURE:</b>	<b>DATE:</b>
	<b>PHONE #:</b> (       )	<b>CERT #:</b>

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

# Multiple CT segments

- A “CT segment” is the point between which chlorine is injected and free chlorine residual is measured
- Treatment plants can have multiple CT segments (i.e. multiple chlorine injection points)



**Total inactivation =  $\sum$  log inactivation from each disinfection segment**



# Multiple CT segments

- Multiple CT segments can be added together in order to meet CTs
- Do not add contact times “T” together!
  - Why? Chlorine, temp, pH may change throughout the process

# Multiple CT segments (cont.)

- Must calculate log inactivation ratios for each segment and add ratios together
  - Inactivation ratio =  $\frac{C1T1_{\text{actual}}}{CT1_{\text{reqd}}} + \frac{C2T2_{\text{actual}}}{CT2_{\text{reqd}}}$
- Modify reporting form: add column for log inactivation ratios (sum must be >1)
  - Not to be confused with 1-log inactivation
- Contact your regulator for further assistance

# What to do when things go wrong:

## Such as:

- Treatment interruptions
- CTs not met
- Turbidity exceeds regulatory limits

## What to do:

- Call your regulatory contact at the drinking water program

# In Summary:

- In order to verify adequate disinfection is taking place, we need to calculate CT achieved ( $CT_{\text{actual}}$ )
- EPA reviewed many disinfection studies in order to create CT Tables that specify minimum CT requirements needed to achieve specific log reduction levels for *Giardia* ( $CT_{\text{required}}$ )
- $CT_{\text{actual}}$  must be equal to or greater than  $CT_{\text{required}}$

# Things you should do:


- Check how T is calculated at your plant
- Do all treatment plant operators understand it?
- Review spreadsheet equation for CTs (if applicable)
- Write an SOP for CT determination
- Arrange for a tracer study if necessary

# Exercise #6 – Example 1

- Filling out the monthly surface water quality operating report for a 2.5-log conventional filtration plant

## Example #1: Conventional or direct filter plant - Turbidity

- Use the data in the graph to record the 4-hour daily turbidities on the first day of the month of the Conventional/Direct Filtration monthly reporting form.
- What number should be entered in the “Highest Reading of the Day (NTU)” column? \_\_\_\_\_



## Example #1: Conventional or direct filter plant - Turbidity

- Use the data in the graph to record the 4-hour daily turbidities on the first day of the month of the Conventional/Direct Filtration monthly reporting form.
- What number should be entered in the “Highest Reading of the Day (NTU)” column? **0.35 NTU**

OHA - Drinking Water Program – Turbidity Monitoring Report Form County:  
Conventional or Direct Filtration

System Name:		WTP-:		Month/Year:			ID #:
DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	<b>0.05</b>	<b>0.07</b>	<b>0.08</b>	<b>0.07</b>	<b>0.15</b>	<b>0.28</b>	<b>0.35</b>
2							
3							
4							
5							



## Example #1: Conventional or direct filter plant - Turbidity

- Let's say your plant runs 24 hours a day and you have turbidity readings filled in for every 4-hour interval for all 31 days of the month. How many readings could you have that were  $> 0.3$  NTU? (Hint: 95% of readings should be  $\leq 0.3$  NTU) \_\_\_\_\_
- What should you do if you answer “no” to the turbidity question “All readings  $\leq 1$  NTU?” on the bottom of the form? \_\_\_\_\_
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c
- What should you do if you answer “no” to the turbidity question “All readings  $<$  IFE triggers?” on the bottom of the form? \_\_\_\_\_
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c



## Example #1: Conventional or direct filter plant - Turbidity

- Let's say your plant runs 24 hours a day and you have turbidity readings filled in for every 4-hour interval for all 31 days of the month. How many readings could you have that were  $> 0.3$  NTU? (Hint: 95% of readings should be  $\leq 0.3$  NTU) **9**  
**(6 readings/day x 31 days = 186 readings total. 5% x 186 = 9.3)**
- What should you do if you answer “no” to the turbidity question “All readings  $\leq 1$  NTU?” on the bottom of the form? **a**
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c
- What should you do if you answer “no” to the turbidity question “All readings  $< \text{IFE triggers?}$ ” on the bottom of the form? **a**
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c

## Example #1: Conventional or direct filter plant - Disinfection

- Use the following parameters to calculate the CTs achieved at a 2.5-log conventional plant and fill it in on the form on first day of the month:
  - Free chlorine residual: 0.6 ppm
  - Contact time: 100 minutes
  - Peak hourly demand: 2000 gpm
  
- Use the following parameters to calculate the CTs required using the EPA tables from Exercise 5 and fill it in on the form:
  - Temp: 12°C
  - pH: 7.2



## Example #1: Conventional or direct filter plant – Disinfection

- Use the following parameters to calculate the CTs achieved at a 2.5-log conventional plant and fill it in on the form on first day of the month:
  - Free chlorine residual: 0.6 ppm
  - Contact time: 100 minutes
  - Peak hourly demand: 2000 gpm
- Use the following parameters to calculate the CTs required using the EPA tables from Exercise 5 and fill it in on the form:
  - Temp: 12°C
  - pH: 7.2

### OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:		WTP-:		Month/Year:		Log Requirement (Circle One): 0.5 / 1.0			ID #:
<sup>t</sup>	Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) 3	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
	1 /	<b>0.6</b>	<b>100</b>	<b>60</b>	<b>12</b>	<b>7.2</b>	<b>21</b>	<b>Yes</b>	<b>2000</b>
	2 /								
	3 /								
	4 /								
	5 /								

## Example #1: Conventional or direct filter plant - Disinfection

- Let's say the Peak Hourly Demand Flow for the day was 2000 gpm. If the Peak Hourly Demand Flow during the tracer study was 1750 gpm, is this a problem? Why or why not?
- What should you do if you answer “no” to either of the CT questions on the turbidity side of form?
- “CTs met at all times?”
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c
- “Residual at EP  $\geq$  0.2 ppm at all times?”
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c



## Example #1: Conventional or direct filter plant - Disinfection


- Let's say the Peak Hourly Demand Flow for the day was 2000 gpm. If the Peak Hourly Demand Flow during the tracer study was 1750 gpm, is this a problem? Why or why not? **Yes this is a problem – flow cannot exceed 10% of tracer study flow.  $10\% \times 1750 \text{ gpm} = 175 \text{ gpm}$ .  $1750 + 175 = 1925 \text{ gpm}$ . Therefore flow cannot be  $>1925 \text{ gpm}$  or else a new tracer study is needed.**
- What should you do if you answer “no” to either of the CT questions on the turbidity side of form?
- “CTs met at all times?” **a**
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c
- “Residual at EP  $\geq 0.2$  ppm at all times?” **a**
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c

# Exercise #6 – Example 2

- Filling out the monthly surface water quality operating report for a 2.0-log slow sand plant

## Example #2: Slow sand filter plant - Turbidity

- Use the data in the graph to record the daily combined filter effluent turbidity on the first day of the month of the slow sand monthly reporting form. Which column should it be reported in and why?
- What number should be entered in the “Highest Reading of the Day (NTU)” column?





## Example #2: Slow sand filter plant - Turbidity

- Use the data in the graph to record the daily combined filter effluent turbidity on the first day of the month of the slow sand monthly reporting form. Which column should it be reported in and why? **Any of the columns is fine to use. Most people use the column that is closest to the time they observed the turbidity**
- What number should be entered in the “Highest Reading of the Day (NTU)” column? **1.2 NTU**

OHA - Drinking Water Program – Turbidity Monitoring Report Form County:  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name:		WTP-:		Month/Year:			ID #:
DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1			0.2				1.2
2							
3							
4							
5							

## Example #2: Slow sand filter plant - Turbidity

- Let's say your plant runs everyday and you have turbidity readings filled in once a day for all 31 days of the month. How many readings could you have that were  $> 1$  NTU and still meet the requirement of 95% of readings being  $\leq 1$  NTU?
- What should you do if you answer “no” to the turbidity question “All readings  $\leq 5$  NTU?” on the bottom of the form?
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c



## Example #2: Slow sand filter plant - Turbidity

- Let's say your plant runs everyday and you have turbidity readings filled in once a day for all 31 days of the month. How many readings could you have that were  $> 1$  NTU and still meet the requirement of 95% of readings being  $\leq 1$  NTU? **1 out of the 31 readings total.  $5\% \times 31 = 1.6$**
- What should you do if you answer “no” to the turbidity question “All readings  $\leq 5$  NTU?” on the bottom of the form? **a**
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c

## Example #2: Slow sand filter plant - Disinfection

- Use the following parameters to calculate the CTs achieved at a 2.0-log slow sand plant and fill it in on the form on first day of the month:
  - Free chlorine residual: 0.3 ppm
  - Contact time: 60 minutes
- Use the chart to calculate peak hour demand.
- Use the following parameters to calculate the CTs required using the EPA tables from Exercise 5 and fill it in on the form:
  - Temp: 9°C
  - pH: 7.8
- Are CTs met for this day?



## Example #2: Slow sand filter plant - Disinfection

- Use the following parameters to calculate the CTs achieved at a 2.0-log slow sand plant and fill it in on the form on first day of the month:
  - Free chlorine residual: 0.3 ppm
  - Contact time: 60 minutes
  - Peak hourly demand: 3300 gpm**
- Use the following parameters to calculate the CTs required using the EPA tables from Exercise 5 and fill it in on the form:
  - Temp: 9°C
  - pH: 7.8
- Are CTs met for this day - **No - CT achieved (18) is < CT required (66)**

### OHA - Drinking Water Program – Surface Water Quality Data Form - *Giardia* Inactivation

System Name:		WTP-:		Month/Year:		ID #:			
						Log Requirement (Circle One): 0.5 / 1.0			
<sup>t</sup>	Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User ( C ) 3	Contact Time ( T )	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
		[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
	1 /	<b>0.3</b>	<b>60</b>	<b>18</b>	<b>9</b>	<b>7.8</b>	<b>66</b>	<b>No</b>	<b>3300</b>
	2 /								
	3 /								
	4 /								
	5 /								

## Example #2: Slow sand filter plant - Disinfection

- How was peak hour demand calculated using only flow readings taken every hour?
- Tabulate the chart data and calculate a running hourly average using 2 consecutive flow readings for every hour.


What number should be entered in the “Peak Hourly Demand Flow” column?

**3300 gpm.**

### **Average of flows between 7 am and 8 am.**

Exercise #6, Example #2 Slow Sand - Peak Hour Demand Determination

Time	Flow Reading (gpm)	Running hourly average of demand flow readings (gpm)
12:00 AM	500	
1:00 AM	850	675
2:00 AM	800	825
3:00 AM	950	875
4:00 AM	950	950
5:00 AM	1500	1225
6:00 AM	2100	1800
7:00 AM	3400	2750
8:00 AM	3200	3300
9:00 AM	2700	2950



## Example #2: Slow sand filter plant - Disinfection

- What should you do if you answer “no” to either of the CT questions on the turbidity side of form?
- “CTs met at all times?”
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c
- “Residual at EP  $\geq 0.2$  ppm at all times?”
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c



## Example #2: Slow sand filter plant - Disinfection

- “CTs met at all times?” **a**
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c
- “Residual at EP  $\geq$  0.2 ppm at all times?” **a**
  - a) Call the state
  - b) Issue a boil water notice
  - c) Issue a public notice within 30 days
  - d) Both a & c



# Emerging Issues

# Emerging Issues

- Climate change and water supply
- Cyanobacteria (Harmful Algal Blooms)
- [www.healthoregon.org/dws](http://www.healthoregon.org/dws)

## News & “Hot Topics”

The screenshot shows the Oregon Health Authority website with a dark blue header. The header contains the Oregon.gov logo and navigation links: About OHA, Programs and Services, Oregon Health Plan, Health System Reform, and Licenses and Certificates. Below the header is a sub-menu for Public Health. The main content area is divided into three columns: Services, Resources, and News and Hot Topics. The Services column lists items like Cross Connection & Backflow Prevention and Emergency Preparedness & Security. The Resources column lists County & Department of Agriculture Resources and Data Online. The News and Hot Topics column has a 'Link' section with items such as 'NEW - Annual Water System Fee Info' and 'Now Open: 2020 Drinking Water Source Protection Grants'. A button at the bottom of the News and Hot Topics section says 'View archived hot topics and news items'.

# Climate Change and Water Supply

- Earlier and heavier snowpack runoff
- Increasing variability of storm frequency and intensity
- Weather extremes already evident
- Increased variability in water quality; can affect both surface and groundwater systems.
- Changes in rainfall patterns affect all systems
- Rising sea levels could lead to salt water intrusion or flooding

# Cyanobacteria

- Produce toxins that can be harmful
- Occur in warm, slow moving water
- Increasing in frequency and duration
  - happening more or better reporting?
  - more people, more nutrients, warmer water
- Resources for operators on-line at:

[www.healthoregon.org/dwcyanotoxins](http://www.healthoregon.org/dwcyanotoxins)

# www.healthoregon.org/dws

- News
- Hot Topics

**Oregon Health Authority** Drinking Water  
Oregon Drinking Water Services

Public Health Division > Environmental Public Health > Drinking Water

## Oregon Drinking Water Services

### Working to keep drinking water safe for Oregonians

Access to safe drinking water is essential to human health. Oregon Drinking Water Services helps to keep drinking water safe for Oregonians.

Oregon Drinking Water Services (DWS) administers and enforces drinking water quality standards for public water systems in the state of Oregon. DWS focuses resources in the areas of highest public health benefit and promotes voluntary compliance with state and federal drinking water standards. DWS also emphasizes prevention of contamination through source water protection, provides technical assistance to water systems and provides water system operator training.

[Contact Us](#) [Sign up for DWS News](#) [Water Advisories Map](#) [Data Online](#)

#### Services

- Cross Connection & Backflow Prevention
- Emergency Planning and Response
- Groundwater & Source Water Protection
- Monitoring & Reporting

#### Resources

- County & Department of Agriculture Resources
- Data Online
- Domestic Well Safety Program
- Drinking Water Advisory Committee (DWAC)

#### \* News and Hot Topics

**Link**

- [2024 Source Protection Grant LOI](#)
- [Annual Water System Fee Info](#)
- [Bipartisan Infrastructure Law Funding](#)

# RESOURCES FOR OPERATORS

# www.healthoregon.org/dws

- Sign up for DWS Alerts
- Contact Us
- Data Online

Contact Us

Sign up for DWS News

Water Advisories Map

Data Online

## Services

- Cross Connection & Backflow Prevention
- Emergency Planning and Response
- Groundwater & Source Water Protection
- Monitoring & Reporting
- Operator Certification

## Resources

- County & Department of Agriculture Resources
- Data Online
- Domestic Well Safety Program
- Drinking Water Advisory Committee (DWAC)
- For Consumers

## \* News and Hot Topics

### Link

[LCRR Service Line Inventory Requirements](#)

[2023 Source Protection Grant LOI](#)

[Startup tips for seasonal systems](#)

[Current Rulemaking: Proposed Rule Amendments](#)

# Tools & Resources

- For surface water systems:  
[www.healthoregon.org/dws](http://www.healthoregon.org/dws)

Click on “Water System Operations” on left-side menu list, then “Surface Water Treatment”

- Monthly Surface Water Quality Report form template
- Tracer Study form
- Surface Water Treatment Rule guidance manual, Appendix C: Determination of Disinfectant Contact Time



# Tools & Resources (continued)

- US Environmental Protection Agency (USEPA)  
Rules  
<http://water.epa.gov/lawsregs/rulesregs/sdwa/currentregulations.cfm>
- AWWA <http://www.pnws-awwa.org/>  
(American Water Works Association)
- OAWU <http://www.oawu.net/>  
(Oregon Association of Water Utilities)
- Oregon Drinking Water Services Circuit Rider  
Program  
<http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Operations/Pages/circuitrider.aspx>
- ORWARN <http://www.orwarn.org/>  
(Oregon Water/Wastewater Agency Response Network)

# Information Available Online

[www.healthoregon.org/dws](http://www.healthoregon.org/dws)

## Oregon Drinking Water Services

### Working to keep drinking water safe for Oregonians

Access to safe drinking water is essential to human health. Oregon Drinking Water Services helps to keep drinking water safe for Oregonians.

Oregon Drinking Water Services (DWS) administers and enforces drinking water quality standards for public water systems in the state of Oregon. DWS focuses resources in the areas of highest public health benefit and promotes voluntary compliance with state and federal drinking water standards. DWS also emphasizes prevention of contamination through source water protection, provides technical assistance to water systems and provides water system operator training.



[Contact Us](#)

[Sign up for DWS News](#)

[Water Advisories Map](#)

[Data Online](#)

### Services

- [Cross Connection & Backflow Prevention](#)
- [Emergency Planning and Response](#)
- [Groundwater & Source Water Protection](#)
- [Monitoring & Reporting](#)
- [Operator Certification](#)
- [Plan Review](#)
- [Drinking Water Funding](#)
- [Water System Operations](#)
- [Capacity Development](#)

### Resources

- [County & Department of Agriculture Resources](#)
- [Data Online](#)
- [Domestic Well Safety Program](#)
- [Drinking Water Advisory Committee \(DWAC\)](#)
- [For Consumers](#)
- [Online Maps](#)
- [Rules & Implementation Guidance](#)
- [Training Opportunities](#)
- [Site Map](#)
- [Contact Us](#)

### \* News and Hot Topics

#### Link

[LCRR Service Line Inventory Requirements](#)

[2023 Source Protection Grant LOI](#)

[Startup tips for seasonal systems](#)

[Current Rulemaking: Proposed Rule Amendments](#)

[Bipartisan Infrastructure Law Funding](#)

[Compliance Monitoring Data Portal](#)

[Per- and Polyfluoroalkyl Substances \(PFAS\)](#)

[Cyanotoxin Resources for Water Systems](#)

[Wildfire Information for Water Systems](#)

[Annual Water System Fee Info](#)

[DWS Annual Compliance Report](#)

[View archived hot topics and news items](#)

Information  
By  
Subject

“Data Online”  
(data specific  
to each water  
system)

Contact Us


News and Hot  
Topics

# Information By Subject

## Services

---

- Cross Connection & Backflow Prevention
- Emergency Planning and Response
- Groundwater & Source Water Protection
- Monitoring & Reporting
- Operator Certification
- Plan Review
- Drinking Water Funding
- **Water System Operations**
- Capacity Development



## Resources

---

- County & Department of Agriculture Resources
- Data Online
- Domestic Well Safety Program
- Drinking Water Advisory Committee (DWAC)
- For Consumers
- Online Maps
- **Water System Operations**
  - Surface Water Treatment
  - Capacity Development
  - Public Notice Resources.....
- Contact Us

# Water System Operations

## Resources for Oregon Water System Operators

<https://www.oregon.gov/oha/PH/HEALTHYENVIRONMENTS/DRINKINGWATER/OPERATIONS/Pages/index.aspx>

[Drinking Water Services](#)

[Water System Operations](#)

[Surface Water Treatment](#)

[Capacity Development](#)

[Public Notice Templates and Resources](#)

[Fact Sheets & Best Management Practices](#)

[Water System Surveys & Outstanding Performance](#)

[Circuit Rider Program](#)

[ePipeline Newsletter](#)

[Emerging Contaminants in Drinking Water](#)

[Per- and Polyfluoroalkyl Substances \(PFAS\)](#)

[Contact Us](#)

### Surface Water Treatment

Water systems that treat surface water sources have to deal with complex regulatory requirements, constantly changing raw water quality, and costly management of various assets. The [Surface Water Treatment](#) site provides information and tools needed to optimize water treatment processes and maximize public health protection without costly capital improvements.

### Capacity Development

Water system capacity is the technical, managerial and financial capability of a water system to achieve and maintain compliance with drinking water standards and consistently provide safe drinking water. The [Capacity Development](#) site provides information and resources for drinking water systems to help build their capacity.

### Public Notice Resources & Templates

Water systems are required to issue public notices to alert consumers under specific circumstances (for example, when exceeding a Maximum Contaminant Level, failing to complete required tests, failing to report the results, or failing to meet treatment technique requirements). This page includes information on public notification requirements and templates for issuing public notices, as well as translations and FAQs for effective communication with partners and the public.

### Fact Sheets & Best Management Practices

Information, techniques, and best management practices for water system management, including coliform sampling plans, start-up and shut-down tips for seasonal systems, shock chlorination instructions, preparing for water system surveys.

### Water System Surveys & Outstanding Performance

Information for water system operators on how to prepare for water system surveys and treatment plant inspections, as well as information on the outstanding performance designation for community water systems.

### Circuit Rider Program

Circuit Riders provide free on-site technical services for short-term operational problems for community water systems serving populations under 10,000, as well as not-for-profit transient and non-transient non-community water systems.

### Water System Operations

- [Surface Water Treatment](#)
- [Capacity Development](#)
- [Public Notice Resources](#)
- [Fact Sheets & Best Practices](#)
- [Surveys & Outstanding Performance](#)
- [Circuit Rider Program](#)
- [Emerging Contaminants](#)
- [Pipeline Newsletter](#)

### Emerging Contaminants in Drinking Water

Emerging contaminants are naturally occurring or manmade chemicals present in drinking water that are known or suspected to pose risks to human health and are not yet subject to federal regulatory oversight. Some emerging contaminants of concern in Oregon include toxins produced by cyanobacteria (cyanotoxins), Per- and Polyfluoroalkyl Substances (PFAS), and Manganese.

### Pipeline Newsletter

Published quarterly by Oregon Drinking Water Services, the Pipeline newsletter provides information on technology, training, and regulatory and policy issues for public water systems in order to improve the quality of drinking water in Oregon.

# Surface Water Treatment

## Optimization, Training and Other Resources

Drinking Water Services

Water System Operations

Surface Water Treatment

Capacity Development

Public Notice Templates and Resources

Fact Sheets & Best Management Practices

Water System Surveys & Outstanding Performance

Circuit Rider Program

ePipeline Newsletter

Emerging Contaminants in Drinking Water

Per- and Polyfluoroalkyl Substances (PFAS)

Contact Us

### Surface Water Treatment Resources

The information on this page is intended for operators and owners of water systems that treat surface water.

[Sign up for Surface Water Treatment News](#)

<https://www.oregon.gov/oha/PH/HealthyEnvironments/DrinkingWater/Operations/Treatment/Pages/index.aspx>

#### What is Optimization?

- Background & Introduction
- Water Treatment Optimization
- Area Wide Optimization (AWOP)

#### Current Optimization Goals

- Conventional & Direct Filtration

#### Learn More About...

- Coagulation
- Flocculation
- Sedimentation/Clarification
- Filtration
- Disinfection

#### Key Links

- [Drinking Water Data Online](#)
- [DWS Main Page](#)
- [For Consumers](#)

#### What's New?

- [Optimizing Filtration After a Wildfire - February 2021](#)
- [Subscribe to the AWOP News](#)
- [New surface water treatment rule guidance is now under the "EPA Quick Reference Guides" section of Forms and Tools.](#)
- [AWWA - Partnership for Safe Water - latest news & optimization guidance](#)

#### Forms, Tools & Resources

- [Forms & Tools](#)
  - [Technical, Managerial & Financial Resources](#)
  - [Algae Resources](#)
  - [Employment Opportunities and Equipment](#)

#### Training Classes

- [Essentials of Surface Water Treatment](#)
- [Slow Sand Filtration](#)
- [Conventional and Direct Filtration](#)
- [Performance Based Training](#)
- [More Training Opportunities](#)

#### Training Articles and Presentations

- [AWOP News - Articles and Training Videos](#)
- [SCADA Alarms for Treatment Plants - March 2021](#)
  - [SCADA Alarm Verification Template](#)
- [Jar Testing Made Easy - Aug 2020 OpFlow Article](#)
- [Distribution System Optimization — Recorded PowerPoint Training \(large file — may take several minutes to download\)](#)
- [Optimizing Corrosion Control and Understanding Lead and Copper Requirements](#)

# “Data Online”

[www.healthoregon.org/dws](http://www.healthoregon.org/dws)

## Oregon Drinking Water Services

### Working to keep drinking water safe for Oregonians

Access to safe drinking water is essential to human health. Oregon Drinking Water Services helps to keep drinking water safe for Oregonians.

Oregon Drinking Water Services (DWS) administers and enforces drinking water quality standards for public water systems in the state of Oregon. DWS focuses resources in the areas of highest public health benefit and promotes voluntary compliance with state and federal drinking water standards. DWS also emphasizes prevention of contamination through source water protection, provides technical assistance to water systems and provides water system operator training.




Contact Us

Sign up for DWS News

Water Advisories Map

Data Online



### Services

- [Cross Connection & Backflow Prevention](#)
- [Emergency Planning and Response](#)
- [Groundwater & Source Water Protection](#)
- [Monitoring & Reporting](#)
- [Operator Certification](#)
- [Plan Review](#)
- [Drinking Water Funding](#)
- [Water System Operations](#)
- [Capacity Development](#)

### Resources

- [County & Department of Agriculture Resources](#)
- [Data Online](#)
- [Domestic Well Safety Program](#)
- [Drinking Water Advisory Committee \(DWAC\)](#)
- [For Consumers](#)
- [Online Maps](#)
- [Rules & Implementation Guidance](#)
- [Training Opportunities](#)
- [Site Map](#)
- [Contact Us](#)

### \* News and Hot Topics

#### Link

[LCRR Service Line Inventory Requirements](#)

[2023 Source Protection Grant LOI](#)

[Startup tips for seasonal systems](#)

[Current Rulemaking: Proposed Rule Amendments](#)

[Bipartisan Infrastructure Law Funding](#)

[Compliance Monitoring Data Portal](#)

[Per- and Polyfluoroalkyl Substances \(PFAS\)](#)

[Cyanotoxin Resources for Water Systems](#)

[Wildfire Information for Water Systems](#)

[Annual Water System Fee Info](#)

[DWS Annual Compliance Report](#)

[View archived hot topics and news items](#)

Information  
By  
Subject

“Data Online”  
(data specific  
to each water  
system)

Contact Us

News and Hot  
Topics

# Drinking Water Data Online

## <https://yourwater.oregon.gov/>

Many data search options are available

Oregon Public Health  
Drinking Water Data Online

Introduction :: **Data Search Options** :: Water System Search :: DWS Home :: DWS Rules

[Data Search Options](#)

### Drinking Water Data Online

Welcome to **Data Online**, the data access site for [Oregon Drinking Water Services](#).

Here you can access a fair amount of data on public drinking water systems in Oregon. You can find data such as coliform testing, chemical testing, contacts, violations, enforcements, public notices, and basic system information.

The [Search Options](#) page explains many of the data pages that are available. Use the [Water System Search](#) page to find a water system by water system ID number, name, or location.

Data shown here are "live" data. That means they're as current as the reports we have in our system. This is the same data that Drinking Water Services (DWS) staff see and use. If something is missing, that usually means it has not been reported to us or we have not entered it yet. If you (water system personnel, county staff, lab staff, etc.) find a report is missing, please forward a copy to us at: **DWS, PO BOX 14350, Portland, OR 97293.**

For questions or updates regarding water system sampling, inventory, or compliance, please contact Drinking Water Services at 971-673-0405 or [Info.DrinkingWater@odhsoha.oregon.gov](mailto:Info.DrinkingWater@odhsoha.oregon.gov).

See the [Contact Us](#) page on the main Drinking Water site for more contact options.

Information for all water systems:

[Water System Inventory](#) :: [Water System Surveys](#) :: [Outstanding Performers](#) :: [Treatment Plant Inspections](#) :: [Treatment](#) :: [Plan Reviews](#)  
[Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Deficiencies](#) :: [System Scores](#) :: [Exceedances](#) :: [Public Notices](#)  
[Water Advisories](#) :: [Contact Reports](#) :: [Cyanotoxins](#) :: [PFAS](#) :: [Post-wildfire VOCs](#) :: [Fluoride](#)

[Introduction](#) :: [Data Search Options](#) :: [Water System Search](#) :: [DWS Home](#) :: [DWS Rules](#)

Need help? [Email Drinking Water Services](#) for assistance.

[Staff/Partner Login](#)

Info by  
County

Oregon  
Health  
Authority

# Find Your Water System

## WS Name Look Up



Oregon Public Health  
Drinking Water Data Online



[Introduction](#) :: [Data Search Options](#) :: [Water System Search](#) :: [DWS Home](#) :: [DWS Rules](#)


### Water System Search

Search by water system name or number:

Search

You can enter all or part of the water system's name. Only exact matches will be returned.

or Search by location:



1. Select Water System Search
2. Enter water system name (e.g., "Salem")
3. Click Search

**Note:** You also could have used WS ID Look Up and entered the ID# for Salem (00731) or you could have used the map





# Select Your Water System

Select the Water System by  
Clicking on the PWS ID#

**Search results:** 5 systems found. *Select a water system by clicking on its row (opens in a new tab).*

PWS ID	Water System Name	Regulating Agency	County Served	System Type	Activity Status
05564	BPA-SALEM SUBSTATION	POLK COUNTY	Polk	OVS	Inactive
95003	FORUM SALEM CAMPUS	DEPT OF AGRICULTURE	Marion	NTNC	Active
00779	SALEM MOBILE ESTATES/SHADY ACRES	MARION COUNTY	Marion	C	Active
00731	SALEM PUBLIC WORKS	REGION 1	Marion	C	Active
00768	SUBURBAN EAST SALEM WD	REGION 1	Marion	C	Active

<https://yourwater.oregon.gov/inventory.php?pwsno=00731>



**OR41 00731 SALEM PUBLIC WORKS** **Classification:** COMMUNITY

<p><b>Contact:</b> DWAYNE BARNES PO BOX 14300 SALEM, OR 97309</p> <p><b>Population:</b> 199,820</p> <p><b>Operating Period:</b> January 1 to December 31</p> <p><b>Certified Operator(s)</b> Required: Y Distribution class: 4 Treatment class: 3 Filtration Endorsement Required: No</p>	<p><b>Phone:</b> 503-588-6483</p> <p><b>County:</b> MARION</p> <p><b>Activity Status:</b> ACTIVE -- <a href="#">History</a></p> <p><b>Number of Connections:</b> 55,970</p> <p><b>Regulating Agency:</b> REGION 1</p> <p><b>Owner Type:</b> LOCAL GOVERNMENT</p> <p><b>Licensed By:</b> N/A</p> <p><b>Approved Drinking Water Protection Plan:</b> No</p> <p><b>Source Water Assessment:</b> Yes</p> <p><b>Last Survey Date:</b> Jul 25, 2023 - Outstanding Performer!</p>	<p><a href="#">View on Map</a></p>
---	--	------------------------------------

General Information

**Sources**

<a href="#">Facility ID</a>	<a href="#">Facility Name</a> - <a href="#">Well Logs</a>	<a href="#">Activity Status</a>	<a href="#">Availability</a>	<a href="#">Source Type</a>
EP-A	EP FOR GEREN ISLAND (ALDRSGATE)	A		SW
SRC-AA	NORTH SANTIAM RIVER	A	Permanent	SW
SRC-AB	GEREN ISLAND EAST WELL - <a href="#">L75842</a>	A	Permanent	GU
SRC-AC	GEREN ISLAND WEST WELL - <a href="#">L75839</a>	A	Permanent	GU
SRC-AD	I.G. / ROUGHING FILTER #1	A	Seasonal	GU
EP-B	EP FOR ASR WELLS	A		GW
SRC-BA	ASR WELL #1 - <a href="#">L82685</a>	A	Seasonal	GW
SRC-BB	ASR WELL #2 - <a href="#">L82688</a>	A	Seasonal	GW
SRC-BC	ASR WELL #4 - <a href="#">L10522</a>	A	Seasonal	GW
SRC-BD	ASR WELL #5 - <a href="#">L16342</a>	A	Seasonal	GW
EP-C	EP FOR HEMLOCK WELL	I		GW
SRC-CA	HEMLOCK WELL - <a href="#">L62600</a>	I	Emergency	GW

Sources

[Find Purchasers/Sellers](#)

**Treatment**

<a href="#">Facility ID</a>	<a href="#">Facility Name</a>	<a href="#">Filter Type</a>	<a href="#">Giardia Removal Credit</a>	<a href="#">Treatment Process</a>	<a href="#">Treatment Objective</a>
WTP-A	TP FOR GEREN ISLAND	SLOW SAND	2.0-log	FILTRATION, SLOW SAND HYPOCHLORINATION, POST PH/ALKA ADJ-SODA ASH OZONATION, PRE ACT. CARBON, PWD - CYANOTOXINS	PARTICULATE REMOVAL DISINFECTION CORROSION CONTROL DISINFECTION OTHER

Treatment

<b>OR41 00731</b>	<b>SALEM PUBLIC WORKS</b>	<b>Classification:</b> COMMUNITY
<b>Contact:</b> DWAYNE BARNES PO BOX 14300 SALEM, OR 97309	<b>Phone:</b> 503-588-6483 <b>County:</b> MARION <b>Activity Status:</b> ACTIVE -- <a href="#">History</a>	<a href="#">View on Map</a>
<b>Population:</b> 199,820	<b>Number of Connections:</b> 55,970	
<b>Operating Period:</b> January 1 to December 31	<b>Regulating Agency:</b> REGION 1	
<b>Certified Operator(s)</b> Required: Y	<b>Owner Type:</b> LOCAL GOVERNMENT <b>Licensed By:</b> N/A	

**Consumer Confidence Reports (Last 5 Years)**

Fac  
EP  
SR  
SR  
SR  
SR  
EP  
SR  
SR  
SR  
EP  
SR

<u>For Year</u>	<u>Date Received</u>	<u>Date Certified</u>
2023	Due 7/1/2024	Due 10/1/2024
2022	7/5/2023	7/5/2023
2021	7/6/2022	7/6/2022
2020	7/1/2021	7/1/2021
2019	6/23/2020	6/23/2020

**Cross Connection/Backflow Prevention Information (Last 3 Records)**

Fac  
WT

<u>Enabling Authority Received</u>	<u>Annual Summary Report Received</u>	<u>Cross Connection Fee Status</u>
<a href="#">Yes (PDF)</a>	<a href="#">2022 (PDF)</a>	2024 - Paid
	<a href="#">2021 (PDF)</a>	2023 - Paid
	<a href="#">2020 (PDF)</a>	2022 - Paid
		2021 - Paid

More information for this water system:

SDWIS ID 3906

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Contacts & Advisories](#) :: [Site Visits](#) :: [Public Notice](#)  
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Schedules](#) :: [LT2](#) :: [GW/GWUDI Source Details](#) :: [Plan Review](#) :: [Annual Fee](#)  
[Chemical Summary](#) :: [Chemical Results](#) :: [Chemical Schedules](#) :: [Chemical Schedule Summary](#) :: [Arsenic RAA](#) :: [Cyanotoxins](#) :: [PFAS](#)  
[Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [DBP Sample Sites](#) :: [FANLs](#) :: [MRDL](#) :: [GWR 4-Log](#) :: [Turbidity](#) :: [SWTR](#) :: [LRAA](#)

Information for all water systems:

[Water System Inventory](#) :: [Water System Surveys](#) :: [Outstanding Performers](#) :: [Treatment Plant Inspections](#) :: [Treatment](#) :: [Plan Reviews](#)  
[Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Deficiencies](#) :: [System Scores](#) :: [Exceedances](#) :: [Public Notices](#)  
[Water Advisories](#) :: [Contact Reports](#) :: [Cyanotoxins](#) :: [PFAS](#) :: [Post-wildfire VOCs](#) :: [Fluoride](#)

[Introduction](#) :: [Data Search Options](#) :: [Water System Search](#) :: [DWS Home](#) :: [DWS Rules](#)

Need help? [Email Drinking Water Services](#) for assistance.

[Staff/Partner Login](#)

Consumer Confidence Report (CCR)

Cross Connection Program Info

<= Many Other Options

# General Information

System  
Classification



OR41 00731

SALEM PUBLIC WORKS

Classification: COMMUNITY

Contact: DWAYNE BARNES  
PO BOX 14300  
SALEM, OR 97309

Population: 199,820

Operating Period: January 1 to December 31

**Certified Operator(s)**

Required: Y

Distribution class: 4

Treatment class: 3

Filtration Endorsement Required: No

Phone: 503-588-6483

County: MARION

Activity Status: ACTIVE -- [History](#)

Number of Connections: 55,970

Regulating Agency: [REGION 1](#)

Owner Type: LOCAL GOVERNMENT



Licensed By: N/A

Approved Drinking Water Protection Plan: No

Source Water Assessment: Yes

Last Survey Date: [Jul 25, 2023 - Outstanding Performer!](#)

[View on Map](#)



All written correspondence goes to this person  
(e.g., violation notices, general mailings, etc.)

[View a list of Certified Operators](#)

# Sources

## Well Log Query Results

Well Tag Nbr: 75842

Well Log	T-R-S/ QQ-Q	Taxlot	Street or
MARI 59138			

MARI 59138 MARI 59138

STATE OF OREGON  
WATER SUPPLY WELL REPORT  
(as required by ORS 537.765)

*Amendment*

WELL I.D. #1 75842  
STREET CARD # 17322 2

Instructions for completing this report are on the last page of this form.

(1) LAND OWNER Well Number  
Name City of Salem Public Works Department  
Address 1410 20th Street S.E.  
City Salem State Oregon Zip 97302

(2) TYPE OF WORK  New Well  
 Deepening  Alteration (repair/recondition)  Abandonment  Construction

(3) DRILL METHOD  
 Rotary Air  Rotary Mud  Cable  Auger  Cable Mud  
 Other *Pump hoist*

(4) PROPOSED USE  
 Domestic  Community  Industrial  Irrigation  
 Thermal  Injection  Livestock  Other

(5) BORE HOLE CONSTRUCTION Special Construction  Yes  No  
Depth of Completed Well 62 ft  
Explosives used:  Yes  No Type Amount

BORE HOLE		SEAL	
Diameter	From To	Material	From To
20"	0 13'	cement	0 2'
14"	13' 66'	bentonite	2' 13'

Sacks or Pounds cement slab 15 sacks

How was seal placed: Method  A  B  C  D  E  
 Other *bentonite placed dry*

Backfill placed from ft. to ft. Material  
Gravel placed from ft. to ft. Size of gravel

(6) CASING/LINER

Casing	Diameter	From To	Gauge	Steel	Plastic	Welded	Threaded
14"	+2	68'	250	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Liner:

Drive Shoe used  Inside  Outside  None  
Final location of shoe(s) *Unknown*

(7) PERFORATIONS/SCREENS  
 Perforations  Screens  
Method Type Material

From To	Slot Size	Number	Diameter	Tele/pipe size	Casing	Liner

(8) WELL TESTS: Minimum testing time is 1 hour  
 Pump  Bailor  Air  Flowing Artesian

Yield gal/min	Drawdown	Drill stem at	Time
	N/A		

Temperature of water *unknown* Depth Artesian Flow Found

Was a water analysis done?  Yes  No By whom  
Did any strata contain water not suitable for intended use?  Too little  
 Salty  Muddy  Odor  Colored  Other  
Depth of strata:

(9) LOCATION OF WELL (legal description)  
County Marion  
Tax Lot None Lot  
Township 9 S Range 1 W E or W WM  
Section 13 NW 1/4 NW 1/4

Lat " " " or " " " (degrees or decimal)  
Long " " " or " " " (degrees or decimal)

Street Address of Well (or nearest address) 2700 Santiam Rd.  
Stayton, Oregon

(10) STATIC WATER LEVEL  
12' 11" ft. below land surface. Date 8/11/05  
ft. below land surface. Date  
Artesian pressure lb. per square inch. Date

(11) WATER BEARING ZONES  
Depth at which water was first found N/A

From	To	Estimated Flow Rate	SWL
	N/A		

(12) WELL LOG Ground Elevation

Material	From	To	SWL
Added 7 ft. of new casing to bring top to new land surface level. Excavated around casing to add bentonite seal			

RECEIVED FEB 05 2009  
AUG 2 2 2005  
WATER RESOURCES DEPT SALEM, OREGON

Date Started 7/22/05 Completed 8/11/05

(unbonded) Water Well Constructor Certification  
I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.

WWC Number 1629 Date 8/15/05  
Signed *[Signature]*

(bonded) Water Well Constructor Certification  
I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.

WWC Number 1273 Date 8/15/05  
Signed *[Signature]*

ORIGINAL - WATER RESOURCES DEPARTMENT FIRST COPY - CONSTRUCTOR SECOND COPY - CUSTOMER 09/19/2004

Facility ID	Facility Name - Well Logs
EP-A	EP FOR GEREN ISLAND WTP
SRC-AA	NORTH SANTIAM RIVER
SRC-AB	GEREN ISLAND EAST WELL - L75842
SRC-AC	GEREN ISLAND WEST WELL - L75839
SRC-AD	INFILTRATION GALLERY

Clicking on a Well ID allows you to view well logs and data from the Oregon Water Resources Department

# Treatment

Treatment Process

Treatment

<u>Facility ID</u>	<u>Facility Name</u>	<u>Filter Type</u>	<u>Giardia Removal Credit</u>	<u>Treatment Process</u>	<u>Treatment Objective</u>
WTP-A	TP FOR GEREN ISLAND	SLOW SAND	2.0-log	FILTRATION, SLOW SAND HYPOCHLORINATION, POST PH/ALKA ADJ-SODA ASH OZONATION, PRE ACT. CARBON, PWD - CYANOTOXINS FLUORIDATION COAGULATION FLOCCULATION PH ADJUSTMENT, PRE SEDIMENTATION	PARTICULATE REMOVAL DISINFECTION CORROSION CONTROL DISINFECTION OTHER OTHER PARTICULATE REMOVAL PARTICULATE REMOVAL PARTICULATE REMOVAL PARTICULATE REMOVAL

## Filter Type:

SS = Slow Sand

CT = Cartridge

BG = Bag

CF = Conventional Filtration

DF = Direct Filtration

MF = Membrane Filtration

UF = Unfiltered

# Sampling Schedules

More information for this water system:

SDWIS ID 3906

- [System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Contacts & Advisories](#) :: [Site Visits](#) :: [Public Notice](#)
- [Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Schedules](#) :: [LT2](#) :: [GW/GWUDI Source Details](#) :: [Plan Review](#) :: [Annual Fee](#)
- [Chemical Summary](#) :: [Chemical Results](#) :: [Chemical Schedules](#) :: [Chemical Schedule Summary](#) :: [Arsenic RAA](#) :: [Cyanotoxins](#) :: [PFAS](#)
- [Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [DBP Sample Sites](#) :: [FANLs](#) :: [MRDL](#) :: [GWR 4-Log](#) :: [Turbidity](#) :: [SWTR](#) :: [LRAA](#)

## Sampling Schedules:

1. Sampling Schedule for Coliform
  - Includes repeat schedules
2. Chemical Schedule Summary
  - Required chemical sampling
3. Chemical Schedules - progress report on chemical sampling

# Sampling Data

Oregon Public Health  
Drinking Water Data Online

Introduction :: Data Search Options :: Water System Search :: DWS Home :: DWS Rules :: Quick Data Links

01441 00731 SALEM PUBLIC WORKS Classification: COMMUNITY

Contact: DWAYNE BARNES Phone: 503-555-0423  
PO BOX 14300 County: MARION  
SALEM, OR 97309 Activity Status: ACTIVE - History  
Population: 192,000 Number of Connections: 55,570  
Operating Period: January 1 to December 31 Regulating Agency: RSD-0211  
Owner Type: LOCAL GOVERNMENT  
Required: Y Licensed By: N/A  
Distribution class: 4 Approved Drinking Water Protection Plan: No  
Treatment class: 2 Source Water Assessment: Yes  
Fluoride Enrichment Required: No Last Survey Date: Jul 23, 2022 - Outstanding Performer

Facility ID: B1-A Facility Name: Well Lease Activity Status: A Availability: Source Code: SW

More information for this water system:

SDWIS ID 3906

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Contacts & Advisories](#) :: [Site Visits](#) :: [Public Notice](#)

[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Schedules](#) :: [LT2](#) :: [GW/GWUDI Source Details](#) :: [Plan Review](#) :: [Annual Fee](#)

[Chemical Summary](#) :: [Chemical Results](#) :: [Chemical Schedules](#) :: [Chemical Schedule Summary](#) :: [Arsenic RAA](#) :: [Cyanotoxins](#) :: [PFAS](#)

[Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [DBP Sample Sites](#) :: [FANLs](#) :: [MRDL](#) :: [GWR 4-Log](#) :: [Turbidity](#) :: [SWTR](#) :: [LRAA](#)

1. Coliform Summary (by month)
2. Coliform Results (by sample, results before 2002)
3. Chemical Summary (VOC, SOC)
4. Chemical Results (individual contaminants)
5. Lead & Copper & Corrosion Control (L&C, pH, etc.)
6. Arsenic Running Annual Average (RAA) & PFAS
7. Turbidity (maximum daily turbidity), LT2 (source crypto/coliform), Cyanotoxins
8. SWTR (results from the bottom of the monthly SW report)
9. LRAA (DBP running annual average results)

Consumer Confidence Reports (Last 5 Years)

CCR Year	Date Received	Date Certified
2022	Due 7/1/2024	Due 10/1/2024
2022	7/5/2022	7/5/2022
2021	7/6/2022	7/6/2022
2020	7/1/2021	7/1/2021
2019	6/22/2020	6/22/2020

Draw Connection/Bedflow Prevention Information (Last 3 Records)

Regulating Authority Reported	Annual Schedule (Report Due)	Draw Connection Fee Status
Yes (PDF)	2022 (PDF)	2024 - Paid
	2021 (PDF)	2022 - Paid
	2020 (PDF)	2022 - Paid
		2021 - Paid

More information for this water system: SDWIS ID 3906

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Contacts & Advisories](#) :: [Site Visits](#) :: [Public Notice](#)  
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Schedules](#) :: [LT2](#) :: [GW/GWUDI Source Details](#) :: [Plan Review](#) :: [Annual Fee](#)  
[Chemical Summary](#) :: [Chemical Results](#) :: [Chemical Schedules](#) :: [Chemical Schedule Summary](#) :: [Arsenic RAA](#) :: [Cyanotoxins](#) :: [PFAS](#)  
[Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [DBP Sample Sites](#) :: [FANLs](#) :: [MRDL](#) :: [GWR 4-Log](#) :: [Turbidity](#) :: [SWTR](#) :: [LRAA](#)

Information for all water systems:  
[Water System Inventory](#) :: [Water System Survey](#) :: [Outstanding Performers](#) :: [Treatment Plant Locations](#) :: [Treatment](#) :: [Sanitation](#)  
[Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Delegations](#) :: [System Scores](#) :: [Resolutions](#) :: [Public Notices](#)  
[Water Advisories](#) :: [Contact Reports](#) :: [Connections](#) :: [PFAS](#) :: [Public Notice](#) :: [Fluoride](#)

Introduction :: Data Search Options :: Water System Search :: DWS Home :: DWS Rules

Need help? [Email Oregon Water Services](#) for assistance. [Staff/Partner Login](#)



# Alerts, Contacts, Advisories & Site Visits

Oregon Public Health Drinking Water Data Online		Oregon Health Authority	
Introduction :: Data Search Options :: WS Name Look Up :: WS ID Look Up :: DWS Home :: Quick Data Links			
OR41 00731	SALEM PUBLIC WWORKS	Classification: COMMUNITY	
Contact:	SOPHIA HOBST 1410 20TH ST SE BLDG 2 SALEM, OR 97302	Phone: 503-583-6483 County: MARION Activity Status: ACTIVE - History Number of Connections: 51,112	Regulating Agency: REGION 1 Owner Type: LOCAL GOVERNMENT Licensee By: N/A Approved Drinking Water Protection Plan: No Source Water Assessment: Yes Last Survey Date: Aug 23, 2011
Population: 189,000	Operating Period: January 1 to December 31		
Certified Operations			
Required: Y			
Distribution class: 4			
Treatment class: 3			
Filtration Endorsement Required: No			

More information for this water system:

SDWIS ID 3906

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Contacts & Advisories](#) :: [Site Visits](#) :: [Public Notice](#)

[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Schedules](#) :: [LT2](#) :: [GW/GWUDI Source Details](#) :: [Plan Review](#) :: [Annual Fee](#)

[Chemical Summary](#) :: [Chemical Results](#) :: [Chemical Schedules](#) :: [Chemical Schedule Summary](#) :: [Arsenic RAA](#) :: [Cyanotoxins](#) :: [PFAS](#)

[Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [DBP Sample Sites](#) :: [FANLs](#) :: [MRDL](#) :: [GWR 4-Log](#) :: [Turbidity](#) :: [SWTR](#) :: [LRAA](#)

2008	Jun 28, 2009	Jun 28, 2009
2007	Jun 04, 2008	Jun 04, 2008
Cross Connection Annual Summary Reports (Last 3 Records)		
<a href="#">Ordinance Received</a>	<a href="#">Ordinance Status</a>	<a href="#">ASR Received</a>
Yes	Final	2011 2010 2009

1. Alerts - Sample results that require State/County/Dept of Ag staff to respond
2. Contacts – Document alert follow-ups and other significant correspondence
3. Advisories – boil water notice advisories, etc.
4. Site Visits – Document surveys and treatment plant inspections

# Violations, Enforcements & Public Notices

Oregon Public Health Drinking Water Data Online			Oregon Health Division
Introduction :: Data Search Options :: WS Name Look Up :: WS ID Look Up :: DWS Home :: Quick Data Links			
OR41 00731	SALEM PUBLIC WORKS	Classification: COMMUNITY	
Contact:	SOPHIA HOBST 1410 20TH ST SE BLDG 2 SALEM, OR 97302	Phone: 503-588-6483 County: MARION Activity Status: ACTIVE - History Number of Connections: 51,112	
Population:	189,000	Regulating Agency: REGION 1 Owner Type: LOCAL GOVERNMENT Licensee By: N/A Approved Drinking Water Protection Plan: No Source Water Assessment: Yes Last Survey Date: Aug 23, 2011	
Operating Period:	January 1 to December 31		
Certified Operations:	Required: Y Distribution class: 4 Treatment class: 3 Filtration Endorsement Required: No		
Sources			

More information for this water system:

SDWIS ID 3906

System Info :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Contacts & Advisories](#) :: [Site Visits](#) :: [Public Notice](#)

[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Schedules](#) :: [LT2](#) :: [GW/GWUDI Source Details](#) :: [Plan Review](#) :: [Annual Fee](#)

[Chemical Summary](#) :: [Chemical Results](#) :: [Chemical Schedules](#) :: [Chemical Schedule Summary](#) :: [Arsenic RAA](#) :: [Cyanotoxins](#) :: [PFAS](#)

[Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [DBP Sample Sites](#) :: [FANLs](#) :: [MRDL](#) :: [GWR 4-Log](#) :: [Turbidity](#) :: [SWTR](#) :: [LRAA](#)

2007	Jun 04, 2008	Jun 04, 2008
Cross Connection Annual Summary Reports (Last 3 Records)		
<a href="#">Ordinance Received</a>	<a href="#">Ordinance Status</a>	<a href="#">ASR Received</a>
Yes	Final	2011 2010 2009

## 1. Violations

- Also shows related enforcement actions
- Systems should strive to see "Returned to Compliance" or "RTC"
- System score should be less than 11 and as close to 0 as possible

## 2. Enforcements

View pdf copies of original Administrative Orders and Bilateral Compliance Agreements as well as their status

## 3. Public Notice

- Notices required
- Notices delivered

# Violations, Enforcements & Public Notices

Oregon Public Health  
Drinking Water Data Online

Introduction | Data Search Options | WS Name Look Up | WS ID Look Up | DWS Home | Quick Data Links

OR41 00731 SALEM PUBLIC WORKS Classification: COMMUNITY

Contact: SOPHIA HOBST Phone: 503-588-6483  
1410 20TH ST SE BLDG 2 County: MARION  
SALEM, OR 97302 Activity Status: ACTIVE - History  
Population: 189,000 Number of Connections: 51,112  
Operating Period: January 1 to December 31 Registering Agency: REGION 1  
Certified Operator(s) Owner Type: LOCAL GOVERNMENT  
Required: Y Licensee By: N/A  
Distribution class: 4 Approved Drinking Water Protection Plan: No

PWS ID: 00731 ---- SALEM PUBLIC WORKS

OR41

## Violation History

Violations are displayed for the last 5 years only.

**Group Abbreviations:** CCR = Consumer Confidence Report

**Gray shading** indicates return to compliance.

[Hide Auto-RTC](#) | [Show Determination Dates](#)

[Go to public notices](#)

Violation Number	Auto-RTC?	Monitoring Period Begin	Monitoring Period End	Facility ID	Analyte Group	Violation Type - Analyte Count <i>Show analytes for all violations</i>	Enforcement Action - Date <i>Show history</i>	Points
902792450	Y	Jul 01, 2023	Jul 05, 2023		CCR	CCR Late/Nonreporting - 1	Returned To Compliance - Jul 05, 2023	1

## SYSTEM SCORE SUMMARY

[Learn about system scores](#)

Unaddressed Points:	0
Number of years the oldest violation has been unaddressed (n):	0
<b>System Score:</b>	<b>0</b>
Points under formal enforcement:	0
Points RTC'd:	1

## 1. Violations

- Systems should strive to see "Returned to Compliance" or "RTC"
- System score should be less than 11 and as close to 0 as possible


# Plan Review Information

Oregon Public Health Drinking Water Data Online		Oregon Health Authority	
Introduction :: Data Search Options :: WS Name Look Up :: WS ID Look Up :: DWS Home :: Quick Data Links			
OR41 00731	SALEM PUBLIC WORKS	Classification: COMMUNITY	
Contact:	SOPHIA HOBET 1410 20TH ST SE BLDG 2 SALEM, OR 97302	Phone: 503-580-6433 County: MARION Activity Status: ACTIVE - History Number of Connections: 51,112	Regulating Agency: REGION 1 Owner Type: LOCAL GOVERNMENT Licensed By: N/A Approved Drinking Water Protection Plan: No Source Water Assessment: Yes Last Renewal Date: August 2014
Population: 189,000	Operating Period: January 1 to December 31		
Certified Operations			
Required: Y Distribution class: 4 Treatment class: 3 Operation Enforcement Bandwidth: N/A			

For further information on this public water system, click on the area of interest below:

- [System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Contacts & Advisories](#) :: [Site Visits](#) :: [Public Notice](#)  
[Coliform Summary](#) :: [Coliform Results](#) :: [Sampling Schedule for Coliform](#) :: [Groundwater/GWUDI Source Details](#) :: [Plan Review](#) :: [Annual Fee](#)  
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Entry Point Detects](#) :: [Single Analyte Results](#)  
[Chemical Schedule Summary](#) :: [Chemical Schedule Details](#)  
[Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [Nitrate](#) :: [Arsenic](#) :: [Radionuclides](#) :: [GWR 4-Log](#) :: [LT2](#) :: [Cyanotoxins](#) :: [PFAS](#)  
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP Sample Sites](#) :: [FANLs](#) :: [MRDL](#) :: [Turbidity](#) :: [SWTR](#) :: [RAA](#) :: [LRAA](#)

For SDWIS: 3906



1. Project ID and Name
2. Date Plans Received
3. Date Preliminary Approval was Granted (no conditions)
4. Date Conditional Approval was Granted (required items not shown on submitted plans)
5. Date Abandoned (project was not completed)
6. Final Approval Date (approval for use)
7. Reviewer (initials of State staff engineer reviewing the plans)

For further information on this public water system, click on the area of interest below:  
[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Enforcements](#) :: [Contacts](#) :: [Site Visits](#) :: [Public Notice](#) :: [Plan Review](#)  
[Coliform Summary](#) :: [Coliform Results](#) :: [Coliform Results before 2002](#) :: [Sampling Schedule for Coliform](#)  
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Entry Point Detects](#) :: [Single Analyte Results](#)  
[Chemical Schedule Summary](#) :: [Chemical Schedule Details](#)  
[Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [Nitrate](#) :: [Arsenic](#) :: [Radionuclides](#)  
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP/TOC/Biomass/Chlorine Monitoring](#) :: [FANLs](#) :: [MRDL](#) :: [Turbidity](#) :: [SWTR](#) :: [RAA](#)

Information by county:  
[Inventory](#) :: [Surface Water Systems](#) :: [Water System Status](#) :: [Outstanding Performers](#) :: [Plan Reviews](#) :: [System Scores](#) :: [Alerts](#) :: [Violations](#) :: [Open Enforcements](#) :: [Significant Deficiencies](#) :: [Cross Connection ABRs](#) :: [Treatment Plant Inspections](#)

[Inventory List](#) for all Oregon Drinking Water Systems in Excel or printable screen format  
[Lab Help](#) :: [Tools for Laboratories](#)

[Introduction](#) :: [Data Search Options](#) :: [WS Name Look Up](#) :: [WS ID Look Up](#) :: [DWP Home](#)

# Annual Fee

Oregon Public Health Drinking Water Data Online		Oregon Health Authority
Introduction :: Data Search Options :: WS Name Look Up :: WS ID Look Up :: DWS Home :: Quick Data Links		
OR41 00731	SALEM PUBLIC WORKS	Classification: COMMUNITY
Contact:	SOPHIA HOBST 1410 20TH ST SE BLDG 2 SALEM, OR 97302	Phone: 503-580-6433 County: MARION Activity Status: ACTIVE - History
Population:	189,000	Number of Connections: 51,112
Operating Period:	January 1 to December 31	Regulating Agency: RBOION 1
Certified Operations:	Required: Y Distribution class: 4 Treatment class: 3 Operation Enforcement Bandwidth: N/A	Owner Type: LOCAL GOVERNMENT Licensee By: N/A Approved Drinking Water Protection Plan: No Source Water Assessment: Yes Last Renewal Date: August 10, 2014

For further information on this public water system, click on the area of interest below:

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Contacts & Advisories](#) :: [Site Visits](#) :: [Public Notice](#)  
[Coliform Summary](#) :: [Coliform Results](#) :: [Sampling Schedule for Coliform](#) :: [Groundwater/GWUDI Source Details](#) :: [Plan Review](#) :: [Annual Fee](#)  
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Entry Point Detects](#) :: [Single Analyte Results](#)  
[Chemical Schedule Summary](#) :: [Chemical Schedule Details](#)  
[Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [Nitrate](#) :: [Arsenic](#) :: [Radionuclides](#) :: [GWR 4-Log](#) :: [LT2](#) :: [Cyanotoxins](#) :: [PFAS](#)  
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP Sample Sites](#) :: [FANLs](#) :: [MRDL](#) :: [Turbidity](#) :: [SWTR](#) :: [RAA](#) :: [LRAA](#)

For SDWIS: 3906

1. Based on system type
2. Based on # of connections for most systems
3. Based on population served for wholesale only systems (no direct retail services)
4. Fee ranges from \$75 for Oregon Very Small (OVS) systems to \$65,000 for large community systems serving more than 100,000 people
5. "Pay Now" option to pay online

For further information on this public water system, click on the area of interest below: <a href="#">System Info</a> - <a href="#">Report for Lenders</a> - <a href="#">Alerts</a> - <a href="#">Violations</a> - <a href="#">Enforcements</a> - <a href="#">Contacts</a> - <a href="#">Site Visits</a> - <a href="#">Public Notice</a> - <a href="#">Plan Review</a> <a href="#">Coliform Summary</a> - <a href="#">Coliform Results</a> - <a href="#">Coliform Results before 2002</a> - <a href="#">Sampling Schedule for Coliform</a> <a href="#">Chemical Group Summary</a> - <a href="#">Latest Chemical Results</a> - <a href="#">Entry Point Detects</a> - <a href="#">Single Analyte Results</a> <a href="#">Chemical Schedule Summary</a> - <a href="#">Chemical Schedule Details</a> <a href="#">Lead &amp; Copper</a> - <a href="#">Corrosion Control (LCR)</a> - <a href="#">Nitrates</a> - <a href="#">Arsenic</a> - <a href="#">Radionuclides</a> <a href="#">DBPs</a> - <a href="#">TOC &amp; Alkalinity</a> - <a href="#">DBP/TOC/Biomass/Chlorine Monoxide</a> - <a href="#">FANLs</a> - <a href="#">MRDL</a> - <a href="#">Turbidity</a> - <a href="#">SWTR</a> - <a href="#">RAA</a>
Information by county: <a href="#">Inventory</a> - <a href="#">Surface Water Systems</a> - <a href="#">Water System Status</a> - <a href="#">Outstanding Permits</a> - <a href="#">Plan Reviews</a> - <a href="#">System Scores</a> - <a href="#">Alerts</a> - <a href="#">Violations</a> - <a href="#">Open Enforcements</a> - <a href="#">Significant Deficiencies</a> - <a href="#">Cross Connection ASRs</a> - <a href="#">Treatment Plant Inspections</a>
<a href="#">Inventory List</a> for all Oregon Drinking Water Systems in Excel or printable screen format <a href="#">Lab Help</a> - <a href="#">Tools for Laboratories</a>
<a href="#">Introduction</a> - <a href="#">Data Search Options</a> - <a href="#">WS Name Look Up</a> - <a href="#">WS ID Look Up</a> - <a href="#">DWP Home</a>

# System Info & Report For Lenders



Oregon Public Health Drinking Water Data Online		
Introduction :: Data Search Options :: WS Name Look Up :: WS ID Look Up :: DWS Home :: Quick Data Links		
OR41 00731	SALEM PUBLIC WORKS	Classification: COMMUNITY
Contact:	SOPHIA HOBST 1410 20TH ST SE BLDG 2 SALEM, OR 97302	Phone: 503-588-6483 County: MARION Activity Status: ACTIVE - History
Population:	189,000	Number of Connections: 51,112
Operating Period:	January 1 to December 31	Regulating Agency: REGION 1
Certified Operations:	Required: Y Distribution class: 4 Treatment class: 3 Emission Enforcement Bandwidth: N/A	Owner Type: LOCAL GOVERNMENT Licensee By: N/A Approved Drinking Water Protection Plan: No Source Water Assessment: Yes Last Renewal Date: August 10, 2014

For further information on this public water system, click on the area of interest below:

[System Info](#) :: [Report for Lenders](#) :: [Alerts](#) :: [Violations](#) :: [Compliance & Enforcement](#) :: [Contacts & Advisories](#) :: [Site Visits](#) :: [Public Notice](#)  
[Coliform Summary](#) :: [Coliform Results](#) :: [Sampling Schedule for Coliform](#) :: [Groundwater/GWUDI Source Details](#) :: [Plan Review](#) :: [Annual Fee](#)  
[Chemical Group Summary](#) :: [Latest Chemical Results](#) :: [Entry Point Detects](#) :: [Single Analyte Results](#)  
[Chemical Schedule Summary](#) :: [Chemical Schedule Details](#)  
[Lead & Copper](#) :: [Corrosion Control \(LCR\)](#) :: [Nitrate](#) :: [Arsenic](#) :: [Radionuclides](#) :: [GWR 4-Log](#) :: [LT2](#) :: [Cyanotoxins](#) :: [PFAS](#)  
[DBPs](#) :: [TOC & Alkalinity](#) :: [DBP Sample Sites](#) :: [FANLs](#) :: [MRDL](#) :: [Turbidity](#) :: [SWTR](#) :: [RAA](#) :: [LRAA](#)

For SDWIS: 3906

## 1. System Info

- Main water system information page (already covered)

## 2. Report for Lenders

- Provides proof that the water supply is under regulatory oversight
- Satisfies lending institutions

# Information Available Online

[www.healthoregon.org/dws/](http://www.healthoregon.org/dws/)

## Oregon Drinking Water Services

### Working to keep drinking water safe for Oregonians

Access to safe drinking water is essential to human health. Oregon Drinking Water Services helps to keep drinking water safe for Oregonians.

Oregon Drinking Water Services (DWS) administers and enforces drinking water quality standards for public water systems in the state of Oregon. DWS focuses resources in the areas of highest public health benefit and promotes voluntary compliance with state and federal drinking water standards. DWS also emphasizes prevention of contamination through source water protection, provides technical assistance to water systems and provides water system operator training.



Contact Us

Sign up for DWS News

Water Advisories Map

Data Online

### Services

- [Cross Connection & Backflow Prevention](#)
- [Emergency Planning and Response](#)
- [Groundwater & Source Water Protection](#)
- [Monitoring & Reporting](#)
- [Operator Certification](#)
- [Plan Review](#)
- [Drinking Water Funding](#)
- [Water System Operations](#)
- [Capacity Development](#)

### Resources

- [County & Department of Agriculture Resources](#)
- [Data Online](#)
- [Domestic Well Safety Program](#)
- [Drinking Water Advisory Committee \(DWAC\)](#)
- [For Consumers](#)
- [Online Maps](#)
- [Rules & Implementation Guidance](#)
- [Training Opportunities](#)
- [Site Map](#)
- [Contact Us](#)

### \* News and Hot Topics

#### Link

[LCRR Service Line Inventory Requirements](#)

[2023 Source Protection Grant LOI](#)

[Startup tips for seasonal systems](#)

[Current Rulemaking: Proposed Rule Amendments](#)

[Bipartisan Infrastructure Law Funding](#)

[Compliance Monitoring Data Portal](#)

[Per- and Polyfluoroalkyl Substances \(PFAS\)](#)

[Cyanotoxin Resources for Water Systems](#)

[Wildfire Information for Water Systems](#)

[Annual Water System Fee Info](#)

[DWS Annual Compliance Report](#)

[View archived hot topics and news items](#)

# End of Part 2

- Complete the application for all 6 contact hours online at:  
<https://www.oregon.gov/oha/PH/HEALTHYENVIRONMENTS/DRINKINGWATER/OPERATIONS/TREATMENT/Pages/sw-essentials.aspx>
- The link to attend more trainings is online under “Free Training Resources” at  
[www.healthoregon.org/swt](http://www.healthoregon.org/swt)
- E-mail questions to:  
[DWS.SurfaceWater@odhsoha.oregon.gov](mailto:DWS.SurfaceWater@odhsoha.oregon.gov)



# QUESTIONS?

- E-mail questions to:  
[DWS.SurfaceWater@odhsoha.oregon.gov](mailto:DWS.SurfaceWater@odhsoha.oregon.gov)
- Call your technical services contact at the State.
- State Drinking Water Services
  - General Info: (971) 673-0405

# Thank you!

- Please provide any feedback you have in the chat for this training.