

## REPORTING REQUIREMENTS



## Overview

- How to fill out the monthly SWTR operating reports
  - How often to record turbidities
  - Highest turbidity of the day
  - Peak hourly demand flow
  - CT calculations
- Common mistakes
- What to do when things go wrong



## How to fill out the monthly SWTR reports

- There are 4 forms:
  - Conventional/Direct
  - Slow Sand / Membrane / DE / Unfiltered
  - Cartridge
  - UV (if used for *Giardia* credit)
- Must use correct form because each has questions that must be answered that are specific to the filtration type



## How to fill out the monthly SWTR reports

Forms have places to report:

- Turbidity
- Peak Hourly Flow
- CT calculations
- Log inactivation requirement (0.5 or 1.0-log, CF/DF only)



## Turbidity

- Record how often?
  - Conventional and direct: every 4 hours
  - SSF, DE & Alternative: daily
- Report CFE turbidities
- Answer questions about IFEs
- Highest turbidity of the day (can be between the 4 hour readings)



OHA - Drinking Water Program – Turbidity Monitoring Report Form County: \_\_\_\_\_  
 Conventional or Direct Filtration

System Name:	ID #:	WTP:	Month/Year:				
DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: \_\_\_\_\_  
 Conventional or Direct Filtration


System Name: \_\_\_\_\_ ID #: \_\_\_\_\_ WTP: \_\_\_\_\_ Month/Year: \_\_\_\_\_

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? Yes / No
All the 4-hour turbidity readings ≤ 1 NTU? Yes / No		
All turbidity readings < IFE <sup>1</sup> triggers? Yes / No <sup>2</sup>		
Notes:	PRINTED NAME: _____	
	SIGNATURE: _____ DATE: _____	
	PHONE #: ( ) _____ CERT #: _____	


Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in column "12 AM" through "8 PM" may not correspond to continuous readings' maximum. IFE = Indiv's Filter Eff. (OAR 333-081-0040)(1)(g)(B)(C))

PAGE 1 of 2




### Peak hourly flow

- Report the Peak Hourly Flow
  - greatest volume of water passing through the system during any one hour in a consecutive 24 hr period
- Not the same as Peak Instantaneous Flow
- Report demand flow: flow leaving the clearwell, not plant flow (in most cases)




### Method for determining peak hourly demand flow

- On a daily basis, use the best available operational data to identify the hour within the 24 hr period that had the highest demand flow
- For the hour of highest demand flow:
  - Calculate the average flow rate within the one hour period (i.e., add the flow rates and divide by the number of data points).
  - Use as many data points as possible, preferably no less than four data points taken at 15 minute intervals



### Method for determining peak hourly demand flow (continued)




- For systems that only have a flow totalizer, spot check throughout the day to determine the time of peak demand
- Once that time has been identified (e.g., 8am or 9pm for residential; mid-day for industrial), then record how much water is used during that hour each day and divide by 60 minutes to get a peak hour demand



OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation


System Name: \_\_\_\_\_ ID #: \_\_\_\_\_ WTP: \_\_\_\_\_ Month/Year: \_\_\_\_\_ Log Requirement (Circle One): 5.5 / 1.0

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1 /								
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								




### Exercise #4

- Calculate peak hourly demand flow based on continuous flow rate data



Time (min)	Demand Flow (gpm)	Running Hourly Average Flow (gpm)
5:00 AM	500	
5:15 AM	900	
5:30 AM	1000	
5:45 AM	1000	850.0
6:00 AM	1525	1,106.3
6:15 AM	1800	1,331.3
6:30 AM	3300	1,906.3
6:45 AM	5000	2,906.3
7:00 AM	5500	3,900.0
7:15 AM	7500	5,325.0
7:30 AM	6000	6,000.0
7:45 AM	5800	6,200.0
8:00 AM	6300	6,375.0
8:15 AM	5550	6,587.5
8:30 AM	6300	6,062.5
8:45 AM	4200	5,662.5
9:00 AM	4400	5,212.5
9:15 AM	3900	4,700.0
9:30 AM	3950	4,112.5
9:45 AM	3400	3,912.5
10:00 AM	3300	3,637.5
10:15 AM	2900	3,387.5
10:30 AM	2850	3,112.5
10:45 AM	3300	3,087.5
11:00 AM	2400	2,982.5
11:15 AM	1000	2,387.5
11:30 AM	2200	2,225.0
11:45 AM	2775	2,093.8
12:00 PM	2600	2,143.8

<= Peak Hour Demand =>



**Exercise #4: Calculating Peak Hourly Demand Flow**

**Directions:** Work as a group to determine what the peak hourly demand flow is based on the graph below.

**Questions:**  
 At what 1-hour interval did PHD occur? **7:00 am (7:01 am) to 8:00 am**  
 What is the peak hourly demand flow (gpm)? **6375 gpm (sum 4 data pts & divide by 4)**  
 What was the peak instantaneous demand flow (gpm)? **7500 gpm**

**Bonus questions:**  
 Is it ok to use the peak instantaneous flow instead for calculating time T? **Yes; it's more conservative**  
 If so, what are the advantages/disadvantages? **Advantage: easy to determine. Disadvantage: it may exceed the tracer study flow by more than 10%**  
 Is it ok to use the average daily flow instead for calculating time T? **No**  
 Why or why not? **Averaging the whole day would not be conservative enough (it would not account for sustained period of high flow which is when it is important for CTs to be met).**

Oregon Health Services

**How to use the EPA CT tables to figure out CT<sub>required</sub>**

- There are six EPA CT tables based on temp
- Find the correct table based on your water temperature in degrees Celsius.
  - $^{\circ}\text{C} = 5/9 \times (^{\circ}\text{F} - 32)$
- If water temp is between values, then round down
  - Example: for water temp of 12°C, use the 10°C table
  - Even if the water temp is 14.9°C, round down to 10°C
- Water gets more viscous the colder it gets and chemical reactions take longer, so rounding temp down is more conservative.

Oregon Health Services

**CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 10°C** *10°C - 14.9°C*

Chlorine Concentration (mg/L)	pH = 6						pH = 6.5						pH = 7.0					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	12	24	31	40	51	73	15	29	44	60	73	88	17	35	52	69	87	104
0.6	13	25	30	38	50	63	16	30	45	60	75	90	18	36	54	71	89	107
0.8	13	25	30	38	50	63	16	30	45	60	75	90	18	36	54	71	89	107
1	13	25	30	38	50	63	16	30	45	60	75	90	18	36	54	71	89	107
1.2	13	27	40	53	67	80	16	32	48	63	79	95	19	38	57	76	95	114
1.4	14	27	41	55	69	82	16	33	49	65	82	99	19	39	58	77	97	116
1.6	14	28	42	56	70	83	17	33	50	66	83	99	20	40	60	79	99	119
1.8	14	29	43	57	72	86	17	34	51	67	84	101	20	41	61	81	102	123
2	15	29	44	58	73	87	17	35	52	68	85	102	21	41	62	83	104	124
2.2	15	30	45	59	74	89	18	35	53	70	88	105	21	42	64	85	106	127
2.4	15	30	45	60	75	90	18	36	54	71	89	107	22	43	65	86	108	129
2.6	15	31	46	61	77	92	18	37	55	72	90	110	22	44	66	87	109	131
2.8	16	31	47	62	78	93	19	37	56	73	91	111	22	45	67	89	112	134
3	16	32	48	63	79	95	19	38	57	75	94	113	23	46	69	91	114	137

Chlorine Concentration (mg/L)	pH = 7.5						pH = 8.0						pH = 8.5					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	21	42	53	63	84	125	25	50	75	99	124	149	30	59	89	119	149	177
0.6	21	43	54	65	87	129	26	51	76	102	128	153	31	61	92	122	153	183

**How to use the EPA CT tables (cont.)**

- There are 7 sections for pH on each table
- Find the section that corresponds to your water's pH level
- If your pH is between the choices, then round up to the higher pH
  - Example: if pH of water is 6.8, use the pH 7.0 section

Oregon Health Services

**CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 10°C** *10°C - 14.9°C*

Chlorine Concentration (mg/L)	pH = 6						pH = 6.5						pH = 7.0					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	12	24	31	40	51	73	15	29	44	60	73	88	17	35	52	69	87	104
0.6	13	25	30	38	50	63	16	30	45	60	75	90	18	36	54	71	89	107
0.8	13	25	30	38	50	63	16	30	45	60	75	90	18	36	54	71	89	107
1	13	25	30	38	50	63	16	30	45	60	75	90	18	36	54	71	89	107
1.2	13	27	40	53	67	80	16	32	48	63	79	95	19	38	57	76	95	114
1.4	14	27	41	55	69	82	16	33	49	65	82	99	19	39	58	77	97	116
1.6	14	28	42	56	70	83	17	33	50	66	83	99	20	40	60	79	99	119
1.8	14	29	43	57	72	86	17	34	51	67	84	101	20	41	61	81	102	123
2	15	29	44	58	73	87	17	35	52	68	85	102	21	41	62	83	104	124
2.2	15	30	45	60	75	90	18	35	53	70	88	105	21	42	64	85	106	127
2.4	15	30	45	60	75	90	18	36	54	71	89	107	22	43	65	86	108	129
2.6	15	31	46	61	77	92	18	37	55	72	90	110	22	44	66	87	109	131
2.8	16	31	47	62	78	93	19	37	56	73	91	111	22	45	67	89	112	134
3	16	32	48	63	79	95	19	38	57	75	94	113	23	46	69	91	114	137

Chlorine Concentration (mg/L)	pH = 7.5						pH = 8.0						pH = 8.5					
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0
0.4	21	42	53	63	84	125	25	50	75	99	124	149	30	59	89	119	149	177
0.6	21	43	54	65	87	129	26	51	76	102	128	153	31	61	92	122	153	183

## How to use the EPA CT tables (cont.)

- Use the 0.5 log inactivation column if your plant is rated at 2.5 log removal for *Giardia*
- All others use the 1.0 log inactivation column
- Note: unfiltered surface water must achieve the 3-log inactivation through disinfection



CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 10°C

10°C - 14.9°C

Chlorine Concentration (mg/L)	pH = 6					pH = 6.5					pH = 7.0				
	0.5	1.0	1.5	2.0	2.5	0.5	1.0	1.5	2.0	2.5	0.5	1.0	1.5	2.0	2.5
0.4	12	24	37	49	61	15	29	44	58	73	19	35	52	69	87
0.6	13	25	38	50	63	16	30	45	60	75	20	36	54	71	89
0.8	13	25	38	50	63	16	31	46	61	77	21	37	55	73	92
1	13	25	40	53	66	16	31	47	63	79	21	37	55	73	92
1.2	13	27	40	53	67	16	32	48	63	79	21	37	55	73	92
1.4	14	27	41	55	68	16	33	49	65	82	21	38	56	74	93
1.6	14	28	42	56	69	17	33	50	66	83	21	38	57	76	95
1.8	14	28	43	57	72	17	34	51	67	84	21	39	58	77	96
2	15	29	44	58	73	17	35	52	69	87	21	41	62	83	104
2.2	15	30	45	60	75	18	35	53	70	88	21	42	64	85	106
2.4	15	30	45	60	75	18	36	54	71	89	22	43	65	86	108
2.6	15	31	46	61	77	18	37	55	72	92	22	44	66	87	109
2.8	16	31	47	62	78	19	37	56	74	93	22	45	67	89	112
3	16	32	48	63	79	19	38	57	75	94	23	46	69	91	114

Chlorine Concentration (mg/L)	pH = 7.5					pH = 8.0					pH = 8.5				
	0.5	1.0	1.5	2.0	2.5	0.5	1.0	1.5	2.0	2.5	0.5	1.0	1.5	2.0	2.5
0.4	21	42	63	83	104	25	50	75	99	124	30	59	89	118	148
0.6	21	43	64	85	107	26	51	76	100	125	31	61	92	122	153

## How to use the EPA CT tables (cont.)

- Match your free chlorine residual on the far left column
- If in between, then round up
  - Rounding chlorine residual up is more conservative because as chlorine residual increases at a given pH, more CT is required
- The point where it intersects with the log inactivation column is the CT required
  - Example: free chlorine residual is 0.6 ppm



CT VALUES FOR INACTIVATION OF GIARDIA CYSTS BY FREE CHLORINE AT 10°C

10°C - 14.9°C

Chlorine Concentration (mg/L)	pH = 6					pH = 6.5					pH = 7.0				
	0.5	1.0	1.5	2.0	2.5	0.5	1.0	1.5	2.0	2.5	0.5	1.0	1.5	2.0	2.5
0.4	12	24	37	49	61	15	29	44	58	73	19	35	52	69	87
0.6	13	25	38	50	63	16	30	45	60	75	20	36	54	71	89
0.8	13	25	38	50	63	16	31	46	61	77	21	37	55	73	92
1	13	25	40	53	66	16	31	47	63	79	21	37	55	73	92
1.2	13	27	40	53	67	16	32	48	63	79	21	37	55	73	92
1.4	14	27	41	55	68	16	33	49	65	82	21	38	56	74	93
1.6	14	28	42	56	69	17	33	50	66	83	21	38	57	76	95
1.8	14	28	43	57	72	17	34	51	67	84	21	39	58	77	96
2	15	29	44	58	73	17	35	52	69	87	21	41	62	83	104
2.2	15	30	45	60	75	18	35	53	70	88	21	42	64	85	106
2.4	15	30	45	60	75	18	36	54	71	89	22	43	65	86	108
2.6	15	31	46	61	77	18	37	55	72	92	22	44	66	87	109
2.8	16	31	47	62	78	19	37	56	74	93	22	45	67	89	112
3	16	32	48	63	79	19	38	57	75	94	23	46	69	91	114

Chlorine Concentration (mg/L)	pH = 7.5					pH = 8.0					pH = 8.5				
	0.5	1.0	1.5	2.0	2.5	0.5	1.0	1.5	2.0	2.5	0.5	1.0	1.5	2.0	2.5
0.4	21	42	63	83	104	25	50	75	99	124	30	59	89	118	148
0.6	21	43	64	85	107	26	51	76	100	125	31	61	92	122	153

## In review:

- temp of 12°C,
- pH of 6.8,
- free chlorine residual of 0.6
  - CT<sub>required</sub> = 36
- Remember...
  - CT<sub>achieved</sub> must be > CT<sub>required</sub>

(CT achieved = chlorine concentration x contact time)



## Exercise #5

- Using EPA CT tables to calculate CTs required



**Exercise #5: Using EPA CT tables to calculate CTs required**

**Directions:** Use the data provided in the examples below to determine the CTs required for giardia inactivation at the treatment plant for that day

**Example #1: Conventional filter plant (2.5-log)**

CT parameters measured at the 1<sup>st</sup> user as follows:  
 •Temperature: 10° C  
 •pH: 7.0  
 •Free chlorine residual: 0.8 ppm  
 •Contact time T: 100 minutes  
 What are the CTs required for that day? \_\_\_\_  
 What was the CT achieved? \_\_\_\_  
 Were CTs met? \_\_\_\_

**Example #3: Membrane filter plant (2.5-log)**

CT parameters measured at the 1<sup>st</sup> user as follows:  
 •Temperature: 8° C  
 •pH: 7.3  
 •Free chlorine residual: 1.3 ppm  
 •Contact time T: 100 minutes  
 What are the CTs required for that day? \_\_\_\_  
 What was the CT achieved? \_\_\_\_  
 Were CTs met? \_\_\_\_

**Example #2: Slow sand filter plant (2-log)**

CT parameters measured at the 1<sup>st</sup> user as follows:  
 •Temperature: 16° C  
 •pH: 6.6  
 •Free chlorine residual: 0.5 ppm  
 •Contact time T: 46 minutes  
 What are the CTs required for that day? \_\_\_\_  
 What was the CT achieved? \_\_\_\_  
 Were CTs met? \_\_\_\_



**Exercise #5: Using EPA CT tables to calculate CTs required**

**Directions:** Use the data provided in the examples below to determine the CTs required for giardia inactivation at the treatment plant for that day

**Example #1: Conventional filter plant (2.5-log)**

CT parameters measured at the 1<sup>st</sup> user as follows:  
 •Temperature: 10° C  
 •pH: 7.0  
 •Free chlorine residual: 0.8 ppm  
 •Contact time T: 100 minutes  
 What are the CTs required for that day? **18**  
 What was the CT achieved? **80**  
 Were CTs met? **Yes**

**Example #3: Membrane filter plant (2.5-log)**

CT parameters measured at the 1<sup>st</sup> user as follows:  
 •Temperature: 8° C  
 •pH: 7.3  
 •Free chlorine residual: 1.3 ppm  
 •Contact time T: 100 minutes  
 What are the CTs required for that day? **31**  
 What was the CT achieved? **130**  
 Were CTs met? **Yes**

**Example #2: Slow sand filter plant (2-log)**

CT parameters measured at the 1<sup>st</sup> user as follows:  
 •Temperature: 16° C  
 •pH: 6.6  
 •Free chlorine residual: 0.5 ppm  
 •Contact time T: 46 minutes  
 What are the CTs required for that day? **24**  
 What was the CT achieved? **23**  
 Were CTs met? **No**



**Bonus:** Use the data provided in the examples below to determine the CTs required for virus inactivation at the treatment plant for that day

Temperature (C) pH<= 6.9	Log Inactivation			
	2.0-log	3.0-log	4.0-log	5.0-log
0.5	6	45	9	66
5	4	30	6	44
10	3	22	4	33
15	2	15	3	22
20	1	11	2	15
25	1	7	1	11

CT parameters measured at the 1<sup>st</sup> user as follows:  
 •Temperature: 10° C  
 •pH: 7.0

What log inactivation is required for viruses in surface water? \_\_\_\_

What are the CTs required for viruses that day? \_\_\_\_

Assuming a contact time T of 30 minutes, what free chlorine concentration is needed to meet the CT required above? \_\_\_\_

What does this tell you about meeting the CT requirements for viruses compared to meeting the CT requirements for giardia? \_\_\_\_



**Bonus:** Use the data provided in the examples below to determine the CTs required for virus inactivation at the treatment plant for that day

Temperature (C) pH<= 6.9	Log Inactivation			
	2.0-log	3.0-log	4.0-log	5.0-log
0.5	6	45	9	66
5	4	30	6	44
10	3	22	4	33
15	2	15	3	22
20	1	11	2	15
25	1	7	1	11

CT parameters measured at the 1<sup>st</sup> user as follows:  
 •Temperature: 10° C  
 •pH: 7.0

What log inactivation is required for viruses in surface water? **4.0-log**

What are the CTs required for viruses that day? **6**

Assuming a contact time T of 30 minutes, what free chlorine concentration is needed to meet the CT required above? **0.2 ppm**

What does this tell you about meeting the CT requirements for viruses compared to meeting the CT requirements for giardia? **If you meet CT requirements for giardia, then you automatically meet them for viruses (i.e. it takes more CTs to inactivate Giardia than it does for viruses)**



**Filling out the monthly surface water quality report form**

**OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>a</sup> [ppm or mg/L]	Contact Time (T) <sup>b</sup> [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>c</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /								
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

So here's our reporting form (available for download on our website...)  
 Every day you must calculate the CTs required using the tables and record it on this form.  
 So let's enter our data from the example into the form starting w/ temp...



**OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>a</sup> [ppm or mg/L]	Contact Time (T) <sup>b</sup> [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>c</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /				12				
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

Here's where we enter temp




OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

System Name: ID #: WTP: Month/Year: Log Requirement (Circle One) 5.3 / 1.6

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>2</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /				12	6.8			
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

Here's where we enter pH




OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

System Name: ID #: WTP: Month/Year: Log Requirement (Circle One) 5.3 / 1.6

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>2</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6			12	6.8			
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

Here's where we enter free chlorine residual




OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

System Name: ID #: WTP: Month/Year: Log Requirement (Circle One) 5.3 / 1.6

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>2</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6			12	6.8	36		
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

And here's where we enter CT required 36, which we found from the EPA tables




OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

System Name: ID #: WTP: Month/Year: Log Requirement (Circle One) 5.3 / 1.6


Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>2</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6			12	6.8	36		
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

OK. We now we need to calculate the actual CTs achieved and compare it to the CTs required of 36 to determine if CTs were met for the day.



## Filling out the monthly surface water quality report (cont.)

- Remember:
  - CT achieved = Chlorine Concentration x Contact Time
- We know the free chlorine residual at the first user is 0.6 ppm
- Contact Time (T) obtained from a disinfection tracer study
  - Example: tracer study shows our contact time to be 110 minutes




OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

System Name: ID #: WTP: Month/Year: Log Requirement (Circle One) 5.3 / 1.6

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup> [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>2</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6	110		12	6.8	36		
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								


Here's where we enter contact time T from our tracer study



OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

System Name:		ID #:	WTP:	Month/Year:	Log Requirement (State Oes) 8.3 / 1.8			
Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup> [ppm or mg/L]	Contact Time (T) <sup>2</sup> [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6	110		12	6.8	36		
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								


So free chlorine residual C of 0.6 ppm times 110 minutes of contact time T = ?



OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

System Name:		ID #:	WTP:	Month/Year:	Log Requirement (State Oes) 8.3 / 1.8			
Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup> [ppm or mg/L]	Contact Time (T) <sup>2</sup> [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6	110	66	12	6.8	36		
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								


CT achieved by the plant is 66. So now we compare this to CT required.



OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

System Name:		ID #:	WTP:	Month/Year:	Log Requirement (State Oes) 8.3 / 1.8			
Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup> [ppm or mg/L]	Contact Time (T) <sup>2</sup> [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6	110	66	12	6.8	36		
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								


In order for CTs to be met, C<sub>actual</sub> must be greater than C<sub>required</sub>, which it is.



OHA - Drinking Water Program – Surface Water Quality Data Form - Giardia Inactivation

System Name:		ID #:	WTP:	Month/Year:	Log Requirement (State Oes) 8.3 / 1.8			
Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>1</sup> [ppm or mg/L]	Contact Time (T) <sup>2</sup> [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? <sup>3</sup> Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6	110	66	12	6.8	36	Yes	
2 /								
3 /								
4 /								
5 /								
6 /								
7 /								
8 /								
9 /								
10 /								
11 /								
12 /								
13 /								
14 /								
15 /								
16 /								
17 /								
18 /								
19 /								

So in the CT MET column we write YES. CTs were met for this day.



### Common mistakes:

- Rounding errors:
  - Must round down for temperature
  - Must round up for pH
  - Must round up for free chlorine residual
- Bad formulas in excel spreadsheets:
  - Make sure you understand your formula
  - Wilkes Equation not allowed, must use Regression Equation



### Common mistakes (continued):

- Not calculating CT's daily
  - Don't wait until the end of the month to do the calculations because if you discover you didn't meet CT's, it's too late!
- If adjusting contact time according to flow rate, use the demand flow, not the plant flow.
- Failure to answer questions at bottom of form correctly (or at all)
- Always answering "Yes" to the questions at the bottom of the form without actually looking at the numbers





## Conventional or Direct: Answer all the yes/no questions

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residuals at entry point ≥ 0.2 mg/l? <b>Yes / No</b>
All the 4-hour turbidity readings ≤ 1 NTU? <b>Yes / No</b>		
All turbidity readings < IFE* triggers? <b>Yes / No</b> ?		
Notes:		
PRINTED NAME:		
SIGNATURE:		DATE:
PHONE #: ( )		CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "9 PM" may not correspond to continuous readings\* maximum. \*Filtered systems only.

PAGE 1 of 2



## Slow Sand/Membrane/DE/Unfiltered

Answer all the yes/no questions

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes / No</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes / No</b>		
Notes:		
PRINTED NAME:		
SIGNATURE:		DATE:
PHONE #: ( )		CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "9 PM" may not correspond to continuous readings\* maximum. \*Filtered systems only.

PAGE 1 of 2



## Cartridge/Bag Answer all the yes/no questions

Cartridge Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes / No</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes / No</b>		
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		
PRINTED NAME:		
SIGNATURE:		DATE:
PHONE #: ( )		CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings\* maximum.

PAGE 1 of 2



## Everyone needs to fill out the CT section!

Cartridge Filtration	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes / No</b>
All daily turbidity readings ≤ 5 NTU? <b>Yes / No</b>		
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		
PRINTED NAME:		
SIGNATURE:		DATE:
PHONE #: ( )		CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings\* maximum.

PAGE 1 of 2



## Multiple CT segments


- A "CT segment" is the point between which chlorine is injected and free chlorine residual is measured
- Treatment plants can have multiple CT segments (i.e. multiple chlorine injection points)
- Multiple CT segments can be added together in order to meet CTs
- Do not add contact times "T" together!
  - Why? Chlorine, temp, pH may change throughout the process



## Multiple CT segments (cont.)

- Must calculate log inactivation ratios for each segment and add ratios together
  - Inactivation ratio =  $\frac{C1T1_{actual}}{CT1_{reqd}} + \frac{C2T2_{actual}}{CT2_{reqd}}$
- Modify reporting form: add column for log inactivation ratios (sum must be >1)
  - Not to be confused with 1-log inactivation





### What to do when things go wrong:

Such as:

- Treatment interruptions
- CTs not met
- Turbidity exceeds regulatory limits

What to do:

- Call your regulatory contact at the drinking water program
- Check out the BMPs on the DWS website in the "Water System Operations" section



### In Summary:

- In order to verify adequate disinfection is taking place, we need to calculate CT achieved ( $CT_{actual}$ )
- EPA reviewed many disinfection studies in order to create CT Tables that specify minimum CT requirements needed to achieve specific log reduction levels for *Giardia* ( $CT_{required}$ )
- $CT_{actual}$  must be equal to or greater than  $CT_{required}$



### Things you should do:

- Check how T is calculated at your plant
- Do all treatment plant operators understand it?
- Review spreadsheet equation for CTs (if applicable)
- Write an SOP for CT determination
- Arrange for a tracer study if necessary



### Exercise #6

- Filling out the monthly surface water quality operating report




### Exercise #6: Filling out the monthly surface water report

#### Example #1: Conventional or direct filter plant

#### Turbidity


- Use the data in the graph to record the 4-hour daily turbidities on the first day of the month of the Conventional/Direct Filtration monthly reporting form.
- What number should be entered in the "Highest Reading of the Day (NTU)" column?



**Exercise #6: Filling out the monthly surface water report Example #1:**  
**Conventional or direct filter plant**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day <sup>a</sup> [NTU]
1	0.05	0.07	0.08	0.07	0.15	0.28	0.35

Conventional/Direct TP: Turbidity vs. Time



**Exercise #6: Filling out the monthly surface water report**

**Example #1: Conventional or direct filter plant**

**Turbidity**

•Let's say your plant runs 24 hours a day and you have turbidity readings filled in for every 4-hour interval for all 31 days of the month. How many readings could you have that were > 0.3 NTU? (95% of readings should be ≤ 0.3 NTU)

•What should you do if you answer "no" to the turbidity question "All readings ≤ 1 NTU?" on the bottom of the form?

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c

•What should you do if you answer "no" to the turbidity question "All readings < IFE triggers?" on the bottom of the form?

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c



**Exercise #6: Filling out the monthly surface water report**

**Example #1: Conventional or direct filter plant**

**Turbidity**

•Let's say your plant runs 24 hours a day and you have turbidity readings filled in for every 4-hour interval for all 31 days of the month. How many readings could you have that were > 0.3 NTU and still meet the requirement of 95% of readings being ≤ 0.3 NTU?

**You could have 9 readings above 0.3 NTU  
 (6 readings/day x 31 days = 186 readings total. 5% x 186 = 9.3)**

•What should you do if you answer "no" to the turbidity question "All readings ≤ 1 NTU?" on the bottom of the form? **a**

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c

•What should you do if you answer "no" to the turbidity question "All readings < IFE triggers?" on the bottom of the form? **a**

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c



**Exercise #6: Filling out the monthly surface water report**

**Example #1: Conventional or direct filter plant**

**CT Calculations (assume 2.5-log conventional plant)**

•Use the following parameters to calculate the CTs achieved at the plant and fill it in on the form on first day of the month:

Free chlorine residual: 0.6 ppm  
 Contact time: 100 minutes

•Use the following parameters to calculate the CTs required using the EPA tables from Exercise 5 and fill it in on the form:

Temp: 12°C  
 pH: 7.2

•Are CTs met at the plant for this day?



**Exercise #6:**  
**Example #1: Conventional or direct filter plant CT Calculations**  
**(assume 2.5-log conventional plant)**

•Use the following parameters to calculate the CTs achieved at the plant and fill it in on the form on first day of the month:

Free chlorine residual: 0.6 ppm Contact time: 100 minutes

•Use the following parameters to calculate the CTs required using the EPA tables from Exercise 5 and fill it in on the form:

Temp: 12°C pH: 7.2

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) [ppm or mg/L]	Contact Time (T) [min]	Actual CT C x T	Temp [°C]	pH	Required CT	CT Met? Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.6	100	60	12	7.2	21	Yes	2000

•Are CTs met at the plant for this day? **Yes**  
**CT achieved (60) > CT required (21)**



**Exercise #6:**

**Example #1: Conventional or direct filter plant**  
**CT Calculations (assume 2.5-log conventional plant)**

•Let's say the Peak Hourly Demand Flow for the day was 2000 gpm. If the Peak Hourly Demand Flow during the tracer study was 1750 gpm, is this a problem? Why or why not?

•What should you do if you answer "no" to either of the CT questions on the turbidity side of form?

•"CTs met at all times?"

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c

•"Residual at EP ≥ 0.2 ppm at all times?"

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c



**Exercise #6:**

**Example #1: Conventional or direct filter plant**

**CT Calculations (assume 2.5-log conventional plant)**

•Let's say the Peak Hourly Demand Flow for the day was 2000 gpm. If the Peak Hourly Demand Flow during the tracer study was 1750 gpm, is this a problem? Why or why not?  
**Yes this is a problem – flow cannot exceed 10% of tracer study flow.  $10\% \times 1750 \text{ gpm} = 175 \text{ gpm}$ .  $1750 + 175 = 1925 \text{ gpm}$ . Therefore flow cannot be  $>1925 \text{ gpm}$  or else a new tracer study is needed.**

•What should you do if you answer "no" to either of the CT questions on the turbidity side of form?

•"CTs met at all times?" **a**

- a. Call the state
- b. Issue a boil water notice
- c. Issue a public notice within 30 days
- d. Both a & c

•"Residual at EP  $\geq 0.2$  ppm at all times?" **a**

- a. Call the state
- b. Issue a boil water notice
- c. Issue a public notice within 30 days
- d. Both a & c



**Example #2: Slow sand, Membrane, or DE filter plant (2-log) Turbidity**

•Use the data in the graph to record the daily CFE turbidity on the first day of the month of the Slow Sand/Membrane/DE Filtration monthly reporting form. Which 4-hour column should it be recorded in? Why?

•What number should be entered in the "Highest Reading of the Day (NTU)" column?

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1							
2							



**Example #2: Slow sand, Membrane, or DE filter plant (2-log) Turbidity**

•Use the data in the graph to record the daily CFE turbidity on the first day of the month of the Slow Sand/Membrane/DE Filtration monthly reporting form. Which 4-hour column should it be recorded in? Why?  
**Any of the columns is fine to use. Most people use the column that is closest to the time they observed the turbidity.**

•What number should be entered in the "Highest Reading of the Day (NTU)" column? **1.2 NTU**

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day [NTU]
1			0.2				1.2
2							



**Example #2: Slow sand, Membrane, or DE filter plant (2-log) Turbidity**

•Let's say your plant runs everyday and you have turbidity readings filled in once a day for all 31 days of the month. How many readings could you have that were  $> 1$  NTU and still meet the requirement of 95% of readings being  $\leq 1$  NTU?

•What should you do if you answer "no" to the turbidity question "All readings  $\leq 5$  NTU?" on the bottom of the form?

- a. Call the state
- b. Issue a boil water notice
- c. Issue a public notice within 30 days
- d. Both a & c



**Example #2: Slow sand, Membrane, or DE filter plant (2-log) Turbidity**

•Let's say your plant runs everyday and you have turbidity readings filled in once a day for all 31 days of the month. How many readings could you have that were  $> 1$  NTU and still meet the requirement of 95% of readings being  $\leq 1$  NTU?  
**Only 1 (5% of 31 readings = 1.6)**

•What should you do if you answer "no" to the turbidity question "All readings  $\leq 5$  NTU?" on the bottom of the form? **a**

- a. Call the state
- b. Issue a boil water notice
- c. Issue a public notice within 30 days
- d. Both a & c



**Example #2: Slow sand, Membrane, or DE filter plant (2-log) CT Calculations**

•Use the following parameters to calculate the CTs achieved at the plant and fill it in on the form on first day of the month:

Free chlorine residual: 0.3 ppm  
 Contact time: 60 minutes

•Use the following parameters to calculate the CTs required using the EPA tables from Exercise 5 and fill it in on the form:

Temp: 9°C  
 pH: 7.8

•Are CTs met at the plant for this day?



**Example #2: Slow sand, Membrane, or DE filter plant (2-log)  
CT Calculations**

•Use the following parameters to calculate the CTs achieved at the plant and fill it in on the form on first day of the month:  
Free chlorine residual: 0.3 ppm  
Contact time: 60 minutes



•Use the following parameters to calculate the CTs required using the EPA tables from Exercise 5 and fill it in on the form:  
Temp: 9°C  
pH: 7.8

•Are CTs met at the plant for this day? **No - CT achieved (18) is < CT required (66)**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.3	60	18	9	7.8	66	No	

**Example #2: Slow sand, Membrane, or DE filter plant (2-log)  
CT Calculations**

•What number should be entered in the "Peak Hourly Demand Flow" column?



**Example #2: Slow sand, Membrane, or DE filter plant (2-log)  
CT Calculations**

•What number should be entered in the "Peak Hourly Demand Flow" column? **3300 gpm. Average of flows between 7 am and 8 am.**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT C X T	Temp [° C]	pH	Required CT Use tables	CT Met? Yes / No	Peak Hourly Demand Flow [GPM]
1 /	0.3	60	18	9	7.8	66	No	3300

**Example #2: Slow sand, Membrane, or DE filter plant (2-log)  
CT Calculations**

•What should you do if you answer "no" to either of the CT questions on the turbidity side of form?

"CTs met at all times?"

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c

"Residual at EP ≥ 0.2 ppm at all times?"

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c

**Example #2: Slow sand, Membrane, or DE filter plant (2-log)  
CT Calculations**

•What should you do if you answer "no" to either of the CT questions on the turbidity side of form?

"CTs met at all times?" **a**

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c

"Residual at EP ≥ 0.2 ppm at all times?" **a**

- Call the state
- Issue a boil water notice
- Issue a public notice within 30 days
- Both a & c

## Emerging Issues



## Emerging Issues

- Climate change and water supply
- Harmful algae blooms
- [www.healthoregon.org/dwp](http://www.healthoregon.org/dwp)

News & "Hot Topics"



## Climate Change and Water Supply

- Earlier and heavier snowpack runoff
- Increasing variability of storm frequency and intensity
- Weather extremes already evident (drought in some States, heavy rain/flooding in others 2011-2012)
- Increased variability in water quality; can affect both surface and groundwater systems.
- Changes in rainfall patterns affect all systems
- Rising sea levels could lead to salt water intrusion or flooding




## Harmful algae blooms

- Produce toxins that can be harmful
- Occur in warm, slow moving water
- Increasing in frequency and duration
  - happening more or better reporting?
  - more people, more nutrients, warmer water
- Best management practices on our website
- <http://public.health.oregon.gov/HealthyEnvironm ents/DrinkingWater/Operations/Treatment/Pages /algae.aspx>



## [www.healthoregon.org/dwp](http://www.healthoregon.org/dwp)

- News
- Hot Topics



## RESOURCES FOR OPERATORS



## Tools & Resources

- For surface water systems: [www.healthoregon.org/dwp](http://www.healthoregon.org/dwp)
- Click on "Water System Operations" on left-side menu list, then "Surface Water Treatment"
  - Monthly Surface Water Quality Report form template
  - Tracer Study form
- Surface Water Treatment Rule guidance manual, Appendix C: Determination of Disinfectant Contact Time



## Tools & Resources (continued)

- EPA Rules <http://water.epa.gov/lawsregs/rulesregs/sdwa/currenregulations.cfm>
- AWWA <http://www.pnws-awwa.org>
- OAWU <http://www.oawu.net/>
- Circuit Rider <http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Operations/Pages/circuitrider.aspx>



## QUESTIONS?

- Call your technical services contact at the State.
- State Drinking Water Services
  - General Info: (971) 673-0405



## Information Available Online

[www.healthoregon.org/dwp](http://www.healthoregon.org/dwp)



- "Drinking Water Data Online" (data specific to each water system)
- Contact Us
- Current News and Events

Information By Subject



## Information By Subject

- Drinking Water
  - County & Dept of Agriculture Resources
  - Cross Connection & Backflow Prevention
  - Emergency Preparedness & Security
  - Groundwater & Source Water Protection
  - Monitoring & Reporting
  - Operator Certification
  - Plan Review
  - Rules & Implementation Guidance
  - Drinking Water State Revolving Fund
  - Water System Operations
  - Advisory Committee
  - Annual Compliance Reporting
- Surface Water Treatment
  - Public Notice Resources & Templates
  - Fact Sheets & Best Management Practices
  - Outstanding Performance
  - Circuit Rider Program
  - Pipeline Newsletter

1. Cross Connection & Backflow Info
2. Emergency Preparedness & Security
3. GW & Source Water Protection
4. Monitoring & Reporting
5. Operator Certification
6. Plan Review
7. Rules & Implementation Guidance
8. SDW Revolving Loan Fund
9. Water System Operations
  - Surface Water Treatment
  - Public Notice Resources
  - Fact Sheets & Best Practices
  - Outstanding Performance
  - Circuit Rider Program
  - Pipeline Newsletter

Information By Subject



## Drinking Water Data Online

Many data search options are available



- Data Search Options
- Info by County
- Info by Water System



## Find Your Water System

### WS Name Look Up

Oregon Public Health  
**Drinking Water Data Online**

Introduction :: Data Search Options :: **WS Name Look Up** :: WS ID Look Up :: DWS Home

Welcome to SDWIS Data Online

Water System Name Search:

Type in a part of the water system's name (like Area to find the City of Bend or Broadhead Post Office, or Area to find USFS Blackhawk Campground) below.

Notes:  
Names or parts of names that include & or ' may not be easily found. So, in those cases, enter the whole name or a part of the name that doesn't include & or '  
The word "and" should be entered in YAO.

From:  Submit Query

1. Select WS Name Look Up
2. Enter water system name (e.g., "Salem")
3. Click Submit Query

**Note:** You also could have used **WS ID Look Up** and entered the ID# for Salem (00731)

Oregon Health  
Naturally

## Select Your Water System

Select the Water System by  
Clicking on the PWS ID#

Oregon Public Health  
**Drinking Water Data Online**

Introduction :: Data Search Options :: WS Name Look Up :: **WS ID Look Up** :: DWS Home

Click on the PWS ID number of your water system to begin the search for information

PWS ID # 41....	Water System
05564	BPA-SALEM SUBSTATION
00779	SALEM MOBILE ESTATES SHADY ACRES
<b>00731</b>	<b>SALEM PUBLIC WORKS</b>
00768	SUBURBAN EAST SALEM WD

Oregon Health  
Naturally

Oregon Public Health  
**Drinking Water Data Online**

Introduction :: Data Search Options :: WS Name Look Up :: WS ID Look Up :: DWS Home :: **Quick Data Links**

**OR41 00731 SALEM PUBLIC WORKS** Classification: COMMUNITY

Contact: FRANCIS KESSLER Phone: 503-361-2220  
1410 20TH ST SE BLDG 2 County: MARION  
SALEM, OR 97302 Activity Status: ACTIVE - History

Population: 199,000  
Operating Period: January 1 to December 31  
Regulating Agency: REGION 1  
Owner Type: LOCAL GOVERNMENT  
Certs: Oregon (971) 873-0410

Number of Connections: 51,112  
Regulating Agency: REGION 1  
Owner Type: LOCAL GOVERNMENT  
Certs: Oregon (971) 873-0410

Required Y  
Distribution class: 4  
Treatment class: 3  
Filtration Endorsement Required: No

Approved Drinking Water Protection Plan: No  
Source Water Assessment: Yes  
Last Survey Date: Aug 23, 2011

### Sources

Facility ID	Facility Name - Well Log	Activity Status	Availability	Source Type
EP-A	EP FOR GEREN ISLAND (ALDERSGATE)	A	Permanent	SW
SRC-AA	NORTH SANTIAM RIVER	A	Seasonal	GU
SRC-AB	GEREN ISLAND EAST WELL - L75842	A	Seasonal	GU
SRC-AC	GEREN ISLAND WEST WELL - L75839	A	Seasonal	GU
SRC-AD	INFILTRATION GALLERY	A	Seasonal	GU
EP-B	EP FOR ASR WELLS	A	Seasonal	GW
SRC-BA	ASR WELL #1 - MAR19024	A	Seasonal	GW
SRC-BB	ASR WELL #2 - MAR190075	A	Seasonal	GW
SRC-BC	ASR WELL #4 - L10522	A	Seasonal	GW
SRC-BD	ASR WELL #6 - L10542	A	Seasonal	GW
EP-C	EP FOR HEMLOCK WELL	I	Seasonal	GW
SRC-CA	HEMLOCK WELL - L42090	I	Emergency	GW

### Treatment

State ID	Facility Name	Treatment Process	Treatment Objective	Filter Type
WTP-A	TP FOR GEREN ISLAND	FILTRATION, SLOW SAND	PARTICULATE REMOVAL	SS
WTP-A	TP FOR GEREN ISLAND	FLUORIDATION	OTHER	SS
WTP-A	TP FOR GEREN ISLAND	PHALKA ADJ-SODA ASH	CORROSION CONTROL	SS
WTP-A	TP FOR GEREN ISLAND	HYPOCHLORINATION, POST	DISINFECTION	SS
WTP-B	TP FOR ASR WELLS	RESID. MAINT. HYPOCHLORINATION	OTHER	

Oregon Health  
Naturally

## General Information

System Classification

**OR41 00731 SALEM PUBLIC WORKS** Classification: COMMUNITY

Contact: FRANCIS KESSLER Phone: 503-361-2220  
1410 20TH ST SE BLDG 2 County: MARION  
SALEM, OR 97302 Activity Status: ACTIVE - History

Population: 199,000  
Operating Period: January 1 to December 31  
Regulating Agency: REGION 1  
Owner Type: LOCAL GOVERNMENT  
Certs: Oregon (971) 873-0410

Number of Connections: 51,112  
Regulating Agency: REGION 1  
Owner Type: LOCAL GOVERNMENT  
Certs: Oregon (971) 873-0410

Required Y  
Distribution class: 4  
Treatment class: 3  
Filtration Endorsement Required: No

Approved Drinking Water Protection Plan: No  
Source Water Assessment: Yes  
Last Survey Date: Aug 23, 2011

**Certified Operators**

View a list of Certified Operators

All written correspondence goes to this person (e.g., violation notices, general mailings, etc.)

Oregon Health  
Naturally

## Sources

### Well Log Query Results

Well Tag Nbr: 75842

Well Log	T-R-S/ Q-Q-Q	Street or Trunk
MARI_08133		

Facility ID Facility Name - Well Log

EP-A EP FOR GEREN ISLAND WTP

SRC-AA NORTH SANTIAM RIVER

SRC-AB GEREN ISLAND EAST WELL - L75842

SRC-AC GEREN ISLAND WEST WELL - L75839

SRC-AD INFILTRATION GALLERY

Clicking on a Well ID allows you to view well logs and data from the Oregon Water Resources Department

Oregon Health  
Naturally

## Treatment

### Treatment Process

State ID	Facility Name	Treatment Process	Treatment Objective	Filter Type
WTP-A	TP FOR GEREN ISLAND	FILTRATION, SLOW SAND	PARTICULATE REMOVAL	SS
WTP-A	TP FOR GEREN ISLAND	FLUORIDATION	OTHER	SS
WTP-A	TP FOR GEREN ISLAND	PHALKA ADJ-SODA ASH	CORROSION CONTROL	SS
WTP-A	TP FOR GEREN ISLAND	HYPOCHLORINATION, POST	DISINFECTION	SS
WTP-B	TP FOR ASR WELLS	RESID. MAINT. HYPOCHLORINATION	OTHER	

Filter Type:  
SS = Slow Sand  
CT = Cartridge  
BG = Bag  
CF = Conventional Filtration  
DF = Direct Filtration  
MF = Membrane Filtration  
UF = Unfiltered

Oregon Health  
Naturally



## Sampling Schedules

For further information on this public water system, click on the area of interest below.

System Info - Report for Lenders - Alerts - Violations - Enforcements - Contacts - Site Visits - Public Notice - Plan Review

Coliform Summary - Coliform Results - Sampling Schedule for Coliform - Groundwater/GWUDI Source Details

Chemical Group Summary - Latest Chemical Results - Entry Point Detects - Single Analyte Results

Chemical Schedule Summary - Chemical Schedule Details

Lead & Copper - Corrosion Control (LCR) - Nitrate - Arsenic - Radionuclides - GWR 4-Log

DBPs - TOC & Alkalinity - DBP Sample Sites - FANLs - MRDL - Turbidity - SWTR - RAA - LRAA

**Sampling Schedules:**

1. Sampling Schedule for Coliform
  - Includes repeat schedules
2. Chemical Schedule Summary
  - Required chemical sampling
3. Chemical Schedule Details - progress report on chemical sampling
4. Lead & Copper
  - clicking "More Info" at the bottom of the tap sample results allows you to see tap sample schedules, minimum water quality parameters to meet, and major milestones

## Sampling Data

For further information on this public water system, click on the area of interest below.

System Info - Report for Lenders - Alerts - Violations - Enforcements - Contacts - Site Visits - Public Notice - Plan Review

Coliform Summary - Coliform Results - Sampling Schedule for Coliform - Groundwater/GWUDI Source Details

Chemical Group Summary - Latest Chemical Results - Entry Point Detects - Single Analyte Results

Chemical Schedule Summary - Chemical Schedule Details

Lead & Copper - Corrosion Control (LCR) - Nitrate - Arsenic - Radionuclides - GWR 4-Log

DBPs - TOC & Alkalinity - DBP Sample Sites - FANLs - MRDL - Turbidity - SWTR - RAA - LRAA

1. Coliform Summary (by month)
2. Coliform Results (by sample, results before 2002)
3. Chemical Group Summary (VOC, SOC)
4. Latest Chemical Results (individual contaminants)
5. Latest Chemical Results (sorted by date)
6. Entry Point Detects (detections only)
7. Single Analyte Results (individual contaminants)
8. Lead & Copper & Corrosion Control (L&C, pH, etc.)
9. Nitrates, Arsenic, Radionuclides, DBPs, TOC & Alkalinity
10. Turbidity (maximum daily turbidity)
11. SWTR (results from the bottom of the monthly SW report)
12. RAA & LRAA (DBP running annual average results)

## Alerts, Contacts & Site Visits

For further information on this public water system, click on the area of interest below.

System Info - Report for Lenders - Alerts - Violations - Enforcements - Contacts - Site Visits - Public Notice - Plan Review

Coliform Summary - Coliform Results - Sampling Schedule for Coliform - Groundwater/GWUDI Source Details

Chemical Group Summary - Latest Chemical Results - Entry Point Detects - Single Analyte Results

Chemical Schedule Summary - Chemical Schedule Details

Lead & Copper - Corrosion Control (LCR) - Nitrate - Arsenic - Radionuclides - GWR 4-Log

DBPs - TOC & Alkalinity - DBP Sample Sites - FANLs - MRDL - Turbidity - SWTR - RAA - LRAA

1. Alerts - Sample results that require State/County/Dept of Ag staff to respond
2. Contacts - Document alert follow-ups and other significant correspondence
3. Site Visits - Document surveys and treatment plant inspections

## Violations, Enforcements & Public Notices

For further information on this public water system, click on the area of interest below.

System Info - Report for Lenders - Alerts - Violations - Enforcements - Contacts - Site Visits - Public Notice - Plan Review

Coliform Summary - Coliform Results - Sampling Schedule for Coliform - Groundwater/GWUDI Source Details

Chemical Group Summary - Latest Chemical Results - Entry Point Detects - Single Analyte Results

Chemical Schedule Summary - Chemical Schedule Details

Lead & Copper - Corrosion Control (LCR) - Nitrate - Arsenic - Radionuclides - GWR 4-Log

DBPs - TOC & Alkalinity - DBP Sample Sites - FANLs - MRDL - Turbidity - SWTR - RAA - LRAA

1. Violations
  - Also shows related enforcement actions
  - Systems should strive to see "Returned to Compliance"
  - System score should be less than 11 and as close to 0 as possible
2. Enforcements
  - View pdf copies of original Administrative Orders and Bilateral Compliance Agreements as well as their status
3. Public Notice
  - Notices required
  - Notices delivered

## Plan Review Information

For further information on this public water system, click on the area of interest below.

System Info - Report for Lenders - Alerts - Violations - Enforcements - Contacts - Site Visits - Public Notice - Plan Review

Coliform Summary - Coliform Results - Sampling Schedule for Coliform - Groundwater/GWUDI Source Details

Chemical Group Summary - Latest Chemical Results - Entry Point Detects - Single Analyte Results

Chemical Schedule Summary - Chemical Schedule Details

Lead & Copper - Corrosion Control (LCR) - Nitrate - Arsenic - Radionuclides - GWR 4-Log

DBPs - TOC & Alkalinity - DBP Sample Sites - FANLs - MRDL - Turbidity - SWTR - RAA - LRAA

1. Project ID and Name
2. Date Plans Received
3. Date Preliminary Approval was Granted (no conditions)
4. Date Conditional Approval was Granted (required items not shown on submitted plans)
5. Date Abandoned (project was not completed)
6. Final Approval Date (approval for use)
7. Reviewer (initials of State staff engineer reviewing the plans)

## System Info & Report For Lenders

For further information on this public water system, click on the area of interest below.

System Info - Report for Lenders - Alerts - Violations - Enforcements - Contacts - Site Visits - Public Notice - Plan Review

Coliform Summary - Coliform Results - Sampling Schedule for Coliform - Groundwater/GWUDI Source Details

Chemical Group Summary - Latest Chemical Results - Entry Point Detects - Single Analyte Results

Chemical Schedule Summary - Chemical Schedule Details

Lead & Copper - Corrosion Control (LCR) - Nitrate - Arsenic - Radionuclides - GWR 4-Log

DBPs - TOC & Alkalinity - DBP Sample Sites - FANLs - MRDL - Turbidity - SWTR - RAA - LRAA

1. System Info
  - Main water system information page (already covered)
2. Report for Lenders
  - Provides proof that the water supply is under regulatory oversight
  - Satisfies lending institutions