
Putting Forms Into Practice



Drinking Water Services Silver Falls Conference April 18, 2018



Situations where forms are needed?

- Coliform investigations
- Chemical detections & MCLs
- Inventory changes
- Water system surveys









Coliform investigations

Sample Date	# Samples	Sample Type	Coliform Type	ResultsID	Repeat of Sample ID	Sample Site	Facility	CI Residual
Oct 19, 2017	1	RP	Total	POSITIVE1764040	1763524	SAMPLE STATION #1	DIST-A	
		RP	E.coli	Absent1764040	1763524	SAMPLE STATION #1	DIST-A	
Oct 19, 2017	1	RP	Total	POSITIVE1764039	1763524	SAMPLE STATION #4	DIST-A	
		RP	E.coli	Absent1764039	1763524	SAMPLE STATION #4	DIST-A	
Oct 18, 2017	1	RT	Total	POSITIVE1763525		OTTER RUN SS #2	DIST-A	
		RT	E.coli	Absent1763525		OTTER RUN SS #2	DIST-A	
Oct 18, 2017	1	RT	Total	POSITIVE1763524		WOOD AVE SS #4	DIST-A	
		RT	E.coli	Absent1763524		WOOD AVE SS #4	DIST-A	
Sep 20, 2017	1	TG	Total	Absent17-56113	1755093	RUESSE WELL	SRC-BA	
Sep 20, 2017	1	TG	Total	Absent17-56112	1755093	SCHOOL WELL	SRC-AA	
Sep 20, 2017	1	RP	Total	POSITIVE1756116	1755093	SAMPLE STATION #1	DIST-A	
		RP	E.coli	POSITIVE1756116	1755093	SAMPLE STATION #1	DIST-A	
Sep 20, 2017	1	RP	Total	POSITIVE1756115	1755093	SAMPLE STATION #2	DIST-A	
		RP	E.coli	Absent1756115	1755093	SAMPLE STATION #2	DIST-A	
Sep 20, 2017	1	RP	Total	POSITIVE1756114	1755093	SAMPLE STATION #3	DIST-A	
		RP	E.coli	POSITIVE1756114	1755093	SAMPLE STATION #3	DIST-A	
Sep 18, 2017	1	RT	Total	POSITIVE1755093		STATION #3	DIST-A	
		RT	E.coli	Absent1755093		STATION #3	DIST-A	



Coliform investigations forms

- Evaluate WS facilities for pathways of contaminant entry
- Summarizes investigation findings & corrective actions needed
- Level 2 Investigation form is located on County & Dept. of Agriculture Resources Coliform Resources Page
- Refer to investigation procedures & other materials online

Coliform Monitoring Resources

As of April 1, 2016 a detailed investigation is required after the MCL for *E. coli* is exceeded or a second level 1 coliform investigation is triggered in a 12 month period. The individual responsible for conducting sanitary surveys at the water system where the investigation was triggered must complete the investigation within 30 days and submit the completed investigation form to DWS.

- A Coliform Investigation Procedure
- Level 2 Coliform Investigation Form (Pillable MS Word)
- Coliform Alert Response Procedure: General procedure for responding to routine sample coliform alerts for all groundwater systems.
- Coliform Response Chart For groundwater systems serving up to 1,000 persons



Two levels of coliform investigations:

- Level 1 coliform investigation (TC+)
 - WS completes investigation form
 - Regulator reviews form for completion
 & corrective action needed
- Level 2 coliform investigation
 - E. coli MCL or 2nd level 1 investigation within rolling 12-month period
 - Regulator completes investigation on site

Combinations resulting in E. coli MCL										
Routine	Repeat									
EC+	TC+									
EC+	Any missing sample									
EC+	EC+									
TC+	EC+									
TC+	TC+ (with no E. coli analysis)									
E. coli positive (EC+),	Total coliform positive (TC+)									



Investigation Forms



PWS Name:

Level 1 Coliform Investigation Form

Oregon Health Authority, Drinking Water Services

Complete the coliform investigation and return the form within 30 days to your County, Dept. of Ag, or State regulatory contact

	Name				Telephone #									
Operator in Direct Responsible Charge														
Person(s) that collected samples if different than above														
Date of Investigation:														
		INVESTIGAT	ION D	ETAILS			_							
Did any of the following events occur prior to collection o positive total coliform samples?	f the	Yes/No	N/A	If Y	es, describe issu	е								
Loss of pressure anywhere in the system		Y N												
2. Maintenance on the system that could have introduced conf	tamination	Y N		1 [0,000	. 1 . 1									
Repair of broken water lines		YN		Orego	Slth									
4. New water lines or service connections added to the system	n	YN		1 862	111 []									
Vandalism or unauthorized access to facilities		YN		1 100	-Authority	Le	vel 2	Coliforn	n Inve	estiga	ition I	orm		
Water line flushing or fire fighting event		YNN		1				h Authorit						
7. Low chlorine or chloramine residual anywhere in the system	ı	YN	П	1		Oregon	ricali	II Addition	y, Dili	iking v	valer 5	ei vice.	3	
8. Failure of chlorination/UV equipment or minimums not met		YNN	П											
9. New or different source of water introduced (example: back	up well)	YNN		1										
10. Loss of electrical power		YNN		PWS Name:									PWSIL	D #: 41
11. Unprotected connection to non-potable water discovered (example:	YNN					Vame						Teleph	one #
private well, irrigation line, fire sprinkler system)				Operator in Direct Respo	nsible Charge (DR								Тепери	
12. Failure to test all backflow prevention devices within the la	st year	Y N		Person that collected san										
13. Discovery of water system components submerged in water (example; well or valves in a flooded vault)	Y N		Date of Investigation:											
Wells & Springs - Inspect each groundwater source for physi	cal defects			1				INVESTIGA	ATION D	FTAILS				
and report:		Yes/No	N/A	Groundwater Source			Well/Sp		Spring	ing Well/Spring Well/Sprin			a	
Cracks or holes in well seal or casing		Y N		Inspect each groundwate	r source for physic	cal defects and	Nam	ie Na	me	Nam	e	Name	N/A	If Yes, describe issue
2. Repair/replacement of well/spring components (example: w	ell pump)	Y N		report:										
Wellhead flooded or water puddled near well		Y N		 Cracks or holes in we 	ll seal or casing		Y N	Y	N	Y N	Y	N		
Screen for well vent missing or damaged		Y N		Wellhead lacks a water	ertight seal		Y N			Y N				
5. Feces, fecal source or other unsanitary conditions at the we	ell/spring	Y N		Screen for well vent m	nissing or damaged	d	Y N			Y N		N		
Leaking sewer lines or septic tanks near well/spring		Y N		 Wellhead subjected to 	flooding or standi	ing water near well	Y N	Y		Y N		N		
7. Cracks or holes in springbox		Y N		Leaking sewer lines o	r septic tanks near	well/spring	Y N	Y		Y N		N		
8. Water flowing or puddled on the ground around springbox		Y N		Feces, fecal source of	bserved near well/	spring	Y N			Y N		N		
				Unsanitary conditions	at the well/spring		Y N			Y N	Y	N		
				8. Contamination during	pump repair/repla	cement or other	Y N	Y	N _	Y N] Y	N		
				wellhead/spring repair										
				Use of an unapproved			Y N			Y N		N_		
				10. Indication of surface	water entering spr	ringbox	Y N			Y N		N.		
				11. Cracks or holes in sp	oringbox		Y N	Y	N	Y N	Y	N		
				Treatment and Disinfec			Plan Name			Plant Name	Plant Name			If Yes, describe issue
				Inspect each treatment p			YN		_ _					
			Inability to maintain residual throughout the distribution system						N	Y N	_ _			
							YN		N	Y N				
							YN			N	Y N			
6				4. Improper chlorine resid	dual measurement	s (method or	Y_ N	Y N	Y	N	Y N			
6				frequency)				I	ı			I	I	

PWS ID #: 41

Coliform investigation scenario

- Community groundwater system with no treatment
- Completed level 1 investigation in prior month
 - no issues were identified
- Triggered level 2 investigation in Sept. 2017
- Routine samples TC+ followed by repeats TC+ (no E. coli)
- Wells in use at the time were coliform absent
- Some waterline maintenance work had been done
- Consolidated connections from neighboring WS
- Coliform event occurred in late summer
- What information would be useful to have for on site visit?



Investigation Map Well Storage TC+ TC-Flow direction

INVESTIGATION DETAILS

Groundwater Source Inspect each groundwater source for physical defects	Well/Spring Name	Well/Spring Name	Well/Spring Name	Well/Spring Name	N/A	If Yes, describe issue			
and report:	Well 1	Well 2							
Cracks or holes in well seal or casing	Y□ N⊠	Y□ N⊠	Y N	Y N		All triggered source water			
Wellhead lacks a watertight seal	Y N	Y N	Y N	Y N		samples collected were coliform			
Screen for well vent missing or damaged	Y□ N⊠	Y□ N⊠	Y N	Y N		absent.			
Wellhead subjected to flooding or standing water near well	Y□ N⊠	Y□ N⊠	Y N	Y N		Wells #1 & #2 located in affected			
Leaking sewer lines or septic tanks near well/spring	Y□ N⊠	Y□ N⊠	Y N	Y N		area inspected during site visit.			
Feces, fecal source observed near well/spring	Y□ N⊠	Y N	Y N	Y N		No issues were found.			
7. Unsanitary conditions at the well/spring	Y□ N⊠	Y□ N⊠	Y N	Y N					
Contamination during pump repair/replacement or other wellhead/spring repair	Y□ N⊠	Y□ N⊠	Y N	Y N		Water supplier inspected additional wells prior to site visit			
Use of an unapproved or untested source	Y□ N⊠	Y□ N⊠	Y N	Y N		and no issues were identified.			
10. Indication of surface water entering springbox	Y N	Y N	Y N	Y N					
11. Cracks or holes in springbox	Y N	Y□ N⊠	Y N	Y N					

Treatment and Disinfection Inspect each treatment plant for physical defects and report:	Plant Name	Plant Name	Plant Name	Plant Name	N/A	If Yes, describe issue
Inability to maintain residual throughout the distribution system	Y N	Y N	Y N	Y N	\boxtimes	No treatment is installed.
Failure of disinfection equipment	Y N	Y N	Y N	Y N	\boxtimes	
Failure to monitor and replace chlorine supply	Y N	Y N	Y N	Y N	\boxtimes	
Improper chlorine residual measurements (method or frequency)	Y N	Y N	Y N	Y N	\boxtimes	
Failure to meet required minimum chlorine residual at the entry point (GW only)	Y N	Y N	Y N	Y N	\boxtimes	



Level 2 Coliform Investigation Form

Page 2 of 4

Treatment and Disinfection Inspect each treatment plant for physical defects and report:	Plant Name	Plant Name	Plant Name	Plant Name	N/A	If Yes, describe issue	
6. Failure to meet CTs at all times (SW only)	Y N	Y N	Y N	Y N	\boxtimes		
7. Failure to meet turbidity standards (SW only)	Y N	Y N	Y N	Y N	\boxtimes		
Failure to meet filtration requirements (SW only)	Y N	Y N	Y N	Y N	\boxtimes		

Storage Tanks Inspect each storage tank for physical defects and report:	Tank Name Res. #1	Tank Name	Tank Name	Tank Name	N/A	If Yes, describe issue
Holes in tank that could allow entry of insects or small animal	Y⊠ N□	Y N	Y N	Y N		Rodents burrowing under structure covering Res. #1. Visual inspection
Roof access hatch or other openings inadequately sealed Vent screens missing or damaged	Y N	Y N N	Y N N	Y N N		during site visit. Other reservoirs inspected by water supplier prior to site visit include Res. #2-#4.
Screen or flap valve on overflow pipe outlet missing or damaged	Y□ N⊠	Y N	Y N	Y N		
Presence of contamination in tank (example: dead animals, insects)	Y□ N⊠	Y N	Y N	Y N		Draining Res. #1 found rodent remnants.
Recent maintenance or work done on the tank	Y□ N⊠	Y N	Y N	Y N		
Improperly cleaned or maintained storage tank	Y N	Y N	Y N	Y N		
Leaks in tank that could be harboring growth	Y□ N⊠	Y N	Y N	Y N		
Inadequate tank controls resulting in poor turnover	Y N	Y N	Y N	Y N		Controls adequate. Concerns with thermal stratification in reservoir affecting water quality.
10. Bladder pressure tank waterlogged	Y□ N⊠	Y N	Y N	Y N		



Distribution System Inspect the distribution system for physical defects and report:	Yes/No	N/A	If Yes, describe issue
Failure to maintain adequate pressure or low pressure event (example: pump failure leading to low pressure)	Y□ N⊠		
2. Recent main break or repair of broken water lines	YM N		Aug. 12 th waterline break on 2 nd street
New water lines or service connections added to the system	Y N		In February 2017, new waterlines were installed in the S and N areas. In 2017, system consolidated connections, waterlines and distribution components from adjacent system.
 Improper construction of new, replaced, or renovated lines or service connections 	Y□ N⊠		
Known leaks in the distribution system	Y N		
Supervisory control and data acquisition (SCADA) and control issues	Y N		

Sampling Protocol Report any defects in sampling protocol:	Yes/No	N/A	If Yes, describe issue
Tap flushed for less than 3 minutes	Y N		
Aerator, screen, hose, or other attachment present during sampling	Y N	\boxtimes	
Leaky or swivel faucet used	Y N		
Samples not kept cool during storage/transportation	Y N		
Inside of bottle/lid touched or lid set down	Y N		
Heavy rainfall or wind at time of sampling	Y N		
7. Sampled at site not on coliform sampling plan or previously unused site	YM N		DCVA sites used for sampling is uncommon.
Other sampling problems	Y N		



Investigation map Well Storage TC+ TC-Flow direction Reservoir #1

Investigation findings

Rodents burrowing under steel structure covering Reservoir #1



SUMMARY: Based on the results of the investigation and any other available information, what is believed to be the cause(s) of the *E. coli* positive or multiple total coliform positive sample(s) from the public water system?

Met with DRC and certified operators. Discussed sampling completed to evaluate coliform occurrence. Coliform sampling and distribution system map were reviewed. Efforts focus on southern portion of the water system served by the two wells 1, 2 and reservoir #1.

Prior to investigation, Reservoir #1 was drained and inspected confirming rodent activity inside the concrete basin. Rodents burrowing under the berm wall may have entered finished water using the wooden ramp and/or by climbing structural support beams. Facilities were shock chlorinated and residual levels measured before and after the reservoirs.

The water system has triggered two coliform investigation. According to Oregon Administrative Rule 333-061-0032(6) (g), triggering three or more coliform investigation within a rolling 12-month period requires water suppliers to install and utilize treatment for disinfectant residual maintenance.

CORRECTIVE ACTIONS: What actions has the water system taken to correct the above mentioned issue(s)? If additional time is needed to correct a deficiency, indicate the date that it will be corrected.

Remove wooden access ramp to Reservoir #1 concrete basin replace with a gravel path. Shoring berm and install flashing and metal collars around support beams inside structure to prevent rodent entry. Remove landscape fabric inside the structure to deter rodents.

Pressure washed and shock chlorinate reservoir. Evaluate and remove trees that could compromise reservoirs, install sampling taps for both reservoirs.

Discussed disinfection practices and customer notification for repairs and/or chlorination activities.

Improve documents for items 1-3 below. Provide written verification that items have been corrected before January 1, 2018.

- (1) Update coliform sampling plan to incorporate new sites and/or sites previously sampled not documented in the plan.
- (2) Review and update written procedures for chlorination.
- (3) Review and update written procedures for notifying customers.



Corrective action

- Access ramp replaced with gravel
- Installed flashing & metal collars on support beams





Coliform investigations - continued

- Things to consider when filling out form:
 - Go through questions in order
 - Take photos when unsure of contaminant concern
 - Refer to survey manual & consult with DWS staff for assistance
 - Describe situation, include map and other details for investigation
 - If facility could not be inspected, note it on the form
 - Complete summary (required) & corrective action sections
 - Does summary capture the coliform event?
 - Are there corrective action due dates to track in Data Online?
 - Send final form to WS for their records



Coliform investigations - lessons learned

- Provide WS with copy of investigation form before onsite visit
- Request information for investigation
 - Distribution map to spatially evaluate coliform results
 - Sampling plan and procedures
 - Access to necessary facilities
 - Photos of facilities that are inaccessible (storage tanks, vaults)
- Investigation may trigger increased sampling
- Multiple investigations may be triggered before issue is resolved
- Unresolved issues may require installing residual maintenance
- What experiences have you encountered with coliform investigations?



Chemical detections & MCL exceedance

- Alerts you may encounter:
 - VOC detection
 - Arsenic MCL
 - Nitrate > ½ MCL
- Refer to online monitoring resources

Monitoring Resources

Drinking Water Services

County & Dept. of Agriculture Resources

Water System Surveys

Conferences and Training

Document Library

Inventory Updates

EPA Staff Resources

Coliform Resources

The information on this page is designed for and intended for use by Drinking Water Services County and Department of Agriculture partners who have specialized training and are registered as environmental health specialists. If you have questions regarding this material please contact Drinking Water Services at (971) 673-0405.

- A Chemical Monitoring Schedules for Community and Non-Transient Non-Community groundwater systems
- Standard Monitoring Framework
- Alerts: What to Do With Chemical Detections
- Arsenic Testing and Follow-up at TNC and State-Regulated Water Systems

Lead and Copper Rule:

- 🔒 Lead or Copper Exceedance Procedure
- A Plumbing Replacement Program Procedure
- Lead and Copper Tap Sample Invalidation Procedure



Chemical detection Scenario

- Detection in 2nd quarter of xylene at 0.0007 mg/L
- Alert emailed to regulator when contaminant is > MDL
- Evaluate if confirmation sample is needed
- Is additional monitoring required?

Refer to "What to Do With Chemical Detections" handout





Alerts: What to Do With Chemical Detections

What to Do With Results Greater Than Zero (Detections)

Oregon Health Authority Drinking Water Services, Updated October 2016

Problem	Action Needed	Resolution	OAR Ci	tation
Inorganics (including	Arsenic) a			
Result over the MCL	Confirmation sample plus quarterly monitoring *. Confirmation sample must be taken within 2 weeks. Average initial + confirmation sample to determine compliance.	Review after 2 quarters for GW, after 4 quarters for SW. Sample qtrly until R&C ^b below MCL, but if running annual average (RAA) is above MCL, treatment is required. For arsenic, DWS generally requires 4 quarters for all systems before review.	OAR 333-061-0036(2)(g) OAR 333-061-0036(2)(a)(D) OAR 333-061-0036(2)(i)(B)	Confirmation sample Quarterly monitoring RAA calculation & compliance determination
Nitrate and Nitrite a				
Result over the MCL	Confirmation sample plus quarterly monitoring.	If avg of initial + confirmation is above MCL, treatment is required. If avg < MCL, monitor quarterly until R&C ^b below MCL.	OAR 333-061-0036(2)(g) (B&C) and OAR 333-061- 0036(2)(i)(C) OAR 333-061-0036(2)(d) OAR 333-061-0036(2)(e)(C)	Confirmation sample Quarterly monitoring nitrate Quarterly monitoring nitrite & at least annually after that
Result ≥½ the MCL	Quarterly monitoring	Continue monitoring qtrly. Review annually to determine whether system should continue quarterly monitoring. If results are R&C ^b below the MCL (for GW) or below ½ the MCL (for nitrates, SW), then system can return to annual monitoring.	OAR 333-061-0036(2)(d) OAR 333-061-0036(2)(e)(C and D)	Quarterly monitoring nitrate Quarterly monitoring nitrite, & at least annually after that (in same quarter as the highest previous result)
Lead and Copper a				
Above Action Level	Review sampling protocol. Collect source testing and WQPs ^c , submit treatment recommendation. May need public education.	Install corrosion control, or make necessary adjustments. 2 six-month rounds less than Action Level, minimum WQPs ^c set.	OAR 333-061-0036(2)(c)(G-H) and 333-061-0034(4) OAR 333-061-0036(2)(c)(F) OAR 333-061-0034(2) & (3) OAR 333-061-0034(5) OAR 333-061-0036 (2)(c)(D)(ii)	Source water testing WQP requirements Treatment requirements Lead public notice/education Monitoring after installing tx
Volatile & Synthetic C				
Result over the MCL	Confirmation sample plus quarterly monitoring. ⁴	Compliance is based on running annual average.	OAR 333-061-0036 (3)(b)(F) OAR 333-061-0036 (3)(a)(F) OAR 333-061-0036 (3)(b)(E) OAR 333-061-0036 (3)(a)(E) OAR 333-061-0036 (3)(b)(H) OAR 333-061-0036 (3)(a)(H)	VOC confirmation sample SOC confirmation sample VOC quarterly monitoring SOC quarterly monitoring VOC annual compliance SOC annual compliance

Chemical detections and MCL exceedance?

Example:

- Alert for detection 2nd quarter of VOC Xylene at 0.0007 mg/L
- Email notification when contaminant is above MDL 0.0005 mg/L
- Average of initial and confirmation samples below MDL
- If average is above MDL increase to sampling <u>quarterly</u>.

Volatile & Synthetic Organics a

Problem	Action Needed	Resolution				
Result > Detection Limit	Confirmation sample plus	If avg of initial + confirmation is				
(for VOCs);	quarterly monitoring.d	below detection limit, or if original				
Result ≥ Detection Limit		sample can be shown to be non-				
(SOCs)	Vinyl chloride samples	representative, resume routine				
	required following certain	monitoring schedule. Document the				
Detect limit for VOCs is	VOC detections in GW	decision.				
0.0005 mg/l.	systems.f	If avg > detection limit, must monitor				
_		quarterly. Review after 2 Qs for GW,				
Detect limits for SOCs		after 4 Qs for SW. If average > MCL,				
vary.		treatment is required. If R&Cb below				
		MCL, sample annually. Review GW				
		after 3 yrs - reduction if no detects.				

Chemical Schedule Change Form

- Download from Inventory Page
- Information to complete:
 - Schedule increase at EP
 - Begins quarter after detection
 - Provide explanation on form for schedule increase
 - Include additional information
 - Follow up after quarterly sampling is completed

1.1%	Health Chemical & Bacteriological Monitoring Schedule Change Form															
ДС	alun		Chemical	αΒ	iciei						vices	iule (Cilai	ige Foli	"	
Syst	em									PW	/S ID# 4	1				
Con	tact with					Р	hone	()			Co	unty				
Staf	f Membe	r _				Α	gency	r			Da	te _				
Check	System Type: Community (C) Non-Transient Non Community (NTNC) Transient Non-Community (NC) State Regulated (NP) Check if New System or Sample Pt: For new systems, include all necessary chemicals and sampling points. Entry Point ID (In SDWIS Entry Pt ID "A" will appear as Facility ID "EP-A", Entry Pt ID "B" will appear as "EP-B" etc.)															
[New Schedule ☐ Schedule Reduction ☐ Schedule Increase															
Sample Point ID Code/Chemical/Analyte Frequency											Fr	d Date				
Sar	(Entry Pt ID or		e reverse for complete of chemical groups and analyte codes	Once	Monthly	Quarterly	Yearly	Once Every 3 Years	Twice Every 3 yrs	Once Every 6 Years	Once Every 9 Years	Begin Date		(Leave closing	(Leave blank unless closing a previous schedule)	
												1	1	1	1	
												1	1	1	1	
												1	1	1	1	
												1	1	1	1	
					Atta	ch add	tional pa	ige(s) a	necess	ary						
Distri	bution S	amp	ling Point ID (In S (DBP Sample P										•	DIST-A")		
	ew Sched	dule		Sched	ule Re	ductio	n		Sched	ule Ir	ncrease					
DBP2 TTHM HAAS IDSE LCR ASBD or TCR	DIST-A IDSE-0 2DBP-01,	1	Sample Site ID or Street Address (Enter for DBPs only. This address will be used to the sample results to the site)	# Samples Required	Monthly	India	or DBP cate Peak th Below	Semi Amual	For Disindicate Month B	BP Poak	For DBP Indicate Peak Month Below	Once Every 6 Years	Once Every 9 Years	Begin Date	End Date	
										_]				1.1	1.1	
														1.1	1.1	
					Тп	T_{G}							ПП	1.1	1.1	



Chemical Schedule Change Form

- Provide system inventory information
- Establish sampling point, chemical, schedule frequency, begin date
- Note additional information in the comments section

Health	Chemical	& B	actei			l Mo nking				edule Change	e Form
System	Lily Cat Farms	Lily Cat Farms					Cat Farms PWS ID# 41 0 1 2			2 3 4	
Contact with	Lily P. Coyote	Lily P. Coyote				Phone (503) 351 - 0351 County Deschutes			County Deschutes	<u> </u>	
Staff Member	er Michelle			Α	gency	:_DW	'S		[Date 4/16/2018	
Check if New Syst	System Type: ☐ Community (C) ☐ Non-Transient Non Community (NTNC) ☐ Transient Non-Community (NC) ☐ State Regulated (NP) Check if New System or Sample Pt: ☐ For new systems, include all necessary chemicals and sampling points. Entry Point ID (In SDWIS Entry Pt ID "A" will appear as Facility ID "EP-A", Entry Pt ID "B" will appear as "EP-B" etc.)										
■ New S	chedule	Sched	ule Re	ductio			Sched	dule ind	crease	1	ı
Sample Point ID (Entry Pt ID or SRC Sampling Point ID)	Code/Chemical/Analyte See reverse for complete list of chemical groups and analyte codes	Once	Monthly	Quarterly	Yearly	Once Every 3 Years	Twice Every 3 yrs	Once Every 6 Years	Once Every 9 Years	Begin Date	End Date (Leave blank unless closing a previous schedule)
EP-A	2955 Xylene			×						06/01/2018	/ /
										/ /	n 1
										/ /	TE al

Chemical Schedule Change Form

- Provide system inventory information
- Establish sampling point, chemical, schedule frequency, begin date
- Note additional information in the comments section

Comments	Detection of xylene in s	ample collected on 4/1/2018.	Confirmation sample collected on
4/15/18.	Average of initial and co	nfirmation sample requires q	uarterly sampling starting 3 rd quarter.

Signature:	Michelle Byrd	Date: 4/16/2018	
_			



Chemical MCL Scenario

- Arsenic result in 1st quarter is 0.012 mg/L
- Confirmation sample is 0.014 mg/L
- Is average of initial detection and confirmation sample are over the MCL?
- Refer to "What to Do With Chemical Detections"





Chemical MCL Scenario

 Quarterly sampling of arsenic is needed to determine compliance by calculating Running Annual Average

Problem	Action Needed	Resolution				
Inorganics (including Arsenic) a						
Result over the MCL	Confirmation sample plus	Review after 2 quarters for GW, after				
	quarterly monitoring a.	4 quarters for SW. Sample qtrly until				
	Confirmation sample must	R&C ^b below MCL, but if running				
	be taken within 2 weeks.	annual average (RAA) is above MCL,				
	Average initial +	treatment is required. For arsenic,				
	confirmation sample to	DWS generally requires 4 quarters for				
	determine compliance.	all systems before review.				

- Fill out Chemical Schedule Change Form
 - Schedule increase for arsenic at EP starting quarter after detection occurred
 - Provide explanation for schedule increase



Changes to distribution sampling

- DBPs, lead & copper & coliform sampling
 - Include number of samples required
 - Street address (if applicable)

Distribution Sampling Point ID (In SDWIS Distrib.Sampling Point "A" will be identified as: Facility ID "DIST-A") (DBP Sample Points must include peak month that sampling is required in and sample location Schedule Increase New Schedule Schedule Reduction
 ■
 Schedule Reduction
 ■
 ■
 Schedule Reduction
 ■
 ■
 Schedule Reduction
 ■
 ■
 Schedule Reduction
 ■
 Schedule Reduction
 ■
 Schedule Reduction
 ■
 Schedule Reduction
 Schedule Reduction
 ■
 Schedule Reduction
 Schedule Reducti DBP2 Once Every 3 Years Sample Site ID or TTHM Semi Annual Once Every 9 Years Once Every 6 Years # Samples Required Street Address HAA5 Monthly DIST-A or (Enter for DBPs only. End IDSE Begin IDSE-01 С This address will be Date Date 2DBP-01, etc. ASBD used to tie sample For DBP For DBP For DBP results to the site) Indicate Peak Indicate Peak Indicate Peak TCR Month Below Month Below Month Below DIST-A 12/31/2017 LCR \times 10 01/01/2018 LCR DIST-A 5 \times^*



More on chemical schedule changes...

- Consider end date when closing schedule to avoid violation
- Check Data Online to see if schedule is correct
- Follow-up after changing schedule if further evaluation is needed
- Questions on required sampling? Consult with DMCE or tech staff.

Chemical Sampling Schedule Status									
Facility ID	Analyte or Group		Sampling Interval	Monitoring Start	Period End	Days Until End	Samples Required	Samples Received	Last Sample Date
EP-A EP FOR WASHINGTON ST WELL	ARSENIC		Quarterly	04/01/2018 -	06/30/2018	74	1	incomplete	03/14/2018
EP-A EP FOR WASHINGTON ST WELL	IOC	notes	9 Years	01/01/2014 -	12/31/2022	1719	1	incomplete	05/19/2008
EP-A EP FOR WASHINGTON ST WELL	NITRATE		Yearly	01/01/2018 -	12/31/2018	258	1	incomplete	11/08/2017
EP-A EP FOR WASHINGTON ST WELL	NITRITE	notes	9 Years	01/01/2014 -	12/31/2022	1719	1	incomplete	07/11/2005
EP-A EP FOR WASHINGTON ST WELL	RAD - GROSS ALPHA		3 Years	01/01/2017 -	12/31/2019	623	1	incomplete	11/08/2016
EP-A EP FOR WASHINGTON ST WELL	RAD - RADIUM 226/228		6 Years	01/01/2014 -	12/31/2019	623	1	done	11/08/2016
EP-A EP FOR WASHINGTON ST WELL	RAD - URANIUM	notes	9 Years	01/01/2014 -	12/31/2022	1719	1	done	11/08/2016
EP-A EP FOR WASHINGTON ST WELL	SOC		3 Years	01/01/2017 -	12/31/2019	623	1	incomplete	11/08/2016
EP-A EP FOR WASHINGTON ST WELL	VOLATILE ORGANICS		3 Years	01/01/2017 -	12/31/2019	623	1	incomplete	11/08/2016

Inventory changes

- Add a new system or update existing system information
- Identifying source & entry point information (2 separate forms)
- Chemical & bacteriological schedule changes
- Submit all 3 forms to DMCE for new systems.

Inventory Updates

Drinking Water Services

County & Dept. of Agriculture Resources

Water System Surveys

Conferences and Training

Document Library

Inventory Updates

EPA Staff Resources

Coliform Resources

Monitoring Resources

The information on this page is designed for and intended for use by Drinking Water Services County and Department of Agriculture partners who have specialized training and are registered as environmental health specialists. If you have questions regarding this material please contact Drinking Water Services at (971) 673-0405.

A Treatment Codes


The following documents are password protected:

- Chemical and Bacteriological Monitoring Schedule Change Form: 👜 fillable MS Word -or- 🔒 printable PDF
- Entry Structure Diagram:
 - · Refer to the treatment code list (above) when filling out this form.
 - Entry Structure Diagram (includes drawing grid)
 - Entry Structure Form and Drawing Grid
- Source Information: @fillable MS Word -or- @printable PDF
- P Water System Information
- Walver request and associated procedure to reduce monitoring from annual to once every three years after a VOC contaminant was detected.



Add a new system or update existing system information

- WS Information form
 - System type, statistics, operational period
 - identify contact person's information
 - activate/deactivate WS
 - Clarify changes or additional information in notes



Identify source & entry point information

- Entry Structure Diagram form
 - Identify source & EP names, type, availability, treatment
 - Grid to draw source & EP physical connection to distribution
 - Refer to instructions on 2nd page of form

System:			PWS ID 41	
Contact with:		Ph#	County:	
Staff member:			Date	
Agency □ State □	☐ County ☐ I	Dept of Ag □ Othe	r	
E. Dir				
Entry Points	1		□ I reatmo	ent Changes Only Designated
	Source Type	Availability	Treatment Codes	
	6 6 5 6 6	(S)	s pe sa	from EP)
	Ground (G) Surface (S) GWUDI (U) P. Grnd (W) P. Surface (P)	Seasonal (S)	Emergency Abandoned Disconnected None	
D Name	Ground Surf GW P. G	Begins Ends	Emerg Abane Disco None	None
A				
			Sources (IDs for sour	
[5]	n Entry Points n sources thru entry p ID, names.) A SRC-BB SRC-BC		Sources (IDs for sour	

Chemical & bacteriological schedule changes

- Identify system information & sampling locations
- New schedules or to increase or decrease sampling
- Sampling frequency depends on chemical group & prior monitoring results (if any)
 - Chemical detections or MCL exceedances email alert initiated
 - Refer to handout "What to do if results are greater than zero."
 - Other considerations refer to <u>Standard Monitoring Framework</u>
 - Determine monitoring period for sampling to occur
- If new system, consult with tech staff/regional engineer on sampling schedules



Water system survey forms

- 571 surveys completed in 2017
- Where to find survey forms & reference materials

Water System Surveys



Survey Manual and Related Information

Conferences and Training

Document Library

Inventory Updates

EPA Staff Resources

Coliform Resources

Monitoring Resources

Compliance Resources

Contact Us

- Water System Survey Reference Manual revised 03/09/2016
- Symbols for Schematics and Sample Water System Schematics
- Qunting Population and Connections for a Public Water System
- A Chemical Monitoring Schedules for Community and Non-Transient Non-Community groundwater systems
- Standard Monitoring Framework to assist with completing the water quality monitoring page of the survey
- Outstanding Performance
- Deficiency List revised 6/24/2015
- Setback Issues Found in a Survey Procedure New 12/15/2015
- Membrane Survey Staff Guide New 12/20/17

Survey Form Templates

- About Survey Template Packets
- Survey Template Instructions
- Outstanding Performer Template

The following documents are password protected (they currently open best in Firefox):

- Packet 1: C-NTNC Groundwater Survey Template revised 04/14/2018
- Packet 2: C-NTNC Surface Water Survey Template revised 04/14/2018
- Packet 3: TNC-NP Survey Template revised 04/14/2018



Water system survey reminders

- Completed surveys are sent to DMCE to update Data Online
- Changes made include:
 - System contact information
 - Changes in use of sources & entry points
 - Changes to water quality monitoring
 - Identify deficiencies & established timeline for correction

		Most Recent Water System Survey		
Survey Date:	Nov 09, 2017			
Notification Date:	Dec 18, 2017			
Regulating Agency:	DWS (REGION 1)			
Survey Frequency:	5 YR - Visit the Water System Sur	veys page to see the list of surveys due each year.		
Deficiencies:	Category	Deficiency	Due Date	Resolved Date
Deliciencies.	Finished Water Storage	Hatch not locked or adequately secured	Apr 23, 2018	
	Finished Water Storage	Roof and access hatch not watertight	Apr 23, 2018	
	Finished Water Storage	No screened vent	Apr 23, 2018	
	Management & Operations	No operations and maintenance manual	Apr 23, 2018	
	Management & Operations	Emergency response plan not completed	Apr 23, 2018	
	Monitoring & Reporting	No coliform sampling plan	Apr 23, 2018	
	Other	verify year-round customers	Apr 23, 2018	

When completing survey forms

- Respond to all questions
- Check for spelling or grammatical errors
- Make sure deficiencies on form are consistent with cover letter
- Verify corrective action due dates are correct
- Use comments sections to provide details for clarity
- Check schedules for changes in monitoring frequency
- Label photos & features on schematic





Changes to survey forms

- Windows version 10 compatibility issues
- Drop-down lists removed
- Data options & references re-inserted into forms
- Consolidated membrane questions into SW forms
- Added annual source sample question/deficiency to TNC page
- Added questions for by-pass piping around treatment & storage used for contact time
- Arranged WQ monitoring page to match order as in Data Online
- Other housekeeping items
- New forms posted on website



Changes to survey forms

1	EOmmon.	1 . 1	
1	00	I+	h
Л	ICa.	IU.	Ш

XYZ Water System
Water System Survey
OHA Drinking Water Services

PWS ID: 41 #### Survey Date: mm/dd/yy

Page 3 of 16

Inventory and Narrative

Outstanding Performer								
Type:			Status	Size	Season:	All year	S	easonal
Community (C) Non-Transient Non-Community (NTNC)			Population:		Begins: (mm/dd)		/	
Transient Non-Community (TNC) Non-EPA (NP)			Connections:	Ends: (mm/dd)				
License:	☐ Not Lic. ☐ Health		Dept. 🔲 Ag	Service A	rea Char	acteristics:		
Responsible Agency:	State	County	/ 🔲 Ag	Owner Ty	pe:			
Operator Certification Requirements:	WD:		WT:	FE FE		Small WS		

Primary Administrative Contact (Mailing Address):	
Contact Name:	Phone: ()
Title:	Cell: ()
Street Address:	Emergency #: ()
City/State/Zip:	Email:
Legal/Owner Address:	
Contact Name:	Phone: ()
Title:	Cell: ()
Street Address:	Emergency #: ()
City/State/Zip:	Email:
System Physical Address:	
Contact Name:	Phone: ()

		Disinfection					
No#	Disinfection Method (Chlorine Gas, Sodium Hypochlorite, On-site Generated Sodium Hypochlorite, Calcium Hypochlorite, Chloramines, Ozone, UV, Mixed Oxidants, Other)	Location	Disinfection Source Water	Residual	Other Purpose	Proportional to Flow	Dosage Recorded
Yes N	o Chlorine residuals 🔲 N/A						
	Is a DPD or other EPA approved me NSF 60/61 certified (or equivalent)? Are entry point residuals recorded Is entry point residual monitoring co Are distribution residuals recorded a Are on-line chlorine analyzers verifie	t least once per day (SWTR, GV ntinuous if population > 3,300 (\$ t least twice weekly?	SWTR, GW	/R 4-log))? ■N/A		
Yes N	o Chlorine gas N/A Separate room for gas storage and fe Fan with on/off switch outside? Vent located next to the floor? Door with a window?	eder?	Gas cyl Door th Self-col	at opens	breathing app		?
Yes N							
	Does all water contact UV (no bypa: Is lamp sleeve cleaned? Is lamp replaced per manufacturer? Intensity sensor with alarm or shut-c						
Yes N	o CT Evaluation for disinfection 🔲 N/	4					
	 Is contact time based on a tracer stop 	idy or adequate alternative? 🔲	N/A				
	Describe adequate alternative metho	d for contact time:					
	■ Is there a flow meter on effluent side	of clearwell /contact chamber	or adequat	e alterna	ative?		



Questions, comments?



Michelle Byrd 971-673-0425 michelle.p.byrd@state.or.us

