

RTCR implementation update




Casey Lyon
Partner training
Bend 4/7/19

Overview of presentation

- Criteria to change coliform monitoring from quarterly to monthly
- Opportunity to collect make-up sample and stay on quarterly monitoring
- Criteria to move from monthly back to quarterly monitoring
- Review of Level 1 investigations
- Level 2 investigations: timeline, field visit, violations

Criteria to increase coliform monitoring to monthly if any of the following criteria are met, OAR 333-061-0036 (6)(b)(C)

- A level 2 coliform investigation is triggered
 - Violation for exceeding the maximum contaminant level for *E. coli*
 - Violation for not completing and reporting a coliform investigation by due date
 - Violation for not correcting sanitary defects found during a coliform investigation by approved due date
-
- Two violations for routine coliform monitoring (for not reporting a required sample on time)
 - A level 1 coliform investigation is triggered and one violation for routine coliform monitoring



What type of system does this increased monitoring apply to?

- ✓ Systems that are on quarterly coliform monitoring
 - ✓ TNC or NTNC
 - ✓ Groundwater
 - ✓ Not seasonal



Process for the schedule change

- Query looks for who meets the criteria listed
- DMCE reviews list to verify accuracy
- Letter generated and made into a PDF
- Schedule changed in SDWIS
- Letter is printed and mailed to system
- PDF is emailed to regulating agency and technical services contact



Change to monthly monitoring letter

You must begin monitoring for coliform bacteria at your water system every month, beginning in November 2017 because the criteria for increased monitoring in OAR 333-061-0036(6)(b)(C) was met.

OAR 333-061-0036(6)(b)(C) specifies that monitoring must be increased if any of the following occur within a 1 year period:

- Violation for exceeding the maximum contaminant level for E. coli;
- Violation for not completing and reporting a coliform investigation by due date;
- Violation for not correcting sanitary defects found during a coliform investigation by approved due date;
- A level 2 coliform investigation is triggered;
- Two violations for routine coliform monitoring (for not collecting a required sample); or
- A level 1 coliform investigation is triggered and one violation for routine coliform monitoring.

The system may have an “opportunity” to stay on quarterly

- OAR 333-061-0036 (6)(b)(A):

“... the Authority may elect to not consider monitoring violations according to paragraph (6)(p)(A) of this rule if ...”

- This “opportunity” will only be an option for systems where the cause is two quarterly monitoring violations.
- Can only do this (opportunity) one time in a 4 quarter period (rolling year – not calendar year).
- Involves taking an extra sample, letter explains details.
- An “opportunity letter” will be sent to the PWS notifying them of this, a copy of the letter will also go to the regulator.

What is the “opportunity” process to stay on quarterly monitoring?

- Violation will be issued on 1st workday after the 10th of each quarter. – it is the systems 2nd violation and starts the opportunity to stay on quarterly monitoring – letter is sent to system
- Take make-up sample by end of current month and report by 10th of next month to stay on quarterly monitoring
- Schedule will change to monthly if this “opportunity” is missed.



Opportunity letter example language

Your water system has missed reporting quarterly sample results twice within the last year. This will cause your coliform monitoring schedule to be increased to once every month unless you do the following:

- Collect the make-up sample before the end of this month and report it by the 10th of next month.
- Collect the normal quarterly sample by the end of the quarter and report it within 10 days of the end of the quarter.

*These samples must also be collected at least one week apart and marked as routine samples.

Failure to collect and report both of these samples on time or meeting any of the other criteria in OAR 333-061-0036(6)(b)(C) will result in coliform monitoring being increased to monthly at your water system.

Criteria to change back to quarterly monitoring

OAR 333-061-0036 (6)(b)(D)

In the previous 12 months:

- Site visit for either a Level 2 investigation or Sanitary Survey (or equivalent)
 - No sanitary defects and they have a protected water source
- All required samples collected and reported
- No E. coli MCL violations
- No coliform investigations required
- No coliform investigation violations



New procedure for returning to quarterly monitoring

A site visit could be substituted, at the regulators discretion, with a conversation with the operator and detailed photos of the water system infrastructure showing no sanitary defects.

Procedure describes what a “protected source” is.



PUBLIC HEALTH DIVISION
Environmental Public Health

Subject:	Coliform – return to quarterly monitoring	Orig Date:	8/8/18
Unit + init:	TS – ks/cl/aw	Revised date:	01/14/19
Purpose & Scope: For Transient systems that were triggered into monthly monitoring, OAR 333-061-0036 (6)(b)(D) specifies criteria to return to quarterly monitoring. This procedure outlines steps to take to allow a system to return to quarterly coliform monitoring.			

Procedure/Process:

1. System requests to return to quarterly.
 - a. Or, regulator reviews schedule during survey and notices that they may qualify.
2. Need 12 consecutive months coliform sampling without any monitoring or reporting violations, or coliform investigation triggers.
 - a. A TC+ with the correct number of repeats in the correct timeframe that are TC- is ok.
3. Need a site visit within the previous 12 months and the system was found to be free of sanitary defects. If defects were found, they must have been corrected and noted. A site visit could be substituted, at the regulator's discretion, with a conversation with the operator and detailed photos of water system infrastructure showing no sanitary defects.
4. Protected source: verified through site visit or photos that there are no priority source-related significant deficiencies.
 - a. Significant deficiencies that are priority source deficiencies could be a physical pathway to contamination. These are the deficiencies that require correction before granting the reduction back to quarterly. The priority source deficiencies are:
 - i. Sanitary seal/casing not watertight
 - ii. No screen on existing well vent
 - iii. Wellhead not protected from flooding
 - b. Non-priority source deficiencies are not considered critical for correction to change the sample schedule. The non-priority source deficiencies are:
 - i. Well does not meet setback from hazards
 - ii. No raw water sample tap
 - iii. No treated sample tap
5. Complete schedule change request form and inform system when their next sample is due.

Level 1 & 2 investigations, are we finding sanitary defects?

- Rodent access & droppings
- Missing / inadequate screens
- Well house broken into
- Broken distribution pipes
- Chlorinator out of Chlorine
- Broken feed pipe on chlorinator
- Don't know last time storage tank was cleaned
- Resurrected use of 3 storage tanks



Level 1 Coliform Investigations



- Conducted by the water system staff
- Must be completed within 30 days
- Includes a basic examination of the source water, treatment, distribution system and relevant operational practices
- Covers likely cause, corrective action plan, and schedule for correction.
- Investigation form is available on our website
- Reports will be reviewed to ensure the investigation was adequate and complete
- **Partner agencies need to send in the level 1 investigation form to DWS in order for the PWS to get credit**

Level 1 Coliform Investigation Triggers

- Level 1 investigations are triggered by the following events:
 - More than 1 sample is total coliform positive at systems collecting fewer than 40 samples per month
 - More than 5% of samples are total coliform positive at systems collecting 40 or more samples per month
 - Failure to collect every required repeat sample



Level 1 Coliform Investigation Form Oregon Health Authority, Drinking Water Services

Complete the coliform investigation and return the form within 30 days to your County, Dept. of Ag. or State regulatory contact

PWS Name:		PWS ID #: 41	
Name		Telephone #	
Operator in Direct Responsible Charge			
Person(s) that collected samples if different than above			
Date of Investigation:			
INVESTIGATION DETAILS			
Did any of the following events occur prior to collection of the positive total coliform samples?	Yes/No	N/A	If Yes, describe issue
1. Loss of pressure anywhere in the system	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
2. Maintenance on the system that could have introduced contamination	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
3. Repair of broken water lines	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
4. New water lines or service connections added to the system	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
5. Vandalism or unauthorized access to facilities	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
6. Water line flushing or fire fighting event	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
7. Low chlorine or chloramine residual anywhere in the system	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
8. Failure of chlorination/UV equipment or minimums not met	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
9. New or different source of water introduced (example: backup well)	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
10. Loss of electrical power	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
11. Unprotected connection to non-potable water discovered (example: private well, irrigation line, fire sprinkler system)	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
12. Failure to test all backflow prevention devices within the last year	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
13. Discovery of water system components submerged in water (example: well or valves in a flooded vault)	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
Wells & Springs - Inspect each groundwater source for physical defects and report:	Yes/No	N/A	If Yes, describe issue
1. Cracks or holes in well seal or casing	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
2. Repair/replacement of well/spring components (example: well pump)	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
3. Wellhead flooded or water puddled near well	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
4. Screen for well vent missing or damaged	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
5. Feces, fecal source or other unsanitary conditions at the well/spring	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
6. Leaking sewer lines or septic tanks near well/spring	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
7. Cracks or holes in springbox	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
8. Water flowing or puddled on the ground around springbox	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	

Rev. 2/16/16

Level 2 Coliform Investigations

- Conducted by the water system's regulating agency (DWS, County, or Oregon Dept. of Agriculture)
- A more in-depth examination of the system and its monitoring and operational practices
- Must be completed in 30 days
- **Level 2 investigations are triggered by the following events:**
 - Violation of the MCL for *E. coli*
 - Two Level 1 triggers within a 12 month period

Level 2 coliform investigations

-Very important to fill out summary page accurately with corrective action due dates if applicable.



Level 2 Coliform Investigation Form Oregon Health Authority, Drinking Water Services

PWS Name:		PWS ID #:	41
	Name		Telephone #
Operator in Direct Responsible Charge (DRC)			
Person that collected samples if different than DRC			
Date of Investigation:		10/17/2016	

INVESTIGATION DETAILS

Groundwater Source Inspect each groundwater source for physical defects and report:	Well/Spring Name Source AA	Well/Spring Name	Well/Spring Name	Well/Spring Name	N/A	If Yes, describe issue
1. Cracks or holes in well seal or casing	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
2. Wellhead lacks a watertight seal	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
3. Screen for well vent missing or damaged	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
4. Wellhead subjected to flooding or standing water near well	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
5. Leaking sewer lines or septic tanks near well/spring	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
6. Feces, fecal source observed near well/spring	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
7. Unsanitary conditions at the well/spring	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
8. Contamination during pump repair/replacement or other wellhead/spring repair	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
9. Use of an unapproved or untested source	Y <input type="checkbox"/> N <input checked="" type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input type="checkbox"/>	
10. Indication of surface water entering springbox	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input checked="" type="checkbox"/>	
11. Cracks or holes in springbox	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input checked="" type="checkbox"/>	

Treatment and Disinfection Inspect each treatment plant for physical defects and report:	Plant Name	Plant Name	Plant Name	Plant Name	N/A	If Yes, describe issue
1. Inability to maintain residual throughout the distribution system	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input checked="" type="checkbox"/>	
2. Failure of disinfection equipment	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input checked="" type="checkbox"/>	
3. Failure to monitor and replace chlorine supply	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input checked="" type="checkbox"/>	
4. Improper chlorine residual measurements (method or frequency)	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input checked="" type="checkbox"/>	
5. Failure to meet required minimum chlorine residual at the entry point (GW only)	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	Y <input type="checkbox"/> N <input type="checkbox"/>	<input checked="" type="checkbox"/>	

Rev. 2/16/16

Level 2 Coliform Investigation Form

Page 4 of 4

SUMMARY: Based on the results of the investigation and any other available information, what is believed to be the cause(s) of the *E. coli* positive or multiple total coliform positive sample(s) from the public water system?

The possible cause for the multiple total coliform positive samples from the public water system could be inadequate disinfection of the water system after the pipeline was reconfigured/repared in the pumphouse.

CORRECTIVE ACTIONS: What actions has the water system taken to correct the above mentioned issue(s)? If additional time is needed to correct a deficiency, indicate the date that it will be corrected.

The water system was provided documents outlining the procedures to shock chlorinate their well and the distribution system. The water system did shock chlorinate the system this afternoon (10-17-2016) and would take a special sample to determine if the corrective action took effect.



COLIFORM INVESTIGATIONS: BY THE NUMBERS

	On time	Late	No report
Level 1	399	74	30
Level 2	263	4	28

As of 4/30/19

On time:
79%

Completed:
94%

Repeats turned in late (investigation triggered but no longer needed)	85

COLIFORM INVESTIGATIONS: BY THE NUMBERS

	On time	Late	No completed
Correct defects	9	7	3
Install disinfection	9	9	4

As of 4/30/19

Questions?

Casey Lyon (541) 726-2587 ext. 31

Casey.lyon@state.or.us

Chuck Michael (971) 673-0420

CHARLES.E.MICHAEL@dhsosha.state.or.us



PUBLIC HEALTH DIVISION
Environmental Public Health



Oregon
Health
Authority