

### **333-061-0064**

#### **Emergency Response Plan Requirements**

All public water systems shall maintain a current emergency response plan.

- (1) The emergency response plan shall be reviewed and updated at least every five years. If a public water system applying for funds from the Safe Drinking Water Revolving Loan Fund Program is required to develop an emergency response plan as a part of a capacity assessment, then the emergency response plan is required to be completed before final payout of the loan.
- (2) All public water systems shall complete a security vulnerability assessment and develop a prioritized plan for risk reduction.
- (3) As evidence of completion, all public water systems shall submit a statement to the Authority certifying that the Emergency Response Plan and vulnerability assessment have been completed according to the requirements of this rule and that staff have been instructed in the use of the emergency response plan. The emergency response plan/vulnerability assessment shall be made available for review by the Authority or the County Health Department. All Community water systems > 3,300 population are required to submit a copy of their Vulnerability Assessment and certification of completion for their Emergency Response Plan and Vulnerability Assessment to EPA as required in the federal Bioterrorism Preparedness and Response Act of 2002.
- (4) Community water systems shall coordinate with the lead County Emergency Coordinator when preparing or revising an emergency response plan.
- (5) The emergency response plan shall include but is not limited to the following elements:
  - (a) Communications and authority.
    - (A) Develop an emergency contacts list, and review and update this list at least annually.
    - (B) Decision-making authorities and responsibilities of water system personnel shall be determined and detailed in the emergency response plan.
    - (C) Procedure for notification of agencies, the water users, and the local media.
  - (b) Water system security. Public water systems shall develop a security program. The security program shall include, but is not limited to, the following components: security management, physical activity, physical security, chemical storage and use, personnel, computer system, and program evaluation as defined in the State Model Emergency Response Plan.
  - (c) Water system hazard review.
    - (A) Public water systems shall conduct an inspection of the water system annually to identify the hazards that could affect the water system.
    - (B) Public water systems shall correct construction deficiencies to eliminate hazards or potential hazards, correct major sanitary survey deficiencies as determined by the Authority, and perform regular maintenance.
  - (d) Emergency equipment and water supplies.

- (A) Public water systems shall make provisions for an auxiliary power supply if not a gravity system, and redundant equipment for critical components. Community water systems shall identify equipment that can be utilized in the event of an intentional attack which can render harmless or significantly lessen the impact of the attack on the public health and safety and supply of public drinking water.
- (B) Public water systems shall develop a plan for emergency water to include the rationing of drinking water, identifying and utilizing alternative drinking water sources and supplies, and alternative distribution of drinking water.
- (e) Emergency response procedures.
  - (A) Public water systems shall develop procedures for responding to emergencies most likely to strike the water system. Community water systems shall develop plans and procedures that can be implemented in the event of a terrorist or other intentional attack on the water system.
  - (B) The emergency response plan shall describe procedures to isolate all parts of the water system. Community water systems shall develop actions and procedures which can render harmless or significantly lessen the impact of terrorist attacks or other intentional actions on public health and safety and supply of public drinking water.
  - (C) The emergency response plan shall describe the emergency disinfection procedure, process for issuing a boil water advisory, and process for handling a waterborne disease outbreak.
- (6) Water system staff shall be instructed and trained in the use of the emergency response plan.

Stat. Auth.: ORS 448.131

Stats. Implemented: ORS 448.131 & 448.160