

<b>Month / Year</b>	<b>Name of Pool:</b>	<b>Location – City</b>
---------------------	----------------------	------------------------

Operator's Initials	DATE	Daily Pre-Opening Tests					Total Alkalinity (2x / week)	Calcium Hardness (1x / wk)	Cyanuric Acid (1x / week)	TDS (Monthly)	<b>Free Cl / Br Readings / pH (every 1 to 2 hrs.)</b>							Number of Bathers - Total	Backwashed - Clean Filters	Recirculation Rate - GPM	Comments - Chemical Added / Amount Spa Problems Mechanical Breakdowns Bather Emergencies > (File Accident Report)
		Clarity	SPA Temp (<104°F.)	Free Chlorine / Bromine	Combined Cl	pH					Insert the Time the Test is Done (below)										
											Cl / pH	Cl / pH	Cl / pH	Cl / pH	Cl / pH	Cl / pH	Cl / pH				
	1																				
	2																				
	3																				
	4																				
	5																				
	6																				
	7																				
	8																				
	9																				
	10																				
	11																				
	12																				
	13																				
	14																				
	15																				
	16																				
	17																				
	18																				
	19																				
	20																				
	21																				
	22																				
	23																				
	24																				
	25																				
	26																				
	27																				
	28																				
	29																				
	30																				
	31																				

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

	<b>Min.</b>	<b>Ideal</b>	<b>Max.</b>
Free Chlorine	1.5 ppm	3.0 – 5.0 ppm	5.0 ppm
Combined Chlorine	0	0	0.5 ppm
Bromine	3.0 ppm	3.0-5.0 ppm	8.0 ppm
pH	7.2	7.3-7.5	7.6
Total Alkalinity	70 ppm	80-120 ppm	180 ppm
Calcium Hardness	175 ppm	250-350 ppm	-
Cyanuric Acid	0	0	150 ppm

Month / Year	License Number
Name of Facility	
Street Address	
City, State Zip	
Name of Operator	Phone

### Monthly Safety Self-Inspection

Item Checked

Maintenance Comments

**Spa & Enclosure**

- Fences – Openings < 4”, Good Repair
- Doors & Gates – Self-Closes, Completely Latches, Good Condition
- Window / Sliding Glass Door – Open < 4”
- Deck Equipment – Good Condition, Fasteners and Fittings not corroded
- Stairs – Handrail tight
- Depth Marking – Easily Readable
- Deck – Clean, Disinfected, Good Repair, No Puddles, No Carpet/Matting/Wood
- Spa Basin – In Good Repair
- Skimmers / Gutters / Tile Line – Clean, Good Repair
- Lighting – Maintained, Adequate
- Safety Equipment – Provided, Good Repair  
First Aid Kit Stocked, Phone Working
- Test Kit – Clean, Stocked w/ Fresh Reagents, Stored in Cool, Dry Location
- Spa Temperature - <104°F. (Ideal 102°F. or less)
- Water Changed – at least monthly, best changed when (“# of bathers” = Volume (gal.) / 3)

**Recirculation Equipment**

- Pumps / Filter / Disinfectant Feeders  
Maintained, Good Repair
- Gauges – Working, Accurate  
Readings within Parameters
- Piping – Good Repair, Marked, No Leaks

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---

---