

FACILITY		PR#:
PROJECT		
ADDRESS		

DETOXIFICATION ROOMS
OAR 333-535-0065
Effective October 1, 2009

_____ Schematic Design (SD) Review _____ Construction Document (CD) Review

REF OAR RULE SECTION	COMPLIED?		COMMENT
	YES	NO	
(1) In hospitals that provide drug or alcohol detoxification services, a minimum of one patient room for detoxification, located to allow direct observation by nursing staff, shall be provided.			
(a) Windows in detoxification rooms shall be of a security type that can only be opened by keys or tools that are under the control of the staff.			
(b) An adjoining or closely available toilet room and a hand-washing station serving detoxification patients only is also required.			
(2) All secured portions of the detoxification facility must comply with the Group 1, Division 2 occupancy classification requirements in accordance with the Oregon Structural Specialty Code.			