

**TABLE 4**  
**OAR 333-076-0185**

**RECEPTACLE REQUIREMENTS PER AREA**

**1. (NUMBER OF DUPLEX RECEPTACLES ACCESSIBLE TO EACH BED, UNLESS OTHERWISE NOTED.)**

<u>LOCATION</u>	<u>TOTAL RECEPTACLES</u>	<u>CRITICAL POWER RECEPTACLES</u>
Patient Stations, including holding and pre-operation	4	1
Non-invasive Procedure Room	4	2
Class B <sup>c</sup> & C <sup>d</sup> Operating Room, Cath Lab	8	6
Surgical Cystoscopy, and Class B <sup>c</sup> Endoscopy and Bronchoscopy	4	2
Post-Anesthesia Care Unit	4	2
Phase 2 Recovery	2	0

- a. Spaces used for more than one function must meet the most restrictive requirements
- b. These requirements do not apply to outpatient facilities that do not perform invasive applications or procedures.
- c. Class B Operating Room. For the purposes of this rule a Class B operating room is for surgery and other procedures that require “conscious” sedation, including but not limited to minor or major surgical procedures performed in conjunction with oral, parenteral, or intravenous sedation or under analgesic or dissociative drugs. A procedure performed in a Class B operating room could also be performed in a Class C operating room.
- d. Class C Operating Room. For the purpose of this rule a Class C operating room is for surgery and procedures that require general anesthesia or “deep” sedation, including but not limited to major surgical procedures that require general or regional block anesthesia and support of vital bodily functions.