

## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1109  
By: Carl  
Lab #: 20160728-136  
Location: Ed facility fountain

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0105		0.001	mg/l	0.020	08/04/2016	bem

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1111  
By: Carl  
Lab #: 20160728-137  
Location: Ed facility blue pod kitchen

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0426		0.001	mg/l	0.020	08/04/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016  
ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1103  
By: Carl  
Lab #: 20160728-127  
Location: new dorm kitchen

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0085		0.001	mg/l	0.020	08/10/2016	bem

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St, NE  
Salem, OR 97310-0203

08/15/2016  
ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1050  
By: Carl  
Lab #: 20160728-126  
Location: Kuenzi Hall boys bathroom

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0020		0.001	mg/l	0.020	08/04/2016	ber

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1049  
By: Carl  
Lab #: 20160728-125  
Location: Kuenzi Hall fountain

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.020	08/10/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

Customer

## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1047  
By: Carl  
Lab #: 20160728-124  
Location: Kuenzi Hall kitchen

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0065		0.001	mg/l	0.020	08/10/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1113  
By: Carl  
Lab #: 20160728-135  
Location: High School fountain

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0018		0.001	mg/l	0.020	08/04/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1104  
By: Carl  
Lab #: 20160728-134  
Location: Lindstrom Hall apt kitchen

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0172		0.001	mg/l	0.020	08/10/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1100  
By: Carl  
Lab #: 20160728-133  
Location: Lindstrom Hall fountain

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0012		0.001	mg/l	0.020	08/04/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1043  
By: Carl  
Lab #: 20160728-132  
Location: Peterson Hall apt kitchen

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0208		0.001	mg/l	0.020	08/04/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016  
ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1040  
By: Carl  
Lab #: 20160728-131  
Location: Peterson Hall fountain

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0033		0.001	mg/l	0.020	08/04/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1037  
By: Carl  
Lab #: 20160728-130  
Location: Wallace Hall kitchen

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0403		0.001	mg/l	0.020	08/04/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1036  
By: Carl  
Lab #: 20160728-129  
Location: Wallace Hall fountain

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0023		0.001	mg/l	0.020	08/04/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Business Services  
Public Serv Bldg/255 Capitol St,NE  
Salem, OR 97310-0203

08/15/2016

ORESCH/D

PO#:

### Collection Information

Date: 07/28/2016  
Time: 1053  
By: Carl  
Lab #: 20160728-128  
Location: Clatterbuck kitche fountain

### Lab Receipt Information

07/28/2016  
1153  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0309		0.001	mg/l	0.020	08/04/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 

Customer