

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/16/2016

ORESCH/D

PO#:

### Collection Information

Date: 11/15/2016  
Time: 0755  
By: Carl  
Lab #: 20161115-006  
Location: kitchen sink High School

### Lab Receipt Information

11/15/2016  
0843  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0010		0.001	mg/l	0.020	12/12/2016	bem

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/16/2016

ORESCH/D

PO#:

### Collection Information

Date: 11/15/2016  
Time: 0745  
By: Carl  
Lab #: 20161115-007  
Location: gym boys bathroom

### Lab Receipt Information

11/15/2016  
0843  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0017		0.001	mg/l	0.020	12/12/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/16/2016

ORESCH/D

PO#:

### Collection Information

Date: 11/15/2016  
Time: 0746  
By: Carl  
Lab #: 20161115-008  
Location: gym water fountain

### Lab Receipt Information

11/15/2016  
0843  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0025		0.001	mg/l	0.020	12/12/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/16/2016  
ORESCH/D

PO#:

### Collection Information

Date: 11/15/2016  
Time: 0823  
By: Carl  
Lab #: 20161115-009  
Location: fountain Claatterbuck

### Lab Receipt Information

11/15/2016  
0843  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0027		0.001	mg/l	0.020	12/12/2016	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## Oregon School for the Deaf, Lead Testing Results Summary

Summary Prepared by Beth Myers, Lab Director

Waterlab Corp. Oregon Accredited Laboratory ORELAP 100039, EPA #008

Page 1 of 1

*NOTE: The Lead Test Results are provided here in two (2) different units so you can choose which one you want to use on your information.*

Source	Date Collected	Lab #	Lead, ug/liter or ppb	Lead, mg/liter or ppm
Clatterbuck Kitchen sink	11/15/2016	20161115-3	9.7	0.0097
Blue Pod Kitchen, Smith Bldg	11/15/2016	20161115-4	3.8	0.0038
Green Pod Kitchen, Smith Bldg	11/15/2016	20161115-5	3.9	0.0039
High School, kitchen sink	11/15/2016	20161115-6	1.0	0.0010
Gym, Boys Bathroom	11/15/2016	20161115-7	1.7	0.0017
Gym, water fountain	11/15/2016	20161115-8	2.5	0.0025
Clatterbuck fountain	11/15/2016	20161115-9	2.7	0.0027

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/16/2016

ORESCH/D

PO#:

### Collection Information

Date: 11/15/2016  
Time: 0740  
By: Carl  
Lab #: 20161115-003  
Location: Clatterbuck kitchen sink

### Lab Receipt Information

11/15/2016  
0843  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0097		0.001	mg/l	0.020	12/12/2016	ber

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/16/2016

ORESCH/D

PO#:

### Collection Information

Date: 11/15/2016  
Time: 0750  
By: Carl  
Lab #: 20161115-004  
Location: Blue Pod kitchen Smith Building

### Lab Receipt Information

11/15/2016  
0843  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0038		0.001	mg/l	0.020	12/04/2016	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/16/2016

ORESCH/D

PO#:

### Collection Information

Date: 11/15/2016  
Time: 748  
By: Carl  
Lab #: 20161115-005  
Location: Green Pod kitchen Smith Building

### Lab Receipt Information

11/15/2016  
0843  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0039		0.001	mg/l	0.020	12/12/2016	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The EPA Level of 0.015 mg/liter (or ppm) also listed as 15 ppb is an ACTION LEVEL, NOT A SAFE HEALTH STANDARD. There is NO safe level of lead in drinking water. This Action Level does NOT mean that waters with lower levels are safe.

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

