

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/07/2023  
Time: 1500  
By: Brian Marshal  
Lab #: 20231215-034  
Location: Peterson kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/07/2023  
Time: 1500  
By: Brian Marshal  
Lab #: 20231215-035  
Location: Peterson water fountain

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	berm

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/07/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-036  
Location: Clatterbuck employee kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	3.45		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/07/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-037  
Location: clutterback nurses water fountain

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis Date Time	Tech
Lead / Schools	SM3113 B	A	4.84		1	ppb	15	12/21/2023	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/07/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-038  
Location: clatterbuck cafeteria fountain

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023  
  
ORESCH/D

PO#:

### Collection Information

Date: 12/07/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-039  
Location: clatterbuck kitchensink

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	6.62		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-040  
Location: wallace water fountain

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	2.71		1	ppb	15	12/27/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023  
  
ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-041  
Location: wallace kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.78		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_





## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-042  
Location: Peck kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	3.03		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-043  
Location: Peck water fountain

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-044  
Location: Panther den kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-045  
Location: lindstrom water fountain

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis Date Time	Tech
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-046  
Location: Lindstrom kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-047  
Location: Smith Blue kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.50		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-048  
Location: Smith water fountain West

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	7.55		1	ppb	15	12/21/2023	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



Customer

## TEST REPORT

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-049  
Location: Smith Green kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	5.44		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_





## TEST REPORT

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-050  
Location: smith staff kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	7.95		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/12/2023  
Time: 0700  
By: Brian Marshal  
Lab #: 20231215-051  
Location: Smith water fountain East

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	berm

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/15/2023  
Time: 0700  
By: Brian Marshall  
Lab #: 20231215-052  
Location: Ulmer Staff kitchen

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/15/2023  
Time: 0700  
By: Brian Marshall  
Lab #: 20231215-053  
Location: Ulmer water fountain

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/15/2023  
Time: 0700  
By: Brian Marshall  
Lab #: 20231215-054  
Location: Ulmer class sink East

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	berm

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/15/2023  
Time: 0700  
By: Brian Marshall  
Lab #: 20231215-055  
Location: Ulmer Class sink SW

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/15/2023  
Time: 0700  
By: Brian Marshall  
Lab #: 20231215-056  
Location: Ulmer class sink South

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	1.69		1	ppb	15	12/21/2023	bern

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023  
ORESCH/D

PO#:

### Collection Information

Date: 12/15/2023  
Time: 0700  
By: Brian Marshall  
Lab #: 20231215-057  
Location: Ulmer class North sink

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	berm

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_





## TEST REPORT

TO: Oregon Dept of Education/Attn: Carl Lohse  
999 Locust St NE  
Salem, OR 97301

12/27/2023

ORESCH/D

PO#:

### Collection Information

Date: 12/15/2023  
Time: 0700  
By: Brian Marshall  
Lab #: 20231215-058  
Location: Kuenzi water fountain

### Lab Receipt Information

12/15/2023  
1550  
RD

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead / Schools	SM3113 B	A	ND		1	ppb	15	12/21/2023	bem

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

