

CHAPTER 27
SEMICONDUCTOR FABRICATION FACILITIES
Double strike through denotes model language deleted by Oregon
Blue text denotes Oregon Amendments

2703.7.3 Hazardous production material (HPM) rooms, gas rooms and liquid storage rooms. Electrical wiring and equipment in HPM rooms, gas rooms and liquid storage rooms shall comply with NFPA 70.

<p>Note: HPM facilities are also regulated by the State of Oregon, Building Codes division, Oregon Administrative Rules Chapter 918, Division 306.</p>
