

## CHAPTER 35

# WELDING AND OTHER HOT WORK

Double strike through denotes model language deleted by Oregon

Blue text denotes Oregon Amendments

**3505.8 Tests.** Tests for leaks in piping systems and equipment shall be made with soapy water **following a change in any connection**. The use of flames shall be prohibited for leak testing.