

CHAPTER 36
MARINAS

Double strike through denotes model language deleted by Oregon
Blue text denotes Oregon Amendments

3604.2 Piers and wharves. An automatic sprinkler system shall be installed under piers or wharves regulated by Section 424 of the *Oregon Structural Specialty Code*, which exceed 200 feet (60 960 mm) in length or exceed 5,000 square feet (465 m²) in area. Such systems shall comply with NFPA 307, *Standard for the Construction and Fire Protection of Marine Terminals, Piers and Wharves*.

Re-number following sections.