

**CHAPTER 53**  
**COMPRESSED GASES**

**Double strike through denotes model language deleted by Oregon**  
**Blue text denotes Oregon Amendments**

**5306.1 General.** *Compressed gases* at hospitals and similar facilities intended for inhalation or sedation including, but not limited to, analgesia systems for dentistry, podiatry, veterinary and similar uses shall comply with Sections 5306.2 through 5306.4 in addition to other requirements of this chapter.

**In addition to the requirements of this section, health care, residential care, and assisted living facilities shall be required to comply with CGA E-10, 2007, *Maintenance of Medical Gas and Vacuum Systems in Health Care Facilities*.**

**5306.4.1 Medical gas system verification. In addition to the requirements of this section, facilities with piped gas and piped vacuum systems shall be required to comply with the verification requirements as specified in NFPA 99. Written documents shall be required for verification testing as specified in NFPA 99.**