

CHAPTER 63
**OXIDIZERS, OXIDIZING GASES AND
OXIDIZING CRYOGENIC FLUIDS**

Double strike through denotes model language deleted by Oregon
Blue text denotes Oregon Amendments

6304.1.4 Automatic sprinkler systems. The *automatic sprinkler system* shall be designed in accordance with NFPA
~~430~~ **400**.