

RED Underlined = Existing Oregon Amendment brought forward from the 2007 OFC

BLUE or BLUE Strikethrough = Oregon Deletion or NOT ADOPTED

TEAL Underlined = New Oregon Amendment in the 2010 OFC

CHAPTER 30

COMPRESSED GASES

3006.1 General. Compressed gases at hospitals and similar facilities intended for inhalation or sedation including, but not limited to, analgesia systems for dentistry, podiatry, veterinary and similar uses shall comply with Sections 3006.2 through 3006.4 in addition to other requirements of this chapter.

In addition to the requirements of this section, health care, residential care, and assisted living facilities shall be required to comply with CGA E-10, 2001 edition, Maintenance of Medical Gas and Vacuum Systems in Health Care Facilities.

3006.4.1 Medical gas system verification. In addition to the requirements of this section, facilities with piped gas and piped vacuum systems shall be required to comply with the verification requirements as specified in NFPA 99. Written documentation shall be required for verification testing as specified in NFPA 99. Refer to the Oregon Plumbing Specialty Code for requirements pertaining to installer performance testing as specified in NFPA 99.