

## CHAPTER 30

### COMPRESSED GASES

**3006.1 General.** Compressed gases at hospitals and similar facilities intended for inhalation or sedation including, but not limited to, analgesia systems for dentistry, podiatry, veterinary and similar uses shall comply with this section in addition to other requirements of this chapter.

**In addition to the requirements of this section, health care, residential care, and assisted living facilities shall be required to comply with CGA E-10, 2001 edition, Maintenance of Medical Gas and Vacuum Systems in Health Care Facilities.**

**3006.4.1 Medical gas system verification. In addition, to the requirements of this section, facilities with piped gas and piped vacuum systems shall be required to comply with the verification requirements as specified in NFPA 99. Written documentation shall be required for verification testing as specified in NFPA 99. Refer to the Oregon Plumbing Specialty Code for requirements pertaining to installer performance testing as specified in NFPA 99.**