

FACILITY		PR#:
PROJECT		
ADDRESS		

ADMINISTRATION AND PUBLIC AREAS
OAR 333-535-0190
Effective October 1, 2009

 Schematic Design (SD) Review **X** Construction Document (CD) Review

OAR RULE SECTION	COMPLIED?		COMMENT
	YES	NO	
The following areas shall be provided:			
(1) Entrance at grade level, sheltered from the weather, and able to accommodate wheelchairs.			
(2) Lobby. It shall include:			
(a) Storage space for wheelchairs			
(b) Reception and information counter or desk;			
(c) Waiting space(s);			
(d) Public toilet facilities;			
(e) Public telephones; and			
(f) Drinking fountain(s).			
(3) Interview space(s) for private interviews relating to social service, credit, and admissions.			
(4) General or individual office(s) for business transactions, medical and financial records, and administrative and professional staffs.			
(5) Multipurpose room(s) for conference, meetings and health education purposes including provisions for showing visual aids.			
(6) Library facilities.			
(7) Storage for office equipment and supplies.			