

TABLE 3
(OAR 333-076-0185)
STATION OUTLET/INLETS FOR OXYGEN, VACUUM AND MEDICAL AIR SYSTEMS
AMBULATORY SURGICAL CENTERS

LOCATION	OXYGEN	VACUUM	MEDICAL AIR
Catheterization rooms	1	2	2
Class A ^b operating room (minimal sedation)	1	1	--
Class B ^c operating room (conscious sedation)	2	2	--
Class C ^d operating room (deep sedation)	2	3	--
Post-anesthesia recovery	1	1	--
Phase 2 recovery	0 ^a	0 ^a	--
Endoscopy procedure room	1	3	--
Endoscopy holding/prep/recovery rooms	0 ^a	0 ^a	--

- a. Portable sources shall be available.
- b. Class A Operating Room. For the purpose of this rule, a Class A operating room is for surgery and other procedures that require “minimal” sedation including but not limited to minor surgical procedures performed under topical and local infiltration blocks with or without oral or intramuscular preoperative sedation. A surgical procedure performed in a Class A operating room could also be performed in Class B or C operating room.
- c. Class B Operating Room. For the purposes of this rule a Class B operating room is for surgery and other procedures that require “conscious” sedation, including but not limited to minor or major surgical procedures performed in conjunction with oral, parenteral, or intravenous sedation or under analgesic or dissociative drugs. A procedure performed in a Class B operating room could also be performed in a Class C operating room.
- d. Class C Operating Room. For the purpose of this rule a Class C operating room is for surgery and procedures that require general anesthesia or “deep” sedation, including but not limited to major surgical procedures that require general or regional block anesthesia and support of vital bodily functions.